

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401

400 Chestnut Street Tower II

January 20, 1983

U.S. Nuclear Regulatory Commission  
Region II  
Attn: Mr. James P. O'Reilly, Regional Administrator  
101 Marietta Street, Suite 3100  
Atlanta, Georgia 30303

Dear Mr. O'Reilly:

OFFICE OF INSPECTION AND ENFORCEMENT BULLETIN 80-20 - RII:JPO 50-327  
AND 50-328 - SEQUOYAH NUCLEAR PLANT - REVISED RESPONSE


In my November 9, 1981 letter to you regarding TVA's response to the subject bulletin on Westinghouse Type W-2 Control Switches, we indicated that we anticipated completing corrective measures for our Sequoyah Nuclear Plant before startup following the first refueling outage for each respective unit. In discussions with the NRC (NRR and OIE) regarding the Integrated Modification Schedule (IMS) for Sequoyah, we indicated that following NRC approval of the IMS, revisions of previous responses for those deferred items would be necessary. We now expect to complete changeout of the W-2 switches for units 1 and 2 before startup after the unit 1 cycle 2 refueling outage. In the interim period, we are continuing to inspect the switches every 31 days, by special maintenance instruction, and after every operation of the switch.

If you have any questions, please get in touch with R. H. Shell at FTS 858-2688.

To the best of my knowledge, I declare the statements contained herein are complete and true.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

  
L. M. Mills, Manager  
Nuclear Licensing

cc: Mr. Richard C. DeYoung, Director  
Office of Inspection and Enforcement  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

8302150554 830120  
PDR ADOCK 05000327  
Q PDR