

APPENDIX A

NOTICE OF VIOLATION

Virginia Electric and Power Company  
North Anna 1 and 2

Docket Nos. 50-338 and 50-339  
License Nos. NPF-4 and NPF-7

As a result of the inspection conducted on September 20-24, 1982, and in accordance with the NRC Enforcement Policy, 47 FR 9987 (March 9, 1982), the following violations were identified.

- A. Technical Specification 6.8.1.C requires procedures for the performance of surveillance tests.

Contrary to the above, procedures 1-PT-52.2 and 2-PT-52.2 were inadequate in that the common provision for equating a change in reactor coolant system inventory with a change in reactor coolant system temperature was appropriate only to the no-load operating temperature condition. Consequently, the reactor coolant system leakage rate could have been significantly under estimated at full power.

This is a Severity Level IV Violation (Supplement I).

- B. Technical Specification 6.9.1.8.C requires a prompt and a written report of abnormal degradation of fuel cladding.

Contrary to the above, fuel cladding failure observed during the 1982 refueling outage was not reported.

This is a Severity Level IV Violation (Supplement I).

Pursuant to the provisions of 10 CFR 2.201, you are hereby required to submit to this office within thirty days of the date of this Notice, a written statement or explanation in reply, including: (1) admission or denial of the alleged violations; (2) the reasons for the violations if admitted; (3) the corrective steps which have been taken and the results achieved; (4) corrective steps which will be taken to avoid further violations; and (5) the date when full compliance will be achieved. Consideration may be given to extending your response time for good cause shown.

Date: October 21, 1982