

LICENSEE EVENT REPORT

Unit 2

CONTROL BLOCK: | | | | | | | | | | (1)

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

7 8 9 14 15 25 26 30 37 38 56
 0 1 | T N S N P | 2 | 2 0 0 - | 0 0 0 0 0 0 - | 0 0 | 3 | 4 1 1 1 1 | 4 | | | (5)

CON'T
 2 8
 0 1 | REPORT SOURCE | L (6) | 0 5 | 0 0 0 0 3 | 2 8 | 7 | 0 1 | 0 7 8 | 3 | 8 | 0 2 | 0 4 | 8 | 3 | (9)
 60 61 68 69 74 75 80
 DCKET NUMBER EVENT DATE REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | Unit 2 was in mode 1 at 96% power. During performance of surveillance instruction
 0 3 | (SI) 51, the boron concentration in the refueling water storage tank (RWST) was
 0 4 | discovered below the 2000 ppm limit. This caused entry into LCOs 3.1.2.6 and 3.5.5
 0 5 | There was no effect upon public health or safety. Previous occurrences - three
 0 6 | (SQRO-50-327/80078, -327/80188, and -327/81037).

0 7 |
 0 8 |

7 8 9
 0 9 | P C | (11) | X | (12) | Z | (13) | Z Z Z Z Z Z | (14) | Z | (15) | Z | (16)
 9 10 11 12 13 18 19 20
 SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP. SUBCODE VALVE SUBCODE

(17) LER/RO REPORT NUMBER | 8 3 | (21) 22 | | (23) 24 | 0 0 4 | (26) | | (28) 29 | 0 3 | (30) 31 | | (32) 33
 EVENT YEAR SEQUENTIAL REPORT NO. OCCURRENCE CODE REPORT TYPE REVISION NO.

ACTION TAKEN | FUTURE ACTION | EFFECT ON PLANT | SHUTDOWN METHOD | HOURS | ATTACHMENT SUBMITTED | NPD-4 FORM SUB. | PRIME COMP. SUPPLIER | COMPONENT MANUFACTURER
 X (18) F (19) Z (20) Z (21) C 0 0 0 0 (22) N (23) N (24) Z (25) Z 9 9 9 (26) 44
 33 34 35 36 37 40 41 42 43 44

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | The cause is not determinable at present. Tests will be run to determine the rep-
 1 1 | resentability of the RWST sampling process and to determine the cause for the low boron
 1 2 | concentration. Action has been initiated to revise procedures to ensure representative
 1 3 | sampling. A design change request has been written to allow better mixing in the event
 1 4 | of a boration or dilution. A followup LER will be written when additional information

7 8 9 12 13 28 29 30 31 36 44 45 46 80
 FACILITY STATUS | % POWER | OTHER STATUS | METHOD OF DISCOVERY | DISCOVERY DESCRIPTION
 E (28) 0 9 6 (29) NA (30) B (31) Surveillance test (32)

7 8 9 10 11 33 34 35 36 44 45 80
 ACTIVITY CONTENT | RELEASED | AMOUNT OF ACTIVITY | LOCATION OF RELEASE
 Z (33) Z (34) NA (35) NA (36)

7 8 9 11 12 37 38 40 41 80
 PERSONNEL EXPOSURES | NUMBER | TYPE | DESCRIPTION
 0 0 0 (37) Z (38) NA (40) NA (41)

7 8 9 11 12 40 41 80
 PERSONNEL INJURIES | NUMBER | DESCRIPTION
 0 0 0 (40) NA (41)

7 8 9 10 42 43 80
 LOSS OF OR DAMAGE TO FACILITY | TYPE | DESCRIPTION
 Z (42) NA (43)

7 8 9 10 44 45 80
 PUBLICITY | ISSUED | DESCRIPTION
 N (44) NA (45) 8302150568 830204 PDR ADDCK 05000328 S PDR NRC USE ONLY