

LICENSEE EVENT REPORT

EXHIBIT A

CONTROL BLOCK: _____ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | C | A | R | S | S | 1 | 2 | 0 | 0 | - | 0 | 0 | 0 | 0 | 0 | - | 0 | 0 | 3 | 4 | 1 | 1 | 1 | 1 | 4 | 5
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33
LICENSEE CODE LICENSE NUMBER LICENSE TYPE CAT 58

CON'T
01 | L | 0 | 5 | 0 | 0 | 0 | 3 | 1 | 2 | 7 | 0 | 7 | 2 | 8 | 8 | 2 | 8 | 0 | 8 | 1 | 9 | 8 | 2 | 9
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30
REPORT SOURCE DOCKET NUMBER EVENT DATE REPORT DATE

02 | B CRD breaker failed to trip by manual trip button on two occasions,
03 | July 28 and July 30, 1982. In both instances, the second time
04 | the button was pressed, the breaker tripped open.
05 | Since the CRD breaker scheme provides alternate means to ensure rod
06 | trip and since the unit was in cold shutdown during this event,
07 | there was no effect on plant or public safety.
08 | _____
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30

09 | I | A | 11 | E | 12 | A | 13 | C | K | T | B | R | K | 14 | A | 15 | Z | 16 |
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32
SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP SUBCODE VALVE SUBCODE
17 | 8 | 2 | 19 | 0 | 1 | 9 | 0 | 3 | L | 0 |
21 22 23 24 25 26 27 28 29 30 31 32
LER/RO REPORT NUMBER EVENT YEAR SEQUENTIAL REPORT NO. OCCURRENCE CODE REPORT TYPE REVISION NO.
18 | A | 19 | Z | 20 | Z | 21 | 0 | 0 | 0 | 0 | Y | 22 | Y | 24 | N | 25 | G | 0 | 8 | 0 | 26 |
33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50
ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NPRD-4 FORM SUB. PRIME COMP SUPPLIER COMPONENT MANUFACTURER

10 | The suspect breaker was removed and a spare Class I breaker installed
11 | in its place. The system was then tested and verified to be operable.
12 | The suspect breaker was examined to determine cause. The shunt trip
13 | linkage arm was out of adjustment.
14 | _____
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30

15 | G | 28 | 0 | 0 | 0 | 0 | 29 | N/A | 30 | B | 31 | While performing surveillance.
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32
FACILITY STATUS % POWER OTHER STATUS METHOD OF DISCOVERY DISCOVERY DESCRIPTION

16 | Z | 33 | Z | 34 | N/A | 35 | N/A | 36 |
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32
ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY LOCATION OF RELEASE

17 | 0 | 0 | 0 | 0 | 37 | Z | 38 | N/A | 39 |
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32
PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION

18 | 0 | 0 | 0 | 0 | 40 | N/A | 41 |
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32
PERSONNEL INJURIES NUMBER DESCRIPTION

19 | Z | 42 | N/A | 43 |
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32
LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION

20 | Y | 44 | Local newspapers and wire services.
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32
PUBLICITY ISSUED DESCRIPTION NRC USE ONLY

NAME OF PREPARER R. W. Colombo PHONE: (916) 452-3211