

APPENDIX A
NOTICE OF DEVIATION

Georgia Power Company
Vogtle 1 and 2

Docket Nos. 50-424 and 50-425
License Nos. CPPR-108 and CPPR-109

Based on the results of the NRC inspection conducted on October 26-29, 1982, certain of your activities appear to deviate from your commitments to the Commission as indicated below:

Paragraphs 3.8.1.2 and 3.8.1.2.3 of the PSAR state that Regulatory Guide 1.10 is to be used as the basis for the making of mechanical (Cadweld) splices in reinforcing bars of Category I concrete structures. Regulatory position C.4 of Regulatory Guide 1.10 requires that separate tensile test cycles be established for mechanical splices in horizontal, vertical, and diagonal bars for each bar size and for each splicing crew.

Contrary to the above, separate tensile test cycles have not been established for each splicing crew.