

JAN 31 1983

Duke Power Company  
ATTN: Mr. H. B. Tucker, Vice President  
Nuclear Production  
P. O. Box 2178  
Charlotte, NC 28242

Gentlemen:

SUBJECT: MEETING SUMMARY - DOCKET NOS. 50-269, 50-270, AND 50-287

This refers to the enforcement meeting held between you and others of your staff and Mr. R. C. Lewis and other members of my staff at our request in the Region II office in January 7, 1983. This meeting related to activities authorized by NRC License Nos. DPR-38, DPR-47, and DPR-55 for Oconee Units 1, 2, and 3. The subjects discussed are detailed in the enclosed inspection report.

Our concerns regarding the identification of two open instrument air manual isolation valves located in a pressurized line penetrating Unit 3 containment, and, the receipt of a contaminated truck at Barnwell were expressed to you at the meeting. Your positive response to our concerns is appreciated.

It is our opinion that this meeting was beneficial and has provided for a better understanding of inspection and enforcement issues. In accordance with Section 2.790 of NRC's "Rules of Practice," Part 2, Title 10, Code of Federal Regulations, a copy of this letter and enclosures will be placed in the NRC's Public Document Room.

Should you have any questions regarding this matter, we will be pleased to discuss them.

Sincerely,

James P. O'Reilly  
Regional Administrator

Enclosure:  
Inspection Report No. 50-287/83-05

cc w/encl:  
J. Ed. Smith, Oconee Station Manager

bcc w/encl:  
NRC Resident Inspector  
Document Management Branch  
State of North Carolina

RII *AG*  
A Ignatonis:dr  
1/5/83

RII *R*  
R C Lewis  
1/27/83

RII *(H)*  
H C Dance  
1/28/83

RII *(C)*  
C Alderson  
1/27/83

RII *(J)*  
J Olsinski  
1/27/83

8302150608 830131  
PDR ADDCK 05000269  
PDR

*AG*  
79 1/27/83  
*AG* 1/27/83

IEO1