

Southern California Edison Company

SAN ONOFRE NUCLEAR GENERATING STATION

P.O. BOX 128

SAN CLEMENTE, CALIFORNIA 92672

RECEIVED
MRC

1982 AUG 18 PM 12:27

SCE

REGION V

TELEPHONE
(714) 492-7700

H. B. RAY
STATION MANAGER

August 13, 1982

U. S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region V
1450 Maria Lane, Suite 210
Walnut Creek, California 94596-5368

Attention: Mr. R. H. Engelken, Regional Administrator

Subject: Docket No. 50-361
30-day Report
Licensee Event Report No. 82-064
San Onofre Nuclear Generating Station, Unit 2


Pursuant to Technical Specification 6.9.1.13.b, this letter provides the written report and completed Licensee Event Report (LER) form for an event involving Limiting Condition for Operation (LCO) 3.6.1.3.

On July 16, 1982, while operating in Mode 3, the inner door of the containment personnel access airlock became jammed in the open position. In accordance with Action Statement a.1 of the LCO, the outer door of the airlock was maintained in the closed position while personnel entering containment worked to free the operating mechanism.

Operability of the inner door was achieved within one hour after adjustments to the operating linkage were made. The high volume of traffic through the airlock doors during the period between initial fuel load and initial criticality is considered to be the primary cause of this occurrence. Since initial criticality, the number of containment entries has been reduced to the absolute minimum and repetition of this occurrence is not anticipated. A complete overhaul of the airlock door mechanism is scheduled for the first shutdown to further reduce the probability of recurrence.

If there are any questions regarding the above, please contact me.

Sincerely,



Enclosure: LER 82-064

8209080086 820813
PDR ADOCK 05000361
S PDR

IE-29

R. H. Engelken

-2-

August 13, 1982

cc: Mr. A. E. Chaffee (USNRC Resident Inspector, San Onofre Unit 2)

U. S. Nuclear Regulatory Commission
Office of Inspection and Enforcement

U. S. Nuclear Regulatory Commission
Office of Management Information & Program Control

Institute of Nuclear Power Operations