



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

February 9, 1983

JAMES P. MCGAUGHY, JR.
ASSISTANT VICE PRESIDENT

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 3100
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Fire Door Blocked Open to
Allow Transport of Resin
LER 83-005/03 L-0
AECM-83/0090

On January 11, 1983, fire door OR106 was blocked open to allow transport of resin through it. A fire watch was established in accordance with Technical Specification 3.3.7.9. The event is reported pursuant to Technical Specification 6.9.1.13.b. Attached is LER 83-005/03 L-0.

Yours truly,

J.P. McGaughy, Jr.
FOR J.P. McGaughy, Jr.

JPM:sap
Attachment

- cc: Mr. N. L. Stampley (w/a)
- Mr. R. B. McGehee (w/o)
- Mr. T. B. Conner (w/o)
- Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk (w/a)
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

8302150635 830209
PDR ADOCK 05000416
S PDR

OFFICIAL COPY

LE 22