LICENSEE EVENT REPORT

CONTROL BLOCK: [ ] (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | CASO2 (2) | 00-000-00 (3) | 41111 (4) | (5)
LICENSEE CODE (14) | LICENSE NUMBER (25) | LICENSE TYPE (30) | CAT (58)

CON'T 01 | REPORT SOURCE L (6) | 05000361 (7) | 072582 (8) | 082482 (9)
DOCKET NUMBER (68) | EVENT DATE (74) | REPORT DATE (80)

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 With the plant in Mode 4, steam generator ΔP indicator 2PDI-0979-1 failed channel
03 check test and was placed in bypass condition prior to Mode 2 entry. The three
04 remaining steam generator ΔP indication channels for #2 steam generator remained
05 operable, thus there was no impact on health and safety of plant personnel or the
06 public.
07
08

09 SYSTEM CODE IA (11) | CAUSE CODE A (12) | CAUSE SUBCODE C (13) | COMPONENT CODE ZZZZZZ (14) | COMP. SUBCODE Z (15) | VALVE SUBCODE Z (16)

(17) LER/RO REPORT NUMBER: EVENT YEAR 82 | — | SEQUENTIAL REPORT NO. 076 | / | OCCURRENCE CODE 03 | REPORT TYPE L | — | REVISION NO. 0

ACTION TAKEN E (18) | FUTURE ACTION Z (19) | EFFECT ON PLANT Z (20) | SHUTDOWN METHOD Z (21) | HOURS (22) 0000 | ATTACHMENT SUBMITTED N (23) | NPRD-4 FORM SUB. N (24) | PRIME COMP. SUPPLIER N (25) | COMPONENT MANUFACTURER Z999 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 The indicator was determined to be valved out. The correct valve line-up was
11 restored. Cause of valve out is still being investigated with final report to be
12 submitted on or about September 30, 1982.
13
14

15 FACILITY STATUS B (28) | % POWER 000 (29) | OTHER STATUS (30) NA | METHOD OF DISCOVERY B (31) | DISCOVERY DESCRIPTION (32) Surveillance Test

16 ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY (35) NA | LOCATION OF RELEASE (36) NA

PERSONNEL EXPOSURES
17 NUMBER 000 (37) | TYPE Z (38) | DESCRIPTION (39) NA

PERSONNEL INJURIES
18 NUMBER 000 (40) | DESCRIPTION (41) NA

LOSS OF OR DAMAGE TO FACILITY (43)
19 TYPE Z (42) | DESCRIPTION NA

8209080104 820824
PDR ADOCK 05000361
S PDR

PUBLICITY
20 ISSUED N (44) | DESCRIPTION (45) NA

NRC USE ONLY

Name of Preparer: H. B. Ray Telephone: 714/492-7700