

APPENDIX A
NOTICE OF VIOLATION

Tennessee Valley Authority
Sequoyah Units 1 and 2

Docket Nos. 50-327 and 328
License Nos. DPR-77 and 79

As a result of the inspection conducted on November 6 - December 5, 1982, and in accordance with the NRC Enforcement Policy, 47 FR 9987 (March 9, 1982), the following violation was identified.

10 CFR 19.12, 20.102 and 20.202 respectively require that prior to permitting an individual to work in a restricted area or enter an area where the individual is likely to receive in excess of 25 percent of the applicable quarterly dose, the licensee shall properly inform the individual of the applicable radiological information, determine the individual's prior occupational dose and supply appropriate personnel monitoring equipment. These requirements are implemented by the licensee's Radiological Control Instructions RCI-2 "Radiological Hygiene Training" and RCI-3 "Personnel Monitoring."

Contrary to the above, an individual entered a restricted area without proper training, determination of prior dose or personnel monitoring equipment in that on November 25, 1982 a Field Services Group electrician entered the Unit 1 containment with a work crew without receiving the training, prior dose determination or personal dosimetry required by RCI-2 and 3. The licensee estimated the worker's dose by during the period based on the dose received other personnel in the area and it was well within regulatory limits.

This is a Severity Level IV Violation (Supplement I). This violation applies to both Units 1 and 2.

Pursuant to the provisions of 10 CFR 2.201, you are hereby required to submit to this office within thirty days of the date of this Notice, a written statement or explanation in reply, including: (1) admission or denial of the alleged violation; (2) the reasons for the violation if admitted; (3) the corrective steps which have been taken and the results achieved; (4) corrective steps which will be taken to avoid further violations; and (5) the date when full compliance will be achieved. Consideration may be given to extending your response time for good cause shown.

Date: DEC 29 1982

8302150670 830210
PDR ADOCK 05000327
Q PDR