

UNITED STATES NUCLEAR REGULATORY COMMISSIONGEORGIA POWER COMPANY, ET AL.DOCKET NO. 50-366NOTICE OF ISSUANCE OF AMENDMENT TO  
FACILITY OPERATING LICENSE

The U.S. Nuclear Regulatory Commission (Commission) has issued Amendment No. 132 to Facility Operating License No. NPF-5 issued to Georgia Power Company, et al. (the licensee), which revised the Technical Specifications for operation of the Edwin I. Hatch Nuclear Plant, Unit 2, located in Appling County, Georgia. The amendment is effective as of the date of issuance.

The amendment modified the Technical Specifications (TS) to permit an increase in the allowable leak rate for the main steam isolation valves (MSIVs) and deleted the TS requirements for the MSIV leakage control system.

The application for the amendment complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations. The Commission has made appropriate findings as required by the Act and the Commission's rules and regulations in 10 CFR Chapter I, which are set forth in the license amendment.


Notice of Consideration of Issuance of Amendment and Opportunity for Hearing in connection with this action was published in the FEDERAL REGISTER on November 5, 1993 (58 FR 59081). No request for a hearing or petition for leave to intervene was filed following this notice.

The Commission has prepared an Environmental Assessment related to the action and has determined not to prepare an environmental impact statement. Based upon the environmental assessment, the Commission has concluded that the issuance of this amendment will not have a significant effect on the quality of the human environment ( 59 FR 9780 ).

For further details with respect to the action see (1) the application for amendment dated October 1, 1993, as revised January 6, 1994, and supplemented February 3, 1994, (2) Amendment No. 132 to License No. NPF-5, (3) the Commission's related Safety Evaluation, and (4) the Commission's Environmental Assessment. All of these items are available for public inspection at the Commission's Public Document Room, the Gelman Building, 2120 L Street NW., Washington, DC 20555, and at the local public document room located at Appling County Public Library, 301 City Hall Drive, Baxley, Georgia 31513.

Dated at Rockville, Maryland, this 17th day of March 1994.

FOR THE NUCLEAR REGULATORY COMMISSION



Kahtan N. Jabbour, Project Manager  
Project Directorate II-3  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation