SAFEGUARDS INFORMATION



UNITED STATES NUCLEAR REGULATORY COMMISSION **REGION II**

101 MARIETTA ST., N.W., SUITE 3100 ATLANTA, GEORGIA 30303 December 27, 1982

Report No. 50-302/82-25

Docket No. 50-302

License No. DPR-72

Licensee: Florida Power Corporation 3201 34th Street, South St. Petersburg, FL 33733

Facility Name: Crystal River Unit 3

Inspection at: Crystal River, Florida

Inspection conducted: October 1, 1982

Date of Last Physical Security Inspection Visit: August 16-20, 1982

Type of Inspection: Unannounced Physical Security

Inspectors:

Security Inspector

Approved by: A

McGuire, Chief, Physical Protection Section

Technical Inspection Branch

Division of Engineering and Technical Programs

Inspection Summary

Areas Inspected: Included review of the circumstances surrounding implementation of compensatory actions for degraded vital and protected area intrusion detection systems.

The inspection involved 12 inspector hours on site by two NRC inspectors.

Results: The licensee was found to be in compliance with NRC requirements except for the following item.

Failure to provide compensatory measures for an accessed vital area door and failure to maintain a compensatory post for an accessed perimeter alarm system (50-302/82-25-01).

SAFEGUARDS INFORMATION

ENCLOSURE CONTAINS SAFEGUARDS INFORMATION. UPON SEFARATION THIS PAGE IS DECONTROLLED.