

THE CINCINNATI GAS & ELECTRIC COMPANY



CINCINNATI, OHIO 45201
August 20, 1982
QA-1952

E. A. BORGMANN
SENIOR VICE PRESIDENT

U. S. Nuclear Regulatory Commission
Region III
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Attention: Mr. J. G. Keppler
Regional Administrator

RE: WM. H. ZIMMER NUCLEAR POWER STATION UNIT I
NRC CIRCULAR 80-01 - GENERAL ELECTRIC COMPANY
RELAYS WITH PETROLEUM JELLY LUBRICATED TIME
DIALS, 10CFR50.55(e) - ITEM E-9 - DOCKET NO.
50-358, CONSTRUCTION PERMIT CPPR-88 - W.O.
#57300 JOB E-5590 FILE NO. NRC-7, ITEM E-9

Gentlemen:

This letter constitutes a supplement to the final report under 10CFR50.55(e) regarding General Electric Company type IAC Induction Disc Relays with petroleum jelly lubricated time dials. Our previous report to you regarding this matter was dated March 30, 1982.

As stated in our previous letter the twenty-six (26) additional relays to replace those that were shipped with a potential manufacturing defect have been received. The relays are currently being tested and calibrated. The anticipated completion date of August 31, 1982, stated in our last report, will not be met. The installation of these relays will be completed by September 30, 1982.

We trust that this will fulfill the reporting requirements under 10CFR50.55(e).

Very truly yours,

THE CINCINNATI GAS & ELECTRIC COMPANY

By

E. A. Borgmann
E. A. BORGMANN
SENIOR VICE PRESIDENT

WPC:as

cc: NRC Office of Inspection & Enforcement
Washington, D.C. 20555
NRC Senior Resident Inspector
Attn: W. F. Christianson
Zimmer Project Inspector
Region III

8209080261 820820
PDR ADOCK 05000358
S PDR

SEP 2 1982
LE27