

February 9, 1983

DISTRIBUTION

Docket  
NRC PDR  
Local PDR  
ORB Reading  
NSIC  
DCrutchfield  
HSmith  
JLombardo  
OELD  
ELJordan  
JMTaylor  
ACRS (10)  
SEPB

Docket No. 50-219  
LS05-83-02-023

Mr. P. B. Fiedler  
Vice President and Director  
Oyster Creek Nuclear Generating Station  
Post Office Box 388  
Forked River, New Jersey 08731

Dear Mr. Fiedler:

SUBJECT: NUREG-0737, ITEM NO. III.D.3.4, "CONTROL ROOM HABITABILITY -  
OYSTER CREEK NUCLEAR GENERATING STATION

In a submittal, dated February 10, 1981, you committed to substantial improvements in your control room habitability system, including a redundant filter system. Our contractor, Pacific Northwest Laboratories (PNL) reported favorably upon its review of these improvements, but was unable to complete its review because the dose computations necessary to demonstrate compliance with GDC 19 required assessment of the capability of the final design capabilities.

In a submittal, dated October 8, 1982, you revised your original response, withdrawing all commitments to provide air filtration, to meet single failure criteria, or to provide redundancy.

As revised, the system design at Oyster Creek is not acceptable. We request that you submit a complete restatement of all commitments with supporting drawings and documentation. A meeting or telephone conference call to discuss this subject could help resolve the subject.

We request that you provide this information within 30 days of receipt of this letter. *SE01*

The reporting and/or recordkeeping requirements contained in this letter affect fewer than ten respondents; therefore, OMB clearance is not required under P.L. 96-511. *DSU USE(SI)*

Sincerely,

Original signed by/

Dennis M. Crutchfield, Chief  
Operating Reactors Branch #5  
Division of Licensing

8302160231 830209  
PDR ADOCK 05000219  
P PDR

OFFICE	CC: See next page	DL:ORB#5	DL:ORB#5			
SURNAME		JLombardo	DCrutchfield			
DATE		02/9/83	02/11/83			

February 9, 1983

cc

G. F. Trowbridge, Esquire  
Shaw, Pittman, Potts and Trowbridge  
1800 M Street, N. W.  
Washington, D. C. 20036

Resident Inspector  
c/o U. S. NRC  
Post Office Box 445  
Forked River, New Jersey 08731

J. B. Lieberman, Esquire  
Berlack, Israels & Lieberman  
26 Broadway  
New York, New York 10004

Commissioner  
New Jersey Department of Energy  
101 Commerce Street  
Newark, New Jersey 07102

Ronald C. Haynes, Regional Administrator  
Nuclear Regulatory Commission, Region I  
631 Park Avenue  
King of Prussia, Pennsylvania 19406

J. Knubel  
BWR Licensing Manager  
GPU Nuclear  
100 Interplace Parkway  
Parsippany, New Jersey 07054

Deputy Attorney General  
State of New Jersey  
Department of Law and Public Safety  
36 West State Street - CN 112  
Trenton, New Jersey 08625

Mayor  
Lacey Township  
818 Lacey Road  
Forked River, New Jersey 08731

U. S. Environmental Protection  
Agency  
Region II Office  
ATTN: Regional Radiation Representative  
26 Federal Plaza  
New York, New York 10007

Licensing Supervisor  
Oyster Creek Nuclear Generating Station  
Post Office Box 388  
Forked River, New Jersey 08731