




KANSAS GAS AND ELECTRIC COMPANY

GLENN L. KOESTER
VICE PRESIDENT - NUCLEAR

February 4, 1983

Mr. W.C. Seidle, Chief
Reactor Projects Branch 2
U.S. Nuclear Regulatory Commission
Region IV
611 Ryan Plaza Drive, Suite 1000
Arlington, Texas 76011



KMLNRC 83-014
Re: Docket No. STN 50-482
Ref: 1) Interim Report KMLNRC 82-221 from GLKoester,
KG&E, to WCSeidle, NRC
2) Interim Report KMLNRC 82-248 from GLKoester,
KG&E, to WCSeidle, NRC
Subj: Potential 10CFR50.55(e) Interim Report -
Diesel Generator Bolt Torque

Dear Mr. Seidle:

The purpose of this letter is to provide a status report on the potentially loose stud/nut combinations in the diesel generators at Wolf Creek Generating Station. This matter was reported to Region IV of the Nuclear Regulatory Commission on June 14, 1982, by Kansas Gas and Electric Company and subsequent status reports were submitted in References 1) and 2).

The rework plan for the inspection and retorquing of the stud/nut combinations in question has been finalized and sent to the job site. The work will be scheduled when compatible with other work in progress.

The status of the inspection and evaluation will be reported on or before June 6, 1983. In the interim, please direct any questions concerning this subject to me or to Mr. Otto Maynard of my staff.

Yours very truly,

Glenn L. Koester

FE 27

GLK:bb
cc:RCDeYoung
TVandel/SSchum

8302160245 830204
PDR ADOCK 05000482
S PDR