



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555-0001

DUKE POWER COMPANY

DOCKET NO. 50-369

McGUIRE NUCLEAR STATION, UNIT 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 141
License No. NPF-9

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment to the McGuire Nuclear Station, Unit 1 (the facility), Facility Operating License No. NPF-9 filed by the Duke Power Company (licensee) dated October 25, 1993, as supplemented December 3, 1993, and February 14, 1994, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations as set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.


2. Accordingly, the license is hereby amended by page changes to the Technical Specifications as indicated in the attachment to this license amendment, and Paragraph 2.C.(2) of Facility Operating License No. NPF-9 is hereby amended to read as follows:

Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 141, are hereby incorporated into this license. The licensee shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of its date of issuance and shall be implemented within 30 days from the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



David B. Matthews, Director
Project Directorate II-3
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Attachment:
Technical Specification
Changes

Date of Issuance: March 22, 1994



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555-0001

DUKE POWER COMPANY

DOCKET NO. 50-370

McGUIRE NUCLEAR STATION, UNIT 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 123
License No. NPF-17

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment to the McGuire Nuclear Station, Unit 1 (the facility), Facility Operating License No. NPF-17 filed by the Duke Power Company (licensee) dated October 25, 1993, as supplemented December 3, 1993, and February 14, 1994, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations as set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

2. Accordingly, the license is hereby amended by page changes to the Technical Specifications as indicated in the attachment to this license amendment, and Paragraph 2.C.(2) of Facility Operating License No. NPF-17 is hereby amended to read as follows:

Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 123, are hereby incorporated into this license. The licensee shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of its date of issuance and shall be implemented within 30 days from the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



David B. Matthews, Director
Project Directorate II-3
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Attachment:
Technical Specification
Changes

Date of Issuance: March 22, 1994

ATTACHMENT TO LICENSE AMENDMENT NO. 141

FACILITY OPERATING LICENSE NO. NPF-9

DOCKET NO. 50-369

AND

TO LICENSE AMENDMENT NO. 123

FACILITY OPERATING LICENSE NO. NPF-17

DOCKET NO. 50-370

Replace the following pages of the Appendix "A" Technical Specifications with the enclosed pages. The revised pages are identified by Amendment number and contain vertical lines indicating the areas of change.

| <u>Remove</u> <u>Pages</u> | <u>Insert</u> <u>Pages</u> |
|-------------------------------|-------------------------------|
| 2-2 | 2-2 |
| 2-3 | 2-3 |
| 2-5 | 2-5 |
| 2-8 | 2-8 |
| 2-9 | 2-9 |
| 2-10 | 2-10 |
| 2-11 | 2-11 |
| 3/4 2-24 | 3/4 2-24 |




Figure 2.1-1
 REACTOR CORE SAFETY LIMITS - FOUR LOOPS IN OPERATION

This page intentionally left blank

|

TABLE 2.2-1

REACTOR TRIP SYSTEM INSTRUMENTATION TRIP SETPOINTS

| <u>FUNCTIONAL UNIT</u> | <u>TRIP SETPOINT</u> | <u>ALLOWABL VALUES</u> |
|--|--|---|
| 1. Manual Reactor Trip | N.A. | N.A. |
| 2. Power Range, Neutron Flux | Low Setpoint - $\leq 25\%$ of RATED THERMAL POWER High Setpoint - $\leq 109\%$ of RATED THERMAL POWER | Low Setpoint - $\leq 26\%$ of RATED THERMA POWER HighSetpoint - $\leq 110\%$ of RATED THERMA POWER |
| 3. Power Range, Neutron Flux, High Positive Rate | $\leq 5\%$ of RATED THERMAL POWER with a time constant ≥ 2 seconds | $\leq 5.5\%$ of RATED THERMAL POWER with a time constant ≥ 2 seconds |
| 4. Intermediate Range, Neutron Flux | $\leq 25\%$ of RATED THERMAL POWER | $\leq 30\%$ of RATED THERMAL POWER |
| 5. Source Range, Neutron Flux | $\leq 10^5$ counts per second | $\leq 1.3 \times 10^5$ counts per second |
| 6. Overtemperature ΔT | See Note 1 | See Note 3 |
| 7. Overpower ΔT | See Note 2 | See Note 4 |
| 8. Pressurizer Pressure--Low | ≥ 1945 psig | ≥ 1935 psig |
| 9. Pressurizer Pressure--High | ≤ 2385 psig | ≤ 2395 psig |
| 10. Pressurizer Water Level--High | $\leq 92\%$ of instrument span | $\leq 93\%$ of instrument span |
| 11. Low Reactor Coolant Flow | $\geq 90\%$ of minimum measured flow per loop* | $\geq 88.8\%$ of minimum measured flow per loop* |

*Minimum measured flow is 95,500 gpm per loop.

TABLE 2.2-1 (Continued)

REACTOR TRIP SYSTEM INSTRUMENTATION TRIP SETPOINTS

NOTATION

NOTE 1: OVERTEMPERATURE ΔT

$$(\Delta T / \Delta T_0) \left(\frac{1 + \tau_1 S}{1 + \tau_2 S} \right) \left(\frac{1}{1 + \tau_3 S} \right) \leq K_1 - K_2 \left(\frac{1 + \tau_4 S}{1 + \tau_5 S} \right) [T \left(\frac{1}{1 + \tau_6 S} \right) - T_1] + K_3 (P - P^1) - f_1(\Delta I)$$

- Where:
- ΔT = Measured ΔT by Loop Narrow Range RTD,
 - ΔT_0 = Indicated ΔT at RATED THERMAL POWER,
 - $\frac{1 + \tau_1 S}{1 + \tau_2 S}$ = Lead-lag compensator on measured ΔT ,
 - τ_1, τ_2 = Time constants utilized in the lead-lag controller for ΔT , $\tau_1 \geq 8$ sec., $\tau_2 \leq 3$ sec.,
 - $\frac{1}{1 + \tau_3 S}$ = Lag compensator on measured ΔT ,
 - τ_3 = Time constants utilized in the lag compensator for ΔT , $\tau_3 \leq 2$ sec.*
 - $K_1 \leq 1.1988$,
 - $K_2 = 0.03354$,
 - $\frac{1 + \tau_4 S}{1 + \tau_5 S}$ = The function generated by the lead-lag controller for T_{avg} dynamic compensation,
 - τ_4, τ_5 = Time constants utilized in the lead-lag controller for T_{avg} , $\tau_4 \geq 28$ sec., $\tau_5 \leq 4$ sec.,
 - T = Average temperature, °F,
 - $\frac{1}{1 + \tau_6 S}$ = Lag compensator on measured T_{avg} ,

TABLE 2.2-1 (Continued)

REACTOR TRIP SYSTEM INSTRUMENTATION TRIP SETPOINTSNOTATION (Continued)

NOTE 1: (Continued)

| | | |
|----------|---|--|
| τ_6 | = | Time constant utilized in the measured T_{avg} lag compensator, $\tau_6 \leq 2$ sec. |
| T^1 | = | ≤ 588.2 °F Reference T_{avg} at RATED THERMAL POWER, |
| K_3 | = | 0.001522, |
| P | = | Pressurizer pressure, psig, |
| P^1 | = | 2235 psig (Nominal RCS operating pressure), |
| S | = | Laplace transform operator, sec^{-1} , |

and $f_1(\Delta I)$ is a function of the indicated difference between top and bottom detectors of the power-range nuclear ion chambers; with gains to be selected based on measured instrument response during plant startup tests such that:

- (i) for $q_t - q_b$ between $-44.0\% \Delta I$ and $+12.0\% \Delta I$; $f_1(\Delta I) = 0$, where q_t and q_b are percent RATED THERMAL POWER in the top and bottom halves of the core respectively, and $q_t + q_b$ is total THERMAL POWER in percent of RATED THERMAL POWER;
- (ii) for each percent imbalance that the magnitude of $q_t - q_b$ is more negative than $-44.0\% \Delta I$, the ΔT Trip Setpoint shall be automatically reduced by 3.436% of ΔT_0 ; and
- (iii) for each percent imbalance that the magnitude of $q_t - q_b$ is more positive than $+12.0\% \Delta I$, the ΔT Trip Setpoint shall be automatically reduced by 1.619% of ΔT_0 .

TABLE 2.2-1 (Continued)

REACTOR TRIP SYSTEM INSTRUMENTATION TRIP SETPOINTS

NOTATION (Continued)

NOTE 2: OVERPOWER ΔT

$$(\Delta T / \Delta T_0) \left(\frac{1 + \tau_1 S}{1 + \tau_2 S} \right) \left(\frac{1}{1 + \tau_3 S} \right) \leq K_4 - K_5 \left(\frac{\tau_7 S}{1 + \tau_7 S} \right) \left(\frac{1}{1 + \tau_6 S} \right) T - K_6 \left[T \left(\frac{1}{1 + \tau_6 S} - T'' \right) - f_2 (\Delta I) \right]$$

- Where:
- ΔT = As defined in Note 1,
 - ΔT_0 = As defined in Note 1,
 - $\frac{1 + \tau_1 S}{1 + \tau_2 S}$ = As defined in Note 1
 - τ_1, τ_2 = As defined in Note 1
 - $\frac{1}{1 + \tau_3 S}$ = As defined in Note 1,
 - K_4 \leq 1.0851,
 - K_5 = 0.02/°F for increasing average temperature and 0 for decreasing average temperature,
 - $\frac{\tau_7 S}{1 + \tau_7 S}$ = The function generated by the rate-lag controller for T_{avg} dynamic compensation,
 - τ_7 = Time constant utilized in the rate-lag controller for T_{avg} , $\tau_7 \geq 5$ sec,
 - $\frac{1}{1 + \tau_6 S}$ = As defined in Note 1,
 - τ_6 = As defined in Note 1,
 - K_6 = 0.001207/°F for $T > T''$ and $K_6 = 0$ for $T \leq T''$,

TABLE 2.2-1 (Continued)

REACTOR TRIP SYSTEM INSTRUMENTATION TRIP SETPOINTS

NOTATION (Continued)

- T = As defined in Note 1,
- T^{*} = ≤ 588.2 °F Reference T_{avg} at RATED THERMAL POWER,
- S = As defined in Note 1, and

f₂(ΔI) is a function of the indicated difference between top and bottom detectors of the power-range nuclear ion chambers; with gains to be selected based on measured instrument response during plant startup tests such that:

- (i) for q_t - q_b between -35% and +35% ΔI; f₂(ΔI) = 0, where q_t and q_b are percent RATED THERMAL POWER in the top and bottom halves of the core respectively, and q_t + q_b is total THERMAL POWER in percent of RATED THERMAL POWER;
- (ii) for each percent imbalance that the magnitude of q_t - q_b is more negative than -35% ΔI, the ΔT Trip Setpoint shall be automatically reduced by 7.0% of ΔT₀; and
- (iii) for each percent imbalance that the magnitude of q_t - q_b is more positive than +35% ΔI, the ΔT Trip Setpoint shall be automatically reduced by 7.0% of ΔT₀.

Note 3: The channel's maximum Trip Setpoint shall not exceed its computed Trip Setpoint by more than 4.4% of Rated Thermal Power. |

Note 4: The channel's maximum Trip Setpoint shall not exceed its computed Trip Setpoint by more than 3.0% of Rated Thermal Power. |

POWER DISTRIBUTION LIMITS

Figure 3.2-1 Reactor Coolant System Total Flow Rate Versus Rated Thermal Power - Four Loops in Operation

