

T-1181
ORIGINAL

OFFICIAL TRANSCRIPT PROCEEDINGS BEFORE

NUCLEAR REGULATORY COMMISSION
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

DKT/CASE NO.

TITLE 274TH GENERAL MEETING

PLACE Washington, D. C.

DATE February 11, 1983

PAGES 124 - 474

8302160282 830211
PDR ACRS
T-1181 PDR

TROY
DELETE ACRS



ALDERSON REPORTING

(202) 628-9300
440 FIRST STREET, N.W.
WASHINGTON, D.C. 20001

1 UNITED STATES OF AMERICA
2 NUCLEAR REGULATORY COMMISSION

3 274TH GENERAL MEETING
4 ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

5 Room 1046
6 1717 H Street, N.W.
7 Washington, D.C.

8 Friday, February 11, 1983

9 The Advisory Committee on Reactor Safeguards
10 met, pursuant to notice, at 8:30 a.m., Jeremiah J. Ray,
11 Chairman, presiding.

12 ACRS MEMBERS PRESENT:

13 JEREMIAH J. RAY, Chairman
14 JESSE C. EBERSOLE, Vice Chairman
15 PAUL G. SHEWMON
16 CARSON MARK
17 CHESTER P. SIESS
18 ROBERT C. AXTMANN
19 DADE W. MOELLER
20 MYER BENDER
21 WILLIAM KERR
22 MAX W. CARBON
23 HAROLD ETHERINGTON
24 FORREST J. REMICK
25 DAVID A. WARD
DAVID OKRENT

ALSO PRESENT:

PAUL BOEHNERT,
Designed Federal Employee

P R O C E E D I N G S

1
2 MR. RAY: The meeting will now come to order.

3 This is the second day of the 274th meeting of
4 the Advisory Committee on Reactor Safeguards. During
5 today's meeting the Committee will hear reports on and
6 discuss the Clinch River breeder reactor project. The
7 items scheduled for discussion on Saturday are listed in
8 the schedule for this meeting which is posted on the
9 bulletin board at the back of the room and on the
10 outside of the room.

11 The meeting is being conducted in accordance
12 with the provisions of the Federal Advisory Committee
13 Act, and the Government in the Sunshine Act. Mr. Paul
14 Boehnert on my right is the Designated Federal Employee
15 for this portion of the meeting.

16 Portions of this meeting will be closed as
17 necessary to discuss proprietary information applicable
18 to this project.

19 A transcript of portions of the meeting is
20 being kept and it is requested that each speaker use
21 their microphone, identify himself or herself, and speak
22 with sufficient clarity and volume that he or she can be
23 readily heard.

24 We have received no written statements or
25 requests to make oral statements from members of the

1 public regarding today's meeting.

2 The only item on today's schedule is the
3 Clinch River breeder reactor project, and Dr. Carbon
4 will begin this discussion. It's yours, Max.

5 MR. CARBON: This is obviously a continuation
6 of the review that has been in progress for some time.
7 I would just review briefly, that in July we discussed
8 site suitability, and in December we had a plant
9 overview, and in January we had heat removal systems.

10 Now today we look at the plant seismic margin,
11 and part of this is a review of material that was
12 covered last July, but part of it was not. And in
13 addition, today there is the mechanical nuclear and
14 thermal hydraulic design with the reactor core, the
15 internals of the reactor vessel.

16 This is to include some discussion at least on
17 instrumentation, and it is I believe -- I hope to
18 include a discussion of the maximum chilling transfer
19 for the core, which Mr. Ebersole wanted or raised a
20 question about last time.

21 In addition, there will be some discussion on
22 the pooled circuitry and the interfaces of steam-water
23 -- I'm sorry, sodium-water, sodium-air, and so on. And
24 there will be a discussion on the materials and a
25 discussion on the steam generator accidents and

1 consequences.

2 Very briefly, for next month we have scheduled
3 reactor shutdown and control, and a very extensive
4 discussion on the containment philosophy and design,
5 which will cover both DBA's and beyond the DBA, CDA
6 energetics, structural margins for energetics, and
7 non-energetic CDA's, including meltdown and thermal and
8 pressure margins for those non-energetic CDA's.

9 And then in April there will be a mix of
10 topics: reliability, in-service inspection, human
11 factors, accident contingency, probably some QA/QC
12 discussion, and I'm not sure but perhaps something on
13 sabotage, depending upon your interest.

14 As sort of a second major item, let me call
15 your attention to how the Staff will be participating
16 today, which is different than it has been in the past.
17 As you are aware, we have been carrying on a review sort
18 of in parallel with the Staff, which we have had
19 extensive discussions with the Applicant at the same
20 time that the Staff has been.

21 Heretofore, the Staff has not had positions on
22 most of the topics that we have taken up. But in
23 contrast, today on these topics the Staff does have and
24 will present actually its final position, I believe, on
25 several topics. We don't have the SER yet. I believe

1 it is scheduled out about March 1st, and so we can
2 reasonably raise any kinds of questions later that we
3 want to after we get the SER.

4 But on the other hand, the more that we can
5 finish up as we go along, the less we will have to
6 duplicate and perhaps the less inefficient use of time.

7 As a third general topic here, let me call
8 your attention to an article on LMFBR's which was passed
9 out in the loose material that should be inside your
10 folder. It's title is "The State of the Art for Fast
11 Reactors." It is by a former Director of the U.K. fast
12 reactor program, and based to a considerable extent on
13 his interpretation of some of the discussion of the
14 material at the fast reactor safety conference in Lyons,
15 France, last July.

16 Dave Okrent and I both attended that. I
17 thought the article would provide good background. As I
18 commented in the cover letter, there are differences in
19 approaches among the French and the British and
20 ourselves that we take to fast reactor safety, and
21 certainly there is no reason to expect that everyone is
22 going to take the same features or anything like that.

23 It is simply that I wanted you to be aware
24 that there are differences and to give all of us the
25 opportunity to explore these differences when they seem

1 worth exploring. Some of the particular ones which have
2 been mentioned in the past -- and again, we use a
3 heterogeneous core, which our people in the U.S. feel
4 offers some definite safety advantages. None of the
5 other three groups, the French or British or Germans, do
6 use such a core.

7 In contrast, the French and British at least
8 make more extensive use of in-core thermocouples, and I
9 believe the British have ultrasonic equipment for
10 under-sodium testing. I think that the British and
11 French are both using core catchers in their large
12 prototype size reactors, several times the size of our
13 CRBR.

14 Going on to item number 4, I would call your
15 attention again to the fact that everyone I think knows
16 that we're scheduled to run to 8:00 o'clock tonight, and
17 that is all right. But I guess I would sort of suggest
18 we try and stay on the relevant topics, so as not to
19 extend it too far beyond that.

20 Finally, let me call on the other working
21 group chairman and Subcommittee members for any
22 additional comments they might wish to make before we
23 start. Bill, do you have any comments?

24 MR. KERR: No.

25 MR. CARBON: Bob Axtmann?

1 MR. AXTMANN: No.

2 MR. CARBON: And Carson?

3 MR. MARK: No, thank you.

4 MR. CARBON: Paul?

5 MR. SHEWMON: No.

6 MR. CARBON: Does anyone else care to make
7 comments or suggestions?

8 MR. RAY: I would like to suggest that serious
9 consideration of your last remark about going beyond
10 8:00 p.m. be dominant, in order not to dilute our
11 considerations.

12 MR. CARBON: I don't think there will be much
13 of a difference of opinion on that.

14 Well, with that, then, let us proceed with the
15 agenda, and it calls for an introduction by Mr. Stark of
16 the NRC.

17 MR. CROSS: Mr. Chairman, this is Peter Gross
18 from DOE. In the interest of making sure we meet the
19 8:00 o'clock deadline for completing this meeting, due
20 to the weather two of our presenters today will not be
21 able to make it. Their planes have been cancelled. And
22 this is Griffin and Mallett from Westinghouse, and
23 unfortunately their flight has been cancelled, and we
24 don't have anyone here who can make those
25 presentations. It is approximately 45 minutes of the

1 schedule.

2 MR. CARBON: Well, if we have to pass we
3 certainly will. On the other hand, the more things that
4 pile up the more difficult it makes it down the road.

5 MR. SHEWMON: If we have to break at 7:15
6 tonight, we might be able to.

7 (Laughter.)

8 MR. BENDER: As an ex-Chairman, you sound very
9 tractable.

10 (Laughter.)

11 MR. STARK: Good morning. I expect all of our
12 reviewers will be present today at the required time.

13 As Dr. Carbon did indicate, the reviewers have
14 completed their SER sections and our SER will be out on
15 March 4th, so the positions you'll be hearing today will
16 be final positions of the Staff. And I guess that is
17 really all I need to say about that.

18 What I would like to then do is go into the
19 next subject, which is the external phenomenon. And
20 what I intend to do here is several things.

21 (Slide.)

22 Most of that information, in fact all of it,
23 is contained in chapter 2, so I thought I would give you
24 a summary of chapter 2 and then we would discuss one or
25 two items in detail.

1 The chapter 2 items were a part of the site
2 suitability report, which was, as Dr. Carbon indicated,
3 was discussed last summer. Since that time the Staff
4 has also completed their SER review for chapter 2.
5 There are two items that have changed since last
6 summer.

7 One is in the meteorology review. You may
8 recall last summer that the meteorological dispersion
9 model then did not comply with Reg Guide 1.145. It now
10 does. The SER reflects that. The results are
11 acceptable. They were acceptable before, but that is
12 just a minor change.

13 The other item is in seismology. The Staff
14 has since received an SER from USGS, who is an advisor
15 to the Staff, and Bob Rothman, who will follow me, will
16 discuss how that particular SER has been factored into
17 our SER. And since there has been a lot of interest in
18 the seismic activity, Bob is going to present in a
19 little more detail the results of the seismic review,
20 kind of a refresher plus an update.

21 The one thing I do want to point out in this
22 particular area in chapter 2 is that the standard review
23 plan does apply and gives us good guidance, and
24 therefore the review on chapter 2 was done in accordance
25 with the standard review plan, and chapter 2 has no open

1 items in it right now.

2 MR. BENDER: I don't even know if this is the
3 right place to raise this question, but I'm going to
4 raise it anyhow. The previous practice in licensing,
5 particularly with respect to hydraulics, has really been
6 related mainly to the question of having to do with
7 small releases of radionuclides.

8 We really haven't tried, as I understand it,
9 to spend much time worrying about very large accidents
10 and how the hydrology of the region might relate to such
11 things. This is only one reactor, so maybe this isn't
12 important.

13 MR. STARK: Well, the environmental statement,
14 the Staff's final environmental statement, does address
15 that, and we looked at the impact on ground water, and I
16 will have to look at that number again, but it is in the
17 order of 12 years or 8 or 9 years until the
18 radioisotopes are found in ground water. That is what
19 you're referring to, due to major accidents.

20 MR. BENDER: Do we have enough information in
21 the way of analysis to support that position? That is,
22 do we understand the mechanism of the accidents well
23 enough to argue that case?

24 MR. STARK: I don't know if I can personally
25 answer that, but I can look at the final environmental

1 statement, see how it is addressed, and give that
2 information, because it is something that we analyze and
3 do predict numbers for. And as I said, they are
4 required as a part of the environmental review.

5 MR. BENDER: This may not be the right place
6 to raise that question.

7 MR. STARK: Let me get the information. Then
8 perhaps if we could look at your question from there. I
9 have a hydrologist here. Maybe he would have the answer
10 to that. Dick Codell from the Hydrology Branch.

11 MR. CODELL: Richard Codell from the
12 Hydrologic Engineering Section.

13 We have in this case presented a small
14 analysis for ground water contamination of the Clinch
15 River. That is in the environmental statement. What we
16 have been doing on all environmental statements is an
17 analysis in which we compare the potential ground water
18 releases and realizing that this problem is, as severe
19 as it might be, is much less of a problem than
20 atmospheric releases, we are able to draw conclusions,
21 and we have done so in the Clinch River case, on two
22 examples of light water reactors in recent times.

23 We have also analyzed the contamination of
24 water supplies, surface water supplies, as a result of
25 atmospheric fallout from large atmospheric releases.

1 Those are Fermi 2 and Indian Point. Those cases are
2 being done ad hoc. We haven't gotten into a large
3 program of doing them on every site.

4 But the results further confirm that the
5 liquid pathway consequences and risks are far less than
6 the atmospheric risks.

7 MR. BENDER: I think that maybe you didn't
8 address the accident concepts in the right way. I
9 really don't have much of a feeling for the surface
10 contamination from an accident that largely involves
11 airborne contamination. I had more in mind those kinds
12 of accidents that postulate penetration of the
13 containment and subsequently they represent a path,
14 liquid pathways from that kind of an accident through
15 the ground system.

16 MR. CODELL: That is exactly the situation we
17 looked at in the Clinch River case, and we considered
18 the penetration of the basemat and subsequent transport
19 of dissolved radionuclides in the ground water to the
20 Clinch River. I don't have the figures in front of me.
21 I am thumbing through the FES. I don't recall that it
22 was any particular problem. That is, no worse than the
23 large majority of light water reactor sites that we have
24 studied.

25 MR. BENDER: What are we presuming that we

1 know about the subsurface structure?

2 MR. CODELL: Well, there are certain basic
3 hydrologic factors that have been studied on the site,
4 such as the permeability, porosity, and there are
5 certain inferences you can make about the chemical
6 behavior of radionuclides in the soil.

7 We also in our branch have been studying
8 methods by which these types of releases could be
9 stopped before they ever reach surface water.

10 MR. BENDER: Could you just provide us a copy
11 of the analysis?

12 MR. CODELL: Do you mean beyond that which is
13 in the FES?

14 MR. BENDER: I don't think the FES has enough
15 substance to it to be able to analyze it. It has
16 general statements.

17 MR. CODELL: I would be glad to work a writeup
18 for our analysis which would explain in a little more
19 detail, although I believe in the Clinch River case we
20 did not spend very much time on it.

21 MR. AXTMANN: As I recall, a week or so ago
22 the project announced the basemat would never be
23 penetrated. But you assume that it would.

24 MR. CODELL: That's right, we assume that it
25 would. I wasn't aware of what you just said.

1 MR. BENDER: It certainly all right to make
2 assumptions about that. I'm not trying to argue with
3 you. I just wanted to see what your analysis was.

4 MR. CODELL: Certainly I would be glad to work
5 something up on that. I could have it done in a few
6 weeks.

7 MR. OKRENT: On the same question, while
8 you're standing, there is some part of the NRC that
9 considers high-level wastes and how long it should stay
10 put if you put it in the ground. And to them 12 years
11 is not a long time. In fact, it is almost like a day.

12 Is there someone within the NRC that looks at
13 how that problem is being approached? Of course, there
14 is a different probability of something being in the
15 ground if in one case you put it in the ground and in
16 the other case it takes an accident, so that would have
17 to be factored into the consideration.

18 But nevertheless, I am interested in knowing
19 whether somewhere within the NRC or within your branch a
20 look at both of these topics has been taken and somehow
21 they are put into a harmonious position.

22 MR. CODELL: I think I understand what you're
23 getting at. As far as I know, no one has ever looked at
24 long-term storage of accidental releases in the ground.
25 I think the assumption we have always gone under is that

1 you would deal with it in the short term, but in the
2 long term you would not allow any kind of accidental
3 releases to stay in place. You would do whatever you
4 had to do after the event, and I can't really go beyond
5 that.

6 I think it would be prudent not to leave any
7 kind of high-level accidental releases in the ground,
8 and I think you would probably excavate and dispose of
9 this material somewhere else.

10 MR. BENDER: You see how easy it is?

11 (Laughter.)

12 MR. OKRENT: I'm impressed.

13 MR. RAY: Go on.

14 MR. STARK: That's all I really had to say.
15 But what I would like to do is now bring Bob Rothman up
16 and have Bob give you an overview and an update of the
17 seismic, the Staff seismic evaluation.

18 MR. OKRENT: Just one quick question. This
19 reactor is designed for the standard tornado in the Reg
20 Guide?

21 MR. STARK: Yes, I think they predicted 73
22 mile an hour winds, so I think it is designed for 90
23 miles.

24 MR. OKRENT: Now, this is tornado, I said.
25 It's just that the Staff is playing with some new method

1 of analysis and I just wanted to find out whether that
2 in some way had drifted into this design.

3 MR. GROSS: Our presenter will cover that in
4 detail when he gets up.

5 MR. OKRENT: Okay.

6 MR. STARK: I will try to look it up, also.

7 MR. ROTHMAN: I'm Robert Rothman in the
8 Seismology and Geosciences Branch.

9 We completed our review of the geology and the
10 seismology of the Clinch River breeder reactor SEP and
11 the USGS has acted as advisors to the Staff. The
12 conclusions reached in the SER are that the faults at
13 the site and the site region are not capable of
14 controlling an earthquake. The design is a recurrence
15 of the 1897 Giles County maximum modified intensity 8
16 event, the SSC of 8.25g anchoring a Regulatory Guide 1.6
17 spectrum. It is possible to account for the occurrence
18 of this in the site vicinity.

19 There are no known capable faults in the
20 Southeastern United States, but as a further
21 confirmatory study of the non-capability of the local
22 faults, the Staff recommends a study to investigate the
23 relationships of the Pleistocene deposits in the local
24 faults in the Clinch River area --

25 MR. KERR: I'm sorry, would you repeat that

1 last statement.

2 MR. ROTHMAN: I said we know of no --

3 MR. KERR: I understood that, but then you
4 said the Staff recommends something.

5 MR. ROTHMAN: The Staff recommends as a
6 confirmatory item a study of the relationship between
7 the Pleistocene river terrace deposits and the local
8 faults in the site region.

9 MR. KERR: And how long would you anticipate
10 such a study would take?

11 MR. ROTHMAN: We're not putting any time limit
12 on this. It is not even being put out as an open item.
13 We're just recommending that it would be prudent for the
14 Applicant to look at these and report on them, possibly
15 in the FSAR. We have no evidence that there are capable
16 sites, but this is something that was done for other
17 sites in the region, such as Watts Bar and Phipps Bend,
18 and the geologists thought such a study could be done
19 but they didn't want to put a licensing condition on
20 it.

21 MR. KERR: I guess I don't understand the
22 significance of the recommendation, then. But maybe I
23 don't need to.

24 Go ahead.

25 MR. ROTHMAN: What they recommend is that we

1 look at where these terrace deposits overlie local
2 faults, that they look and see if there have been
3 displacements of the terrace deposits which would
4 indicate recent movement of the faults or possibility of
5 the faults.

6 MR. MOELLER: If that was done for these other
7 sites, would the data there not apply?

8 MR. ROTHMAN: Well, that's right, and the
9 Staff has based its conclusion on knowledge of work that
10 was done for the other sites. There are, however, from
11 what I understand -- and I'm not a geologist and I
12 haven't looked at this -- that there are river deposits
13 or terrace deposits in the vicinity of Clinch River,
14 along the Clinch River, that have not been looked at.
15 They were looked at, as I said, in the Watts Bar region
16 and in the Phipps Bend region.

17 The existence of a possible seismogenic zone
18 has been postulated in eastern Tennessee. The evidence
19 for such a zone does not warrant its consideration as a
20 capable fault within the meaning of Appendix A to Part
21 100 of 10 CFR.

22 The results of seismological research in the
23 region, including the data from a well distributed
24 network of seismic stations, will be monitored to
25 further address this postulation. A probabilistic

1 analysis was performed by the USGS and it indicates an
2 order of magnitude difference in the recurrence of the
3 SSE acceleration if this seismogenic zone is considered
4 to exist, as opposed to the diffuse seismicity in the
5 southern Appalachian region.

6 And that is basically where we stand.

7 MR. OKRENT: What would the numbers be for
8 each of the two assumptions, then?

9 MR. ROTHMAN: For the diffuse zone, the
10 numbers are on the order of two times 10^{-4} , and you
11 have about an order of magnitude higher if you assume
12 this. And this zone was assumed to be 140 kilometers
13 long, capable of an earthquake on the order of magnitude
14 7 or such, and it passes within 15 kilometers of the
15 Clinch River site. And it would be about -- the
16 exceedance was about an order of magnitude.

17 MR. OKRENT: So depending upon which postulate
18 you make, two times 10^{-3} , two times 10^{-4} , is that
19 what you're saying?

20 MR. ROTHMAN: Well, the diffuse zone is not
21 the one end of it and this zone the other. There are
22 other models that could be looked at, like requiring the
23 Giles County earthquake to be confined within the Giles
24 County seismic zone, which would then decrease your
25 recurrence.

1 So in other words, we're not looking at two
2 end members. These are just two things that the USGS
3 looked at.

4 MR. OKRENT: I don't recall. If the USGS
5 recent considerations on the Charleston earthquake were
6 applied, would they move that into a zone which
7 encompassed Clinch River?

8 MR. ROTHMAN: We are not very clear on that,
9 on just how far west under -- you know, there are
10 several hypotheses on how the Charleston earthquake
11 could reoccur, and in maybe one or two of those it might
12 be, have to be considered, but not in all of them. And
13 this has not been addressed.

14 As you know, there is a planned program for
15 addressing the Charleston event, and part of that is
16 going to be a probabilistic study that will be
17 performed. So it will be addressed as far as the
18 eastern plants are concerned.

19 I don't know what the USGS would say, if they
20 would say that they would consider Clinch River as part
21 of their eastern seaboard in their recent Charleston.

22 MR. OKRENT: I guess I'm a little surprised
23 that the project office hasn't tried to find out just
24 where this particular reactor fits with regard to that
25 question. I don't think it is going to be a major

1 consideration, let me say, but nevertheless I would have
2 thought you would have tried to get that particular
3 point nailed down.

4 MR. ROTHMAN: It is addressed in the SER, in
5 the geology section of the SER.

6 MR. BROCHAM: This is Steve Brocham with the
7 Geology Section.

8 In the position the USGS sent to us, they
9 defined the eastern system as the coastal plain and the
10 Piedmont. Taking that definition strictly, Clinch River
11 is west of their definition of the eastern seaboard.

12 MR. OKRENT: Thank you. That is a direct
13 answer, I think.

14

15

16

17

18

19

20

21







22

23

24

25

IMAGE EVALUATION
TEST TARGET (MT-3)



1 MR. CARBON: Any other questions?

2 (No response.)

3 MR. CARBON: Continue.

4 MR. ROTHMAN: That's all I have.

5 MR. CARBON: Good. Thank you.

6 I guess that concludes the Staff
7 presentation. Let's move on then to the Applicant.

8 MR. MOELLER: Could you clarify for me the
9 topics on tornadoes also, what were tornadoes? Oh, this
10 is the tornadoes.

11 MR. CARBON: Yes. I wondered if there were
12 any questions of the Staff.

13 MR. STARK: I was doing some looking after Dr.
14 Okrent asked me a question, and I guess I will touch on
15 both tornadoes and on hurricanes in the SER section that
16 I'm reading.

17 It said between 1953 and 1974 54 tornadoes
18 within a 10,000 square mile area containing the site.
19 This results in a mean annual tornado frequency of 2.5,
20 and a recurrence interval for a tornado at the plant
21 site of 1,450 years. The design basis tornado
22 characteristics selected by the Applicant conform to the
23 recommendations of Reg Guide 1.76, which is design basis
24 tornado for nuclear power plants.

25 It gives the characteristics: rotational.

1 speed, 290 miles per mile; translational speed, 270
2 miles; and at 3 psi a pressure drop occurring at a rate
3 of 2 1/2 psi per second.

4 It goes on to say that remnants of hurricanes
5 and tropical storms occasionally affect the area, and
6 during the period of 1871 to 1973, nine tropical storms
7 or hurricanes passed through the region. And it said
8 the fastest mile of wind recorded in this area has been
9 73 miles per hour at Knoxville in July of 1961.

10 That's all I have to say right now.

11 MR. CARBON: Are there any more questions of
12 the Staff?

13 (No response.)

14 MR. CARBON: Go ahead, Mr. Palm.

15 MR. PALM: My name is Bob Palm from Burns and
16 Rowe, the AE for the project. What I intend to cover
17 very briefly is a summary of how the Clinch River design
18 accommodates the effects of various natural phenomena
19 that could occur at the Clinch River site.

20 (Slide.)

21 These include the tornado, which Mr. Stark
22 just talked about; maximum precipitation effects at the
23 site, specifically at the Clinch River site; also, flood
24 effects at the Clinch River site; and earthquake
25 conditions.

1 (Slide.)

2 As far as the design basis tornado is
3 concerned, the safety-related structures are designed in
4 accordance with the regulatory guide requirements, and
5 we have established a design basis tornado in accordance
6 with Reg Guide 1.76.

7 Under Region I -- eastern Tennessee does fall
8 under Region I which is the maximum region in the
9 eastern part of the country which is subject to the
10 maximum tornado wind velocities -- the rotational
11 velocity of 290, a translational of 70 for a total wind
12 velocity of 360 miles per hour.

13 As Rich pointed out, we have a pressure drop
14 of 3.0 psi which is accommodated by the exterior
15 envelopes of all the safety-related structures. The
16 calculated velocity pressures are distributed in
17 accordance with wind distribution formulas which are
18 included in the ANSI standard. These are well known and
19 pretty much followed on all nuclear power plants.

20 (Slide.)

21 In line with tornado protective design we also
22 have generated a large spectrum of missiles which are
23 reported in the PSAR, and based upon the design to
24 protect the safety-related structures from these
25 missiles, we have a minimum thickness of concrete of 2

1 foot 3 inches, and this is somewhat larger than the
2 required minimum for the current standard review plan.

3 We also do provide at openings, whether they
4 be vent openings or exhaust openings or inlet openings
5 at roofs or walls, we have protective structures to
6 prevent any path of a missile entering inside the
7 buildings.

8 The method of analysis is reported in a lot of
9 detail in Section 3.5 of the PSAR, and this includes
10 formulas and design approach for protection of steel,
11 protection of vital equipment housed in either steel
12 structures or concrete structures. This includes
13 penetration, potential scabbing or generation of
14 secondary missiles from the impact on the outside face
15 of the structure.

16 Also, the design includes overall and
17 localized stability of the structure to assure that the
18 protective envelope is not overstressed either locally
19 or in a general way.

20 MR. SHEWMON: If you go back to your previous
21 slide, you refer to this as being Region I.

22 (Slide.)

23 Is that more or less severe than out in the
24 plains where tornadoes are common?

25 MR. PALM: Region I, I don't know of the

1 specific extent of it. I do believe it does go out into
2 the midwest belt, and it comes as far east as the
3 Appalachians.

4 MR. SHEWMON: When was the last time there was
5 a tornado in Knoxville?

6 MR. PALM: When is the last time? I'm sorry.
7 I don't know. I believe it was fairly recent, within
8 the last ten years.

9 MR. EBERSOLE: I lived there. It was a few
10 years ago. It took out a dock and left a path through
11 the woods down there of torn-out trees. And I think it
12 is probably about six or seven years ago.

13 MR. SHEWMON: They do come through
14 periodically then?

15 MR. EBERSOLE: Yes.

16 MR. SHEWMON: Thank you.

17 MR. PALM: That's right. There is a report on
18 the history of tornadoes in the Clinch River site in the
19 PSAR.

20 (Slide.)

21 As far as the maximum precipitation is
22 concerned --

23 MR. MOELLER: Excuse me. On the slide you had
24 shown just before this one you pointed out that your
25 concrete is 2 feet 3 inches versus 2 feet. How much

1 more protection does that give you? Is there a way to
2 quantify that? I mean can you tell me a percentage?

3 MR. PALM: Well, it is pretty much --

4 MR. MOELLER: Is it linear?

5 MR. PALM: It is pretty much linear for half
6 the depth, because the rule says you design the missile
7 penetration or you calculate the missile penetration,
8 then you double the thickness of the wall. So, in
9 essence, we have about -- if you divide the 2 foot 3 in
10 half, you've got 1 foot, 1 1/2 versus the 1 foot, and
11 that is kind of a straight line factor of safety above
12 the minimum requirement.

13 MR. MOELLER: Thank you.

14 MR. EBERSOLE: May I ask a question? The most
15 obvious result of a tornado would be to tear out the
16 normal power system and leave you riding on the diesels
17 for some long time. Have you put any particular design
18 protection for the diesel plants themselves to
19 accommodate that situation?

20 MR. PALM: Yes, sir.

21 MR. EBERSOLE: How quickly do you need power?
22 For how long an interval can you be in blackout?

23 MR. PALM: I can't answer that question. I
24 don't know if anybody from the project could.

25 MR. EBERSOLE: I take it you could be in AC

1 blackout for some period of time?

2 MR. CLARE: Yes. This is George Clare from
3 Westinghouse. As we have presented to some of the
4 subcommittees in the past, we do have the capability to
5 sustain a complete station blackout for some period of
6 time. We don't consider that to be a design basis for
7 the plant, but we do have that capability.

8 We also have the capability, a tornado
9 protective capability for all three of our diesel
10 generators to run many days without even any fuel being
11 brought on site.

12 MR. EBERSOLE: Thank you.

13 MR. CARBON: What have you done, as an
14 example, to especially tornado-harden the diesel sites?
15 You answered Mr. Ebersole's question that you had taken
16 extra efforts. What have you done on it?

17 MR. PALM: The diesel generators are housed in
18 a concrete tornado-hardened enclosure, seismic Category
19 I setting on subsurface material to account for
20 potential instability from tornado winds or the
21 earthquake. In general, that is what we're doing.

22 MR. CARBON: I presume this is the same as
23 would be done at any plant.

24 MR. PALM: That is correct, sir. That's right.

25 (Slide.)

1 Now, as far as the floods are concerned, Mr.
2 Newton, who will be following me, is from TVA, and he
3 will cover the basis for the flood condition at the
4 Clinch River site in more detail. However, we have
5 determined or calculated the PMF -- that is, the
6 probable maximum flood -- at a maximum elevation of
7 about 780, 780 feet, including a 40-mile per hour wind
8 velocity and resultant wave runup. However, the maximum
9 flood at the site is governed by an upstream dam
10 failure, that being the Norris dam. And this dam
11 failure is combined with one-half of the PMF; and as I
12 said, the details of the basis for this elevation, the
13 analysis for this elevation, will be covered by Mr.
14 Newton.

15 In any case, the plant grade is established at
16 elevation 815. It is well above this maximum
17 hypothesized calculated water level. And further, the
18 safety-related structures, including the diesel
19 generator building, emergency cooling water facility are
20 designed for assuming that the flood level -- rather,
21 the groundwater level, reaches the same level as the
22 flood, 809 feet.

23 We have accounted for hydrostatic effects and
24 included water tightness features in any of the design
25 of these structures below grade or below this flood

1 elevation.

2 (Slide.)

3 The earthquake design --

4 MR. CARBON: Excuse me. Was it your intention
5 to skip over the slide on the maximum precipitation?

6 MR. PALM: I'm sorry. That was not my
7 intent. Thank you.

8 (Slide.)

9 The maximum precipitation again at the site --
10 and I'm talking about the area or the region of
11 calculation for determining the maximum flood level of
12 the river, but this is specifically at the local area of
13 the site -- we have first of all designed the drainage
14 facilities for a 100-year storm, which is a maximum 3
15 1/2 inches of rain per hour.

16 The design has further been evaluated for a
17 maximum potential storm based upon probable maximum
18 precipitation, better known as PMP, where we have
19 examined the conditions at the site based on 14 inches
20 of rain in an hour and almost 30 inches in an 8-hour
21 period. And based upon this quantity of water
22 inundating the site, we have determined that we can
23 allow a 6-inch maximum of flooding in the plant area.

24 To account for this, we have building entries
25 12 inches above grade, and we have allowed a maximum of

1 8 inches of ponding on the safety-related roof areas.
2 And if there is excessive water, it is discharged to
3 grade. We also do provide curbs, I believe, that are 18
4 inches or 2 feet in height around any openings in the
5 safety-related building roofs.

6 And equivalent to this PMP we have a
7 calculated 80-inch snowfall, and this is equivalent to a
8 40-pound roof load which is also included in the
9 design. Actually, the 40-pound roof load is covered
10 well by the tornado design requirements, so the capacity
11 is well above what both the water and the potential
12 collected snow on the roof.

13 MR. CARBON: The 100-year storm itself is, I
14 believe, taken to be 3 1/2 inches per hour maximum, is
15 that correct?

16 MR. PALM: Yes. This is from the records that
17 we have included in the SER. I don't know for how long
18 a period those records are.

19 Don Newton, do you have any idea on the
20 rainfall records?

21 MR. NEWTON: I think that all comes -- this is
22 Donald Newton, TVA, Flood Hazard Analysis. I assume
23 that you're using the National Weather Service CP-40
24 rainfall, and the years of record that are in that, I'm
25 not really sure. That is a fairly old document, but it

1 is still the standard.

2 MR. PALM: The origin of all of this data is
3 from the National Weather Service.

4 MR. MOELLER: I don't understand why you
5 designed for drainage at 3 1/2 inches per hour, but you
6 allow the rain to fall at 14 inches per hour.

7 MR. PALM: Primarily because this is a maximum
8 probable event, and as long as the site can tolerate
9 some overcapacity of the system design, then we don't
10 see that there is any safety problem. The reason why is
11 primarily economics insofar as the drainage system is
12 concerned. We would have to go to say from a 42-inch
13 drain pipe to something like maybe 8 feet.

14 MR. MOELLER: I see. That is helpful.

15 MR. PALM: And we have accounted for this in
16 the local topography and the slopes, et cetera.

17 MR. OKRENT: If I could come back to wind for
18 one minute, does the tornado design provision cover
19 steady wind speeds far greater than the wind speeds for
20 which you've designed the plant, or if there were
21 greater wind speeds, steady wind speeds than you
22 designed for could that create problems for some
23 components or systems, and if so, how?

24 MR. PALM: Wind speeds greater than the design
25 tornado velocity, you're talking winds in general?

1 MR. OKRENT: No. You design, if it understand
2 it correctly, for tornado wind speeds, but also there is
3 some kind of what I would call steady wind speed.

4 MR. PALM: I had intended to cover this very
5 briefly, but because of time or whatever, our design is
6 basically for an equivalent 90-mile per hour wind.

7 MR. OKRENT: Suppose it were 120 miles per
8 hour, would that create a problem, or does your tornado
9 design cover it?

10 MR. PALM: The tornado design would cover it,
11 that is right.

12 MR. OKRENT: Would it cover 150? That is a
13 pretty high wind speed. I'm just trying to understand.

14 MR. PALM: To understand it, we, as far as the
15 design is concerned, there is no time element involved
16 in the velocity pressure distribution or design
17 pressures.

18 MR. OKRENT: Okay. That answers it.

19 MR. EBERSOLE: Let me ask a question in this
20 matter. The negative pressure in tornadoes, there's two
21 ways to go at this. You can either build a building to
22 sustain it, or you can fit it. Which did you do?

23 MR. PALM: We have a combination actually.
24 The structures, the envelopes are actually designed for
25 the 3 psi. There are certain systems that do allow for

1 venting certain compartments because of --

2 MR. EBERSOLE: But you have, in general, you
3 have put an envelope around the whole thing for 3 psi?

4 MR. PALM: That's right.

5 MR. EBERSOLE: If that is bridged, do you then
6 have a flow path inside that will prevent excessive
7 pressure in compartments?

8 MR. PALM: It won't be breached. The design
9 will not allow it.

10 MR. EBERSOLE: You're counting on the
11 perimeter. You don't have a bleed-down path from
12 compartment to compartment inside.

13 MR. PALM: I believe we do, yes. Through some
14 of the openings and so forth there is a bleed-down path,
15 and we do have.

16 MR. EBERSOLE: And that assumes you have a
17 hole on the perimeter?

18 MR. PALM: That's right. I understand your
19 question now. You have to hypothesize that you do
20 indeed have a certain compartmentalization where you do
21 have bleed-in of the pressure reduction.

22 MR. EBERSOLE: So you use both approaches.

23 MR. PALM: That is correct.

24 MR. EBERSOLE: Thank you.

25 (Slide.)

1 MR. PALM: On the earthquake design this is a
2 review of basically what was covered at the summer of
3 '82 meeting, pointing out the major parameters for
4 establishing the safe shutdown earthquake for Clinch
5 River using the tectonic approach, the Southern Valley
6 and Ridge province, in accordance with the regulation.

7 We have identified the largest historical
8 earthquake in the province and Charles County, Virginia;
9 and NRC had classified this earthquake as an intensity
10 8. And based upon these requirements, we correlated the
11 intensity to acceleration using the most conservative
12 intensity correlation relationships recognized by NRC,
13 and on the basis of that we came up with a .25 g zero
14 period acceleration. And this large earthquake at Giles
15 was assumed to occur at the site, at the Clinch River
16 site.

17 We have used a one-half SSE as the OBE for
18 Clinch River. This is also included in the design. And
19 all the design, including damping factors, generation of
20 the ground motion input, modeling techniques, method of
21 analysis and so forth, follows the recognized and
22 accepted light-water practice that is identified in the
23 standard review plan and the regulatory guides.

24 So that is nothing unique about our approach.
25 And Mr. Morrone of Westinghouse will get into the

1 details insofar as the available margin that we have
2 through this design approach that we have taken.

3 MR. CARBON: Have you gotten into different
4 kinds of earthquake design problems, this being a
5 liquid-metal reactor, things like sloshing in the pool?
6 What are the different problems that you face on thin
7 wall pipes instead of thick? Can you comment on some of
8 those things?

9 MR. PALM: Well, most specific analyses were
10 done by Westinghouse. We provided all of the input to
11 them insofar as the response spectra and time
12 histories. And perhaps Paul Dickson or George Clare
13 might want to comment on that.

14 MR. DICKSON: This is Paul Dickson of
15 Westinghouse.

16 Yes, there are some differences, and they are
17 accounted for in the analyses.

18 MR. CARBON: Can you summarize the differences
19 and say something about how significant they have been?
20 What has been the net effect?

21 MR. DICKSON: One of the differences you
22 alluded to was the fact that we have a large surface in
23 the pool, and there is some sloshing of sodium which is
24 different than a water system, at least in the water
25 vessel for a light-water reactor. And then the thinner

1 pipes, the seismic pipe at least in the primary system
2 tends to control the piping design for the location of
3 snubbers and hangers, as opposed to say a light-water
4 reactor where the seismic design is probably less
5 controlling because the pressure is more of a
6 consideration. In the intermediate system the
7 sodium-water reaction is more controlling than the
8 seismic design.

9 Did that answer your question?

10 MR. CARBON: Yes. I think so.

11 MR. PALM: I would say, just to make a general
12 comment further to what Dr. Dickson said, is that there
13 is a lot more detailed interplay between the structural
14 building design and the systems and component design for
15 liquid-metal components, very much so.

16 (Slide.)

17 In summary, based upon potential natural
18 phenomena that has been identified that could occur at
19 the Clinch River site, we have established conservative
20 design bases to, in the Clinch River design, to
21 accommodate the loads effects generated from these
22 phenomena. And we have essentially completed the Clinch
23 River design to show that indeed the design does cover
24 these design bases and resultant conditions.

25 Mr. Newton of TVA will now continue on the

1 flood analysis.

2 Are there any further questions on this?

3 MR. DICKSON: While Mr. Newton is coming up,
4 if I could add just one more thing. One other
5 difference in order to accommodate our guard vessel
6 concept, most of our large components such as the
7 reactor vessel must be supported from the top, and that
8 enters into the seismic design analysis capability
9 significantly.

10 MR. NEWTON: I'm Donald W. Newton. I head the
11 Flood Hydrology section of the Flood Hazard Analysis
12 branch of the Tennessee Valley Authority, and what I am
13 going to try to do is to briefly summarize the
14 determination of the design basis flood level for the
15 breeder site.

16 The handout that I provided, I have cut some
17 of that material out in an effort to shorten the talk;
18 so if you have any questions why, we can come back to it.

19 Our determinations, though made in the early
20 '70s, are in accordance with the current Regulatory
21 Guide 1.59 and the ANSI documents, and may be a little
22 safer than are required.

23 (Slide.)

24 This shows you the site, the location. We
25 have roughly outlined the watersheds, the site being

1 here, which is directly on the Clinch River, with
2 drainage area some 3400 square miles. The site is
3 actually also on an arm of the Watts Bar reservoir, so
4 the watershed in yellow, which is the watershed above
5 Watts Bar dam, can also influence the site somewhat.
6 That drainage area is -- the total in yellow is some
7 17,310 square miles. This dam is some 55 miles below
8 the site.

9 (Slide.)

10 This is a diagram that maybe will show you a
11 little bit better what is involved in the
12 determination. You can see the site here between mile
13 16 and 18 on the Clinch River. Upstream where you have
14 the Norris dam, which really ends up being the
15 controlling feature in terms of flood levels at the
16 site, the small dam, Melton Hill, downstream, and then
17 Watts Bar dam downstream on the Tennessee River, also a
18 potential source of flooding, with Tellico and Fort
19 Loudon dams here, Douglas and Cherokee and Fontana. And
20 there being the site.

21 (Slide.)

22 MR. CARBON: Are you going to get into which
23 of those dams can be assumed to fail and what this does
24 to the flood level?

25 MR. NEWTON: Yes. Very briefly.

1 MR. MOELLER: Would you repeat the difference
2 in the red and the yellow? The yellow drains towards
3 the Watts Bar dam?

4 MR. NEWTON: Yes. The yellow is the total
5 drainage area above Watts Bar dam.

6 (Slide.)

7 MR. MOELLER: And then the red is above what?

8 MR. NEWTON: Above Clinch River. That is the
9 Clinch River; that long, skinny watershed is your Clinch
10 River. And we are, of course, on the Clinch River below
11 Norris dam, which is up in here, and then this is that
12 total drainage area above Watts Bar which doesn't prove
13 to be controlling, but it has an influence so you have
14 to take a look at it.

15 MR. MOELLER: Thank you.

16 (Slide.)

17 MR. NEWTON: Your potential sources of
18 flooding at the site are storms, storms which produce
19 the probable maximum precipitation on the Clinch River,
20 and that I showed you in red, or on the Tennessee River
21 shown in yellow, or some combination thereof; floods
22 that we call the maximum probable flood are the
23 definition of the upper limit of flooding; and
24 seismic-induced floods from seismically-induced dam
25 failures. And this proves to be the controlling event.

1 We didn't examine in detail, but you need to
2 consider snowmelt or ice jams. We are in a temperate
3 climate, and that is not controlling. Or landslides,
4 and there is a small slide volume potential, but they
5 are limited. So the controlling event is the
6 seismic-induced dam failure.

7 (Slide.)

8 I'm going to skip over the determination of
9 the PMF, the most severe flood that can reasonably be
10 predicted because it is not controlling by a significant
11 amount. In other words, we examined four different
12 storms, a number of different storm patterns, different
13 seasons, to try and determine the most critical flood
14 centering.

15 There were some dam failures. Fort Loudon and
16 Tellico upstream would fail. Part of Melton Hill would
17 fail. But all of this together produced a design flood
18 level or a flood level of, I will show you later, which
19 is much less than the controlling event. So let's not
20 -- I will skip over that unless you have some questions
21 later.

22 MR. CARBON: I have one question there. You
23 say some of those dams would fail. It's my impression
24 that your knowledge or our knowledge in general of which
25 dams will fail from seismic events is really not very

1 good. Is your knowledge of failure from flooding on a
2 much firmer basis?

3 MR. NEWTON: Yes. In this case we are having
4 water overtopping the earth embankments, so it is a
5 question of will it overtop an earth embankment, a road
6 and fail, and we have enough information about that.
7 And the depth and duration of overtopping was such that
8 we are quite clear that the earth portions of the dam
9 would fail.

10 In the case of Melton Hill it was a concrete
11 dam, and the structural analysis would say yes, it would
12 fail.

13 MR. CARBON: And you're also on firm ground on
14 the ones that won't fail.

15 MR. NEWTON: Yes. And it depends upon the
16 storm center where the largest floods occur. So we are
17 pretty clear on that analysis.

18 In refreshing your memory now when we are
19 looking at floods resulting from seismic events,
20 obviously I'm saying if a dam should fail from a seismic
21 event, we are talking about the two situations that we
22 examined: a failure caused by the safe shutdown, the
23 largest earthquake, and that is assumed to occur
24 coincident with a 25-year flood with your reservoir at
25 that maximum level during that flood event, or a smaller

1 earthquake, OBE, and a larger flood, one-half of this
2 probable maximum flood. Again, with the reservoir at
3 the maximum level during that storm, the dam is assumed
4 to fail or at least is examined at that level.

5 MR. SIESS: Well, those two combinations must
6 be chosen on some kind of a probabilistic basis, am I
7 correct? That is, the larger earthquake and the 25-year
8 flood and the smaller earthquake I assume at half the
9 PMF is a greater return period than 25 years, is that
10 right?

11 MR. NEWTON: Yes. Much greater than that,
12 yes. It is an attempt -- I don't know the details of
13 how that particular standard came up with, but this
14 would be your upper limit on your seismic, your SSE.

15 MR. SIESS: But not zero probability.

16 MR. NEWTON: I don't believe so, and that is
17 not my field. Somebody else would have to tell you what
18 that probability is.

19 MR. SIESS: Is it intended that somebody will
20 address the probabilities associated with those?

21 MR. NEWTON: I'm not so sure. I would make
22 the point that what we are showing is that even those
23 were to occur, the plant is safe against that, so we're
24 really talking about something above what flood levels
25 this would cause. I believe the probability maybe on

1 the order of what, 1 in 10,000 for the SSE. I am not
2 really sure. That is not my field. I think I've heard
3 that number.

4 MR. DICKSON: That we will be addressing later.

5 MR. SIESS: Thank you.

6

7

8

9

10

11

12

13

14

15

16 -

17

18

19

20

21

22

23

24

25

1 MR. EBERSOLE: Let me ask a question. Did you
2 say that if you have a PMF, that is, 100 percent PMF,
3 that you do or do not have to consider the dam failure?

4 MR. NEWTON: In the storm, the probable
5 maximum precipitation which occurs over the watershed
6 and translating that flood into flood flows and flood
7 hydrographs, we do have to evaluate the upstream dams to
8 make sure that they can contain that flood.

9 If it cannot contain it, if it would be over
10 top, then the question is if it is over top, is it
11 sufficient to fail the dam. And in our determination of
12 the PMF for the breeder reactor site there were, in the
13 critical storm combination situations, there was
14 overtopping and failure of some upstream dams.

15 MR. EBERSOLE: Then the worst order would come
16 from 100 percent PMF or maximum possible flood, which
17 would produce the dam failure, right? Not these here.

18 MR. NEWTON: These are the controlling
19 events. The PMF is a much lower flood level.

20 MR. EBERSOLE: Is it?

21 MR. NEWTON: Yes, much lower, as I will show
22 you later on. I'm skipping over it because it is
23 non-controlling.

24 MR. EBERSOLE: I see.

25 MR. NEWTON: It comes to elevation 778.

1 MR. EBERSOLE: The PMF? Now, you're talking
2 about the PMF on the Norris Reservoir?

3 MR. NEWTON: In this case, the storm which was
4 found to produce the maximum flood elevation at the site
5 was not centered above Norris Reservoir; it was 50 miles
6 North-Northeast of Knoxville, up at Bulls Gap. But that
7 is a little different.

8 MR. EBERSOLE: Let me get back to the crux of
9 it. On the Norris Reservoir the maximum possible flood
10 level, it's considered to fail Norris Dam?

11 MR. NEWTON: No, no way. It doesn't even come
12 close.

13 MR. EBERSOLE: So you don't have to deal with
14 that.

15 MR. NEWTON: You don't even have to deal with
16 that.

17 MR. EBERSOLE: If you did, that would be the
18 worst case, wouldn't it?

19 MR. NEWTON: Yes, it would probably would be.
20 Depending upon whether or not it overtops and Norris Dam
21 would fail, and it is a concrete dam and structurally it
22 might contain it.

23 MR. EBERSOLE: Are there any earthen fills up
24 away from Norris dam that come down? Any saddle dams?

25 MR. NEWTON: Not that I'm aware of offhand.

1 That was never an issue, so we didn't look at it in
2 detail.

3 MR. MOELLER: Do I understand correctly that
4 these two alternatives are sort of standard? I mean, do
5 you always use these?

6 MR. NEWTON: These are the standards specified
7 by NRC.

8 MR. MOELLER: Thank you.

9 MR. NEWTON: And that is why NRC criteria --
10 they have specified that we shall examine these, and we
11 have.

12 (Slide.)

13 Norris Dam we actually examined. Now, there
14 were some 10 dams and combinations of dams that could
15 fail in various combinations or centerings of these
16 various earthquakes, and we examined all of those and
17 what you boil down to, which is pretty obvious, is that
18 ~~Norris Dam upstream~~, if it were to fail, becomes the
19 controlling events.

20 So the others were all looked at. You can
21 forget about them. We come back to Norris, and let's
22 take a look at Norris.

23 Now, we examined the dam. We concluded
24 actually that it would not fail in an SSE or an OBE.
25 The factor of safety would not be less than one, but

1 because of the uncertainties in such estimates, we went
2 ahead and did determine -- well, let's postulate it
3 would fail -- and determine what is the most likely mode
4 of failure should it occur.

5 So we have bypassed the argument -- well,
6 would it or wouldn't it fail; we don't think it would.
7 And then we got into a discussion of well, given that
8 you have decided that it would fail, what is the most
9 likely mode of failure. And let me simply show the two
10 modes of failure.

11 (Slide.)

12 This is in the operational basis earthquake,
13 which is the smaller earthquake. It is the larger flood
14 and therefore, the highest head water levels, and
15 therefore, it becomes controlling. And this is a brief
16 outline of what we postulated would happen in terms of
17 the mode of failure we're talking about. A concrete
18 gravity dam which is some 1860 feet across the top. It
19 is some 285 feet high. We have a spillway section in
20 here. We have the powerhouse section in here
21 (indicating). And for the OBE we postulated that these
22 taller blocks would simply overturn like this. That
23 would produce an opening here of some 665 feet wide.
24 The engineers estimated that if it did happen,
25 most likely mode of failure would be the overturning of

1 these blocks like this, and then the base of the dam
2 would create a debris level here, about elevation 970.
3 This would all come into this valley such as this
4 (indicating). Note that it doesn't completely valley
5 and there is actually significant end-around flow. But
6 what you have created, in a sense, is a weir here, 665
7 feet wide, with an elevation of 970 for the top. But
8 there is end-around flow.

9 This would be judged to be the likely
10 situation in an OBE.

11 (Slide.)

12 In the SSE, we have a wider section. The
13 analysis indicated that there would be more of the
14 blocks that would fail, creating an 833 feet wide weir.
15 ~~The top of the concrete would be controlled by the width~~
16 of the base and again, would be at about elevation 970.

17 In this case, there is a wider section that
18 one nearly fills the valley and we have less end-around
19 flow, given the mode of failure. The next step is the
20 determination of the downstream flood levels.

21 (Slide.)

22 And the major elements of that kind of a
23 determination, of course, is to determine the flows in
24 the reservoir and in the streams and in the system for
25 this 25-year flood, and we have a watershed model which

1 was used to develop the PMF calibrated against zero
2 flood, which was used to determine these flows.

3 We are concerned about the outflow from a
4 breached Norris Dam. This is a question of the rating
5 curves at the dam. Then we're talking about combined
6 flows at the site. The flow from the dam out-breach and
7 flow from the surrounding watersheds.

8 The unsteady flow models were used to
9 determine the flows at the site. This is at present the
10 most sophisticated procedure for analyzing that. The
11 rating curves -- and that is the next slide --

12 (Slide.)

13 which establish the discharge from the failed
14 dam are shown here. These were developed from a 1 to
15 150 scale hydraulics model study, and verified very
16 closely by hydraulic analysis. I won a \$10 bet. This
17 is the rating curve for the OBE, the 665-foot section,
18 and to everyone's surprise initially, you get a little
19 more outflow because of that end-around flow around the
20 concrete sections. And this would be the rating curve
21 for the SSE where you got more debris, more in the
22 downstream channel.

23 So the discharge from the dam is really more
24 nearly controlled by the debris, in this case, than it
25 is the width of the weir.

1 (Slide.)

2 In the OBE, what you would have -- the dam was
3 postulated to fail at the peak of the flood. You would
4 have this very sharply rising outflow hydrograph with
5 1,960,000 cubic feet per second coming out of the dam.
6 The dam would drain relatively rapidly like this if it
7 failed at elevation 1035.

8 MR. REMICK: What is the importance of the
9 March date at the bottom?

10 MR. NEWTON: The March date ties into the date
11 of the probable maximum flood. You not only need to
12 look at the time and aerial distribution of the storms,
13 but what time of year meteorologically. You can get
14 large area storms in our region in March; you get
15 smaller area storms and your maximum PMP tends to come
16 in July, and we had a fairly large 8000 square-mile storm
17 which produced PMP on 8000 square miles. So that is a
18 March storm. Most likely, it would occur in mid-March.

19 This is a one-half PMF, and you assume it
20 fails at the peak of it, and that gets you to March.

21 MR. REMICK: March 26th.

22 (Laughter.)

23 (Slide.)

24 MR. NEWTON: This does create some interest.
25 Down at the site, then, we have reduced from 1.9 million

1 down to about 900,000 cfs, and this would be the
2 hydrograph at the site at mile 18 upstream, reaching an
3 elevation of 804 with plant grade up here at 815 or
4 downstream a little bit lower, 798. And that would be
5 your elevations at the site.

6 (Slide.)

7 So that from the standpoint of the analysis,
8 then, we have these flood elevations, the PMF which I
9 didn't discuss but which was evaluated in detail with a
10 maximum flood level of 777.8. The OBE with a one-half
11 PMF, a controlling event. Now, this is without wind
12 waves; just the still water level. We would have
13 reached elevation 804.3 or for the SSE failure in a
14 smaller flood, 796.

15 So then, then, becomes our controlling event.
16 And according to NRC criteria, if we are above that
17 elevation including wind waves, then we are safe.

18 Now, there has been some question about how
19 sensitive our conclusions are on that elevation 804,
20 regarding the modes of failure, the debris level and the
21 width of that failure. We made an engineering judgment,
22 we made a study. We said hey, this is the most likely
23 mode of failure.

24 (Slide.)

25 But obviously, you could postulate somewhat

1 different modes, so we looked at a number of
2 possibilities just arbitrarily. You make an engineering
3 judgment, and this one looks like it makes sense but
4 let's try and bracket it. So we took three blocks, 168
5 feet. And this is all in the OBE, by the way. We
6 simply concentrated on that because that is controlling.

7 168 feet wide in contrast to 665 -- let's take
8 it all the way down. Let's assume that debris is out of
9 the way. We would have reached 808 here at mile 18,
10 808.4, somewhat higher. Let's assume more blocks fail,
11 370 foot wide. Let's assume that the debris is a lot
12 lower. We don't think it would be completely washed
13 out, but maybe it is lower. You would have 925.

14 Pick a number. Well, you would reach 811.9.
15 You are somewhat higher. Let's take the same 665-foot
16 wide section that we postulated but let's lower the
17 debris level from 970 to 945. Well, we would get
18 808.9. Let's give a dimension to the whole problem.
19 Let's see what the upper limit is.

20 Well, the upper limit would be assume that the
21 dam completely and instantaneously disappeared. It is
22 unrealistic but it certainly screens the upper limit,
23 and you have got elevation 818, which is some three feet
24 above. But using this as a device to see what is the
25 upper limit, -- and obviously, there is going to be

1 debris -- we think it adds credibility to these kinds of
2 numbers.

3 We assume that we are not sensitive -- we
4 think our basic conclusion that it will not exceed 815
5 is not sensitive to these levels of debris levels.

6 MR. REMICK: Maybe you explained this and I
7 missed it, but the significance of mile 16 and mile 18
8 -- why two, and measured from what? From the dam?

9 MR. NEWTON: The miles are measured from the
10 mouth of the Clinch River, so you are coming upstream.
11 And remember that we are on an arm like this of the
12 Clinch River, so mile 18 is the upper side, and mile 16
13 is on downstream. There is some slope plus some
14 storage. So in a sense, it becomes the controlling
15 point. It is the first point of attack to the site, and
16 therefore, that is what we looked at.

17 MR. CARBON: Just for understanding, what is
18 the significance of 815 again?

19 MR. NEWTON: This is the plant grade. This is
20 the one that we want to make sure that the plant grade
21 is above any maximum flood level. So this 815 is the
22 discussion we had previously. Everything -- all
23 safety-related structures are above that; at or above
24 that. So if we can show that that is above any flood
25 level, then we are safe.

1 There is one other argument in here that we
2 could make. That is, that we don't think that the dam
3 would fail in an OBE. It might be more likely to fail
4 in an SSE, which is a smaller flood, less head water
5 levels. And although we didn't compute it, if you
6 instantly vanish the dam, we estimate that the elevation
7 would be on the order of 810.

8 So we think that any way you look at it, from
9 a practical standpoint, 815. At that plant site level
10 there is no flood level; you are well above any flood
11 level.

12 MR. EBERSOLE: Don, could I ask you a
13 question? That old Dam Norris used to have gasoline
14 engine generators with which they intend to control
15 their gates and sluices in the event of a loss of
16 power. Are all of your analysis based upon any idea
17 that those gates will be closed under these maximum
18 flood conditions? You know, I'm talking about spillway
19 gates.

20 MR. NEWTON: We're talking about the
21 spillways, and in our flood studies -- and these, of
22 course, are even the 25-year -- we operated the dams as
23 we would in that kind of a flood, and the gates were
24 assumed operable.

25 MR. EBERSOLE: But those engines were taken

1 away about 30 years ago because they wouldn't work,
2 anyway. So do you not have to make your analyses on the
3 basis that the gates are down and the power is lost?

4 MR. NEWTON: We don't believe so. In our
5 current dam safety program and inspection and the rest
6 of it, we feel sure that -- George, do you know what the
7 auxiliary backup is for power for gate operation at
8 Norris?

9 MR. McCANON: Jess, I'm sorry, I do not know
10 the answer to your question.

11 MR. EBERSOLE: Would you identify yourself?

12 MR. McCANON: I'm George McCannon, Civil
13 Engineer in TVA's Hydro-Design Project.

14 MR. EBERSOLE: Well, I remember that about 25
15 years ago they decided to throw those old engines away
16 because they never could get them started in the first
17 place. But that left a residual question of whether, in
18 a terrible storm condition you, in fact, had to lift the
19 gates. A storm which would have taken down the
20 transmission lines.

21 MR. KERR: I would have thought there would be
22 a connection to the hydro generator station itself. I
23 don't know.

24 MR. EBERSOLE: The engines were put there for
25 a purpose, Bill.

1 MR. KERR: That was put there in the days when
2 they thought there might be droughts and they thought
3 the reservoir might be empty.

4 (Laughter.)

5 MR. NEWTON: Let me answer it this way. We're
6 right now involved in a complete review of older dams,
7 dam safety, what have you. As a part of that rule, we
8 are specifically examining the operability of the gates'
9 inflood, such as what we're talking about. This is a
10 part of what we are doing. I don't now remember the
11 details of Norris. I could of some others, but Norris I
12 don't because we haven't gotten to it.

13 MR. EBERSOLE: But your basic --

14 MR. NEWTON: Our basic answer is that we will
15 be able to operate those gates by some means in floods
16 of this type. This is specifically what we're looking
17 at.

18 MR. EBERSOLE: You might have to put some new
19 diesels there.

20 MR. NEWTON: We might have to. We might have
21 100 people standing up there.

22 (Laughter.)

23 Whatever it is, we will have some means to
24 operate those gates. We've got to.

25 MR. EBERSOLE: I'm not sure that the people

1 here appreciate the implications of having a bad flood
2 with those gates down. Would you explain that to them?

3 MR. NEWTON: Well, having the flood with the
4 gates down would be advantageous to us.

5 MR. EBERSOLE: Would it?

6 MR. NEWTON: Yes, in the sense that if those
7 Norris gates -- you can raise to control storage, to
8 operate them. If they are down, then you have got your
9 spillway capacity with no stoppage at all.

10 MR. EBERSOLE: But you have an overtopping of
11 the gates to deal with.

12 MR. NEWTON: Well, the gates are down into the
13 spillway crest itself, so that then you have --

14 MR. EBERSOLE: Oh, I'm sorry. I really mean
15 when the gates are up. I'm 180 degrees away.

16 MR. NEWTON: But the point is if the gates are
17 up, then you would have flow over the top of the gates.
18 But what we're doing is operating those gates in floods
19 of this sort with our control downstream at
20 Chattanooga. We would operate those gates as we would
21 during a flood of that type, and the details of the
22 operations we assume -- frankly, I don't remember.

23 MR. SIESS: Does it take power to operate
24 those gates, to lower them?

25 MR. EBERSOLE: Yes.

1 MR. NEWTON: I think so.

2 MR. McCANON: Yes. And our policy is that we
3 will have backup capabilities of operating all of our
4 gates.

5 MR. SIESS: How long do you have to lower the
6 gates once one of these huge storms starts? Does it
7 have to be done in minutes, hours or days?

8 MR. NEWTON: You are now getting into the
9 details of this particular operation, and as I say, we
10 made these basic studies back in the 70s. Depending on
11 our dam we have anywhere -- some of them are remotely
12 operated and we can operate them right away. Some
13 require people going there and opening them, and then
14 after you've opened them there is a certain amount of
15 time.

16 MR. SIESS: I'm sorry, I'm assuming -- I'm
17 going along with Mr. Ebersole's assumption that for some
18 reason you've lost transmission lines and you -- how
19 much time do you have to do something in the way of
20 repairs or getting other sources of power?

21 MR. NEWTON: We have, in the first place there
22 is some warning that a flood of this sort is happening
23 and is occurring. Because we're talking about a storm
24 -- well, one of the slides we have which I didn't show
25 you talked about a storm where we had a three-day

1 antecedent storm. A three-day dry period and then a
2 three-day main storm.

3 What we do is we think through, when do you
4 have to operate those gates, as a part of our analysis,
5 and I don't remember the details. And we have available
6 auxiliary power or some means to operate those gates so
7 that we operate them the way we want to operate that dam
8 to efficiently control downstream flooding. And we've
9 thought through and worked out the timing and the rest
10 of it. I just don't know the details and I can get it
11 for you if you like.

12 MR. SIESS: And when you efficiently control
13 downstream flooding, that's giving due consideration to
14 Clinch River?

15 MR. NEWTON: Yes.

16 MR. SIESS: Not to Knoxville?

17 MR. NEWTON: As a matter of fact, if we were
18 to operate strictly for the site we would have not let
19 the elevation get to head water elevation, 1035. We
20 actually could have let it go lower. What we did was we
21 operated the dam as we would in a flood like that. We
22 did reach elevation 1035 and we showed that if the dam
23 did fail in that situation, you were still below the
24 plant site.

25 MR. SIESS: Where is 1035 in relation to the

1 spillway?

2 MR. NEWTON: I don't recall offhand. I would
3 have to look that up. I've got a book back here. Do
4 you remember, George? Do you have it handy. I think
5 it's 1024, isn't it?

6 MR. McCANON: The crest is 1020.

7 MR. SIESS: The crest of the spillway, so this
8 is with gates down and 14 feet ahead over the spillway.

9 MR. NEWTON: Yes. As I say, it has been some
10 years, and if you want those details we will get them
11 for you.

12 MR. EBERSOLE: Don, in general but
13 specifically with respect to Norris, is the safety
14 concept of this sort of thing dependent on having
15 guaranteed operation of the spillway gates?

16 MR. NEWTON: No, I don't think so. Do you
17 mean the safety of the dam or the safety of the site?

18 MR. EBERSOLE: Well, the safety of the
19 flooding problem I'm talking about. Are you depending
20 upon, in fact, getting the gates down? That's all I am
21 after.

22 MR. McCANON: Are you talking about the Clinch
23 River reactor? We don't believe the operation of the
24 gates has any effect.

25 MR. NEWTON: If we couldn't operate the gates

1 and couldn't raise them and couldn't force the
2 headwaters that high --

3 MR. EBERSOLE: So you could take the problem
4 as if you had a full maximum flood with the gates stuck
5 in the up position?

6 MR. NEWTON: I can't answer that.

7 MR. EBERSOLE: Well, they can stick in either
8 direction if you haven't got power.

9 MR. NEWTON: I don't know the answer to
10 whether it was stuck up or not. I don't know.

11 MR. EBERSOLE: That is why I said assuming
12 they were down.

13 MR. NEWTON: I just don't now know that answer.

14 MR. SIESS: I think the case that Mr. Ebersole
15 is postulating would be gates up, half the PMF. Now, I
16 assume that would put the water level up above 1035.

17 MR. NEWTON: I don't know.

18 MR. SIESS: And then fail the dam with an
19 earthquake?

20 MR. EBERSOLE: No, I'm not on the earthquake;
21 I'm just on the flood. But I have stuck the gates.

22 MR. SIESS: Well, why would you limit it to
23 the flood case and not the earthquake case?

24 MR. EBERSOLE: Well, I had a concept that if
25 the gates were stuck in the up position and due to this

1 terrible storm you had no AC power to operate the gates
2 and you would overtop the gates with them in the up
3 position and that would lead to degradation of the dam
4 in the worst possible way.

5 MR. NEWTON: I don't know.

6 MR. SIESS: Overtopping a concrete dam is not
7 nearly as automatic a failure as overtopping an earth
8 dam.

9 MR. EBERSOLE: I don't know if there are other
10 aspects.

11 MR. NEWTON: No, there are not. We did not go
12 through and say hey, suppose the gates are up. And I
13 don't know when you would put them up in your flood
14 operations. You have to lift them in a flood
15 operation. We did not go through -- and you would have
16 to postulate at what time they were up.

17 The Norris Dam, it was pointed out, is a
18 concrete dam, and you are beginning to pile unlikely on
19 unlikely on unlikely now.

20 MR. EBERSOLE: So you're ready to take the
21 maximum possible flood with the gates up? Do I hear
22 that?

23 MR. NEWTON: We don't think that is a logical
24 prudent combination. That is, we don't believe the
25 gates will be stuck up. We didn't examine that to

1 determine. If it was true, you would have to raise the
2 gates at the worst possible time and then assume they
3 are stuck. And that just doesn't seem to be
4 engineeringly sound.

5 MR. EBERSOLE: I think it focuses on the
6 reliability of power for the gates.

7 MR. NEWTON: The reliability of the ability to
8 operate the gates -- and we believe that with our
9 inspection and maintenance system, with our backup
10 systems and our constant checks, that we can, in truth,
11 operate those gates. There is considerable free board
12 -- I know this -- above the PMF, as we did compute it,
13 but before you get to the top of the dam. I guess it
14 would be that even if you assumed everything worst, the
15 worst storms at the worst time, the worst possible storm
16 at the worst possible time, and all your auxiliary power
17 operations and everything goes out and the gates are
18 stuck at the worst, at the top --

19 MR. EBERSOLE: Why were those engines put
20 there originally?

21 MR. NEWTON: Pardon?

22 MR. EBERSOLE: Why were those engines put
23 there originally?

24 MR. NEWTON: Jess, you always try to have a
25 backup system. That is what we're talking about, is the

1 reliability of the backup system if power is gone. In a
2 storm like, it is very well you would stop generating.
3 As a matter of fact, we postulate that the turbines are
4 not operating in a storm of this storm, and that is not
5 available tous, and that you do have to have some means
6 of opening those gates with the power not available at
7 the site. This is standard operating procedure. And I
8 apologize for not remembering all of those details.

9 MR. SIESS: I would like to change gears and
10 get back to the slide you have on the screen, which is
11 the OBE with one-half the PMF in a sensitivity study
12 that is based upon reservoir elevation of 1035.

13 MR. NEWTON: That's right.

14 MR. SIESS: All of those examples, right?

15 MR. NEWTON: Correct.

16 MR. SIESS: And that's 14 feet of flow over
17 the down gates.

18 MR. NEWTON: Correct.

19 MR. SIESS: It seems to me that it would be
20 helpful as a sensitivity study to see what you would get
21 there if the gates were up. Would it be overtopped with
22 one-half the PMF? That is, would it be 1035?

23 MR. NEWTON: I would have to go back and
24 examine -- and as I say, it has been some time since we
25 did these flood routings -- as to specifically what our

1 operations are. The bottom line would be that if you
2 could reasonably postulate -- well, not reasonably
3 because we think we have got one reasonable. But if you
4 were to say everything went bad and you did have a
5 higher elevation than 1035, in truth you would have some
6 higher elevations down at the site.

7 Once again, assuming that the dam fails, which
8 we don't think it will.

9 MR. SIESS: But again, for a sensitivity
10 study, that would seem to be an appropriate parameter.
11 I mean, right now I get a certain amount of comfort out
12 of looking at 818 there for just wiping the dam out. In
13 other words, you varied the conditions of the dam in
14 that figure, and it seems to me that varying the
15 elevation of the reservoir would be another basis for a
16 sensitivity study that might come out still comfortable.

17 MR. NEWTON: It could be it would be lower or
18 higher. We would also have to go lower. I would also
19 point out that another sensitivity is around the
20 earthquake. We don't think the dam will fail in an
21 OBE. It would be more likely to fail in an SSE, and
22 that was the elevation 810 that I gave, in contrast to
23 the 818. So if you slice it that way, you come up with
24 818 down to 810. If you do simply debris levels you get
25 this, and as you say, whether the 1035 varied up or

1 down, you would come around it.

2 But I would think that we might want to go
3 below 1035, too. I would have to review the actual
4 details of our assumed operation. And I wish I could
5 remember that because I have a feeling that that is your
6 answer. I think the gates probably got down pretty
7 early in the flood, and it may well have been right at
8 the start. I'm not really sure.

9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

1 MR. MOELLER: In your opening remarks you said
2 you examined Norris dam in order to postulate whether it
3 might fail, and you concluded that it probably would
4 not, but nonetheless you went ahead and did your
5 analysis.

6 Now, what do you mean by saying that you
7 examined Norris dam? Did you look at the design,
8 original design, or did you go out? Do they do annual
9 inspections, and you looked at that?

10 MR. NEWTON: Let me call upon Joe Hunt to
11 answer that.

12 MR. HUNT: Joe Hunt, civil engineer in our
13 Civil Engineering branch.

14 We did some analyses of our dam, earthquake
15 analyses. We have looked at the performance of concrete
16 gravity dams during past earthquakes. We have regular
17 inspection programs where we go out and inspect our
18 dams. Based upon all those things we feel very
19 confident that the dam will not fail.

20 We have a present dam safety evaluation study
21 under way where we have evaluated the dam for
22 earthquakes, and the earthquakes we are looking at are
23 larger than the OBE. They are not as large as the SSE,
24 but they are larger than the OBE. And in today's
25 evaluation the dam would not fail for an OBE.

1 MR. HOELLER: Okay. That is helpful. Thank
2 you.

3 MR. NEWTON: I think the point, in answer to
4 the sensitivity, I think we have gone overboard to try
5 and make sure that the site was well above any flood
6 level. And I'm not just sure where you quit asking
7 these "what ifs," not that they aren't real.

8 MR. CARBON: Chet, is your question resolved?

9 MR. SIESS: I would still like to see the
10 sensitivity study on the reservoir elevation, as long as
11 Jesse has the question about the gates. It may not be a
12 reasonable assumption, but we are not noted for
13 reasonable assumptions.

14 MR. NEWTON: We can look at that. I think I
15 would first like to review and have available the
16 information about what our actual gate operations
17 assumptions were in that flood. We can certainly
18 provide that. Our current workload would make that on
19 down the road some place, but depending upon how
20 important it was, it certainly can be done. And I would
21 have to ask somebody else as to their feelings as to
22 whether you want to get us to get into that.

23 MR. GROSS: If it is important, we can provide
24 that in a relatively short period of time, probably
25 before the next full committee meeting. That would be

1 one month.

2 MR. NEWTON: How much time?

3 MR. GROSS: About one month.

4 MR. NEWTON: I'm not sure whether physically
5 we've got the manpower that we could put off our other
6 jobs. We will have to argue about that.

7 MR. GROSS: If I understand the discussion --

8 MR. NEWTON: We can give the discussion about
9 the gate operations and the rest of the assumptions to
10 test in truth to see about the 1035, but to do a series
11 of runs postulating 1035 or 1040 or whatever the
12 different elevations are, and then the downstream flood
13 levels, you're talking about a healthy amount of work.
14 And whether that could be done in a month or not I don't
15 know.

16 MR. CARBON: I guess there would be no great
17 need before the April meeting, so a couple of months is
18 all right. But we would like it then.

19 MR. GROSS: Okay.

20 MR. CARBON: I have one more question there.
21 What role does the Melton Hill dam play?

22 MR. NEWTON: Very little. It is not important
23 to the final conclusion. That is assumed to fail.

24 MR. CARBON: The dams of the other branch past
25 Tellico and so on, do they play a role in terms of if

1 they go out and you have flooding below Kingston, that
2 this backs up and affects CRBR?

3 MR. NEWTON: These were all examined, and they
4 are noncontrolling. That is in the SAR. I don't
5 remember the exact flood levels, but they were all
6 investigated, and they are lower flood levels.

7 MR. CARBON: But they don't in any way cause
8 backup combined with Norris that would change the values
9 you have given us here?

10 MR. NEWTON: You postulate a centering of an
11 earthquake, and we looked at an earthquake centered such
12 that Norris would fail. We looked at the forces on the
13 surrounding dams, and there would be no failure. So
14 what we have done is a whole series of movements of
15 earthquakes throughout the region looking for
16 combinations of possible failures and this kind of a
17 thing. And there are no other failures coupled with
18 Norris. There are other failures of other dams in which
19 Norris is not impacted and doesn't fail, so it is not a
20 reasonable or a logical combination. We have looked at
21 those logical combinations.

22 MR. CARBON: Any further questions?

23 (No response.)

24 MR. CARBON: I guess that's it then. Thank
25 you, Mr. Newton.

1 We have a break scheduled. I guess we might
2 as well take it now.

3 (Recess.)

4 MR. CARSON: Let's continue.

5 MR. MORRONE: Good morning. My name is Tony
6 Morrone. I'm with Westinghouse Advanced Reactors
7 division.

8 (Slide.)

9 This presentation is on reserve seismic
10 margins available beyond the .25g SSE of CRBR. The
11 evaluation was made based upon a generic basis with
12 ratios and extrapolations.

13 As I was saying, the evaluation was made on a
14 generic basis with ratios and extrapolations from linear
15 elastic analysis. We have not performed nonlinear
16 inelastic analysis, nor have we made a statistical
17 evaluation.

18 The margins thus determined are applied to the
19 CRBR SSE to determine a maximum ground acceleration or a
20 reserve margin earthquake at which systems, structures
21 and components begin to fail.

22 MR. OKBENT: What does "generic" mean as you
23 used it?

24 MR. MORRONE: We did not look at every piece
25 of equipment. This, I believe, will become evident as I

1 show how some of these margins were obtained.

2 (Slide.)

3 First of all, I would like to define some
4 terms so we can understand what the reserve seismic
5 margin is; and that is, the seismic reserve strength or
6 capability available when the calculated effects stress
7 functional performance due to all loadings equal
8 allowable limits, like code or performance.

9 In some specific evaluation we also considered
10 a design margin, which is the ratio of the allowable
11 over the calculated. I would also like to define a
12 nominal margin. This is discussed in the Battelle Labs
13 report on realistic seismic margins by Rutabo and
14 Desei. And this is the ratio of the ultimate strength
15 over the allowable stress when the allowable stress is
16 equal to the calculated stresses; and that is the
17 seismic stress and the nonseismic stress.

18 MR. OKRENT: What has that got to do with
19 reserve margins, in your opinion?

20 MR. MORRONE: The reserve margin will be based
21 on a nominal margin, and I will show you that after this
22 nominal margin is determined, that I will convert this
23 nominal margin into a seismic only margin just using the
24 seismic portion of the load.

25 MR. OKRENT: But I'm trying to understand, are

1 you suggesting that one can go to ultimate before
2 failure of all of the components?

3 MR. MORRONE: I am going up to failure, and I
4 am using ultimate.

5 MR. SHEWMON: Let me ask a different
6 question. I was going to ask you if all of these
7 stresses were elastic.

8 MR. MORRONE: All elastic.

9 MR. SHEWMON: Say they assume it's a piece of
10 glass. The ultimate is still elastic, I guess.

11 MR. MORRONE: The ultimate given by the ASME
12 code, yes, sir.

13 MR. SHEWMON: So what is the ultimate given by
14 the ASME code? How is it established? Physically what
15 happens to the material at that point?

16 MR. MORRONE: Well, I would say that
17 deformations become so large that there is structural
18 damage at that point.

19 MR. SHEWMON: Now, you have run a
20 stress-strain curve. Where is it? Is it at the
21 ultimate stress or at the elastic limit?

22 MR. MORRONE: At the ultimate stress.

23 MR. SHEWMON: So it is not elastic.

24 MR. MORRONE: Correct. But as I mentioned, we
25 based this evaluation on ratios to ultimate.

1 MR. SHEWMON: So what you have is some stress,
2 what the elastic strain would be to give you the stress
3 that would correspond to the ultimate, or is it the
4 strains which would correspond?

5 MR. MORRONE: It is the stress which would
6 correspond to the ultimate. I do have a vu-graph here
7 that will show the margin that we get to ultimate.
8 Perhaps that might clear it up.

9 MR. OKRENT: I would like to understand why it
10 is whatever you're using is the right thing to use.
11 It's not clear to me whether you're talking about many
12 oscillations or a single applied load, for example, in
13 deciding what the failure point is. And also, I don't
14 know why for some components it is suitable to go to
15 failure, because something may need to function or it
16 may need to form and not allow something to function or
17 whatever.

18 What you're doing may be fine, but I am unable
19 to relate it to the application.

20 MR. MORRONE: If you will bear with me,
21 perhaps I might answer your concerns as I go through the
22 presentation.

23 MR. EBERSOLE: Pardon me. I guess I can't
24 believe that that is a conservative way to calculate
25 margin when you use S as the numerator. I got the

u

1 impression that S was when you are really gone.

2 u
MR. BENDER: Why don't we wait and hear his
3 story and then challenge it?

4 MR. MORRONE: There will be a lot of
5 calculations that you may want to challenge. But
6 anyway, to continue, the reserve margin earthquake then
7 is the .25g SSE at Clinch River times this reserve
8 seismic margin.

9 The sources are the conservative predictions
10 of building and equipment response and conservative
11 definitions of structural and functional performance
12 limits.

13 (Slide.)

14 Okay. I would like to show you a system
15 evaluation procedure. We have this diagram with two
16 branches. The righthand addresses the reserve seismic
17 capability of buildings and structures, which is given
18 by the product of the structural strength reserve
19 capability and the seismic restraint conservatism.

20 The lefthand branch addresses the reserve
21 seismic capability of system equipment which is limited
22 by either the structural reserve capability or the
23 equipment functional reserve capability. So we consider
24 the lower of the two to arrive at the equipment
25 capability.

1 The equipment structural reserve capability is
2 given by the product of the structural strength reserve
3 capability and seismic response conservatism.
4 Similarly, the equipment functional reserve capability
5 is given by the seismic response conservatism and the
6 system functional reserve capability. All of these
7 blocks contribute to these margins. We will go through
8 all of them.

9 MR. WARD: Since you may be talking about -- I
10 gather you're going to be talking about strains beyond
11 elastic, isn't there some interaction or potential for
12 interaction between those two legs of the system as
13 you've described it there.

14 MR. MORRONE: In the equipment?

15 MR. WARD: I mean in the building and
16 structure. If it is deformed beyond, can't that have
17 some effect on the capability of the system contained
18 within the building?

19 MR. MORRONE: Yes.

20 MR. WARD: But that is treated in your
21 analysis.

22 MR. MORRONE: To a small extent. For example,
23 when the building -- when the reinforced concrete
24 cracks, the reinforcing steel would yield, we do have
25 lower responses for the building. So the equipment flow

1 response spectra would pertain to this, so it would have
2 a positive effect on the capability of the equipment.

3 MR. WARD: Positive in that case. Is it
4 positive in all cases?

5 MR. MORRONE: In this example it would be
6 positive in all cases, because most of our equipment is
7 designed with response spectra techniques, and we use
8 elastically-derived spectra.

9 (Slide.)

10 This vu-graph shows the equipment structural
11 strength reserve capability. The first is given by the
12 material minimum strength assumptions. The ASME code
13 dictates that minimum strength values be used to derive
14 allowable stresses. However, for seismic capability, a
15 reserve margin earthquake, it is appropriate to use
16 average strengths.

17 From a study of ultimate strength curves
18 published by ASME, we found that the ratio of average to
19 minimum ultimate strength is 1.25. However, in this
20 report by Rutabo and Desei, they mentioned a ratio of
21 1.2, so we used those lower ratios here.

22 MR. OKRENT: Before you go on, I guess, I am
23 trying to understand why it is appropriate to use
24 average, since if some components or some parts of a
25 component are stronger than average and some components

1 or some parts of a component are weaker than average but
2 always above code minimum, using the average will
3 certainly underestimate the capability of the stronger
4 part, but it will overestimate the capability of the
5 weaker part. And it is the weak point that is of
6 interest.

7 Could you help me?

8 MR. MORRONE: Well, for design purposes I
9 agree with you. We should not use average. But
10 remember, what we are trying to do here, we are trying
11 to determine the largest earthquake that this plant
12 could take before the system starts to fail. And I
13 believe in this case using an average value is more
14 appropriate than using a minimum value.

15 MR. OKRENT: I would agree if somehow you have
16 eight columns, and they share the load in such a way
17 that if one gives, the other picks it up and so forth,
18 and in some way it is the average strength that works.
19 But on the other hand, if I postulate two pipes, each of
20 which you need one of them to have to serve a vital
21 function, and one of them is above average and one below
22 average, using the average doesn't tell you what will
23 happen.

24 MR. DICKSON: This is Paul Dickson of
25 Westinghouse.

1 I think we're missing a little point here.
2 This plant is designed to an SSE of .25 g's for a zero
3 period of ground acceleration, and it is designed to all
4 the code rules.

5 Now, all the components that must be Category
6 I will survive in the most conservative of analytical
7 methods as well as the use of minimum straight
8 properties. What we have been asked is since there is a
9 concern that the probability of an earthquake larger
10 than .25 is not absolutely zero, what is likely to be
11 the size of the earthquake where you really have
12 failures? And that is what we were trying to look at.

13 We are not pretending that this is an absolute
14 guarantee that you can go beyond that. We guarantee .25
15 g's ground acceleration. We're just trying to make a
16 reasonable view at what is the size of the earthquake
17 where you would expect failures to occur. And I believe
18 that if you will let Mr. Morrone continue through this a
19 little bit, we might get to that point.

20 MR. OKRENT: Well, he is proceeding along
21 making certain assumptions. I would like to understand
22 the basis for the assumptions. And by the way, we might
23 as well go back to a point that was a little bit
24 obscure, I think, when the Staff made their
25 presentations, obscure to me compared to what I see in

1 their evaluation.

2 What I read from the USGS is a somewhat
3 indefinite position concerning what they would choose as
4 even the SSE for the site, let alone what the frequency
5 of the SSE is that he mentions.

6 So I think in the first place it would be
7 awkward for everybody, for example, if this plant were
8 built to a certain basis and had no reserve margin
9 really, and three years later, as happened in other
10 plants, there is a re-evaluation for some reason.

11 Well, whatever basis you're using, it seems to
12 me you should be able to say why it is relevant; and I'm
13 trying to understand why in this particular case average
14 is relevant rather than what you think is the point
15 above minimum that you are pretty sure will occur.

16 MR. DICKSON: And basically that is what Mr.
17 Morrone is trying to address when he gets to the end.
18 He doesn't take the best of all of these margins. He
19 takes where he thinks the mean is. But when he gets to
20 his final number, it is not a number that if the SSE
21 were changed to we could immediately accept it.

22 MR. WARD: This is sort of a best estimate
23 reserve margin?

24 MR. DICKSON: That's correct. That is what it
25 is, and we want to present it on that basis.

1 MR. MORRONE: For a design basis earthquake we
2 have to remove the conservatism. The conservatism is a
3 big source. Certainly the other area of structural
4 strength reserve capability is the code design stress
5 limits for service limit level B, which is the faulted
6 condition.

7 The components, of course, are designed for an
8 allowable main tensile strength stress of 70 percent of
9 the ultimate. Therefore, we obtain a ratio of ultimate
10 strength to allowable stress of 1.43, which is just the
11 reciprocal of .7. And the total structural strength
12 nominal margin is 1.72. And I sort of underline here
13 "nominal," because the seismic only margin given by only
14 the portion of the loading that is seismic will be
15 higher than this.

16 (Slide.)

17 Now we come to the system seismic response
18 conservatism. This consists of five items. First is
19 the system damping assumptions. The damping values used
20 in CRBR are consistent with Regulatory Guide 1.61, and
21 they are conservative, especially the 3 percent of
22 damping value for equipment and large piping.

23 From a Westinghouse report on damping values
24 of nuclear power plant components it was shown that a 4
25 percent damping value was conservative, and we design

1 our PWRs with this 4 percent value.

2 Now, considering the fact that for this
3 evaluation we are at stress levels at or near ultimate,
4 a realistic damping value would be at least 5 percent
5 from floor response spectra for Clinch River, a typical
6 reduction in going from 3 percent to 5 percent is 1.2.

7 The other source is the development of the
8 ground accelerogram. In generating a motion time
9 history for the ground, we envelop the NRC criteria
10 response spectra very conservatively. It is shown in
11 the handouts. And also, we do not take advantage of the
12 standard review plan rule that we can be below the
13 criteria response spectra by five points.

14 We have estimated the conservatism here as
15 being 5 percent. Also, there is a reduction of floor
16 response spectra due to the inelastic action of the
17 building. This will be discussed in more detail when we
18 come to the building margins. We only take a 5 percent
19 factor for this reduction.

20 We developed design response spectra with
21 computer-generated spectra by enveloping the upper and
22 lower bounds of soil moduli by widening the peaks and
23 smoothing the spectra to eliminate valleys and spectral
24 fluctuations. In addition, the flow response spectra
25 are conservative when applied to a piece of equipment

1 uncoupled from the building.

2 Newmark showed that there is a limit on the
3 amplification above the design response spectrum and
4 floor response. Our floor response spectra exceed this
5 limit. So for this total conservatism it's within 10
6 percent.

7 MR. BENDER: I just wanted to establish a
8 frame of reference. This kind of analysis is evidently
9 being done to show that the pressure maintaining
10 capability of the system has some margin. If you're
11 referring to the Westinghouse work, for example, that
12 was mainly on piping systems, as I recall.

13 MR. MORRONE: Not piping systems, no, sir.

14 MR. BENDER: It was not?

15 MR. MORRONE: Do you mean the report on
16 damping values?

17 MR. BENDER: Yes.

18 MR. MORRONE: No. This considered all
19 equipment. I happen to be the author of that report,
20 and I had Japanese test data, the Indian Point No. 2
21 results.

22 MR. BENDER: But it was all based upon a level
23 of stress applied under pressure loads, wasn't it?

24 MR. MORRONE: I don't think pressure loadings
25 even came into it. It was with small excitations. Some

1 of these tests and structures, they came from glass
2 tests, some laboratory tests. Pressure did not enter
3 into this.

4 MR. BENDER: That is helpful.

5 Is there any question of displacement in this
6 analysis, deformations of any sort?

7 MR. MORRONE: That comes in in the functional
8 capability where some equipment is limited to a yield
9 criterion such that they will not deform excessively.
10 So the functional performance is ensured by limiting the
11 stresses at or near normal yield. And I will show an
12 example of one of these components that had that kind of
13 functional limitation.

14 MR. BENDER: Okay. Thank you.

15 MR. MORRONE: For time history analyses we
16 modified this for the possible frequency variations of
17 the building. One way would be to vary the time
18 interval at which the accelerations are given analogous
19 to compressing and expanding the time history.

20 The other method that we use on CRBR is to
21 develop spectra consistent histories; that is, we modify
22 the original motion and ensure that the response
23 spectrum of this original motion fully envelops the
24 design response spectrum. So we should have at least a
25 10 percent conservatism in here.

1 So the total system seismic response
2 conservatism is the product, of course, of these first
3 three factors, and just once, the 1.1, depending upon
4 which type of analysis we perform.

5 (Slide.)

6 Okay. Now we come to the seismic only
7 margin. The equipment structural reserve seismic margin
8 is the product of the structural strength reserve
9 seismic margin and the seismic response conservatism.

10 Now, recall that we have had the nominal
11 margin of 1.72 for structural strengths. Using this
12 report by Rutabo and Desei, which is NUREG/CR-2137 and
13 using their terminology, we define a seismic only margin
14 with either of these two equations.

15 The question here is by what amount can the
16 seismic load only be increased to yield a nominal margin
17 of 1 instead of 1.72. So with a conservative assumption
18 that the portion of the seismic load -- and our
19 equipment varies from 60 to 90 percent -- substituting
20 in this formula we obtain a structural strength reserve
21 seismic margin of 2.2 where K equals 60 percent, 1.8
22 where K equals 90 percent. Therefore, multiplying by
23 the seismic response conservatism, we obtain equipment
24 structural reserve seismic margin from 2.6 to 3.2.

25 MR. OKRENT: Is this where I should understand

1 why ultimate is the right thing to use when you may have
2 some hundred or so oscillations? In other words, I'm
3 trying to understand are you picturing where you're
4 going through significant plastic deformation but not
5 reaching ultimate on each of these oscillations and
6 therefore not failing.

7 What is the picture you have of what's going
8 on?

9 MR. MORRONE: The picture is that how far can
10 I load this equipment before it starts to fail.

11 MR. OKRENT: But there is a difference between
12 loading once to near ultimate and loading 100 cycles to
13 near ultimate. Do you agree?

14 MR. MORRONE: Are you talking about fatigue?

15 MR. OKRENT: I am talking about multiple large
16 plastic deformations, that you can a failure mode due to
17 that without ever having nominally reached ultimate low
18 cycle fatigue.

19 Now, I'm just trying to understand whether you
20 think in what you've done you've incorporated that, and
21 if so, how; or if you think in fact you're not getting
22 to the region of low cycle fatigue because of what
23 you're doing. I'm trying to understand your picture.

24 MR. DICKSON: Excuse me.

25 Tony, how many cycles do we take in SSE and

1 how many of them are close to reaching the .25g
2 acceleration?

3 MR. MORRONE: Well, first of all, fatigue is
4 not evaluated for a faulted condition, but the SSE, of
5 course, it is one SSE, and there are ten cycles of
6 motion in the SSE. So we're talking about ten cycles.

7 MR. OKRENT: Yes, but we're also talking about
8 larger earthquakes which are longer, which may have more
9 cycles.

10 MR. MORRONE: Peak cycles. I'm talking about
11 peak cycles.

12 MR. OKRENT: So am I. Again, I'm trying to
13 understand in what you've done whether you've included
14 an allowance for low cycle fatigue or you don't expect
15 to get into that region or just what.

16 MR. MORRONE: Fatigue, in my estimation, is
17 not a consideration for the SSE. It is for the OBE.

18 MR. OKRENT: I'm sorry. You're trying to show
19 us how much margin you have, and you are using ultimate
20 as a measure. If you're going to ultimate, you are
21 going beyond the point at which you normally design for
22 the SSE. And you tell me fatigue is no consideration
23 for the SSE, and I agree.

24 MR. MORRONE: Due to the small number of
25 cycles.

1 MR. OKRENT: I would like to know whether this
2 has been factored at all into your choice of ultimate.

3 MR. MORRONE: No, sir.

4 MR. OKRENT: It has not?

5 MR. MORRONE: It has not been.

6 MR. OKRENT: Okay. Then that is something to
7 be looked at possibly.

8 MR. EBERSOLE: Are you going beyond the point
9 where you get permanent deformation just a little bit?
10 All right. Then if you have ten cycles, why aren't
11 these just arithmetically added, because I don't see any
12 reason for the equipment to return to its original
13 position.

14 MR. MORRONE: Okay. But remember this
15 evaluation is not based on strain levels.

16 MR. EBERSOLE: Well, I think that is one of
17 the problems. Later on I'm going to ask you how you're
18 going to design a battery rack, and I'm going to do so
19 for a very good reason: the belief that you must
20 consider strain, because it will depend upon the level
21 of movement that is permitted in such a design as to
22 whether or not you succeed in shutting the plant down.

23 MR. MORPONE: Is that usually analyzed or is
24 it tested?

25 MR. EBERSOLE: I think it is analyzed from the

1 standpoint of the straps that you put around the
2 battery. Now, on a modular basis they may shake an
3 individual battery, but I don't think anyone shakes an
4 entire set of cells.

5 What you do is you bolt these rigid and
6 inelastic cells together with hard copper bus bars, and
7 you create a system which is highly susceptible to minor
8 deflections.

9 MR. OKRENT: By the way, is there some report
10 I should have read that gives all of this in much more
11 detail?

12 MR. MORRONE: This report here is a good
13 reference.

14 MR. OKRENT: No. But that describes what you
15 are presenting here, your analysis and so forth. Has
16 that all been documented?

17 MR. MORRONE: There is an older report where
18 we presented a seismic capability not going to
19 ultimate. Okay. We just considered basically the
20 conservatism we had in our design, and those were the
21 margins that we had at which the plant could operate
22 without any problem.

23 I understood that we wanted to look at the
24 margins beyond the SSE, and this is my attempt to show
25 margins beyond the SSE.

1 MR. BENDER: It's been a while since I looked
2 at this report of Rutabo and his associates, but I think
3 this was sort of an arbitrary definition that he used to
4 develop his margin of conservatism.

5 But really to do this right -- and I'm not
6 sure you need to do it right -- but it seems to me that
7 if you were trying to be rigorous about it, you would be
8 trying to look at what the deformations were as a
9 function of the load. In a seismic event the loading
10 has a very short peak period. Even if it is a long
11 period, the time at peak load is very short; and so the
12 time at which you would see the forces representing
13 ultimate strength would be short.

14 And it seems to me to look at it you would
15 want to have some kind of a stress-strain relationship
16 that is a function of time. Have you tried to look at
17 anything like that?

18 MR. MORRONE: No. You would do this for all
19 equipment?

20 MR. BENDER: No. I would try to do it for
21 some typical equipment just like you're talking about
22 doing. I looked at a few typical applications so I
23 could get some feeling for what the relationship is
24 between the loading that might represent peak conditions
25 and what your nominal design loading is.

1 MR. MORRONE: And what would you consider as
2 failure then due to strength?

3 MR. BENDER: Well, I wouldn't really try to
4 get to failure. I would try to look at something a
5 little bit less than failure, because failure is a very
6 hard thing to define.

7 MR. SHEWMON: But that's what he's asking you
8 to design. Granted everything you've said, you have to
9 take some condition.

10 MR. BENDER: Well, I don't want to find the
11 margins of failure. I want to find out whether there is
12 some margin, and I can define it anywhere I want to. I
13 can define it at 90 percent, which is not a bad way to
14 do it.

15 MR. PALM: I think perhaps to alleviate the
16 committee's concern, there is additional margin beyond
17 what Mr. Morrone has identified as the seismic
18 capability limit. And that is about in the order of 70
19 to 80 percent of the whole plastic strain range of the
20 material. When you are talking ultimate strength as
21 your maximum capability, well, you're just up at the
22 front end of the flat part of the curve on a
23 stress-strain curve. And you do have a significant
24 plastic range beyond that.

25 MR. BENDER: For a period of time.

1 MR. PALM: For a period of time.

2 Now, the important point is that under dynamic
3 type loads, particularly for the safe shutdown
4 earthquake, the structure or the component isn't going
5 to feel it once it gets out in that plastic range. It
6 will feel it to a certain point, but it will not be a
7 sustained type of load where the strain will keep
8 increasing until you do reach a rupture limit.

9 So that is a very important fundamental to
10 understand, that we are nowhere near that point. We are
11 up at what we consider the ultimate. You do have a lot
12 more to go before you even would start to worry about
13 rupture.

14 MR. WARD: I think that may be true for a
15 system where you worry about rupture, but here we're
16 talking about not just structures but equipment. And in
17 many cases you are concerned with loss of function
18 somewhere. So I think maybe it's a little too
19 optimistic to say you have that long part of the curve
20 available.

21 MR. MORRONE: For functional requirements we
22 do limit the stresses to the upper level.

23 MR. SHEWMON: Tell me, is it inherent in all
24 earthquake situations that one goes through several
25 cycles and ultimately then builds up enough amplitude to

1 take it to yield?

2 MR. MORRONE: Well, the cycles of the
3 earthquake are a direct function of the amplification.

4 MR. SHEWMON: Okay. But what you -- you see
5 where I'm coming from is that these damping values,
6 though the engineering profession is unwilling or
7 incapable of giving much credit for it, the damping
8 values rise precipitously as you approach the yield; and
9 if you try to take an harmonic oscillator and oscillate
10 it at its yield strength, you've got a hundred percent
11 damping.

12 MR. MORRONE: They do increase, I agree.

13 MR. SHEWMON: So if one was or I was convinced
14 that indeed all of these things had to oscillate and
15 build up in amplitude until they got to the yield, then
16 I would take much more comfort out of the assumption of
17 5 percent or 3 percent damping because I know that is
18 extraordinarily conservative as you approach yield.

19 But I am not familiar enough with the things
20 you are treating to know whether or not indeed it takes
21 several cycles for all of these things to build up to
22 that load or not.

23 MR. MORRONE: Well, certainly if we had an
24 earthquake with a single spot there would be no buildup,
25 so it is a function of the DBA and the number of cycles

1 in a motion which builds up. Of course, when we say
2 yield we do mean that the state of stress in the
3 component is yield.

4 MR. SHEWMON: But that state of stress is
5 critically dependent on the damping and how much energy
6 has been dissipated in the cycles before it gets to
7 yield.

8 MR. MORRONE: Yes. With an assumption of a
9 certain damping value when we determine the stress.
10 Now, you may say well, but with this stress you could
11 use some more damping; so if you put more damping, then
12 the response is lower. So you could go in circles that
13 way, but they are interrelated.

14 MR. SHEWMON: I think that is probably the
15 main source of the conservatism, though it gets
16 complicated enough that it is very difficult to take any
17 credit for it.

18 MR. MORRONE: Well, I feel quite comfortable
19 with 5 percent damping to ultimate.

20 MR. PALM: Would the committee like to see a
21 diagram on the blackboard of perhaps the conditions of
22 conservatism in this assessment?

23 MR. WARD: Yes, sure, if that's all right.

24 MR. MORRONE: I do have near the end a list of
25 additional conservatisms which we have not addressed.

1 MR. PALM: It is a function of strain and
2 stress. You draw a simple stress-strain diagram of
3 steel material. Normal allowable stresses are basically
4 tied in with this point here on the curve below the
5 yield limit -- the yield limit being basically about
6 7/10 of -- allowable limit being about 7/10 of yield.
7 You get up to yield at this point on the curve, and
8 beyond this we reach a point which is identified as the
9 ultimate limit.

10 Now, the margin that Mr. Morrone is talking
11 about is basically the difference between the allowable
12 and the ultimate. The question was raised about
13 additional capability to sustain cyclic effects, dynamic
14 loads beyond the design basis earthquake that we have
15 identified. This is what you do have available, and
16 this is a very significant road out on the plastic range.

17 Now, I'm talking generically. We can be
18 relating this to a structure. We can be relating it to
19 a piece of pipe or a reactor vessel.

20 MR. MORRONE: There's a large amount of energy
21 absorbed.

22 MR. EBERSOLE: Can you relate it to a piece of
23 equipment which is sensitive to displacement, like a
24 shaft, running in a shaft bearing, or I mentioned
25 earlier a brittle set of batteries contained in a bunch

1 of iron straps.

2 MR. PALM: Yes, this could be displacement
3 oriented. It is directly correlatable to displacement.
4 But when you're talking displacement you have to get
5 into specifics, whether you're talking about a shaft or
6 a vessel.

7 MR. EBERSOLE: What I'm really saying is much
8 equipment is going to be displacement sensitive and not
9 strain sensitive.

10 MR. PALM: I understand that.

11 MR. MORRONE: Well, for that the limit is
12 yield, so it is elastic.

13 MR. EBERSOLE: No. I'm saying if you go
14 beyond a certain level of amplitude of movement that the
15 machine quits even though it is still in the elastic
16 regime.

17 MR. MORRONE: But the stress limit will
18 prevent that from happening.

19 MR. PALM: That is all I wanted to say. If
20 you wanted me to expand on this, or if Tony wanted to.

21 MR. WARD: Tony, I guess what I haven't
22 understood yet is you have said that pieces of equipment
23 that perform, they are functionally limited. You
24 estimate they could just go to the elastic limit.

25 I don't see where that comes into your

1 equations here. I guess you're treating it generically.

2 MR. MORRONE: Well, I do have another slide
3 that will show that.

4 (Slide.)

5 I just wanted to show you an example of a
6 specific component, in this case the containment
7 vessel. From a buckling analysis based upon ASME code
8 case and 284, we obtained a nominal margin of buckling
9 of 1.9. Then again, a seismic only margin when plugged
10 into this equation with an actual ratio of seismic to
11 total loadings of 70 percent comes out to be 2.29 along
12 with the system response, seismic response
13 conservatism. The equipment structural reserve seismic
14 margin would be 3.3 as limited by the containment vessel.

15 Paul Falk this evening will give you an
16 example of another specific component -- the steam
17 generator.

18 Now, we come to the functional reserve
19 capability. As you saw from the system evaluation table
20 --

21 (Slide.)

22 -- The equipment capability is also affected
23 by functional requirements, and these requirements are
24 most important for the shutdown system and the shutdown
25 heat removal system.

1 Now, the question here is not stress but the
2 design intended function. The shutdown system
3 components must remain structurally intact with no
4 excessive deformation. Also, the effect of seismic
5 excitation on scram insertion rates must be shown to be
6 acceptable.

7 This vu-graph shows the margin that we have in
8 our scram calculations. The scram analysis is performed
9 with various retardation forces, including impact forces
10 given by the earthquake. These impact forces are
11 multiplied by a certain coefficient of friction to
12 obtain equivalent vertical frictional forces which
13 retard the scram time.

14 The first item of conservatism was that the
15 scram insertion performance was evaluated by factoring
16 the impact forces to .33 g's instead of .25; therefore,
17 we have an initial margin of 1.32. Then for reactivity
18 insertion the assumption was made of the worst case rod
19 position and minimum rod worth rather than maximum rod
20 worth and associated rod position; and this was
21 calculated to be equivalent to an increase in the
22 earthquake of 10 percent.

23 The other item is friction coefficient. We
24 used a value of 1.0 from tests on the primary control
25 rod system. We obtained a mean sliding coefficient of

1 friction of .45, so the ratio of those two gives us
2 2.2. Also, we did not use any impact damping. And a
3 sensitivity calculation with a 10 percent impact damping
4 value based upon 50 percent coefficient of restitution
5 showed us that the impact forces would be reduced from 7
6 to 10 percent, which was a factor of 1.07 here.
7 Therefore, the functional reserves seismic margin is the
8 product of those four, and multiplied by the seismic
9 response we have a seismic margin of 5.0 for scram
10 calculations.

11 MR. OKRENT: Before you leave that, in that
12 friction coefficient what goes into the 0.45, which I
13 guess is the number you think is better. How well is
14 this ascertained, and does this allow for stainless
15 steel swelling and flowing or whatever kind of
16 distortion might occur?

17 MR. MORRONE: They are actually tests that we
18 perform at ARD with a full-size control rod drive.

19 MR. OKRENT: But that would not be on a core
20 which has been subjected to distortion over life.

21 MR. MORRONE: Well, this friction is between
22 the drive line and the guide tubes.

23 MR. OKRENT: But does it depend at all on
24 alignment questions or things of this sort? I'm just
25 trying to understand.

1 MR. MORRONE: I don't think so.

2 MR. SHEWMON: The normal force would. He's
3 talking about a friction coefficient which is the ratio
4 of the normal force to the sliding force. And I think
5 you are saying he may not know the normal force very
6 well, and he is saying but he measured the ratios. I
7 think you're talking about different things.

8 MR. DICKSON: Yes. Let me add to that. That
9 1.0 coefficient, friction coefficient was used in the
10 analysis. That assumed the worst possible boiling in a
11 destroyed core and the worst possible offset of the
12 upper internals to the core itself.

13 MR. OKRENT: Yes, but you're now assuming .45
14 in this analysis which related to, if I understand
15 correctly, a situation -- well, I'm just trying to
16 understand.

17 One other small point: in the 1.45 number,
18 part of this came from using 5 percent versus 3 percent
19 damping.

20 MR. MORRONE: Yes, sir.

21 MR. OKRENT: Now, does that change indicate
22 something that you feel should apply for all systems or
23 for piping systems? Is it something that originates in
24 the building itself?

25 MR. MORRONE: There would be additional

1 equivalent damping given because of the cracking of the
2 concrete in the building. We have not considered that.
3 This 5 percent is for equipment and large diameter
4 piping, all equipment in large diameter piping that were
5 allowed to use 3 percent for design purposes.

6 I'm saying that the close to ultimate, there
7 is so much energy dissipation in --

8 MR. OKRENT: Well, I don't know what the valid
9 response is, but it is conceivable to me that you're
10 building to stay elastic and not cracking or whatever,
11 and so transmit forces with sort of normal kind of
12 damping and control rods are not the large piping. They
13 might get whatever it is is transmitted via the floor
14 which is maybe very strong for whatever reasons or
15 whatever. But I'm just trying to understand now whether
16 that factor of 1.45 is good for all equipment of what.

17 MR. MORRONE: I believe it is good for all
18 equipment. We're not stipulating that the building
19 would remain elastic and the equipment would remain
20 elastic. We're saying for stress levels at or near
21 ultimate what would a realistic damping value be.

22 MR. OKRENT: Okay.

23 (Slide.

24 MR. MORRONE: For the shutdown heat removal we
25 considered two systems, or rather we evaluated two

1 systems: the normal system and a backup system. The
2 normal system capability is limited by the rupture discs
3 that are in the sodium piping between the IHX and the
4 steam generator.

5 The evaluation was based upon the worst loop.
6 The other two loops experienced lower seismic
7 excitations, but we did not have the calculations for
8 those. They would have been more appropriate to use for
9 this evaluation.

10 And you can see from here how we arrive at the
11 seismic response conservatism, how we have this grading
12 of 339, and then we subtract five-year aging effects and
13 come up with 296 psi. Then we subtracted the steady
14 state operating pressure, normally 77 psi for seismic.
15 The calculations with the .25g SSE give us a 45 psi
16 pressure; therefore, the rupture disc functional reserve
17 seismic margin, that is 1 plus the 32 or 45 or some
18 place about 32 divided by 45.

19 Now, you see, the seismic response
20 conservatism here has decreased. It is no longer 1.45,
21 because in the analysis of the piping systems, the time
22 histories were used directly as provided by the
23 architect engineer rather than develop the design
24 margin. So I took that margin out, and we have a
25 functional reserve margin of 2.26 for the rupture discs.

1 MR. EBERSOLE: How do you test the rupture
2 discs?

3 MR. MORRONE: How do we test the rupture discs?

4 MR. EBERSOLE: Yes. It is just like a fuse,
5 isn't it? You can't test it.

6 VOICE: Infrequently.

7 MR. EBERSOLE: Infrequently somebody said. So
8 what is your level of confidence that you in fact obtain
9 on the ruptured stress that you intend to get? Do you
10 do a PRA on that or something?

11 MR. MORRONE: I don't know.

12 MR. CLARE: George Clare from Westinghouse.

13 We have not, of course, tested the rupture
14 disc units that will be used in the plant. What we have
15 done is to build identical units from the identical
16 material that will be used in the plant and tested them,
17 both in the sense of a static test and also in the sense
18 of putting them in sodium systems and testing them with
19 various types of loading there to understand their
20 failure or their behavior as they rupture.

21

22

23

24

25

1 MR. EBERSOLE: How thin is the material?

2 MR. CLARE: I can look that up for you and
3 when we get to the steam generator presentation later
4 today I will give you that number.

5 MR. EBERSOLE: Thank you.

6 (Slide.)

7 MR. MORRONE: The backup system for heat
8 removal is the direct heat removal service, DHRS. And
9 here is a list of the major components of the system.
10 We evaluated all of them, and they showed very large
11 margins except for the electromagnetic pumps which were
12 limited by functional criteria by keeping the stresses
13 at or below yield.

14 The evaluation of these pumps is shown here.

15 (Slide.)

16 Again, the calculated design margin based upon
17 yield criterion of 1.01. That is, we were this much
18 below yield than with the material minimum yield
19 strength assumption. We obtained the structural
20 strength functional margin of 1.21. The actual ratio of
21 the seismic to the total loading is 32 percent. Using
22 these values in the equation we have seen previously, we
23 have obtained a reserve seismic margin of 1.66, which
24 when multiplied by the system seismic response
25 conservatism gives us an equipment functional reserve

1 seismic margin of 2.41.

2 By the way, this is the limiting margin that I
3 will show you in our conclusions.

4 MR. EBERSOLE: May I ask a question? Do you
5 need DC, direct current, to shut this plant down and
6 monitor the success of the shutdown? Do you need the DC
7 power supply?

8 MR. DICKSON: Not to shut it down.

9 MR. EBERSOLE: I mean to remove decay heat.

10 MR. DICKSON: You don't need it to remove
11 decay heat. You need it to monitor decay heat, and you
12 need it to control the water level in the steam drum.

13 MR. EBERSOLE: What about the EM pumps?

14 MR. DICKSON: You do not need the EM pumps to
15 shut this plant down.

16 MR. EBERSOLE: You're telling me you can
17 really go completely blind on DC power?

18 MR. DICKSON: Those EM pumps are strictly
19 backup.

20 MR. EBERSOLE: So the awkwardness would be in
21 not knowing what you're doing, right?

22 MR. DICKSON: It is conceivable that you could
23 send two operators; one to operate a valve and another
24 one to look at the site class in the steam drum, and
25 they could do that. Obviously, that couldn't be done

1 instantaneously.

2 MR. EBERSOLE: Are there any environmental
3 heat-up problems that would result from that, a failure
4 of DC, because it automatically means you would use the
5 AC cooler?

6 MR. DICKSON: We have evaluated that and there
7 are some equipment losses we sustained. If you have a
8 sustained loss of all AC power to provide cooling, you
9 could still successfully shut the plant down.

10 MR. EBERSOLE: Thank you.

11 MR. MORRONE: These, by the way, are tested.

12 MR. DICKSON: The only things that need DC
13 power for safe heat removal is some valves that provide
14 the aux feedwater to the steam drums.

15 MR. MOELLER: Are the approaches that you are
16 using in calculating these reserve, or the margins, are
17 these standard procedures? Why I ask, like you say, the
18 scram insertion performance was evaluation to .33 g
19 instead of .25, so you divide .25 into .33 and you get
20 1.32.

21 Now, is that linear? You're treating it
22 linearly?

23 MR. MORRONE: Certainly.

24 MR. MOELLER: There's no question but what a
25 .33g is exactly 1.32 times as bad as a .25.

1 MR. MORRONE: Well, the impact forces do come
2 from a non-linear analysis of the drive line. But the
3 inputs to this non-linear analysis come from a reactor
4 systems analysis. So the input to the non-linear
5 analysis would be, of course, just the ratio of the
6 maximum accelerations.

7 MR. DICKSON: If I could add just a little
8 bit, in some cases the results of the analysis is
9 non-linear, but when he gets down what he is looking at
10 is what is the size of the earthquake that this plant
11 can really stand and has margin to stand. And since
12 that shutdown system was evaluated specifically for a
13 .33g earthquake, that clearly is one place where you
14 could use the ratio of the two.

15 MR. MOELLER: Okay, thank you.

16 MR. MORRONE: Before concluding the
17 presentation on equipment, I would like to show examples
18 of the reserve seismic margin for equipment, which is
19 qualified by tests rather than by analysis.

20 (Slide.)

21 This equipment consists mostly of
22 instrumentation and control equipment of the plant
23 protection systems. The qualification is to IEEE
24 standard 344. We used two types of test motion; single
25 frequency tests at resonance, regardless of what the

1 natural frequency of the building is. We subject
2 equipment with a motion which has the same frequency as
3 the equipment. Also, we use multiple frequency tests
4 with random motion.

5 The criterion here is a full enveloping of the
6 required response spectrum with the test response
7 spectrum. The required response spectrum is the
8 spectrum calculated at the mounting of the equipment.
9 Test response spectrum is the response spectrum of the
10 shake table motion.

11 (Slide.)

12 To give you typical examples of some of the
13 equipment that was tested, this is a typical comparison
14 of the RRS and TRS. This is the test response. You can
15 see that the enveloping is very conservative; way above
16 the requirements, to both ZPA values and maximum peak.

17 We have a similar comparison for the vertical
18 direction. That happened to be for the horizontal
19 direction.

20 (Slide.)

21 And this is even better. Based upon these two
22 viewgraphs, --

23 (Slide.)

24 then I have a typical example of the reserve
25 seismic margins. For tested equipment, the seismic

1 response conservatism here includes a 10 percent margin
2 required by IEEE 323, but not the margin due to damping
3 because damping is inherent in the equipment.

4 Therefore, the seismic response conservatism is 1.33;
5 then if we determine a margin on the ratios of the ZPAs
6 we would get a reserve seismic margin of 2.85 times
7 1.23, of 3.79 times the margin to fragility.

8 This equipment is not tested to fragility. So
9 we have a reserve margin to fragility before the
10 equipment would fail. Based upon the peak we have 2.05
11 margin to fragility.

12 MR. OKRENT: Has this equipment all been
13 tested or is it going to be tested?

14 MR. MORRONE: A lot of it has already been
15 tested. There is other equipment that has not yet been
16 tested.

17 MR. MOELLER: On this chart now, it is similar
18 to some of the other ones that you presented, you will
19 do certain things to two dozen places and other things
20 to one. Is that because of a less certainty in the
21 development of the required response spectrum? For
22 example, on the shutdown margin, the friction
23 coefficient, you could have divided and gotten 2.22 but
24 you stopped at 2.2. I guess I just need to be educated.

25 MR. MORRONE: It may be sloppiness, but there

1 is no hidden meaning in the decimal places. The
2 conclusion goes to one place, anyway.

3 MR. MOELLER: Okay, thank you. Of course, if
4 you stop at one place on the ground and accelerate, what
5 is that accelerogram?

6 MR. MORRONE: Yes. We could not take
7 advantage of the 5 percent. Sometimes we have to go to
8 two places.

9 (Slide.)

10 We now come to the buildings and structures'
11 structural strength reserve, seismic margins. This
12 evaluation was made for shear walls, since most of the
13 load at shear walls are seismic and the structures are
14 designed by strength methods with load factors and
15 strength reduction factors. And the OBE load
16 examination -- and OBE is a service load and, by the
17 way, the design is controlled by service load, the load
18 factor for the OBE is 1.9; for the SSE it is 1.0.

19 Even though the OBE is one-half of the SSE for
20 maximum ground acceleration, actually the OBE produces
21 much more than one-half the SSE loading because smaller
22 damping values are used for the OBE. And if we
23 conservatively assume that this ratio is 55 percent,
24 then we obtain a 5 percent margin, .55 times 1.9, for
25 the strength reduction factors, the ACI code limits, the

1 allowable below ultimate capacity and reduction factors
2 are applied, which range from .75 to .90. Using the
3 most conservative factor taking the reciprocal of .90,
4 we get a margin of 11 percent.

5 Also, we have minimum strength assumptions
6 analogous to the equipment, so the reinforcing steel
7 yield -- we estimate that the yield strength is 15
8 percent higher than specified. The concrete design is
9 based upon 28-day strength. However, the plant will not
10 go into operation until a year or more after the
11 concrete is poured, and we estimate that the aging
12 effects of concrete result in a 25 percent increase in
13 ultimate strength. Since the shear strength varies
14 proportional with the square root of ultimate strength,
15 we obtained a factor of 1.22.

16 The last item here is the redundant path loads
17 that we have in buildings. Since these buildings are
18 interconnected in a common foundation map -- they are
19 multiple, inter-connected cells -- the failure of one
20 would be picked up by the other. We will only assign a
21 5 percent margin here, so the total structural strength
22 reserve for seismic margins comes out to be 1.37.

23 MR. BENDER: It is not clear to me why the
24 concrete and reinforcing steel margins are additive.
25 What is that?

1 MR. MORRONE: It's not clear why they are?

2 MR. BENDER: Why they are additive? Where did
3 we get 1.37?

4 MR. MORRONE: 1.37 is the product of all four,
5 but 1.2 is the square root of 1.25. Now, I did not add
6 the 5 to 15 on top of the concrete aging.

7 MR. BENDER: Never mind, it's not important.

8 MR. SIESS: There are some things you've done
9 now that I'm sure are strictly correct, but what you
10 have done I think has been done reasonably
11 conservatively. The 1.37 you come up with is a bottom
12 line and does not look unreasonable. But you must
13 realize that that is an average value.

14 All of the parameters you've been messing with
15 up there are variables. They have some distribution.
16 Some are low, some are high. And what you have been
17 dealing with pretty much are averages and not with
18 extremes. So on the average, you have a margin of
19 something like that, maybe a little larger.

20 MR. MORRONE: But on the conservative side;
21 average on the conservative side.

22 MR. SIESS: I don't know what you mean by
23 conservative side, if I'm talking about a margin.

24 MR. MORRONE: Well, for example, we use .90
25 here instead of .75. That is on the conservative side.

1 MR. SIESS: But the .90 is in there to take
2 account of low yield strength steel, so you've moved it
3 over from the lower side of the distribution to the
4 mean, and then in the next one you've moved it somewhat
5 to the right of the distribution to date. You can't
6 take account of the fact that the average strength of
7 steel is usually higher than the specified strength.
8 The minimum strength is usually lower; the average
9 strength is usually higher. So you've messed with some
10 of the distributions and I could say you counted things
11 twice.

12 MR. MORRONE: Well in this case, you
13 understand I only counted the concrete reserve strength.

14 MR. SIESS: Yes, but that only affects shear,
15 and any connections are much more sensitive to flection
16 rather than shear, especially under repeated loads. So
17 the 1.37 is maybe conservative but it is an average and
18 there could be parts of the structure where it is less
19 1.37.

20 MR. WARD: But yet, he agreed at the beginning
21 of that that what he is attempting to do is to assess
22 sort of a best estimate of seismic.

23 MR. MORRONE: A statistical study would be
24 required. This is not a statistical study.

25 MR. ETHERINGTON: I don't know if this is a

1 best estimate. I don't really think so, because it
2 doesn't take into account things that we have observed.
3 We have observed deficiencies in engineering. We have
4 observed deficiencies of construction, materials and
5 none of these are factored in.

6 Of course, I would think if someone would try
7 to conduct all of the bad things that they could think
8 of, they could very well come up with a negative margin
9 if they neglected the good things.

10 MR. SIESS: That is the point I was trying to
11 make; that the worst case is likely to be below 1 and
12 the best case is likely to be well above the 1.37. So
13 if you take the 1.37 as about an average margin, I think
14 it is not unreasonable. And that is what he means by
15 best estimate.

16 MR. MORRONE: Remember, the purpose of this
17 evaluation.

18 MR. OKRENT: Well, we will get back to the
19 purpose when you're done.

20 MR. SIESS: I don't recall that anywhere you
21 factored into the structural strength the fact that all
22 of it is not contributed by earthquake.

23 MR. MORRONE: At the beginning, when I started
24 discussing the buildings I stated that this considers
25 shear walls.

1 MR. SIESS: I'm sorry.

2 (Slide.)

3 MR. MORRONE: Okay. A second viewgraph for
4 buildings and structures considers the seismic response
5 conservatisms, which is a bit different from equipment
6 we still have, the 1.05 for the development of the
7 ground accelerogram. However, here we considered the
8 reduction of the response spectrum due to the inelastic
9 action of the buildings.

10 As you know, there is a substantial reserve
11 strength in the inelastic range with energy absorption
12 due to cracking of the concrete and yielding of the
13 reinforced steel. Newmark discusses an inelastic design
14 response spectrum in this document here, NUREG/CR-0098,
15 where the spectral accelerations are reduced for all
16 frequencies below 33 hz. This reduction is a function
17 of the ductility factor and the frequency.

18 And the suggestion for the ductility factor of
19 structures' housing plus Class 1 equipment was 2 and 3.
20 Also, the constant production in the design spectrum
21 from 2 to 8 hertz was given by this equation 1 over the
22 square root of 2U minus 1. And using four ductility
23 factors of 2 and 3 in this equation, we come up with
24 elastic accelerations reduced by 45 to 58 percent, which
25 results in the reserve margin of 1.7 to 2.2.

1 Multiplied by the 1.05, we get building and
2 structures' seismic response conservatism of 1.8 to 2.4.

3 MR. SIESS: Are there any cases in the design
4 of this plant where failure would be defined in terms of
5 excessive deformation rather than inadequate resistance?

6 MR. MORRONE: Probably with the EM pumps.
7 That is why we had the yield criterion.

8 MR. SIESS: I'm talking about structures now
9 in relation to this slide.

10 MR. MORRONE: Bob, can you help?

11 MR. PALM: The answer is no.

12 MR. OKRENT: How about penetrations in
13 structures?

14 MR. PALM: I'm sorry?

15 MR. OKRENT: Where there are penetrations in
16 structures.

17 MR. PALM: I'm not sure how that relates to
18 Dr. Siess's question.

19 MR. SIESS: You see, the point is that some of
20 the conservatisms you've taken advantage of here in
21 terms of inelastic behavior will lead to increased
22 strength, but also, to increased deformation, and that
23 is not the conservative direction if deformation is a
24 governing factor.

25 MR. PALM: Yes, I understand that.

1 I am not quite sure I understand your
2 question, Dr. Okrent.

3 MR. OKRENT: Well, I would have to assume that
4 the reliability of some kinds of penetrations in an
5 earthquake would depend upon the amount of deformation.
6 If I am wrong, correct me.

7 MR. PALM: You are right.

8 MR. OKRENT: All right, then. I will add my
9 question to Dr. Siess's and ask whether, in fact, that
10 something that one should read about -- it is not in the
11 list of viewgraphs.

12 MR. PALM: I understand your question now, and
13 that is considered as part of the design process between
14 the architect engineer and the system designer where we
15 do, in addition to providing responses, we do give
16 displacements -- time history displacements, and the
17 design of penetrations that are linked to the structure
18 are also included in the loads and the displacements
19 translated between, let's say, a fixed point on the
20 structure and a connecting system. Does that answer
21 your question?

22 MR. OKRENT: Let me pursue this just one
23 minute. I would have to assume that you do this at the
24 SSE level. They also did this at the SSE level at
25 Indian Point 2, but when they looked beyond the SSE

1 level, as I am sure you are aware, the clearances were
2 not sufficient. In this case, the deformations might be
3 awkward.

4 Well, what I find is of interest, but I can't
5 tell --

6 MR. PALM: I have your question now, and I
7 think the answer is, at least from my end, that we have
8 not checked displacements at penetrations or at similar
9 type of locations.

10 MR. OKRENT: Well, this is a problem with what
11 you call a generic look, because if when one does a
12 generic look, you are not sufficiently complete, it may
13 be deceptive.

14 (Slide.)

15 MR. MORRONE: Here is the summary of the
16 reserve seismic margins. You see that the system
17 reserve seismic margin is 2.4, which is really
18 controlled by the functional reserve seismic margin.
19 This was the DHRS functional margin. The structural
20 reserve margin is 2.6 to 3.2, which is similar to that
21 of the buildings and structures.

22 MR. DICKSON: Tony, I think it's worth noting
23 here that all of the argument earlier about whether you
24 should go to ultimate does not become a controlling
25 one. It is thrown out with the 2.4 functional, which is

1 based upon yield.

2 MR. MORRONE: Good point.

3 MR. OKRENT: Well, that is for some
4 applications; not for all.

5 MR. WARD: It is based upon yield for that one
6 particular piece of equipment.

7 MR. DICKSON: Well, that's right, but you see,
8 that is what is the controlling number. That goes right
9 on up to the top which limits the reserve seismic
10 capability for the whole plant.

11 MR. MORRONE: So we're saying let's take this
12 down to 2.4, then, and that would not affect this
13 reserve seismic capability.

14 MR. DICKSON: In that chart, only the minimum
15 is allowed to proceed on to the top; whatever is
16 limiting.

17 MR. OKRENT: Okay. Within that context. But
18 you have left an impression that there are some larger
19 margins on other things based upon the analysis.

20 MR. WARD: I guess the point is if one of the
21 other systems that was analyzed to ultimate, if it had
22 been analyzed to yield, it might have come out lower
23 than 2.4.

24 MR. DICKSON: That is possible. What he
25 looked at to yield were those that required

1 dimensionality in order to work, and the two he used
2 here were the EM pumps and the control rods.

3 MR. SIESS: Let me postulate something, the
4 answer to which might help me a little bit. Suppose now
5 you went about the design of this plant for seismic
6 excitation 2.4 times what it has been designed for in
7 the present SSE, but you allowed a criterion of no loss
8 of function. Would you make any changes in the design?

9 MR. OKRENT: Or in the tests.

10 MR. MORRONE: Now, as far as giving the
11 qualification by test, no. Changes in the design, I
12 would not think so. But remember, that we can do that
13 because of code requirements.

14 MR. SIESS: That was a postulation. It was a
15 way of looking at it. You are satisfied yourself now
16 that you can take 2.4 times the SSE with no loss of
17 function?

18 MR. MORRONE: No, I'm saying 2.4 times the
19 SSE, we will get malfunction, or it will start there.

20 MR. SIESS: But at 2.39 there would be no loss
21 of function?

22 MR. MORRONE: That is the bottom line.

23 MR. DICKSON: In all likelihood.

24 MR. MORRONE: I do believe that we have even
25 more than this because of this list of conservatisms.

1 (Slide.)

2 I will not go through all of this and take the
3 time. You have it in your handouts. I would just like
4 to highlight that the design of most equipment is
5 controlled by the OBE and not SSE. And again, the OBE
6 loads are greater than one-half of the SSE load. So
7 really, the margin that we had before, the reciprocal of
8 1.47, that is too low because under the SSE design,
9 we're below the code allowables, quite a bit below
10 because they were controlled by the OBE. And we have
11 all of these margins that really have not been
12 quantified.

13 So the 2.4 I believe is a good estimate and
14 not necessarily optimistic.

15 (Slide.)

16 So in conclusion, we have the CRBRP system.
17 For system equipment we have a structural reserve
18 seismic margin of 2.6 to 3.2, which when multiplied by
19 .25g gives us a reserve margin earthquake from .65g to
20 .8g. However, the functional reserve seismic margin is
21 2.4; therefore, the reserve margin earthquake is .6g.

22 For CRBRP buildings and structures, the
23 reserve seismic margin is 2.5 to 3.2, and the equivalent
24 reserve margin earthquake is from .62 to .80. The
25 conclusion, the bottom line, is that the CRBRP seismic

1 capability is at least .6g.

2 MR. OKRENT: Well, in the letter that the ACRS
3 wrote dated July 13, 1982, there, the last two
4 paragraphs read as follows, and I will just read them
5 and then comment.

6 "With regard to the seismic design of this
7 plant we believe it is important that the combination of
8 seismic design basis and margins and the seismic design
9 be such that this accident source represents the load
10 contributions to the overall loads of the plant. We
11 believe this matter will warrant detailed examination at
12 the construction permit stage to insure that necessary
13 margins are available for all important systems and
14 components.

15 "The NRC staff has concluded that the CRBR
16 plant can be designed and constructed in such a manner
17 that it will no greater risk to the health and safety of
18 the public than an LWR plant using current safety
19 criteria. We agree the proposed site is suitable for
20 such a plant."

21 Okay. Reading that leads me to request the
22 applicant and to the staff -- not to be answered today,
23 but I think, although your presentation is interesting,
24 I don't find myself able to digest it all, nor can I
25 take the set of viewgraphs and send it to appropriate

1 consultants and ask for a review as to its adequacy. So
2 in my opinion, this is an area that should be
3 documented, and with a chance for the ACRS to have it
4 looked at hard as to why what you say is adequate and
5 that your generic sampling is adequate as well as your
6 methodology and so forth for the purpose.

7 And again, I'm giving an individual opinion,
8 reading this letter and interpreting it I think in what
9 to me is a sort of straightforward way, and I think from
10 the staff at some point we need to hear why, in view of
11 what they now deem to be the margins for LWRs, in view
12 of what they can tell either qualitatively or
13 quantitatively, that the SSMRB program or so forth --
14 why, in this regard, Clinch River is equivalent to an
15 LWR, since in some of the recent LWR studies the seismic
16 is turning up as a non-unimportant contributor to risk.

17 And as an afterthought, it seems to me it
18 would be of some interest to see whether, -- without
19 asking the SSMRP program to try to analyze this, which
20 would be another two-year project or something --
21 whether what they have learned from what they have done
22 introduces any questions to be looked at for CRBR, that
23 perhaps you wouldn't look at without the benefit of
24 whatever comments they have.

25 MR. WARD: Is there a topical report on the

1 material which Mr. Morrone has covered?

2 MR. MORRONE: Not yet. We do have no report.
3 We have a 1977 report that discusses margin, but not
4 beyond the SSE.

5 MR. WARD: Is that report available, the 77
6 report?

7 MR. MORRONE: We've given it to the staff.

8 MR. DICKSON: Yes, the 77 report is available,
9 and basically, it describes the methodology and some of
10 the designs have changed.

11 MR. CARBON: Let me ask the applicant if it
12 clear to you what Dr. Okrent has asked and requested.

13 MR. GROSS: Well, let me try and take a stab
14 at that. I believe that what Dr. Okrent requested was a
15 report that describes in a little greater detail the
16 material which Mr. Morrone presented here today so that
17 he and some consultants could review it.

18 MR. OKRENT: Well, it is for you to judge what
19 you consider to be adequate to be responsive to the
20 issue. I wouldn't say specifically, it was a report
21 which covered only what was here, because that may not
22 be adequate for answering the question. The material
23 presented here.

24 In other words, as I indicated earlier, the
25 generic sampling itself has to be thought about and one

1 has to make a case for why it's adequate to the purpose.

2 MR. BENDER: Could I ask the staff whether it
3 agrees with the conclusions that have been drawn by the
4 applicant?

5 MR. STARK: I would try to answer that
6 indirectly. I was going to discuss this at the end of
7 this presentation anyway. But ACRS prepared a letter on
8 January 11th which the staff is reviewing right now
9 concerning this particular subject. And the staff has
10 prepared a formal response for it. I had an opportunity
11 to look at it briefly yesterday and it says basically,
12 they agree with the need to assess or produce additional
13 information in this area.

14 The staff, as far as Clinch River is concerned
15 -- I am going to give a little bit of an overview and
16 then at the end talk about some specifics for Clinch
17 River. The response that the staff has prepared for
18 this letter is saying that the staff and researchers are
19 proposing a seismic research plan to work on this
20 particular item.

21 In addition to this, the staff is talking
22 about the SSMRP program to see if it can be used or
23 modified to support this particular program. But in
24 general, the staff feels for Clinch River that the
25 structural and equipment design margins can be handled

1 on a generic basis, but it appears that the piping
2 design margins can't be handled generically. And it is
3 the piping design margins that we are looking at and
4 incorporating into our mechanical and materials review
5 for Clinch River.

6 So, the way I have answered it, I guess to
7 both of you but to Dr. Okrent, is that we hope we can
8 handle a large portion of it generically, but the piping
9 we feel we can't.

10 MR. OKRENT: Well, I am willing myself to have
11 someone make a case that there are some parts of this
12 plant that look enough like other plants that have been
13 analyzed, even though they are LWRs that you can draw
14 some general conclusions and so forth. And maybe it is
15 only the piping that is enough different. The piping is
16 clearly different, being thin-walled.

17 I myself haven't tried to look at other parts
18 to see whether there should be a few additional things
19 or many additional things that need their own look.
20 Maybe the piping may be able to stand up, but it should
21 be a considered judgment.

22 MR. EBERSOLE: Can I ask Ken a question? A
23 while ago I was searching for what I guessed might be
24 the Achilles heel of the shutdown heat removal process,
25 and I picked the batteries because that is where it is

1 in LWRs. In essence, the whole shutdown heat removal
2 process is propped up by the batteries.

3 I got the impression that you're better off
4 than they are. But I wonder, since I saw a few things
5 here and you mentioned about looking at the gauge glass
6 and I thought about what is getting the water to the
7 gauge and is it continuing to run, so unless you can
8 really show that you can, without benefit of DC,
9 continue the shutdown heat removal process, then we get
10 back to questioning what ought not to be as difficult a
11 design problem: the batteries in the DC systems.

12 There was an LER not long ago that said in
13 some plant and maybe more plants these critical cells
14 were simply spontaneously cracking. They didn't need an
15 earthquake; they were cracking while they were sitting
16 there. And the reason for that was that the structure
17 of the entire integrated cell was, of course, different
18 from that of an individual -- the entire battery,
19 rather, was different than an individual cell and they
20 were bolted together with rigid copper bus bars, and a
21 minute amount of deflection in these would simply crack
22 these brittle plastic or other brittle material cells,
23 and promptly create an open or short circuit and you
24 would lose the DC.

25 I only mention this as a point of fine detail

1 where unless you really cover it carefully, the whole
2 show is lost. So I will ask you again to either defend
3 that you can get along without the DC system or show
4 that you will always have it. And I suspect the latter
5 is going to be the case.

6 MR. DICKSON: I'm sorry, sir, you suspect the
7 latter is the case? That you would have to have the
8 batteries?

9 MR. EBERSOLE: I don't think you can get along
10 without it.

11 MR. DICKSON: For all design basis events we
12 have assumed the batteries are available. We have
13 considered what would happen if you lost the batteries,
14 and it can be operated manually.

15 Now, we have not done a detailed review to
16 determine just how long you have and what are the
17 resultant temperatures. But as was presented earlier,
18 the sodium in the system is fairly forgiving and it
19 absorbs a significant amount of heat. At one of the
20 earlier meetings you saw that we have considerably more
21 time than the light water reactor to respond so while we
22 have not done an analysis to look at it, I am reasonably
23 confident that if we did, we could show that two
24 operators could operate a shutdown heat removal system
25 without batteries, except in their flashlights and in

1 their walkie-talkies.

2 MR. EBERSOLE: I think that would be a major
3 showing if you could do that.

4 MR. REMICK: I have a question of the staff.
5 Are there, in the Commission's rules and regulations,
6 any requirement for design margin beyond the SSE for
7 CRBR?

8 MR. STARK: There are no regulations right now
9 beyond the SSE for any plant.

10 MR. REMICK: Light water, also?

11 MR. STARK: That's correct.

12 MR. REMICK: And so I'm not sure what this
13 exercise, other than being of interest in knowing, but
14 from a licensing standpoint, the importance of it if
15 that shutdown margin was 1.2 or 1; having certificates
16 from the licensee on the plant?

17 MR. STARK: As it stands right now, according
18 to the requirements it doesn't, but ACRS sent a letter
19 last month to the Commissioners who in turn sent it on
20 to the staff and we are assessing that and trying to
21 initiate new research programs and modify existing
22 research programs to look at this and attempt to address
23 it. But there are no regulations right now.

24 MR. REMICK: To try to get an understanding of
25 what shutdown margins might be?

1 MR. STARK: That's correct.

2 MR. OKRENT: If the staff stays with its
3 current approach -- in a sense one might say it's the
4 legal approach -- that they are faced with this big
5 problem of lots of reactors potentially being in the
6 same tectonic region that contained the Charleston
7 earthquake. I don't think they can live with the past.

8 MR. STARK: We also don't currently have a
9 good method to evaluate this particular margin, and know
10 that it is conservative and know that it is well tested
11 and well founded, also.

12 MR. SIESS: If the staff stays with the same
13 legal approach, the remedy is to raise the SSE to a
14 lower probability earthquake.

15 MR. OKRENT: But we've got a lot of reactors
16 that are sitting there.

17 MR. BENDER: I think the point I was going to
18 make is simply this. I'm not sure I would agree with
19 Dr. Okrent that we need to change the SSE, but even if
20 we did, it is not necessary to show that you can stand a
21 .6g.

22 MR. OKRENT: I wasn't suggesting we need to
23 change the SSE. From a safety point of view, I was
24 saying if you say there are certain legal requirements,
25 as in Appendix A, that they go by tectonic regions and

1 use the largest historic one and so on, it creates some
2 problems.

3 MR. BENDER: Well, it bothers me some that we
4 are trying to -- we have gotten ourselves wrapped up in
5 a legal question. And this is something that ought to
6 be dealt with in a technical way. And really, if the
7 staff has looked at the site enough to draw the
8 conclusion that there is no reason to change the SSE, I
9 think I would have to agree with Dr. Remick that we
10 surely ought not to waste any time trying. But if you
11 haven't reached that position, then we would like to
12 know what it is you are going to go to.

13 And that's the main reason, as I understood
14 it, that we put something in the letter to deal with
15 margins beyond the SSE. If you can really establish
16 that you've got the right number, it doesn't make sense
17 to start fighting for a bigger number. That is a
18 personal opinion.

19 MR. OKRENT: Well, Mike, I think there's
20 another interpretation to the letter, and in fact, it
21 doesn't say that the SSE should be larger. I think the
22 question is when you design for the SSE, whatever it is,
23 is the contribution to risk from earthquakes an
24 acceptably low portion of the overall risk and so
25 forth. That is not the same as saying designed for a

1 larger earthquake. And all of the rules and so forth.

2 MR. BENDER: I don't know what the statement
3 meant, and right now I guess I would like to know what
4 it is we're trying to get at. What do we want the staff
5 to do?

6 MR. STARK: Let me try it again. The staff
7 believes we would license the plant at 2.5g without a
8 requirement for additional seismic margins. We are,
9 however, openminded to the comment of ACRS, and ACRS has
10 been asking this question for a long time for a large
11 number of plants. And therefore, we are honestly
12 looking i to this particular area for additional
13 information to see what we should do wath it.

14 MR. SIESS: I don't see how the staff can talk
15 about additional seismic margin when they don't know
16 what the seismic margin is now. That is, you don't know
17 the return period of the SSE.

18 MR. KERR: Well, it might be that they have to
19 do this in order to carry on a conversation with the
20 ACRS, who keeps talking about additional seismic margins.

21 (Laughter.)

22 MR. CARBON: I wonder if we could move on.
23 Mr. Clare?

24 MR. CLARE: Yes.

25 (Slide.)

1 I'm George Clare with the Westinghouse Advance
2 Reactors Division. I do have a few comments to make
3 about seismic margins. Perhaps in light of the ongoing
4 discussion this is more of a footnote than anything of a
5 great amount of significance, but let me go ahead
6 anyway. It may help perhaps put a cap on some of the
7 discussion.

8 (Slide.)

9 I am not here to give you the results of any
10 independent assessment of seismic margins. The most
11 detailed look that we have is the one that Tony Morrone
12 just presented to you. However, we do have the benefit
13 of a compilation of studies that have been done over the
14 last 10 years or so of earthquakes in the Oak Ridge
15 area, and these have been plotted up on a particular
16 graph by some gentlemen at Oak Ridge National
17 Laboratory. Mr. Beavers, Mr. Manrod and Mr. Stoddart.

18 And without going into any detail, what you
19 can see from this particular viewgraph is that the range
20 of the studies over the last 10 years is consistent with
21 the conclusion that was drawn by USGS and cited by Mr.
22 Rothman earlier this morning that the .25g SSE chosen by
23 CRBRP would have a recurrence frequency on the order of
24 every 1000 to 10,000 years.

25 Now, the question is how does this relate to

1 what Mr. Morrone said a few minutes ago. And what he
2 said is that he thought, without being too detailed,
3 that the plant would be able to withstand an earthquake
4 on the order of two times the SSE peak ground
5 acceleration, and that would take us well beyond the
6 point where these curves are drawn, and it would take us
7 well above the once in every 10,000 years.

8 (Slide.)

9 The conclusions that we draw from that rather
10 simplistic look at things are, as I said, the recurrence
11 frequency of our SSE is 10^{-3} to 10^{-4} per year. The
12 earthquake with an acceleration twice that of the SSE
13 would have a recurrence frequency considerably less than
14 10^{-4} per year. And therefore, we think that is a good
15 kind of intuitive feeling for the risk we get from the
16 plant.

17 Now, in light of the questions that were
18 raised a few minutes ago, I can reflect a little bit on
19 studies that were done by the project several years
20 ago. And we did do some early risk assessments. They
21 were for a design other than the current design of the
22 plant, however, very similar designs.

23 And what we found, using the analysis
24 methodology that was used in WASH-1400 -- and we are
25 aware that there are some criticisms of that assessment

1 technology, but that was what we used. And in fact, the
2 likelihoods of earthquakes that were used in that study
3 were of the order of the midpoint of the spread of
4 data. What we found was that the risk from large
5 earthquakes was not insignificant, but was not the
6 dominant factor in the risk from the plant. It was a
7 significant contributor, but I believe the contribution
8 was less than 50 percent of the overall risk, and, of
9 course, that was broken into several categories and so
10 that is a little bit of a vague statement.

11 We know more about the plant today, both from
12 studies similar to the ones that Tony said, and most
13 particularly I would point out his comments on the
14 rupture discs in the intermediate heat transport system,
15 where we know a lot more today than we did back in 1976
16 when the earlier assessment was done. And in fact, that
17 would lead us to the conclusion that the seismic risk is
18 less than what was estimated in the earlier assessment.

19 The only other point is, of course, that we
20 are doing a PRA at this point in time. Really, we're
21 just getting started on it. It will be concluded
22 sometime in the next couple of years, and that
23 assessment will specifically include an assessment of
24 seismic risk. It will include the consideration of the
25 likelihood of the larger earthquakes as well as the

1 fragility of the equipment for such events. And that is
2 the situation we find ourselves in at this point in time.

3 MR. SIESS: Could you tell me who Wiggins is
4 on that chart?

5 MR. CLARE: J.H. Wiggins.

6 MR. SIESS: From California?

7 MR. CLARE: Yes. That's it.

8 MR. CARBON: Any further questions?

9 MR. OKRENT: Well, again, although I think it
10 will be helpful when the PRA is available, the design of
11 the plant can't be changed very readily as a result of
12 the PRA. I don't think it will be helpful to anyone if
13 a plant is built and there happen to be one or two
14 places in it that are less capable to withstand seismic
15 events than what has been estimated here. These turn
16 out to be rather important.

17 I might note a number like something smaller
18 than 10⁻⁴ per year is a pretty small number in some
19 contexts, but it is a pretty large number if you
20 envisage that you don't have containment integrity and
21 you have a serious accident. So one has to, again, look
22 more deeply into these numbers to see what their context
23 is.

24 I really think it is better to know more now
25 than to invite the kind of troubles that keep cropping

1 up in this area later.

2 MR. CARBON: Any other comments or questions?

3 If not, thank you, Mr. Clare. Let's move
4 right on.

5 MR. GROSS: Before we move to the next
6 subject, I wonder if we could ask for Mr. Newton of TVA
7 to come back. He has gotten some information which
8 responds to earlier questions.

9 (Slide.)

10 MR. NEWTON: The question that was raised was
11 around the question of how high was the head water level
12 and the sensitivity of our conclusions about the maximum
13 flood level at the site, and let me go through that.
14 The answer lies in the operations that we assumed.

15 MR. CARBON: Excuse me, just a second. Was
16 that in reference to Dr. Siess' question?

17 MR. NEWTON: No, it was in reference to your
18 question and Jesse Ebersole's question that raised a
19 question about the maximum flood level at the site.
20 There were two questions. It was the operability of the
21 gates, and Mr. Buchanan, in a minute, will tell you what
22 the backup system is.

23 The answer really lies in how we assume the
24 operation. And I know this is an extremely tall slide,
25 but basically, these are hydraulic lift gates so

1 normally they are in a down position. So that we have
2 an OG overflow crest and these hydraulic lift gates are
3 in the down position in a flood operation. And to
4 operate the gates we open a valve, run the water in and
5 lift these gates up. And we can lift them from a crest
6 elevation of 1020, so that it is up in a full position
7 with the top crest elevation at 1034. We raise the
8 gates.

9 In our flood operations in both the PMF and in
10 the one-half PMF -- remember, the one-half PMF goes with
11 the seismic OBE failure -- we have lifted the gates
12 deliberately to force the flood levels to the maximum
13 heights possible, because what we are doing is we are
14 utilizing the storage that we have. Norris Dam has a
15 tremendous amount of storage; it is safe against a PMF
16 so we are using it in these big floods, or we would use
17 it. They haven't happened yet.

18 We would use it in these big floods to
19 minimize the downstream impacts. We've got that
20 storage. So what we did postulate was an opening of the
21 gates, and we forced the heat water levels to the
22 maximum that they could be forced to. We couldn't get
23 it any higher than the 1035 that we use in our OBE
24 operations.

25 So the answer to your question is there is no

1 other operation. If the gates were not to operate, we
2 would assume they would be down in the closed position
3 and we would have passed more water and we wouldn't have
4 gotten that high. If they were to be opened and not be
5 operable, it doesn't make any difference because in
6 effect, that is what we have already assumed. We have
7 assumed that they are up. So that we do have the
8 maximum head water level in the PMF and in the OBEs, and
9 we think we are fully covered.

10 Now, I will let Mr. Buchanan answer the backup
11 system. Suppose we had to operate the gates --

12 MR. CARBON: Hold up a minute. Chet, does
13 that help you?

14 MR. SIESS: Well, it was Jesse's question.

15 MR. EBERSOLE: Yes, you answered my question.

16 MR. NEWTON: I just didn't remember those
17 details. These are our normal operating procedures
18 which we assumed, and that is what we assumed.

19 MR. EBERSOLE: Well, that's the most
20 pessimistic assumption you could make.

21 MR. NEWTON: That's right.

22 MR. MOELLER: Since you said the water raises
23 the gates, then these engines that Jesse was talking
24 about, are they to lower the gates?

25 MR. NEWTON: There is a hydraulic lift gate,

1 and we have to open up valves and let water in, and that
2 water lifts the gates.

3 MR. MOELLER: So is the power to open the
4 valves?

5 MR. NEWTON: It is the power to open them.
6 Mr. Buchanan can tell you about that and the backup
7 system.

8 MR. CARBON: Is there no further interest in
9 this?

10 MR. EBERSOLE: I have none. If he is already
11 in the worst configuration. I guess we can close it on
12 that.

13 MR. CARBON: Fine, thank you.

14 MR. NEWTON: We've got a backup system. It is
15 manual.

16 (Laughter.)

17 MR. CARBON: Thank you, Mr. Newton. Let's go
18 ahead, then. Mr. King?

19 MR. KING: I'm Tom King of the staff. We
20 actually have three speakers for Chapter 4. I will
21 introduce them. The first one is Ralph Baars of Los
22 Alamos National Laboratory and he will talk about the
23 mechanical design and the fuel blanket and control
24 assemblies. He was the primary reviewer and worked
25 under the direction of Mike Tokar of the Core

1 Performance Branch.

2 Following Ralph, Walter Brooks from the Core
3 Performance Branch will present our evaluation of the
4 electronics design, and following Walter I will present
5 the evaluation of the thermal hydraulic design.

6 We will start off with Ralph Baars.

7 (Slide.)

8 MR. BAARS: My name is Ralph Baars from Los
9 Alamos National Laboratory. As indicated by the last
10 bullet on the viewgraph, I was the reviewer of the fuel
11 system. This first viewgraph where we are enumerating
12 the scope of the review that was conducted, we looked at
13 the mechanical design of the fuel blanket and control
14 pins and assemblies, including the design criteria
15 limits, the design methods, the steady state conditions
16 and the transient conditions.

17 We reviewed the development testing plans,
18 including in-reactor, ex-reactor, steady state and
19 transient conditions. Can you hear me okay?

20 MR. SHEWMON: Sir, in your presentation
21 someplace will you get to a comparison between this and
22 the FFTF fuel or what the experience base of this fuel
23 is in use or would be in use?

24 MR. BAARS: I touch on it very briefly. I
25 didn't have anything specifically prepared as a direct

1 comparison. They are very similar systems.

2 MR. SHEWMON: Well, it seems to me that if one
3 takes an empirical approach, the proof is in the burning
4 or the heating or whatever the simile should be, and
5 therefore, I would be interested in hearing not only
6 what you did in your ab initio mechanical parts, but
7 indeed, how much you think we can rely on the experience
8 that has been developed in other people's radiation
9 experiments.

10 MR. BAARS: I think I will get into that later
11 on. I don't know whether what I have got is specific
12 enough for your satisfaction, but I will try to address
13 it.

14 MR. SHEWMON: Fine.

15 MR. SCHWALLIE: Sam Schwallie from
16 Westinghouse. In my presentation a little bit later I
17 can get into just exactly what he's talking about in
18 terms of geometric comparisons with FFTF as well as the
19 data base.

20 MR. BAARS: We do think that this is a rather
21 powerful favorable factor in favor of the CRBR system.

22 (Slide.)

23 For the means of guiding ourselves as to
24 adequacy of the fuel system, we adopted these acceptance
25 criteria. We looked at the conformance with the general

1 design criteria as they were modified to four LMFBRs,
2 this having been done in the first review on the CRBR.
3 In particular in this review, we were concerned with
4 what is the general design criterion 8 for reactor
5 design, and this was the one that specified acceptable
6 fuel design limits must be established and are to have
7 an adequate margin.

8 Secondly, we spent some time reviewing 4.2 of
9 the standard review plan for guidance in reviewing the
10 fuel system design, and we tried to stay fairly close to
11 the intent of that document. That, of course, is rather
12 specifically oriented toward LWRs, but we attempted to
13 comply with what we perceived as the intent.

14 Thirdly, we looked at the completeness and
15 adequacy of the applicant's design criteria limits, the
16 design methods and the conceptual design, and we
17 reviewed the development testing to support these
18 criteria limits and methods.

19 (Slide.)

20 This viewgraph identifies some of the
21 favorable factors that we see for the CRBR fuel system.
22 First of all, there is a massive test program that has
23 been conducted and is ongoing now and will continue. We
24 think that the results from these tests have shown that
25 we can expect there to be rather few failures to the

1 CRBR core exposure, which is what we've considered here.

2 I don't mean to say that there have been no
3 fuel failures in the test program. What I do mean here
4 is that the failures that have occurred have been almost
5 all related to factors that have nothing to do with
6 CRBR. In most cases, they are related to reconstitution
7 of test assemblies.

8 Secondly, the operation is far from coolant
9 saturation lessening the chance of cooling
10 discontinuities. Thirdly, the proposed scram trip
11 settings terminate abnormal occurrences far short of
12 significant fuel damage or disruption. Fourthly, we
13 feel that the relatively low smear density design of
14 CRBR fuel, 85 percent, 85 1/2 percent to be precise, is
15 about twice -- provides about twice the relative volume
16 to accommodate radial expansion, as is the case with LWR
17 fuel design.

18 MR. WARD: What is the definition of smear
19 density?

20 MR. BAARS: Smear density is simply what the
21 definition of the fuel would be if it was smeared out
22 completely throughout the volume available inside the
23 cladding.

24 MR. SHEWMON: In cross section, usually, is it
25 not?

1 MR. BAARS: Yes, that is correct. One minus
2 that number, or 100 minus that number would give you the
3 percent of the volume inside the cladding. That is not
4 actually dense fuel.

5 MR. WARD: So you're saying that it is a
6 similar number for LWR fuel, 93 percent?

7 MR. BAARS: Something like that. There are
8 fall back positions of reduced power exposure and
9 operating temperature available in the event of
10 significant problems involved in operation.

11 And finally, one of the more important factors
12 here, we are now beginning to accumulate data and will
13 have a substantial amount of data available on a very
14 similar system; namely, the FFTF fuel pin. It has the
15 same fuel density and has slightly less pellet density,
16 slightly smaller cladding gap and does not have axial
17 blankets. Apart from that, it is very nearly identical.

18 (Slide.)

19 We have identified some issues, and the first
20 one here is related to the criteria concerning the
21 coolable geometry limits. Before launching into the
22 details of this, I want to make sure to try to put this
23 in the best perspective that I can.

24 The fuel designs with the current scram trip
25 settings do not being to approach any challenge to

1 coolable geometry. We are concerned here strictly with
2 whether the coolable geometry limits themselves as
3 proposed by the applicant would do the job if they were
4 ever approached.

5 The first problem that we have here is
6 cladding melting and appears to be the basis for
7 assuring -- a lack of cladding melting appears to be the
8 basis for insuring against coolable geometry. Now, I've
9 called this a limit here; it is not, in fact, a limit.
10 As the applicant treats it, he, up until now, has not
11 been willing to regard that as a limit. That is a
12 somewhat abstruse point at this time because if we have
13 a limit, we have a problem with it.

14 First of all, we find no good basis provided
15 in the PSAR as to why simply avoidance of cladding
16 melting would insure coolable geometry. We did look at
17 some data, a small amount that was relevant and that we
18 had time to look at. We did not find evidence there
19 that either a ballooning or a gross slumping was likely
20 before you got right up to melting.

21 Nevertheless, we are dubious that any large
22 portion of the core could withstand extreme temperatures
23 of this sort without some impact on coolable geometry.
24 We strongly recommend that the applicant adopt a firm
25 cladding temperature as a coolable geometry limit, one

1 that would be well below melting, and for which he has
2 data that he can show that coolable geometry definitely
3 would not be affected, if that were observed.

4 MR. WARD: Is there any -- you say that they
5 have a cladding limit. Is there any monitoring of core
6 temperatures which will be helpful in precluding the
7 problem you're talking about?

8 MR. BAARS: There is outlet temperature
9 monitoring. I am not extremely familiar with it, but I
10 think it probably will be treated better in the later
11 presentations. The presentation on thermal hydraulics.
12 And possibly, the applicant will have some more
13 information on that.

14 Secondly, to assist in assuring the cladding
15 melting will not be reached, a no-boiling guideline is
16 used. This is a violable limit that is that boiling can
17 be exceeded in essentially screening criteria where
18 above boiling you would analyze further to determine
19 whether the cooling geometry would be compromised.

20 The operable thing here is the word "viable"
21 and we are concerned because we've got no information as
22 to how such cases would be evaluated or what sort of
23 criteria they would use to judge whether coolable
24 geometry would be compromised or not, and whether they
25 would address all the relevant phenomena.

1 These first two points I think primarily
2 relate to other cooling type transients. The third
3 point is that we don't believe that either cladding or
4 coolant temperature base limits are adequate of
5 themselves to guard against molten fuel expulsion, when
6 overpower conditions are present.

7 We feel that some limit more directly related
8 to overpower should be named here. We feel this has
9 some basis in the testing program in that the
10 unterminated transient overpower tests that have been
11 conducted, those in which molten fuel expulsion
12 occurred, almost all of them occurred with coolant
13 temperatures below boiling. And sometimes, at cladding
14 conditions that were within some of the cladding
15 temperature guidelines.

16 MR. CARBON: Excuse me, Mr. Baars. We seem to
17 be falling further and further behind, and I wonder if
18 you could speed up any.

19 MR. BAARS: Sure. At any rate, the applicants
20 here have committed to address all of these issues and
21 document a comprehensive basis for coolable geometry
22 limits by the time the FSAR is submitted.

23 (Slide.)

24 MR. CARBON: If you could wind up in five
25 minutes or something it would be very helpful.

1 MR. BAARS: I will do my best. This
2 enumerates, identifies the issues on methods that we
3 have. The applicant uses two models to evaluate fuel
4 performance. The cumulative damage function model,
5 commonly referred to as CDF, and the ductility limited
6 strain or DLS model.

7 The first one, the CDF model, is the more
8 sophisticated of the two. It uses realistic properties
9 and addresses things that are generally in a more
10 mechanistic fashion. The ductility limited strain model
11 is very much an empirical model. The problem we have
12 with the cumulative damage function is we feel the model
13 should be qualified to integral rod test data so as to
14 be sure to pick up any mechanisms that might be
15 operating that are modeled in the procedures for the
16 model.

17 Secondly, the model does not address the fuel
18 adjacency effect. I don't want to get into that. It
19 occurs when the cladding next to the fuel appears to be
20 more degraded than at the molten fuel. We feel at the
21 present time the model does not address that; at least,
22 the information available to us. And we feel that this
23 should be addressed. It is an important fact.

24 Finally, the statistical base does not cover
25 the data variance. This stems primarily because the

1 applicant wishes not to include the part of data
2 variance that is due to error in measurement, inability
3 to run identical tests, et cetera. We don't disagree
4 with this, but we feel the applicant should provide a
5 firm supportable basis for that amount of the data
6 variance, and to date he has not done so.

7 The ductility limited strain model is very
8 similar to the FFTF design procedure. There have been
9 some changes in the model, and we feel that it should be
10 requalified to the integral rod test data. The margin
11 to failure with this model we don't believe has really
12 been established. Some sort of means to quantify what
13 margin there is between what this model predicts and
14 what actually occurs we think should be enumerated.

15 The applicant has committed to address the CDF
16 issues by submittal of the FSAR. We have not
17 specifically asked him to sign on the dotted line as far
18 as the DLS model is concerned. We do say in the SER
19 that if he wishes to use the model for the FSAR, that we
20 think these issues should be addressed.

21 (Slide.)

22 This addresses some of the issues we have
23 identified for data base issues. This covers the
24 atypical factors, the coverage for operating range and
25 then some data in the cladding area. Again, I want to

1 put this in perspective. Many of these factors the
2 applicant agrees with. He has ongoing programs
3 addressing them. In some cases he has the data in hand,
4 although we have not seen it.

5 What we have attempted to do here primarily is
6 to provide a snapshot as to our view of what the status
7 of data is as of the information that was available to
8 us when we made the review. In particular, the item
9 here under cooling at the end of life and the response
10 to high fluence and high temperature, I believe he has
11 that in hand but has not relayed it to us. The atypical
12 factors are something that have hung around for a long
13 time and we feel they should be addressed so that the
14 perceived relevance of the data is not marred.

15 Under the coverage area there, virtually all
16 of the data base is 25 percent plutonium, and the CRBR
17 design value of plutonium content is 32 percent. So
18 there is some data available in this area that indicate
19 there aren't any great cliffs out there, but we feel
20 that a firmer data base is desirable.

21 Blanket rods -- we think there is not much
22 data, or there are not many tests that have been run.
23 There is no data that is available to us. There is an
24 extensive program plan to address this area,
25 particularly with the radiations in the FFTF.

1 Slow over power -- again, in the range from
2 the power to melt test up to the 50 cent per second
3 crack test, there is virtually no data at all as to the
4 mechanisms involved in a cladding breach. We feel quite
5 strongly about this, and the applicant does have an
6 ambitious program running in EBR-2 in a transient mode
7 to address this area.

8 Finally, on cladding, the fuel adjacency
9 effect, how much data is actually needed here I guess at
10 this point is problematical. There is a lot of
11 information available. I think it needs to be
12 integrated and put together, and perhaps at that time,
13 additional data might be needed.

14 (Slide.)

15 Our conclusion on the fuel system is that we
16 believe that prospects for success of the CRBR fuel
17 system justify issuance of a construction permit. We do
18 have a caveat here that, however, we feel that the
19 ability to clearly demonstrate acceptability of the
20 system for an operating license without resorting to
21 fallback positions depends upon addressing the
22 identified issues.

23 (Slide.)

24 Our basis for these conclusions includes the
25 previously-enumerated favorable factors. I think that

1 was about the third viewgraph I showed. Secondly, all
2 of the foregoing issues are primarily relevant to the
3 ability to evaluate fuel performance, and not to fuel
4 performance itself.

5 Thirdly, the programs are underway or have
6 been committed by the applicant to resolve the issues by
7 FSAR submittal, and the final point is we believe that
8 the availability of fallback positions allows deferral
9 of resolution to the FSAR. And that concludes my
10 prepared presentation.

11 MR. SHEWMON: Before you got into controlled
12 ramps, when you talked about failure you were talking
13 then about rupture of the cladding during normal
14 operation. Is that what you were judging against when
15 you talked about failure margins or probabilities or
16 whatever?

17 MR. BAARS: That was with the CDF model under
18 the fuel evaluation models.

19 MR. SHEWMON: When you talked about failure I
20 didn't know what you were talking about and I'm asking
21 what you meant.

22 MR. BAARS: I'm talking about failure of the
23 cladding.

24 MR. SHEWMON: So it is rupture of the cladding.

25 MR. BAARS: That's correct.

1 MR. SHEWMON: What is the predicted or
2 expected life that you judged against? There was
3 something in here.

4 MR. BAARS: What was the goal that I judged it
5 against? 80,000 megawatt days per ton.

6 MR. SHEWMON: Okay. And the control material
7 which you mentioned -- I didn't hear it -- is boron
8 carbide? Pellets and stainless steel?

9 MR. BENDER: That's correct. It is in
10 pellets. They're in stainless steel, relatively a half
11 an inch in diameter or larger.

12 MR. SHEWMON: And the blanket is UO2
13 unenriched?

14 MR. BAARS: That is correct. Those are also
15 relatively large pins. There are 61 pin bundles. I can
16 show some of these.

17 MR. SHEWMON: I will take your word for it.

18 MR. BAARS: Yes, they are 61-pin bundles.
19 They are in exactly the same duct as the fuel assemblies
20 are installed in. The fuel assemblies are 217-pin. The
21 absorber assemblies, the primary controls, are, I
22 believe, 39-pin assemblies, and the secondary control
23 systems are 31-pin assemblies.

24 MR. SHEWMON: Fine, thank you.

25 MR. CARBON: Other questions?

1 (No response.)

2 Thank you, Mr. Baars. Let's move on, then.

3 Mr. Brooks?

4 MR. BROOKS: My name is Walter Brooks and I am
5 with the Core Performance Branch at NRC. And I will
6 discuss --

7 (Slide.)

8 --the section 4.3, which is nuclear design of
9 the PSAR, or the SER. And I will discuss the design
10 bases including development of the principal design
11 criteria, the design description which I will describe
12 only very briefly because it will be described in
13 considerable detail later by the applicant. I will talk
14 a little bit about the reactivity coefficients and, as
15 you see, power distributions, reactivity coefficients,
16 et cetera.

17 I should say that the nuclear design portion
18 of the safety evaluation report was based on a technical
19 evaluation that was prepared by Los Alamos Laboratories,
20 and one of the preparers of that report, Mr. Kinman, is
21 with us today in case you have detailed technical
22 questions, the answers to which I might not know. He is
23 prepared to answer questions.

24 The Core Performance Branch then took that
25 technical evaluation report and prepared the safety

1 evaluation report from it, putting it in the terms of
2 the various requirements and meeting those requirements.

3 (Slide.)

4 The next slide shows the principal design
5 criteria affecting the core, and some of these, of
6 course, you recognize. The PDC-8 is the one that was
7 just talked about with the fuel and specified acceptable
8 design limits. And the rest of these -- that is the
9 list. I will talk about them independently as I go down
10 through the subjects. We don't need to spend anymore
11 time on this, since we are in a hurry.

12 (Slide.)

13 What I will show next is a core layout, and
14 this, again, will be presented and discussed in
15 considerable detail by the applicant. I would just like
16 to point out the control systems. There are two control
17 systems, two scram system. Both a primary control
18 system and a secondary control system. The primary
19 control system consists of these three assemblies in
20 what is called row 4 on the corners, and the six
21 assemblies on the corners of row 7.

22 So there are a total of 9 control assemblies
23 that make up the primary control system. There are 6
24 which are on the flat of row 7. These make up the
25 secondary control system. And there is another

1 interesting part in here; there are 3 more -- I'm sorry,
2 there are 6 more. There are 6 assemblies here that
3 start life as blanket assemblies and stay in the reactor
4 for a year as blanket assemblies and then are
5 transferred like Cinderella's pumpkin into a fuel
6 assembly to extend their life for another year.

7 MR. BENDER: Have you prescribed any mode of
8 control here? Is there a modal control specified?

9 MR. BROOKS: A mode of control?

10 MR. BENDER: Yes. That rods have to move
11 collectively or separately or some such thing as that.

12 MR. BROOKS: That has been prescribed, and I
13 think the applicant will probably discuss that. But let
14 me say what is. The secondary scram rods are removed
15 from the core. The three primary scram rods in the
16 center of the core. The row 4 rods are also parked
17 above the core during operation. Operational control of
18 the plant is then obtained from the six other primary
19 control rods which are partially in the core during
20 operation.

21 These are operated, as I understand the
22 system, they are each operated separately but they are
23 constrained to be within a very short distance of each
24 other. That is to say, they do not get lifted as a
25 bank, but they must be banked.

1 MR. BENDER: guess I was leading into a
2 question. Does the staff try to put any limits on
3 variations in the rod behavior within that bank, or are
4 you relying on the applicant to tell you what he's doing?

5 MR. BROOKS: We would have no restrictions.
6 Well, let me say it a different way. We would permit
7 anything as long as he didn't violate his fuel limit,
8 His linear heat generation limits.

9 MR. BENDER: So you would correlate this with
10 the previous information regarding the thermal
11 performance of the fuel? Is that what we are hearing?

12 MR. BROOKS: What we will come down to in a
13 bit --

14 MR. BENDER: Maybe I ought t wait, I'm sorry.

15 MR. BROOKS: Well, I just wanted to point out
16 the control systems, and there will be considerably more
17 detailed information later.

18 (Slide.)

19 Now, let me talk a little bit about the
20 relevant criteria to the reactivity control system.
21 These are, as you see, 23, 24, 25, 57 and 58. Now, 23
22 is the criterion which states that SAFCO shall not be
23 exceeded for the reactivity control system. This is the
24 so-called single failure; that is, any single
25 malfunction.

1 24, which requires two independent systems,
2 that one has to protect against SAFCOs in normal
3 operation, and anticipated operational occurrences. The
4 other of which must protect, must assure the ability to
5 cool the core in the event of such an occurrence.

6 These systems, both systems, have to have
7 sufficient reactivity worth in order to hold the core
8 subcritical at the hot shutdown state, with a stuck
9 rod. Each system must independently be able to do this
10 in the absence of the other system, and in the presence
11 of a stuck rod in the system. And then, one of the
12 systems has to be capable of taking it all away to
13 refueling temperatures.

14 PDC-25 requires both systems to maintain the
15 capability to cool the core under accident conditions.
16 And also, you assume a stuck rod for that case, also.
17 And PDC-57 requires that the reactivity control system
18 be designed so that reactivity insertion rates and
19 amounts are limited -- the amounts are limited to
20 preclude significant damage to the core boundary or loss
21 of ability to cool the core.

22 Criterion 58 requires that the systems be
23 designed to be highly reliable. Mostly, that is -- that
24 criterion will be discussed further when we get around
25 to talk about the control systems themselves, and I

1 won't say anymore about it.

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

1 The design bases that the Applicant derived
2 from these criteria will be discussed later by the
3 Applicant, and I will merely say that it is the Staff
4 judgment that the design bases that were chosen by the
5 Applicant meet these criteria.

6 Now, the rod worths that were calculated by
7 two-dimensional diffusion theory code, which actually
8 all of the effects were treated by use of the buckling
9 turn, and this is the sort of procedure that is standard
10 and is acceptable if properly verified. The Applicants
11 have verified these calculations against a number of
12 critical experiments in the ZPTR series.

13 We have some concern that the experiments for
14 which we so far have data have not been terribly close,
15 and a number of them are homogenous core experiments,
16 and there has been one pre-engineering mockup. So we
17 have some concern about the fine-tuning the methods, but
18 the Applicant has committed to perform experiments and I
19 think probably has already performed them, but to
20 document the results for the FSAR review.

21 As far as the results of the calculations are
22 concerned, the results in the PSAR showed that in fact
23 the systems do meet the shutdown requirements with an
24 additional margin of more than a dollar at the worst
25 case.

1 MR. OKRENT: That's not very much reactivity.

2 MR. BROOKS: No. It is not one percent, but
3 it is like half a percent.

4 MR. OKRENT: Is there any U-275 in this?

5 MR. BROOKS: There is very little. The beta
6 is 0034.

7 MR. RAY: Is this in 1967 or in 1983 dollars?

8 (Laughter.)

9 MR. OKRENT: It is a U-238 dollar.

10 (Laughter.)

11 MR. BROOKS: With regard to PDC-57 which
12 requires that the reactivity insertion limits be
13 limited, the Applicant has looked at the case where the
14 rods go out the fastest they can; that is to say, they
15 go out at some, as I recall at 35 or 37 inches per
16 second or something of that nature when the roller nuts
17 spring off by centrifugal force and drop the rods, so
18 that's as fast as you can move them. And have shown
19 that they still have plenty of margin to core
20 coolability.

21 MR. CARBON: If we could try and wind up in
22 about five minutes.

23 MR. BROOKS: Yes. The power distributions are
24 used here --

25 Well, let me then take the next slide.

1 (Slide.)

2 Here the power distribution and
3 instrumentation, the relevant criteria with respect to
4 these things are 8, 11 and 18. Criterion 8 requires
5 that the reactor and associated coolant and protection
6 system be designed to assure that SAFCOs are not
7 exceeded during normal operation or anticipated
8 operational occurrences.

9 Now, the design basis that has been used to
10 meet this requirement is that incipient fuel melting
11 shall not occur under these conditions -- that is to
12 say, normal operation -- and anticipated operational
13 occurrences. And specifically what they have done is to
14 take 15 percent over power conditions and include three
15 signal uncertainties.

16 Now, as you have heard earlier, incipient,
17 because this coolant is so far from saturation,
18 incipient fuel melting is the thing you get first. So
19 this is an appropriate criterion to use here for SAFCOs.

20 The Applicant has set design limits, linear
21 heat generation design limits of 16 kilowatts per foot
22 on the fuel and 20 kilowatts per foot in the blanket,
23 and the arrangement of the fuel and the blanket
24 assemblies has been chosen to meet these conditions. So
25 that as the plant progresses through life with different

1 control rod positions and so forth, you always need the
2 16b kilowatts per foot; and they have shown, given part
3 of the distribution values for this six cycles, and
4 shown that they meet these limits.

5 Now, the prior distributions again are
6 performed by the 2D-2D synthesis method, which is again
7 a technique which is used for light-water reactors and
8 is acceptable if it is properly verified. And here
9 again, they have verification that has been performed of
10 the synthesis, but here again not for the engineering
11 mockup critical. And again, the Applicant has committed
12 to perform these tests and document them for the FSAR
13 review.

14 Our Criterion 11 requires that instrumentation
15 be provided to monitor the core variables over the range
16 of operation for normal operation occurrences, normal
17 operation anticipated occurrences and postulated
18 accidents in order to assure adequate safety.

19 MR. CARBON: Mr. Brooks, could you simply go
20 to your results and conclusions? Just take up your
21 results and conclusions on these.

22 MR. BROOKS: All right.

23 Then let me the make an overall conclusion. I
24 won't go through the rest of these individual subjects.
25 Let me make an overall conclusion.

1 Our overall conclusion is that we believe that
2 the nuclear design of the core meets the requirements of
3 the criteria that are listed here. What we will require
4 and the Applicants have committed to do is more
5 verification of their methods and some more
6 documentation of their methods so that these can be
7 reviewed in the FSAR. That is the thrust.

8 MR. CARBON: But you anticipate no particular
9 problems?

10 MR. BROOKS: We anticipate no particular
11 problems. We think that there may be small differences
12 as a result of the new critical experiments that will be
13 performed, but we don't anticipate any problems.

14 MR. CARBON: Fine.

15 Are there questions?

16 (No response.)

17 MR. CARBON: Thank you.

18 Let's move on to Mr. King.

19 And, Mr. King, could you try and wind up by

20 1:15?

21 MR. KING: I will try and wind up before that.

22 (Slide.)

23 My name is Tom King, and I am with the Program
24 Office in NRR, and I will just run through quickly the
25 scope of our review.

1 What it involved was a thermal hydraulic
2 design of all the in-vessel components. We looked at
3 the criteria, the design methods for both steady state
4 and transient conditions. We looked at the development
5 testing done and startup testing planned, and we had
6 help. We had Brookhaven and Argonne National
7 Laboratories do some independent calculations for us to
8 overcheck some of the Applicant's analysis, and we had
9 Wolfgang Barthold of Barthold and Associates do an
10 independent review of the thermal hydraulic design.

11 (Slide.)

12 Briefly, our acceptance criteria were
13 conformance with two principal design criteria: the one
14 on reactor design and the one on flow blockage;
15 conformance with the applicable sections of the standard
16 review plan on thermal hydraulic design.

17 We looked generally at the completeness and
18 adequacy of the Applicant's design criteria methods and
19 design, and the same thing for his development testing.
20 And as I mentioned, we did some confirmatory analysis to
21 overcheck the results, the Applicant's results, in what
22 we felt were some of the critical areas of thermal
23 hydraulic design. And I will talk about those in a
24 little bit more detail.

25 (Slide.)

1 The major safety features that we considered
2 the design has is it provides for decay heat removal via
3 natural circulation. It prevents gas entrainment in the
4 reactor vessel by venting potential collection areas and
5 providing a suppressor plate at the top of the upper
6 plenum. It minimizes the potential for flow blockage
7 via several features incorporated in the design:
8 multiple flow paths at the inlet strainer, wide openings
9 at the bottom of the assembly to allow for any axial
10 motion of the assembly. It provides monitoring
11 instrumentation for core assembly outlet temperatures.

12 Someone had a question on that earlier. That
13 is not safety grade instrumentation. It is not part of
14 the plant protection system, but it does provide pretty
15 thorough coverage of the core outlet temperatures.

16 (Slide.)

17 MR. WARD: Does that monitoring permit, for
18 example, recognition that a fuel element might be
19 swelling; there might be clad ballooning before there is
20 failure of the clad?

21 MR. KING: Only if there was swelling due to
22 overtemperature. If the swelling was not resulting in
23 some out of normal temperature, it would not tell you
24 that.

25 MR. WARD: But I mean will the swelling

1 introduce enough change, the swelling itself be a cause
2 of change in coolant temperatures?

3 MR. KING: Theoretically, if you get enough
4 swelling and it started to cut off flow through the
5 assembly, you would notice the outlet temperature drop.

6 MR. WARD: That is what I mean. Does that
7 system -- can it be expected to detect serious fuel
8 swelling before there is failure of the cladding in an
9 individual fuel element?

10 MR. KING: If you had serious fuel swelling
11 that was causing flow starvation, it would tell you that
12 that was happening. Whether or not you would get
13 cladding failure before you got to the point where the
14 thermocouples were detected, I don't know.

15 MR. CARBON: Dave, there are not thermocouples
16 on all channels.

17 MR. KING: There are on most channels. For
18 the fuel and inner blanket there are only about 12
19 positions out of about 170 that do not have
20 thermocouples.

21 This is the second half of that slide on what
22 we consider important features. The design requirements
23 require prevention of control rod flotation during
24 refueling due to inadvertent start of the primary
25 pumps. The design requirements for the thermal

1 hydraulic design requirements are based upon being able
2 to meet all of the structural temperature requirements
3 of the in-vessel components: the fuel blankets, the
4 permanent core support structure, upper internal
5 structure, pipe components, and the new orificing design
6 of the fuel and blanket control assemblies provides
7 shielding to the core support structure.

8 (Slide.)

9 Resulting from our review were four areas that
10 we had some concern in that we consider to be acceptable
11 for resolution during final design, and these are the
12 margin of flotation on the primary control rods. We're
13 not satisfied that there is enough margin. Since it is
14 a replaceable component, we consider resolution of that
15 issue as part of final design acceptable.

16 In the FFTF operation, cycle 1, they observed
17 a delta P increase of approximately 4. We don't know
18 what the cause of that was or what the implications are
19 on CRBF design, but that will be something that will
20 have to be resolved as part of the final design and
21 factored into the design.

22 MR. OKRENT: How much?

23 MR. KING: Sixteen psi.

24 MR. OKRENT: Out of what?

25 MR. KING: Out of roughly 120. Again, we

1 consider that adequate for resolution during final
2 design because there are fallbacks to reduce power,
3 reduce flow, reduce burnup.

4 The latest power-to-melt data from FFTF
5 testing needs to be factored into the final design, and
6 we had some questions on the application of hot channel
7 factors, primarily in -- well, one in the natural
8 circulation area for which high channel factors should
9 be used, and then in the normal steady state operation.

10 The uncertainty is on the hot channel factors
11 and the fact that they're being applied in a linear
12 fashion. Again, we feel the Applicant has committed to
13 address our concerns in that area as part of final
14 design, and we feel that is adequate.

15 (Slide.)

16 I mentioned our overcheck calculations done by
17 Brookhaven and Argonne. Just briefly what was done is
18 we have done overchecks of steady state full power core
19 conditions, the natural circulation condition, the DHRS
20 flow, which is the direct heat removal system. Our
21 concern there was what the in-vessel thermal hydraulics
22 were like. And we are continuing even beyond the CP
23 stage to do some more work in that area, independently
24 looking at primarily sensitivity of these various
25 calculations to changes in what we consider key

1 parameters, trying to find out really what are the key
2 parameters.

3 The results of our independent calculations,
4 we didn't look for exact agreement with the Applicant,
5 but we wanted to see if we independently calculated the
6 design criteria he met and see if we came up with the
7 same trend for the transient that the Applicant did.

8 (Slide.)

9 And this is our overcheck using the
10 supersystems code by Brookhaven on the natural
11 circulation case station blackout, and we got very good
12 agreement between SSC and what the Applicant was
13 proposing.

14 MR. CARBON: Have both those codes been
15 benchmarked against the FFTF results such that you would
16 expect them to agree?

17 MR. KING: They have been checked against
18 FFTF. They have not been changed to exactly fit FFTF,
19 but they were checked to verify that they predict actual
20 in-reactor data.

21 MR. CARBON: Were they changed to some extent?

22 MR. KING: I will ask. Jim Guppie is here
23 from Brookhaven. I will ask him to comment on that
24 since he's the one that did the calculations.

25 MR. GUPPIE: I'm Jim Guppie from Brookhaven

1 National Labs talking for the SSC calculations.

2 We have not fully completed our FFTV
3 validation studies, but we have done analyses
4 comparisons out to say five or six minutes into the
5 various transients at 175 percent, 35 and 5 percent
6 power. What is done is the modeling is not changed.
7 However, the input, the geometric description for SSC is
8 then appropriately changed to simulate the FFTF plant.

9 And when we did that and ran comparisons,
10 having then known after the fact what the power levels
11 were and the power history so that you can better
12 determine what the decay heating is and so on and so
13 forth, our comparisons were fairly reasonable with the
14 plant data.

15 MR. CARBON: All right.

16 (Slide.)

17 MR. KING: We had similar calculations done by
18 the COMMIX code at Argonne, and this is just one example
19 to give you a feel for the kind of comparison we're
20 getting between COMMIX and the Applicant, which is
21 called ARD-308 here.

22 (Slide.)

23 I will skip some of these in the interest of
24 time.

25 On the DHRS operation we had concern about the

1 in-vessel thermal hydraulics; that since the inlet and
2 outlet lines of the DHRS were basically the same
3 elevation and were not too far apart, were we going to
4 get any short-circuiting.

5 (Slide.)

6 And not remove heat but have incoming flow go
7 right out the outlet line.

8 We had run a calculation using the same
9 assumptions the Applicant had used on short-circuiting
10 and came up with this comparison of prediction of what's
11 going to happen to in-vessel temperatures under a 20
12 percent short-circuiting, and then it showed the SSC
13 predicts fairly well what the Applicant predicts.

14 (Slide.)

15 We also did a little sensitivity calculation
16 to show if the short-circuiting were higher or lower,
17 how that would affect temperatures. The middle curve is
18 the nominal case, the one the Applicant used, and that
19 corresponds to 20 percent short-circuiting. And as you
20 get more and more short-circuiting, your temperatures go
21 up.

22 COMMIX is a very detailed in-vessel thermal
23 hydraulics code, and we did a calculation to try to get
24 a better handle on what kind of short-circuiting did we
25 really have, and we just got some results this week, and

1 it really indicates the short-circuiting is very close
2 to zero, and it's going to be very close to what is
3 represented by the bottom line.

4 (Slide.)

5 Our conclusion basically is that the design
6 has a high probability of meeting the design criteria.
7 There are fallbacks of reduced power, flow or burnup if
8 complications arise during final design. We consider
9 the design acceptable for ACP, and the basis for these
10 conclusions --

11 (Slide.)

12 -- Are what we consider the incorporation of
13 the significant safety features, the fact that the
14 Applicant has significant test program, development test
15 program to support the thermal hydraulic design, both
16 full-scale tests, sodium and water, on assemblies and
17 scale models of in-vessel geometry.

18 The FFTF fuel design and the in-vessel thermal
19 hydraulic design is similar to CRBR, and we would
20 consider continued FFTF operations certainly would give
21 us useful information and would apply to CRBR. And we
22 consider the independent calculations that we have done
23 so far confirm that the Applicant's design will meet the
24 design criteria. And the Applicant has committed to
25 testing during initial startup to confirm natural

1 circulation and to confirm DHRS performance, and to
2 measure in-vessel temperatures and vibrations as part of
3 the startup program.

4 And the preliminary safety analysis we feel
5 has been done with all or a lot of conservatisms that
6 result in conservative predictions.

7 MR. BENDER: Have you tried to compare what
8 has been done for CRBR with what was done for PHOENIX?

9 MR. KING: In terms of the development testing?

10 MR. BENDER: Was the same kind of confirmation
11 program used of the design?

12 MR. KING: I have not tried to make that
13 comparison.

14 MR. BENDER: Just as a frame of reference, it
15 seems to me like there would be some advantage in seeing
16 what a successful reactor system has used, if that one
17 is said to be successful, because we don't have a lot of
18 experience.

19 MR. KING: It is very similar to FFTF. I have
20 made that comparison. It is very similar in terms of
21 the analysis method, the development testing, and the
22 design; and in fact, there is probably more being done
23 in Clinch River than there was in FFTF.

24 MR. BENDER: Well, that is a good frame of
25 reference.

1 MR. EBERSOLE: Is the FFTF cooled by liquid
2 water in the final sense?

3 MR. KING: FFTF is sodium cooled, and the heat
4 is dumped directly from an intermediate sodium system to
5 the air through an air blast heat exchanger.

6 MR. EBERSOLE: I was really getting around to
7 this. What is the practical consequence of rupturing a
8 steam tube in this plant? Well, I guess one way to
9 express it, how long a shutdown would that produce if
10 you burst a steam tube in the steam generator?

11 MR. KING: I can't answer that.

12 MR. EBERSOLE: Would it be a year for heaven's
13 sakes?

14 MR. KING: I would have to ask the Applicant.

15 MR. DICKSON: We're going to go into that
16 later in the presentation.

17 MR. KING: That concludes what I had to say.

18 MR. CARBON: Are there other questions?

19 (No response.)

20 MR. CARBON: Fine. Thank you, Mr. King.

21 Before turning the session back to the
22 Chairman, let me introduce Dr. Grace, who is with us
23 today. Dr. Nelson Grace, who is replacing Paul Check as
24 the director of the CRBR Project Office.

25 I might just comment that he used to be with

1 FFTF and then strayed into the fusion field and is now
2 back home.

3 Mr. Chairman, it's back to you.

4 MR. RAY: I would adjourn now for lunch and
5 with the understanding we will be back at 2:15.

6 (Whereupon, at 1:5 p.m., the meeting was
7 recessed for lunch, to be reconvened at 2:15 p.m., the
8 same day.)

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

1 AFTERNOON SESSION

2 (2:15 p.m.)

3 MR. RAY: The meeting will resume, and Dr.
4 Carbon will chair it.

5 MR. CARBON: And we will move on with Mr.
6 Baloh.

7 MR. VIJUK: I'm Bob Vijuk rather than Frank
8 Baloh. The reactor portion of the agenda will be
9 covered as shown on this vu-graph. Frank Baloh will
10 talk about the reactor vessel and internals -- that is,
11 everything other than the reactor core -- and then we
12 will discuss the reactor core in three parts: the
13 nuclear design, thermal hydraulic design, and finally
14 the mechanical and structural design and the fuel and
15 blanket assemblies.

16 Our plan is to spend about a half hour in each
17 area unless you would like us to alter it. We intend to
18 tell you -- to describe the design to you and tell you
19 the basis for the design. We intend to describe the
20 design and tell you the basis for the design, but we
21 want to focus on the development testing that we have
22 done to either demonstrate features of the design or the
23 performance of the total design.

24 You will see that the state we are in is very
25 different as we move through here. Most of this part of

1 the reactor is either totally fabricated or well along
2 in the fabrication. Then in the core areas you will see
3 that all of the development programs are essentially
4 done, and we will present you some data that is not in
5 the PSAR on criticals, but work has been completed. So
6 the Staff did not have the benefit of that in their
7 review.

8 In the thermal hydraulic area we are almost
9 done with testing, and we will show you some -- what
10 that program looked like. In the fuel and blanket area
11 there is much testing that is still in progress, largely
12 in FFTF, and you will be told what that is going to be.
13 So our focus is to show you how we demonstrate or will
14 demonstrate that the design will do its job.

15 With that, unless you want us to revise our
16 plan, we will move right into reactor internals.

17 (Slide.)

18 MR. BALOH: Okay. As Bob has said, what I am
19 going to be doing is giving you a brief description of
20 the reactor enclosure.

21 MR. CARBON: Mr. Baloh, could you sort of
22 stand aside if possible?

23 MR. BALOH: I'm going to be describing the
24 reactor enclosure which includes the enclosure head, the
25 vessel, the lower internals, which includes all of the

1 permanent structures other than the core removal
2 components which will be discussed later, and then
3 finally the upper internal structure itself.

4 (Slide.)

5 This is an isometric of the reactor vessel
6 closure head. It is approximately 21 feet in diameter
7 by about 13 feet high, and in its normal operating
8 condition weighs about a million pounds. When it's
9 configured for refueling it will be up to about a
10 million and a half.

11 Characteristics that distinguish it are the
12 three rotating plugs. That configuration is to support
13 the refueling operation. The in-vessel handling machine
14 would be mounted on the nozzle you see here on the small
15 rotating plug, and by rotating the intermediate plug you
16 can envision being able to locate over any radial
17 location of the core. The core is directly below these
18 control rod drive mechanism nozzles that you see here;
19 so with the rotation of the IRP one would be able to
20 locate this radially over any location, and then by
21 rotation of the large plug hit any of these
22 circumventional locations at that radius.

23 These operations would be done in parallel.
24 It wouldn't be necessary to sequence one to the other.
25 The nozzles you see here are support nozzles for the

1 upper internal structures which I will describe briefly
2 later. The head structure itself is mainly carbon
3 steel. These 22-inch plugs that you see on the top,
4 there are three plugs that are nested. They are
5 effectively the same composition all the way down, but
6 they are separated obviously so that they can rotate.

7 Each of the plugs are suspended from what we
8 call riser assemblies. These are cylindrical shells
9 that attach to the plugs and then have a flange on the
10 top to which a bearing assembly which has an integral
11 bull gear attached to it driven by the plug drives for
12 the refueling operation.

13 The temperatures of the plugs themselves are
14 kept uniformly at 400 degrees throughout both operation
15 and refueling to assure consistent alignment at all
16 times. The main function of the risers is to reduce
17 that temperature down to a maximum of 125 up in this
18 area where there are some elastomer seals and the
19 bearing.

20 The primary separator for the cover gas is a
21 dip seal. That exists between each of the plugs and
22 also between the outer plug and the flange of the
23 vessel.

24 MR. CARBON: Is the entire cooling by gas?

25 MR. BALOH: Cooling of what?

1 MR. CARBON: The what.

2 MR. BALOH: No. There are head heaters. As
3 you can see here, during normal operation approximately
4 half the heat is supplied from the reactor itself, the
5 other half from these electrically controlled -- they
6 are on a control system. There is also a forced
7 circulation so that the entire head access area is
8 available for manned access at all times. We predict
9 less than 5 MR per hour during operation in this area.
10 The design requirement is 25 MR per hour in that area,
11 and it has got a nominal temperature of about 80 degrees
12 in that location.

13 MR. EBERSOLE: We were talking earlier about
14 the loss of power. Are there any cases where loss of
15 power would affect these artificial heating systems that
16 keep the sodium liquid below the dip seal sodium -- any
17 sodium anywhere, including impulse lines or whatever?

18 MR. BALOH: I don't think there is any
19 concern. If the reactor was critical, obviously loss of
20 power would shut you down. You would then have natural
21 circulation set up.

22 MR. EBERSOLE: No. I don't mean that. I mean
23 are there other places in the circuit where one must fit
24 in artificial heat at all times to keep it liquid?

25 MR. BALOH: No. In fact, the heating of the

1 head itself is to maintain consistent alignment. It is
2 not directly a safety consideration. And you could lose
3 all of these heaters, and it would not prevent shutdown
4 or anything of that nature.

5 MR. CARBON: To understand this, does the
6 reactor vessel support ring more or less rest on the
7 platform, the floor?

8 MR. BALOH: The outer -- you'll see a little
9 bit later when I show an isometric of the vessel there
10 is a ledge here that the outer ring is mounted to, and
11 then it goes up through the outer assembly, and that is
12 --

13 MR. CARBON: Well, in effect, the head
14 assembly sits in.

15 MR. BALOH: That's right. There's an annulus
16 here between the riser assembly and the vessel flange.
17 There are three shield plates that are between nine and
18 ten inches depending upon which one in thickness down to
19 this location. We're talking all carbon steel
20 material. On the lower shield plate we have suspended
21 -- and this picture doesn't show it -- these are
22 subassemblies of reflector plates that provide reflected
23 insulation. There is somewhat over 300 degree
24 temperature.

25 MR. ETHERINGTON: I'm missing something

1 somewhere. You mentioned heating. Isn't this cooling
2 during operation?

3 MR. BALOH: No. We're heating to maintain
4 uniformity of temperature.

5 MR. ETHERINGTON: But why did it need to be
6 heated? Is it losing temperature below? There would be
7 a gradient across it if we did not heat it, and there
8 would be gradients set up. What we're doing is
9 maintaining uniformity. We're actually maintaining
10 within about 15 degrees plus or minus with a design
11 requirement around 50.

12 MR. REMICK: Frank, I believe EBR-2 had
13 problems with the rotating plugs freezing and binding,
14 or I shouldn't say binding. But are there any special
15 provisions to prevent that here?

16 MR. BALOH: Well, first off, we have had
17 considerable contact with the EBR-2 people. They've
18 been involved in our design as consultants from its
19 inception, and we believe we have addressed all of their
20 problems.

21 First off, they used a bismuth-based tective
22 which they have frozen and into the blade section of the
23 dip seal they heated. The problem that they run into is
24 they had a very legal seal system, and oxygen was able
25 to get down into the dip seal area and cause what they

1 called clinkers that actually froze things up, and they
2 did not have the access for cleaning which we have also
3 incorporated.

4 So, yes, we were aware of their problems. We
5 have addressed them. And we use sodium which is always
6 liquid. And the seal system that we have has argon over
7 it, and it is a multiple barrier seal system. In fact,
8 the seal systems up in this portion, the primary
9 function is to maintain the purity. The radioactive
10 cover gas interface is right here, so the remainder of
11 the seal system is to keep that environment pure so that
12 we don't have those problems.

13 MR. REMICK: Thank you.

14 MR. BALOH: The last portion I will describe
15 here --

16 MR. SHEWMON: Before you leave that subject,
17 you said you do have ports for cleaning.

18 MR. BALOH: Yes.

19 MR. SHEWMON: How do you expect to clean it?

20 MR. BALOH: Well, first of all we don't have a
21 freeze-thaw cycle, so that the approach that is taken is
22 that we would put in a scoop-type device, slowly rotate
23 the plug, and we can actually through a glove box
24 mechanism take the crud that would accumulate on the
25 surface of the sodium dip seals.

1 MR. SHEWMON: And you think you could sweep it
2 up to a given point?

3 MR. BALOH: Yes. There has been testing done
4 of that operation. The lower portion of the head has
5 the suppressor plates. These are also suspended from
6 the bottom of the lowest shield plate, and their
7 function is to assure that we do not get gas entrapment
8 into the melted sodium.

9 And one of the areas where the core-to-scale
10 tests that were done on the outlet plenum indicated that
11 initially this design had the suppressor plates
12 approximately two feet below the sodium. They are now
13 three feet. Testing has confirmed that that is where
14 they should be to do the job.

15 The closure head itself is assembled and has
16 gone through considerable functional testing of the
17 plug-drive systems, the elastimer seals, leakage rates,
18 and effectively it has been confirmed to do all the job
19 that it has been set out to do. Positioning accuracy
20 came well within all of our requirements and guidelines.

21 (Slide.)

22 The reactor vessel is primarily a 304
23 stainless steel structure. It's 59 feet high by
24 approximately 20 feet in diameter. The top phlange you
25 can see here. The phlange where the closure head sits

1 you can see schematically the area where the trough or
2 the dip seal would be. This phlange is carbon steel.
3 It thermally matches the expansion characteristics of
4 the closure head, and it is also maintained at the same
5 400 degree temperature.

6 There is a transition joint in the vessel of
7 inconel-600 that takes us from the carbon steel down
8 into the 304 stainless structure. This transition joint
9 is low temperature. The top is around 400; the bottom
10 around 600. And it is a couple of feet above the sodium
11 level, so it doesn't see sodium.

12 Inside the vessel is a 316 liner. Its
13 function is to shield the 304 primary structure of the
14 vessel from the hot outlet plenum. It effectively keeps
15 the entire vessel then outside of the creek regime, and
16 that was its function. It comes in at around a maximum
17 of 870 degrees. It is mounted on a forging at this
18 elevation.

19 Now, there are three outlet nozzles, three
20 three-foot diameter outlet nozzles, and this is one of
21 the areas where special consideration had to be given.
22 Because of the feature that we added, there is some
23 differential expansion between the vessel liner now and
24 the vessel itself.

25 The design accommodates that and can prevent

1 leakage of the bypass coolant which goes behind the
2 liner and prevents it from mixing with the hot outlet
3 plenum coolant.

4 We have done extensive testing in that area,
5 both to demonstrate that the seal can accommodate the
6 differential expansion and the interfaces for wear
7 couples and so on.

8 At the lower portion of the vessel there is
9 another forging. It has a support cone which on this
10 picture you can see how it supports the core support
11 plate itself; and I will address that a little bit
12 further later.

13 The inlet nozzles, there are three of those
14 two feet in diameter again. The deflection of the
15 incoming sodium downward is a result of inlet plenum
16 testing, core-to-scale testing again, and to assure that
17 the flow does not impinge directly on some of the lower
18 internal components, as you will see in one of the next
19 vu-graphs.

20 MR. WARD: At the end of life will the neutron
21 irradiation down the core area significantly affect the
22 stainless steel properties?

23 MR. BALOH: No. This is going to be well down
24 below any threshold for loss of ductility in this area.

25 MR. CARBON: What is your philosophy on why

1 you have the inlets down below the level of the core
2 rather than up above?

3 MR. BALOH: Philosophy? I would think from a
4 natural circulation point of view that this would be the
5 ideal location.

6 Paul, do you want to add anything to that?

7 MR. DICKSON: No. What Max is referring to is
8 the idea of bringing in the inlet nozzle at a higher
9 elevation rather than the downcomer down inside the
10 vessel. It obviously makes for a much larger vessel.
11 And you realize it is inside a guard vessel.

12 MR. BALOH: I didn't mention that, but there
13 is a guard vessel that goes above the minimum safe level
14 with a three to six-inch annulus all the way around this
15 vessel.

16 MR. CARBON: But the inlet pipes nevertheless
17 go through the guard vessel and out, I guess.

18 MR. DICKSON: They actually are an integral
19 part of the guard vessel.

20 MR. CARBON: All right. To be sure, they turn
21 up just as soon as they go outside?

22 MR. DICKSON: There is no piping in the
23 primary system. That is outside the guard vessel. That
24 is not an elevated pipe. That is the rule. And it
25 applies to this as well.

1 (Slide.)

2 MR. BALOH: This is a picture of the completed
3 reactor vessel prior to its shipment to storage, which
4 it is in now.

5 MR. BENDER: Could I ask about that transition
6 weld from carbon steel to inconel-600 to stainless? Is
7 that the combination?

8 MR. BALOH: That's right.

9 MR. BENDER: Are there any metallurgical
10 pitfalls in that thing that you have to watch for?

11 MR. BALOH: Yes. And we did considerable
12 addressing of that. In fact, in Appendix G of the PSAR
13 there is a discussion of that very question. One of the
14 things in our research that we found was that the
15 primary cause whereby metallic welds do fail occurred
16 above 800 degrees. We were virtually unable to find any
17 failures in fossil fueled vessels or elsewhere at lower
18 temperatures, and especially when a high nickel filler
19 is used for making the weld to cut down the carbon
20 migration and factors such as that.

21 This entire concern has been addressed and has
22 been documented in that section of the PSAR.

23 MR. BENDER: Is any surveillance required?

24 MR. BALOH: Right now the surveillance is a
25 VTM-2 type inspection for Section 11 of the code. The

1 initial radiography and such was wide spectrum x-ray
2 double angle, and the normal PT and so forth to go
3 through it.

4 MR. BENDER: I wasn't sure what operating
5 history might do to you.

6 MR. BALOH: Again, the temperatures I think
7 are the key. The actual ferritic weld at the top is
8 just a little over 400, about 450.

9 MR. SHEWMON: How many cycles of temperature
10 do you expect to go through up there?

11 MR. BALOH: Well, again, that's very near the
12 area where we control temperature with the head heaters
13 and so on. Internal cycling is extremely small. There
14 are very small temperature changes up there and very
15 long in nature, nothing very rapid.

16 MR. CARBON: We speak once in a while and ask
17 questions about the core support structure. It's highly
18 unlikely to break, of course, but with the vessel wall
19 itself and all the weight that it is supporting and the
20 sodium and so on is that an equal improbability to the
21 core support?

22 MR. DICKSON: We consider both of those well
23 beyond any design basis.

24 MR. CARBON: I know you do. But again, we
25 frequently ask to discuss questions about core support.

1 MR. DICKSON: We're going to give you a
2 complete rundown of that at some later meeting.

3 MR. CARBON: And my question is, improbable as
4 it is, is the possibility of the pressure or the reactor
5 vessel itself in the core equally --

6 MR. BALOH: In this particular case I think
7 the key is that we would never expect -- and I would
8 just use the actual picture --

9 (Slide.)

10 -- A rapid failure. This whole area is going
11 to be monitored for any leaks. And so that if there is
12 any cracking or anything, which we certainly don't
13 expect, that would be monitored, and then the VTM-2, the
14 visual inspection that would take place in this annulus,
15 would also be another means of identifying any potential
16 initiation of flaws.

17 (Slide.)

18 This is a picture of the lower internals. It
19 is slightly enlarged, but basically it is the area you
20 see here. And starting at the bottom end we have the
21 core support structure itself, the plate, which is
22 two-feet thick. We have a number of channels for
23 feeding sodium to the bypass, which goes into this
24 annulus to feed the liner and some of the other
25 peripheral assemblies which I will discuss.

1 The core support itself is welded to this core
2 support cone which I showed you on the vessel vu-graph
3 earlier. Also attached to the core support base is a
4 16-foot but 2-inch thick structure with two forgings at
5 the elevation where the load paths of the core
6 assemblies are reacted.

7 The base of the core support has what we call
8 module liners. These are cylindrical capsules which fit
9 into the base of the core support. They provide the
10 blockage features, and if you can imagine when all of
11 these assemblies are in, there would be another barrier
12 here. And testing again has confirmed that you could
13 take essentially complete blockage of several of these
14 and see almost no change in the outlet temperature
15 because of the bypass feed that can come in from various
16 other locations.

17 MR. SHEWMON: Halfway up that drawing I see
18 something called core former structures. Do those move
19 in and out?

20 MR. BALOH: This is a passive core restraint
21 system. Let me work my way up. I was going to say a
22 few words on those.

23 MR. SHEWMON: Fine.

24 MR. BALOH: Into the module liners we insert
25 what we call lower inlet modules, LIMs; and what these

1 are are assemblies having a body and a stem which you
2 can't see because they are down into the module liners.
3 But seven assemblies insert into each of these. They
4 can be control rod assemblies, blanket assemblies or
5 what have you.

6 For the blanket and control rod assemblies
7 there are orifice cartridges in here that meter the
8 flow. The orificing for the fuel itself is contained
9 within the fuel assemblies and in some of the peripheral
10 LIMs. There are also cartridges in the stem which
11 provide flow to the outer shield assemblies through
12 these bypass flow modules, which there are six of around
13 the base on the outside of the lower inlet modules.

14 There is a seven-inch thick shield surrounding
15 the core area on top of which is the core former
16 itself. These are forged streams which have six
17 segments pinned in place at the predetermined radius to
18 give the proper gaps for containment of the assemblies
19 that go into the core. And I'm not sure if they will be
20 talking about this further, but it is mainly a matter of
21 setting these gaps in the band between acceptable
22 refueling loads to pull them out and compactness of the
23 core to control reactivity during normal operation.

24 But these are preset at installation. What is
25 set is the actual orientation and their location

1 relative to the center of the core.

2 MR. SHEWMON: Your feeling is that with the
3 316 you won't have enough swelling to actually bind up
4 your core at full burnup, is that it?

5 MR. BALOH: You mean swelling of the fuel
6 assemblies in the core itself?

7 MR. SHEWMON: Yes.

8 MR. BALOH: Yes. I would have to defer that
9 question to the people who will be talking about
10 assembly design, but yes.

11 MR. SHEWMON: Well, the reason for them is so
12 that you could get the fuel out after.

13 MR. BALOH: But even an FFTF where the design
14 was started with both passive and activated core or core
15 former capability, at the end it was a pin and set
16 operation. That is now also a passive system, and I
17 believe it has been confirmed to show acceptable
18 operation.

19 MR. SHEWMON: I doubt if they have full burnup
20 on the core yet. Okay.

21 MR. BALOH: The last of the items I will
22 discuss is the horizontal baffle. You can see it in
23 better perspective here. It provides the boundary
24 between the hot outlet plenum sodium and the inlet
25 plenum sodium which is bypassed; about 2 percent of the

1 flow is bypassed up through and behind the liner to
2 provide the cooling and the lower temperature on the
3 vessel itself.

4 There are five fuel transfer ports in the
5 horizontal baffle assembly itself. This is where when
6 the in-vessel transfer machine temporarily parks
7 assemblies for pickout by the ex-vessel transfer machine.

8 (Slide.)

9 This is a picture of the upper internals
10 structure. It is primarily a 316 stainless steel
11 structure, box structure, 3-inch plate top, 4-inch plate
12 in the bottom. The whole assembly is suspended from the
13 intermediate rotating plug of the closure head via
14 14-inch columns that are one-inch thick.

15 The lower portion -- and I will give you just
16 a little more detail after I go through the general --
17 is a mixing chamber basically where the effluent from
18 the core is mixed. The delta t's from varying
19 assemblies can run 250, 260 degrees, and so this chamber
20 in this location serves to mix and then pass up through
21 these chimneys which also show a little more detail on.

22 Beyond that, the control rods, 15 control rod
23 drive mechanisms mounted on the IRP, the drive lines
24 pass through the shrouds which are made of inconel, and
25 the shrouds then connect to -- not the shroud but the

1 drive lines which pass through them connect to the
2 control assemblies themselves.

3 Because the upper internal structure is
4 mounted on the closure head, the fuel assemblies and
5 such are on the core support. There are alignment keys
6 that the UIS inserts into during normal operation. For
7 refueling operation there is a jacking mechanism on top
8 which jacks this whole assembly about 9 1/2 inches up
9 and out, and then it rotates with the refueling
10 equipment.

11 (Slide.)

12 Just to give you a brief runthrough on what
13 the functions are, mainly I've already said that it
14 provides the control rod alignment with the core via the
15 shroud tubes and the alignment features where it goes
16 into the core former at that elevation. It also
17 protects against cross-flow as it comes out into the
18 outlet plenum region, so that the concerns for vibration
19 and such of the drive lines is minimized.

20 It mixes the core outlet flow.

21 (Slide.)

22 As the flow comes out, as I said, there is a
23 relatively large delta t, and there are a number of
24 items in this mixing box. The box itself is encased in
25 inconel to withstand the thermal cycling imposed by the

1 striping of these relatively large delta t's of the core
2 effluent.

3 These items you see here, instrument post, I
4 will speak a little bit about the analysis. The shroud
5 tubes come down through the chimneys and also are in
6 this location, so that as the fluid comes up into this
7 chamber because of the distribution and velocity and so
8 forth, there is a torroreal motion here, and then there
9 is mixing and then passing up through the chimneys.
10 There are 29 of these chimneys. They are also made of
11 inconel. And as the fluid comes up, it then is injected
12 into the higher portions of the outlet plenum. That is
13 one of the next items here, mitigates transients.

14 During a scram when the effluent from the core
15 would be cold there was concern that there would be
16 short-circuiting. In fact, testing showed there would
17 be short-circuiting. So by having the sodium, the cold
18 sodium injected into the hot outlet plenum, we avoid the
19 short-circuiting effect, and indeed have confirmed that
20 the outlet plenum flow during transients as well as
21 day-to-day operation meets all the design requirements.

22 (Slide.)

23 It also serves as an additional backup
24 holddown. The core assemblies themselves are held in
25 place by hydraulic balance. The lower portion -- and I

1 don't have that picture -- the lower portion inside the
2 core support plate itself. There is communication to
3 low pressure plenum. All of the assemblies have direct
4 access to that, so that the pressure underneath all the
5 assemblies have access to the low pressure plenum, and
6 so they are hydraulically stable. However, if for
7 whatever reason hydraulic balance should be lost, all of
8 the core assemblies, blanket assemblies have this
9 secondary feature, and what you are looking at is the
10 bottom portion of an instrument post, which looks like
11 this.

12 And you are seeing the three pods, or whatever
13 you would call them, that would cover all of the core
14 assemblies, blanket assemblies and such. And in
15 addition, where the instrument posts are not there, the
16 lower portion of the shroud tubes serve as that function.

17 The overall upper internal structure can exert
18 166,000 pounds of upward force. If it were required to
19 have the upward force of several assemblies, it would be
20 well within any of that capability.

21 The instrument posts themselves, these, each
22 of the instrument posts contains a dry well which
23 terminates either at the center or in one of the three
24 outer locations into which a thermocouple is inserted.
25 These are replaceable thermocouples, and they provide

1 then the indication of the temperatures of the effluent
2 coming from the various subassemblies.

3 They are mounted on the top plate of the
4 mixing chamber, and the leads, one of the concerns again
5 was to assure that when we -- the leads themselves --

6 (Slide.)

7 -- Then come up through the support columns
8 and into the head access area.

9 I think I have probably taken my time. If
10 there aren't any questions, I will let the people who
11 are going to be talking about all of the action in the
12 core itself take over at this point.

13 (Slide.)

14 MR. DONCAL: In this part of the reactor
15 discussion I will present an overall overview of the
16 CRBRP nuclear design with special emphasis being given
17 to the experimental support that we have performed to
18 validate our predictions.

19 As you can see, the outline is as follows.
20 Initially what I will do is present you a very brief
21 discussion of the reactor description and show you some
22 of the design bases that we used in laying out the CRBRP
23 core arrangement.

24 This will be then followed by an overview of
25 the critical experimental program followed by very

1 specific examples of reactor design areas that have been
2 supported by the experimental program. This will give
3 you some insight into our ability to predict the nuclear
4 predictions on CRBRP. I will then have a brief summary.

5 (Slide.)

6 The CRBRP reactor has 156 fuel assemblies and
7 76 inner blanket assemblies arranged in what we call a
8 heterogeneous arrangement. As you can see, in the
9 center of the reactor we have a small island of blanket
10 assemblies, and this island is in turn surrounded by
11 rings of fuel, blanket fuel, blanket fuel assemblies.

12 This whole heterogeneous arrangement of fuel
13 and internal blanket assemblies are then in turn
14 surrounded by 126 radial blanket assemblies. The design
15 of the radial blanket assembly is identical to that of
16 the inner blanket assembly. In turn, the blanket
17 assemblies are then surrounded by 312 radial shield
18 assemblies.

19 The core height of CRBRP -- that is, the
20 active core height -- is 36 inches. On the top and
21 bottom of this active height of core we have 14 inches
22 of axial blankets.

23 Now, the particular arrangement that we have
24 here for the heterogeneous arrangement was basically
25 selected to achieve a breeding ratio of 1.2 in all

1 operating cycles of CRBRP using a fuel assembly very
2 similar to that used in FFTF. We call that the small
3 pin design or .23 pin diameter.

4 So to achieve a breeding ratio of 1.2, we went
5 to the heterogeneous arrangement. In going to that
6 arrangement we also noted that we have additional
7 benefits such that we reduced the fluences on the fuel
8 assemblies by approximately 20 to 30 percent. So that
9 was a significant gain.

10 In addition, we cut down the sodium void
11 worth. We made a considerable reduction in the sodium
12 void worth in the fuel assemblies in the reactor. So
13 these were positive gains we achieved in going to the
14 heterogeneous configuration.

15 The next point that I would like to make is
16 that we did a lot of detailed analysis in coming up with
17 this overall arrangement where you see the selective
18 arrangements of fuel and blanket assemblies. And in
19 doing this we achieved a configuration that only has one
20 single fuel enrichment. In other words, we only had one
21 single fuel enrichment in all of these assemblies.

22 In addition, you can see around the control
23 assemblies we made pockets of fuel assemblies. This was
24 done to enhance our control rod worth, and thus we were
25 able to achieve the requirements that are listed in

1 General Design Criterion 24.

2 (Slide.)

3 The next point that I would like to very
4 briefly cover with you is the CRBRP fuel management
5 scheme because it is quite simplified.

6 As you can see here, all fuel and inner
7 blanket assemblies are replaced as a batch every two
8 years. In other words, this whole entire fuel and inner
9 blanket assemblies are replaced as a batch with the
10 exception that in alternating years at this location --
11 we have six of these locations -- we start with internal
12 blanket assemblies, and then at the end of the burn we
13 replace them with six fuel assemblies to give us
14 sufficient excess reactivity to perform the subsequent
15 burn.

16 In the radial blanket assemblies you can see
17 first the first row because they are in the high flux
18 region. We operate them for four years at continuous
19 operation. We can't keep them in the reactor. And the
20 second row of radial blanket assemblies are maintained
21 within the -- are kept in the reactor five years.

22 Using this fuel management scheme that I've
23 illustrated here, we are able to keep the fuel peak
24 linear powers in the fuel assemblies below 16 kilowatts
25 per foot on all operating cycles, and in the internal

1 and radial blanket assemblies below 20 kilowatts per
2 foot.

3 MR. WARD: Is that 1.2 breeding ratio the
4 average in equilibrium?

5 MR. DONCALS: In fact, it is. Our minimum
6 value is very close to 1.2. We are actually in excess
7 of that in our equilibrium cycle.

8 MR. SHEWMON: Did you say what your heat per
9 linear foot -- you said it was 20?

10 MR. DONCALS: In our fuel assemblies -- I will
11 get to that a little later, but in our fuel assemblies
12 the design criteria that we used, it's only a design
13 criteria in laying out this arrangement, was that we
14 would maintain the peak linear power in the fuel below
15 16 kilowatts per foot, and in the inner blanket
16 assemblies and the radial blankets, 20 kilowatts per
17 foot.

18 MR. DICKSON: Excuse me, Dick. You should add
19 to that that is with 15 percent overpower.

20 MR. DONCALS: In the later part of my
21 discussion I will present that. That is the definition
22 of a peak linear power. But in a subsequent part of the
23 discussion I will present what we include, what we
24 define as the peak linear power.

25 (Slide.)

1 Very briefly, on the CRBRP control assemblies,
2 just to identify them for you, CRBRP has 15 control
3 assemblies, and they are broken down into two banks. We
4 have two banks -- the secondary control system and the
5 primary control system.

6 The secondary control systems are located in
7 what we call the flat position of the seven row
8 position. These control assemblies are parked at the
9 exit of the core during full power operation; that is,
10 at the exit of the core at the top of the core and the
11 axial blanket interface. They have sufficient
12 reactivity to shut down the reactor from any operating
13 condition with a step rod and any anticipated fault down
14 to refueling conditions. That is the purpose of the
15 secondary system.

16 The primary system we have nine control
17 assemblies, and you can see there are three in the row 4
18 position, and they are also removed from the reactor at
19 hot full power conditions and parked at the exit of the
20 core. The remaining six primary rods here at the corner
21 positions are used to maneuver reactivity and supply the
22 necessary reactivity in the operating cycle.

23 This combined bank here is able to shut the
24 reactor down to hot standby conditions with a stuck rod
25 and also any anticipated fault that we have considered

1 to date.

2 (Slide.)

3 Now, the next subject that I would like to
4 briefly go over and really highlight in my discussion
5 here is the CRBRP nuclear experimental program that we
6 have used to support all of our analytical predictions.

7 Here is a schematic of the various disciplines
8 that either have planned, analyzed or actually performed
9 the experiments. Since we are the lead reactor
10 manufacturer, Westinghouse specified the experimental
11 needs of this design in very general terms.

12 We then met with Argonne, GE and ourselves in
13 what we call program planning meetings. These occurred
14 very six months, six to eight months. And then after
15 those meetings we then met with the Department of Energy
16 under our base program, Phil Henning's organizations,
17 and our own Clinch River project organization, and we
18 had an agreed plan to perform the subsequent experiments
19 at ANL, ANL or the Argonne National Laboratory who
20 performed these experiments in the ZPPR facility. And
21 then each of the disciplines -- and that is the point I
22 would like to get across; it is not just Westinghouse --
23 but Argonne would analyze those experiments,
24 Westinghouse and GE. These results were then compared,
25 and Westinghouse would then incorporate the biases and

1 uncertainties in the design. So we have a lot of
2 cross-checks between the various disciplines.

3 (Slide.)

4 Just to show you, the experiments were
5 performed at the ZPPR facility or the Argonne on the
6 west site at Idaho Falls, and deep within this massive
7 structure here -- it is really concrete, steel and sand
8 -- we have our ZPPR plutonium critical assembly.

9 (Slide.)

10 And as many of you are aware, it is a split
11 bed type assembly in which the halves are shown on the
12 side and also on this side. The CRBRP core was mocked
13 up by taking two-inch drawers with the representative
14 core material and what we call platelet form and
15 inserting them into this matrix, and also in this matrix
16 you can't see here too well, but this was one of our
17 configurations in our experimental program. After the
18 core is configured, these two halves are brought
19 together, and we have our critical assembly.

20 (Slide.)

21 Now, the reactor design areas -- and this is
22 the meat of my discussion here -- have been supported by
23 other critical assemblies as are shown. Shown are the
24 power reactor design parameters that the nuclear people
25 basically predict, and the critical experimental data

1 source that has been obtained.

2 You can see we have a lot of data in support
3 of our fuel enrichments, power distributions, control
4 rod margins, reactivity coefficients, the various ones,
5 and also other parameters such as breeding, temperature
6 defect, ex-core detectors, and fast flux and fluences.

7 Now, what I would like to do is to highlight
8 various experimental results that we have had obtained
9 in these different design discipline areas and show you
10 how well we do in our analytical predictions.

11 (Slide.)

12 The fuel enrichment philosophy in CRBRP, as
13 many of you are aware, is just to guarantee that the
14 reactor can be maintained at hot full power conditions
15 throughout each design burnup cycle. To do this we
16 normally just put enough nominal excess reactivity into
17 the system to do that, plus whatever uncertainty level
18 that we want to accomplish this at.

19 Now, as you can see, the key under the nominal
20 excess reactivity is the prediction of the cold critical
21 Eigen value, and I brought along some predictions in the
22 ZPPR-7 facility of this value that we have achieved.

23 (Slide.)

24 And here you can see -- here are some
25 different configurations in ZPPR-7. Here is our

1 calculated K effective values, our experimental values,
2 and our C/E values. And as you can see, the mean is
3 .989, or we have roughly a 1 percent value in our
4 predictions. Likewise, the standard deviation is very
5 tight on this. It is something on the order of .16
6 percent. So we do fairly well on our predictions of the
7 Eigen value.

8 And using information like this plus a lot of
9 other experimental data, we have come up with the CRBRP
10 fuel enrichments are on the order of 33 percent. That's
11 defined as plutonium over plutonium plus uranium.
12 That's the single enrichment for all fuel assemblies.
13 And our beginning of life fissile inventory is on the
14 order of 1500 kilograms.

15 Another area that we have a lot of
16 experimental data -- and I'm not going to show you too
17 much of it, but I would just like to highlight it to
18 you, and here is what Paul Dickson was alluding to, what
19 we call our peak linear power.

20 (Slide.)

21 Really it is like most physicists do. We use
22 the radial power distribution normalization, the axial
23 normalization, and we define it with our 15 percent
24 overpower consideration. Likewise, we use the 3 sigma
25 value when we quote the 16 kilowatts and 20 kilowatts

1 value.

2 What I would like to do is just briefly
3 highlight how we can come up with this uncertainty in
4 the analytical predictions that we use in our power
5 distributions.

6 Now, you won't be able to see this too good.

7 (Slide.)

8 Here is -- this is the mockup of the ZPPR
9 facility. Here is the blanket fuel, blanket fuel,
10 blanket control assembly locations, and here is the
11 blanket assemblies, radial blankets surrounding the core.

12 The only point that I would like to point out
13 here is that we have a lot of detail. Shown here is the
14 calculated-to-experimental ratio for the Uranium-235 n
15 fission reaction rate. And the point that I would like
16 to bring out here is we have a lot of radial definition
17 in both the fuel assemblies and the internal blankets as
18 well as the radial blankets, and also in both directions
19 and throughout the reactor.

20 Now, we have similar data like this for all
21 the major different reaction rates in CRBRP.

22 (Slide.)

23 And I have summarized them for you on this
24 sheet here to show you the accuracy that we do predict
25 these various reaction rates.

1 Here's the reaction rates in the fuel at the
2 beginning of life and at the end of life. We have
3 listed the C/E values so you can see in the plutonium
4 it's very good because that is the most power
5 normalization that we have, and about 2 percent 1 sigma
6 in fission reactions. You can see the various values in
7 the inner blankets.

8 Now, taking data, this data, and using it with
9 our predictions, we then came up -- we predicted the
10 power distribution in all of the operating cycles.

11 (Slide.)

12 Now, this figure here shows you a composite or
13 a snapshot of the maximum powers in the reactor. It is
14 not at any given time, but the maximum power in the fuel
15 assemblies -- these are these locations here -- that
16 occur at the beginning of the cycle, and in the radial
17 blanket assemblies where you see the 20 and these heavy
18 hot line values. It is at the end of cycle 4 where you
19 build up most of your plutonium.

20 So you can see here at this location this is
21 where we've refueled that blanket with the fuel
22 assembly. At the midterm we have 15.9 kilowatts per
23 foot.

24 MR. SHEWMON: What is your average linear
25 power then in that? Pick a high number at random and

1 tell me what the average would be.

2 MR. DONCALS: I can tell you our radial --
3 well, let me define it this way for you.

4 (Slide.)

5 The combined effects of the FNR and FNZs,
6 maybe the FNRs around 20, 25 percent, and the FNZ is
7 around 30 percent. So you've got like 50 percent due to
8 your shape factor.

9 MR. SHEWMON: Is that max-to-average ratio?

10 MR. DONCALS: Yes. Say 25 percent for the
11 radial parameter; say 30 percent for the axial. So it
12 is about the 50 percent for those two combined effects.

13 Does that take care of it?

14 MR. SHEWMON: No, because I want to know what
15 an average rod power is at the middle, if you wish, and
16 there is also 3 sigma in there plus 15 percent.

17 MR. DONCALS: The 15 percent, well, we have
18 about 50 or 55 percent for this quantity; we have about
19 15 percent for that. If you just do not multiply them
20 but add them, you get about 60, 65. This value is not
21 large. It is about 8 percent. So we don't have a lot
22 of gradients in the assembly, so basically you can take
23 that value and divide by that magnitude, and you will
24 have the average value.

25 But as you can see, the uncertainty is

1 relatively small in their prediction.

2 (Slide.)

3 The next subject that I would like to briefly
4 cover, also to give you some more insight into the
5 experimental results that we have to support our design,
6 is in the area of the control rod worth data in CRBRP.

7 Now, we have taken a whole host of
8 experimental data, and you can see we have performed
9 various bank worths as illustrated here. We have also
10 looked at asymmetric groupings of rods with different
11 banks in and out. We have looked at pin control rod
12 mockups versus these plates that we have in the ZPPR and
13 bunching experiments where you will take pins in one
14 array and then bunch them or predict those, and we also
15 obtained the axial worth profile.

16 We also have not in the control area, but we
17 have performed fuel blanket interchange worth
18 experiments where we do interchange those six assemblies
19 at the mid-year cycle.

20 Now, what I would like to do is show you some
21 of the bias factors that are associated with these
22 various control rod bank worths.

23 (Slide.)

24 That will give you a magnitude of how well we
25 do predict these worths. And shown is the control rod

1 worth predictions, the calculated worths and the
2 measured worths. For the beginning of life condition
3 that is identified as ZPPR-11B and end of life as 11C.

4 And you can see in the row 3 or the inner
5 control, three control rods; these are close. And in
6 the row 7 position, flat positions, about 7 percent and
7 4 percent. In the corner positions at the end of cycle
8 mockup they were slightly better than that. So the
9 biases are fairly small in these parameters.

10 Our uncertainty that we apply also is of the
11 order of 12 percent; so in our control rod predictions
12 in Clinch River we apply these biases plus a 3 sigma
13 value, and we quote an additional 12 percent reduction
14 in these worths.

15 (Slide.)

16 The last area that I would like to very
17 briefly cover with you is show you some of the
18 experimental results that we have obtained in the
19 reactivity coefficient areas, and this is a significant
20 one here.

21 This is again the ZPPR-11B configuration. You
22 won't be able to read these different numbers, but what
23 it illustrates is we performed a detailed radial zone
24 voiding map in the ZPPR facility in which we took the
25 sodium void out of selective regions in the reactor; and

1 you can see the highest number is 13. So we really
2 voided this whole reactor in 13 individual steps. This
3 gave us a host of data that we could then go back and
4 look at our analytical predictions and see what the
5 normalization to this would mean in the way of sodium
6 void in CRBRP.

7 What is shown here we feel is very significant.

8 (Slide.)

9 And let me discuss this very briefly. Using
10 ENDF-3 data file one would predict -- and I'm only going
11 to talk about the six-inch fuel height region -- one
12 would predict about \$1.15 in sodium void worth for
13 CRBRP. If one would take the ENDF-4 data, which is a
14 later data than we are currently using, one would
15 predict \$1.90.

16 Now, what we did, we then went back to the
17 experimental data that I illustrated that we were taking
18 and got biased factors of what we call our moderation
19 and leakage terms in our perturbation calculation, and
20 we now predict with -- we analyzed the ZPPR facility
21 with ENDF-3, and then we got those biases and applied
22 them to predictions using ENDF-3, and we got \$1.50 for
23 the sodium void worth.

24 We did the same calculation with ENDF-4. We
25 went back to the experimental data, analyzed it with

1 that, brought the appropriate biases, and we predicted
2 \$1.49. So we feel fairly confident in the biasing
3 technique that we came up with here, and we got
4 consistent bias sodium void worths in CRBRP.

5 (Slide.)

6 The next subject I would very briefly cover is
7 we have also made Uranium-238 small sample Doppler. We
8 have performed a small sample Doppler experiment. Shown
9 is the measured fuel U-238 Doppler in the ZPPR
10 facility. And also we calculated the Doppler, and you
11 can see we got very good agreement. In fact, we
12 underpredicted it by about one or two percent. So it
13 gave us a lot of confidence that the Doppler prediction
14 that we are putting in PSAR and that we are quoting is
15 fairly good.

16 (Slide.)

17 In summary, I would like to just say that the
18 bias factors and the uncertainties in the calculated
19 CRBRP nuclear parameters are based on an extensive zero
20 power critical experimental data base. The experiments
21 have been completed. We are now in the process of
22 finishing up the analysis on them and incorporating them
23 in our data.

24 Thank you.

25 MR. REMICK: One of the criticisms one hears

1 of the CRBR is that it is an outmoded design. Would you
2 have any reaction to that from a nuclear design
3 standpoint?

4 MR. DONCALS: Well, myself we have actually
5 written some articles on that particular subject where
6 we have counterargued on it, and we feel that CRBRP is
7 not an outmoded design. It is a very advanced design.
8 We are incorporating the heterogenous configuration
9 which has considerable merits. We find that, as I
10 showed before, that with a small pin similar to FFTF one
11 can achieve high breeding ratios. You can reduce the
12 fluences on the fuel assemblies by 20 to 30 percent, and
13 that has a significant effect on fuel life time. We cut
14 the sodium void by half with the design. And we have
15 breeding ratios in excess of 1.2, and our doubling time
16 is on the order of 30 years, and that is very similar to
17 the large plant design. So we feel it is a very
18 advanced design and not an outmoded design.

19 MR. BENDER: Excuse me. Can I ask a couple of
20 questions about the evaluation of the core under
21 malfunction conditions? You assume sticking rods, I
22 guess. What does it do to the power distribution?

23 MR. DONCALS: In CRBRP -- the question came up
24 earlier this morning -- but we keep our bank, we operate
25 in a bank mode, but we keep the bank within an inch and

1 a half. We want all the rods to be within an inch and a
2 half of the average position. And that would result in
3 power perturbations with the extreme one being out
4 relative to the bank on the order, I would estimate, of
5 4 percent.

6 Now, that 4 percent uncertainty has been
7 included in when we quote the 15 kilowatts per foot.

8 MR. BENDER: I don't have any reason to know
9 that it can or cannot happen, but is it possible for one
10 rod to stick in a position that is significantly
11 different from that allowed for inch variation?

12 MR. DONCAL: There are procedures that if it
13 does stick, there will have to be -- and I believe maybe
14 Paul Dickson could explain it better than I. If a rod
15 would stick in a given position and it gets out of
16 alignment more than an inch and a half, some corrective
17 action must be taken at that point; that is, in our tech
18 specs and in our procedures.

19 MR. VIJUK: You're really assuming the rod is
20 stuck and doesn't come in. The bank is maintained. It
21 is monitored. There are two kind of displacement
22 transducers on the rod positions, and there are
23 electronic rod blocks on the positions. The controlling
24 bank must be within an inch and a half during operations.

25 MR. BENDER: And if it isn't, what happens?

1 Does the reactor scram?

2 MR. VIJUK: If it isn't, there's a technical
3 spec shutdown.

4 MR. BENDER: Okay. Let me ask a slightly
different question. Since the fuel is moving around a
6 little bit in this reactor, I guess, you are shifting
7 fuel elements occasionally, I guess, or are you?

8 MR. DONCAL: Do you mean shuffling fuel?

9 MR. BENDER: Yes.

10 MR. DONCAL: No. In CRBRP we burn in place
11 and then replace the whole core. We never shuffle
12 assemblies.

13 MR. BENDER: And how about the blanket?

14 MR. DONCAL: No. We burn in place and then
15 remove it.

16 MR. BENDER: So there's no problem of
17 misplacement of fuel.

18 MR. DONCAL: No. That is one of the things
19 we like about our design, that we are able to, because
20 the power distribution is relatively flat, we achieve
21 uniform burnups, and we don't have to shuffle fuel.

22 MR. BENDER: That's good. Thank you.

23 (Slide.)

24 MR. MARKLEY: I am Bob Markley, and I will be
25 discussing the core thermal and hydraulic analysis and

1 design. I will cover the core T&H description and
2 bases, including flow paths, principal design data, flow
3 allocation; summarize the performance predictions, both
4 steady state and in transients; cover the T&H
5 development test programs, including some examples of
6 data; and conclusions.

7 (Slide.)

8 This is a schematic of the reactor itself.
9 The flow comes in through inlet nozzles, mixes in the
10 inlet plenum, is fed into the lower inlet modules via
11 primary or auxiliary ports. The lower inlet module
12 directs the flow to the core assemblies -- and when I
13 say core here I mean fuel blanket control -- and even
14 the radial shield assemblies.

15 The flow there is predominantly axial. It is
16 just like swirl to the flow and the bundles, the volume
17 in the mixing chamber and through the outer plenum up
18 here.

19 MR. WARD: Where does the swirl come from? Is
20 that the stable swirl just by the inlet flow?

21 MR. MARKLEY: We have wire wrap spacer
22 systems, so they are excellent mixing devices.

23 (Slide.)

24 The principal core T&H design data, just to
25 review this with you, for fuel and blanket, this is the

1 number of rods per assembly. The rod diameters, as we
2 mentioned, about .230. This is the outside diameter,
3 about a half an inch blanket, the pitch-to-diameter
4 ratio, the wire wrap lead or pitch, and some of the
5 lengths of flows in the bundles themselves.

6 (Slide.)

7 This vu-graph summarizes the flow allocations
8 that we have determined to meet design requirements.
9 What I have here are the principal or major flow paths.
10 We have orificing zones as shown here in these
11 assemblies, and then the major constraint, the
12 constraint that has determined that flow basically
13 determined the flow that we have allocated to those
14 assemblies. And let me just go through that a little
15 bit.

16 We have 66 percent of our flow fed to the fuel
17 assemblies, 16 percent to the inner blankets, 12 percent
18 to the radials, a little over 1 percent to the control
19 assemblies and so forth for removable radial shield, the
20 vessel and leakages and so forth. And the 66 percent
21 flow to the fuel assemblies is metered in 6 orificing
22 zones, 6 different flows.

23 Naturally, the highest power assembly gets the
24 most flow and so forth. So we can optimize both
25 temperatures and the use of flow. The same thing for

1 the inners, the blanket and the radial blanket. As you
2 notice, there is one zone of 6 here in both. That is
3 the alternating fuel blanket assembly.

4 MR. BENDER: When are those orifice
5 adjustments made? Are they predesigned into the core?

6 MR. MARKLEY: Yes.

7 MR. BENDER: And are they never changed during
8 the life of the core?

9 MR. MARKLEY: No. The fuel orificing is in
10 the fuel assembly, so they would be designed into the
11 fuel prior to putting it in whenever you replace these
12 assemblies. The same thing for the inner blankets. A
13 portion of the radial blankets is in the assembly and
14 some in place. So you have -- you can control the flow
15 basically as you put the core in as you design it.

16 MR. BENDER: How do you check to be sure
17 you've got the right flows?

18 MR. MARKLEY: We have outlet thermocouples.
19 That is certainly one check.

20 MR. SCHWALLIE: We have a mechanical
21 discrimination system; that is one-way discrimination
22 such that any assembly that goes into its right place,
23 and if it's in the wrong place it's always overcooled.

24 MR. DICKSON: You're not relying upon
25 thermocouples to tell you have the right flow

1 distribution, the mechanical discriminators that he just
2 spoke of.

3 MR. BENDER: That doesn't tell you whether
4 you've got too much. It just keeps you from getting too
5 little.

6 MR. DICKSON: That's correct.

7 MR. SHEWMON: Why don't you two hold a public
8 discussion?

9 (Laughter.)

10 MR. WARD: They can't all be overcooled. You
11 couldn't get them all in.

12 MR. DICKSON: That's correct.

13 MR. MARKLEY: We certainly have flow checks to
14 check the flows so we know what the flows are.

15 MR. DICKSON: Prior to inserting them in the
16 reactor.

17 MR. MARKLEY: Within a very close amount.

18 MR. MOELLER: On the last item on the right
19 there you have what, 1.4 percent. I can understand
20 bypass. How much is actually leakage, or are you
21 referring to leakage as sort of another way of saying
22 bypass?

23 MR. MARKLEY: As you know, we have piston
24 rings in our assemblies, and we have run a considerable
25 number of tests on the piston rings. We have them

1 characterized, and that is what we mean by data and
2 calculations. And again, this is a maximum value of
3 leakage through the various paths of that sort.

4 MR. MOELLER: It is leakage through the
5 paths. It is not leakage as you would think of leakage
6 out of the primary system or something like that.

7 MR. MARKLEY: No.

8 Just to go through one of these, and certainly
9 the basis for our allocation of the fuel assemblies are
10 the pin lifetime and in transient considerations, the
11 striping and the assembly outlet temperatures, and we
12 consider all of those a priori in setting the flows.

13 (Slide.)

14 This vu-graph summarizes the principal core
15 T&H performance data. These are the design conditions
16 for the plant. I think you have seen those before.
17 This is the pressure drop from nozzle to nozzle in the
18 reactor, and by fuel inner blanket and radial blanket.
19 I have already mentioned the number of flow zones,
20 orificing zones. This gives you a feel for the range of
21 the hot spots.

22 This is the cladding ID temperature that we
23 see in the fuel, and the maximum temperature in the fuel
24 in the inner blankets and the radial blankets. These
25 are the values of the fission gas pressure buildup

1 through burnup, maximum value of the fuel around a
2 thousand, for the inner blankets 2 to 300 psi. And
3 those temperatures and pressures meet the lifetime
4 requirements that Mr. Schwallie will discuss later.

5 These are the type of velocities we see in the
6 bundles of the fuel and blanket assemblies; and again,
7 that is well below the limit of about 30 feet per second
8 which is a very conservative limit that we've set.

9 Also, the maximum mix mean outlet temperatures
10 on a nominal basis here for the various assemblies, and
11 the magnitude of the temperature gradients, the maximum
12 temperature gradient we will see between a fuel and a
13 radial blanket assembly.

14 MR. WARD: What is the basis for the 30 feet
15 per second limit?

16 MR. MARKLEY: We have looked at capitation
17 erosion-corrosion considerations. We feel 30 feet per
18 second is even no problem, but we set up a limit of 30
19 feet per second for that. We also have limits in the
20 orificing the same way, but again, we feel they are very
21 conservative for those considerations.

22 MR. MOELLER: Help me with understanding this
23 pressure of the fission gas. What is the cladding
24 designed to withstand?

25 MR. MARKLEY: Well, it is a function of

1 temperature, of course, but it is -- well, it is
2 certainly above that.

3 MR. MOELLER: And does that assume some
4 leakage rate?

5 MR. MARKLEY: No. This is the gas that is
6 captured in your pins.

7 MR. MOELLER: This is the pressure inside the
8 pin itself?

9 MR. MARKLEY: Right.

10 MR. MOELLER: Okay. Not the pressure being
11 exerted on the fission gas.

12 MR. MARKLEY: It's the internal fission, your
13 fission gases due to burnup which you accumulate inside
14 the pin.

15 MR. MOELLER: Okay.

16 MR. AXTMANN: Have your fuel elements been
17 tested for four years in a reactor?

18 MR. MARKLEY: Ambrose. I think Ambrose
19 Schwallie knows that history very well.

20 MR. SCHWALLIE: This is Ambrose Schwallie.

21 We have run pins in EBR-2 of this very similar
22 design except for overall length considerations,
23 certainly these pressures and beyond those times for
24 years. The EBR-2 data base I'm going to call the
25 reference pin design which is similar to Clinch River,

1 and that of FFTV has shown that 80,000 burnup is very
2 easy to accommodate in all stainless steels, and we've
3 achieved burnups of around 140,000 and 160,000 in a few
4 experimental pins.

5 MR. AXTMANN: Let me propose a scenario that
6 the wire wrap is -- how is it held to the fuel element?

7 MR. MARKLEY: It's captured at each end and
8 wrapped around the rod.

9 MR. AXTMANN: Suppose in two years that the
10 wire wrap starts to degrade. Somebody used the wrong
11 weld to attach it to the fuel element, so that you start
12 getting little fragment bits as a progressive disease.
13 And this is imaginary. How would you find out about
14 that as wire wrap starts to fragment?

15 MR. MARKLEY: First of all, as you know, there
16 is a lot of experience with wire wrap bundles. In
17 irradiation experiments we have not seen that kind of
18 performance.

19 MR. AXTMANN: I suppose you haven't, but I'm
20 postulating now --

21 MR. MARKLEY: I think you might get -- again,
22 as you know, the wire wrap does give you a slight local
23 hot spot. If the wire wrap accumulated, you would still
24 have that hot spot. It has to be right at the top of
25 the fuel to give you any real hot spot problem. I don't

1 think it would give you much of a problem.

2 MR. VIJUK: You would pick that up through
3 your operating fuel monitoring system. If you got this
4 hypothetical degradation, eventually you would get some
5 breached cladding. We have a tech spec on the
6 operations. We would detect failures as they occur
7 where the activity in the cover gas at the top of the
8 vessel. We would then have delayed neutron detectors on
9 the primary pipes and so forth, and then we have a tech
10 spec limit on how many failures we can operate the
11 reactor with.

12 MR. MARKLEY: I don't even --

13 MR. VIJUK: That's the only control on it.
14 There was no other way that you would be monitoring for
15 such a phenomenon taking placing. You just look for
16 breaches of the water.

17 MR. WARD: How do you locate the fuel pin or
18 the assembly that fails?

19 MR. VIJUK: We have a discrete tag gas. Each
20 assembly contains a tag gas that you can pick up.

21 MR. AXTMANN: Thank you.

22 (Slide.)

23 MR. MARKLEY: Okay. This is a map of the core
24 assembly mixed mean outlet temperatures. This is at the
25 beginning of cycle 1. What I was showing here, this is

1 the center of the core, and this is a one-sixth sector
2 of the core. Your radial blanket, two rows of radial
3 blankets out here.

4 The control assemblies -- and this is the
5 assembly number, the nominal mix in the outlet
6 temperature, and this is the outlet temperature on a 3
7 sigma basis. The darkened-in assemblies here are just
8 the ones where we look at every assembly, we look at
9 every pin and analyze it and determine where the hottest
10 pin and where the peak pins are.

11 And these are -- this is a peak fuel pin that
12 is located in this assembly, the hottest fuel pin in
13 this assembly, the hottest and peak inner blanket
14 assembly in this assembly, and the hottest -- I'm sorry
15 -- the peak radial blanket pin in this assembly and the
16 hottest pin. And those pins we look at in great detail
17 and do a lot of structural analyses on those to
18 determine that they are the limiting pins and
19 characterize them.

20 MR. WARD: During operation you will have a
21 single thermocouple at the outlet of each one of those
22 assemblies?

23 MR. MARKLEY: That's right. Except I think
24 there are eight fuel and a few radial blankets that
25 don't have it.

1 MR. WARD: During operation how do you expect
2 you will deal with failures of those thermocouples?
3 Will you allow operation if a certain number of them
4 fail?

5 MR. MARKLEY: Yes. We will allow operation
6 and with a certain number of failures, and that will be
7 determined.

8 MR. CARBON: What is the magnitude of the
9 percentage that you will allow?

10 MR. MARKLEY: I don't believe we've come up
11 with that number unless Paul Dickson has.

12 MR. DICKSON: Yes. As Mr. Vijuk stated
13 earlier, we are looking for failures for monitoring the
14 activity of the cover gas, the tag gases appearing in
15 the cover gas, or if the failure results in the breach
16 of the fuel region, the delayed neutron detectors.
17 Those are our primary means of detecting failures rather
18 than thermocouples.

19 The only requirement to continue operation of
20 the plant as far as thermocouples are concerned are
21 those that we discussed last which are the control
22 thermocouples.

23 MR. MARKLEY: And there are 30 of those.

24 MR. SHEWMON: Replacing a thermocouple isn't
25 too hard, or is it major exercise even when you're

1 changing fuel?

2 MR. MARKLEY: You can replace the
3 thermocouples. You may elect to wait until the end of
4 the cycle when you are shut down to do that.

5 MR. SHEWMON: That wasn't my question. The
6 question was how much extra work is it when you are shut
7 down at the end of a cycle?

8 MR. MARKLEY: I will have to ask someone else
9 to answer that.

10 MR. SHEWMON: Is it harder than putting in
11 another fuel rod?

12 MR. BALOH: This is Frank Baloh.

13 You would only replace thermocouples when you
14 were shut down, and it is an extensive process. It is
15 not like putting in another assembly. You would not
16 just do it in a very quick manner like a few minutes or
17 even an hour.

18 MR. SHEWMON: Thank you.

19 MR. EBERSOLE: When one of these fuel pins
20 bursts for whatever reason, does that produce any sort
21 of immediate reaction?

22 MR. MARKLEY: Yes. You release cover gas
23 where we detect that.

24 MR. EBERSOLE: In the course of dumping the
25 962 psi gas load into the core, in the worst place does

1 that produce a minor power pulse of any sort?

2 MR. MARKLEY: No. We would not see that in
3 this power.

4 MR. EBERSOLE: Thank you.

5 MR. ETHERINGTON: Do you have a procedure for
6 locating failed fuel pins?

7 MR. MARKLEY: Yes, we do. We have tag gas
8 which is a different type of concentration.

9 Ambrose, do you want to answer that?

10 MR. SCHWALLIE: Yes. This is Ambrose
11 Schwallie.

12 Each assembly has a tag gas which is a
13 xenon-krypton mixture and those isotopes. And through
14 mass spec dialysis or diagnosis of the cover gas we
15 could determine which assembly it is.

16 MR. WARD: I guess I missed the significance
17 of the 30 control thermocouples.

18 MR. MARKLEY: Throughout this core we have 30
19 thermocouples that are used for control, and they are,
20 if you average them, they are very close to the value of
21 the average.

22 MR. WARD: They represent the core average?

23 MR. MARKLEY: Right. There are 30, and they
24 are symmetrically located, et cetera, so that we get a
25 good average condition of the core, and they are also

1 over even the maximum temperature assemblies and so
2 forth, too.

3 MR. REMICK: Can you select a different 30
4 from time to time? If one fails, can you select another?

5 MR. MARKLEY: Yes, you can hook up others.
6 You could actually lose some of those and still have a
7 very close average. And over a lifetime of a core those
8 average out very close to staying constant, within a few
9 degrees.

10 MR. DICKSON: The 30 includes an allowance for
11 failures. The 30 includes spares.

12 (Slide.)

13 MR. MARKLEY: The next page in your handout
14 also shows a similar map for the hot spot temperatures
15 also. I didn't intend to show that. You can look at it
16 in your handout.

17 (Slide.)

18 The next page in your handout also shows a
19 typical cladding and temperature-pressure history
20 showing how the hot spot temperature, the hottest pin in
21 that assembly, the hot spot temperature changes over two
22 cycles and how the pressure will build up as you
23 typically see. And this type of information is given to
24 the structural analyst, and they use those to determine
25 the integrity and the lifetime of the assemblies

1 themselves.

2 (Slide.)

3 The next area I would like to cover or at
4 least summarize are the design transients, and they fall
5 into two categories, undercooling and overpower type
6 events. And what I'm going to show you here is our
7 worst case undercooling event, the results of it.

8 This is the three-loop natural circulation
9 transient which I believe you had presented to you
10 before. I will summarize the maximum cladding. This
11 was the hottest spot in the core in each of these
12 assemblies that we predict and the time of occurrence.

13 These results are presented in detail in this
14 report. What I have listed here is the assembly, the
15 fuel assembly where you see the hottest pin inner
16 blanket assembly and the radial blanket assembly. These
17 are the nominal temperatures, and they are 1300 below,
18 and in a 3 sigma worst case with a lot of conservatisms,
19 we calculate temperatures as high as 50 and 65. Our
20 acceptance criteria is boiling, less than boiling, and
21 boiling at these locations would be 1720 or greater
22 because that is based certainly -- the hottest spot is
23 at the top of the fuel. It is also based upon these
24 conservative conditions of zero flow, zero cover gas
25 pressure, and the minimum cool level.

1 And as you can see, we have even with the 3
2 sigma conditions, we have greater than 150 degrees
3 margin on a 3 sigma worst case basis, and like greater
4 than 400 degrees margin on the basis of a nominal
5 calculation.

6 (Slide.)

7 And the next vu-graph shows you one of the
8 reasons why we feel these are very conservative
9 calculations. And I have not listed all of the
10 conservatisms here because there is a long list of them,
11 but I think this puts it all together in perspective.

12 What I am showing here is we have done some
13 pre- and post-test analyses of the FFTF natural
14 circulation tests, and they ran their tests from 100
15 percent power and 100 percent flow, and what I'm showing
16 here is the measure and the predicted sodium
17 temperatures.

18 This is at the top of the fuel section where
19 you get the maximum temperatures. It is this particular
20 thermocouple located in the fuel, and it is for the row
21 2 photo in the FFTF test.

22 This shows the sodium temperature versus time,
23 and here we have the measured data as measured from that
24 test. These were the pre-test predictions and the
25 post-test predictions of our best expected values, and

1 they are pretty close to nominal. Actually, if anything
2 they are a little conservative because I think the
3 designers always want to make sure they have some
4 conservatisms in there. But they are pretty close to
5 nominal-type calculations. They are best expected.

6 The difference here is that when we put the
7 actual operating conditions in that test, the decay
8 powers and so forth, we got a little different
9 conditions but still quite close to what we expected.

10 Now, if you go to the same basis as the 3
11 sigma worst case temperatures that I just presented to
12 you, this is this prediction, predictions from the
13 current CRBR assessment approach, you would predict a
14 temperature like this, and that is about 3 to 400
15 degrees above what you expect.

16 We also feel there is a lot of buoyancy help
17 in these kind of low flow conditions and inner assembly
18 heat transfer. These things, your hot spots, are always
19 going to be helped by those self-compensating effects.
20 And there's even about a hundred degrees conservatism in
21 that. And this is the prediction with accounting for
22 what we call inter- and intra-assembly flow and heat
23 redistribution. Basically it is buoyancy and heat
24 transfer between the assemblies, as you will see, in a
25 low flow condition.

1 MR. CARBON: On the measured data curve are
2 there quite adequate points to really shape that curve?

3 MR. MARKLEY: Yes. There is a lot of
4 intermediate points, though it would get too busy if I
5 put them all on.

6 MR. MOELLER: Excuse me. Could you go back
7 two slides where you were showing the pressure buildup
8 with time in the plenum?

9 (Slide.)

10 What I need clarified is across the abscissa
11 you show CY-3 and CY-4. Is that -- no, go back one more
12 on the graph, the graph before this chart -- you show --
13 is that the third and fourth year?

14 MR. MARKLEY: Yes. This just happens to be
15 one typical example I show you for the third and fourth
16 cycle. It is typical of the temperature and pressure
17 histories that we see in a fuel pin.

18 MR. MOELLER: Well, what about the first and
19 second year?

20 MR. MARKLEY: It's similar. Just not as long.

21 MR. MOELLER: I'm not with you.

22 MR. DICKSON: Bob, he's missing the point.
23 Each assembly is only in there two years. This assembly
24 was brand-new at the beginning.

25 MR. MOELLER: I'm sorry. I thought they were

1 in there for four years.

2 MR. DICKSON: Some of the blankets are in
3 there for four years, the radial blankets, and some of
4 the radial blankets are in there for five years; but
5 everything within the core is two years.

6 MR. MOELLER: Thank you.

7 (Slide.)

8 MR. MARKLEY: Again, because of the press of
9 time I'm summarizing our transient area. And this just
10 summarizes.

11 We certainly have established the proper
12 interface requirements such as the PTS settings, flow
13 coastdowns and other things that affect your
14 transients. We have compatible steady state operating
15 conditions, and this was greatly influenced by our
16 orificing, by flattening and reducing maximum
17 temperatures, by optimizing the flow to the various core
18 assemblies.

19 And all design basis accidents, both overpower
20 and undercooling, have been evaluated on a conservative
21 basis and meet the guidelines of no boiling, no clad
22 melting, and acceptable lifetime structural integrity.

23 (Slide.)

24 Okay. The next area I would like to cover
25 then is the T&H development testing. The last time I

1 was here I presented the example on the list of the fuel
2 assembly development area, so I will go through quickly
3 some of the development testing for blanket assemblies
4 that we've conducted.

5 (Slide.)

6 We have conducted or performed a full-scale
7 61-rod heat transfer test in sodium -- this is a
8 prototypic blanket bundle -- looking at the very
9 detailed temperature distributions. We had around 700
10 thermocouples in this. We got electrically heated rod.
11 We not only looked -- we covered a very wide range of
12 operating conditions, and we also included transients,
13 natural circulation, and so forth, and that program is
14 about completed. And I will just show you a few
15 examples of that and try to give you a feel for what we
16 have done there.

17 (Slide.)

18 These are the wide range of test parameters
19 that we have covered. As far as flows, well below
20 anything we expect in natural circulation. The
21 temperature range, we have looked at flat power skews
22 all the way up to 4.6 to 1, very steep power skews. We
23 have simulated our adiabatic boundaries. We have
24 auxiliary reduction inside, so we can look at
25 inter-assembly heat transfer. You can cool these ducts

1 or you can heat them. And we have covered a lot of data
2 in that area. We also have a lot of transient and
3 natural circulation data, too.

4 MR. CARBON: These are electrically heated
5 rods?

6 MR. MARKLEY: Yes, they are. Let me just show
7 you one or two pieces of data from that.

8 (Slide.)

9 This is a plot of normalized temperature
10 across this 61-rod bundle, and these are the typical
11 sets of data that we have obtained. This is at the core
12 midplane, the heated zone midplane. This is a plot at
13 the outlet of the heated zone, and of course there is
14 where you see your maximum temperature. And this is a
15 plot of an elevation 25 inches up into the bundle.

16 We have several test series here, and every
17 time we would run a test series with a gradient of this
18 sort, which is 2 to 1 across the bundle, we would then
19 reverse it and check the test again. And you can see
20 excellent duplication of test results.

21 We also made code predictions, and you can see
22 our subchannel code predictions versus that. And
23 naturally, one of the important things we look at are
24 the peak predicted hot spot versus the measured hot spot.

25 MR. WARD: Did you actually make those as

1 predictions before you ran the test?

2 MR. MARKLEY: Yes. And after, too.

3 MR. WARD: That's easier, isn't it?

4 (Laughter.)

5 (Slide.)

6 MR. MARKLEY: And then you would take those
7 hot spots you measured and predicted data for all of the
8 varying conditions that you looked at, plot them, and we
9 would do a statistical analysis of that, get the direct
10 bias and the statistical variations, and that determines
11 the uncertainty with which you can predict that
12 temperature. And you can see we have a lot of data
13 points for a prototypic bundle there

14 (Slide.)

15 MIT has done a lot of work, fundamental work,
16 research work in these areas. We also had a 5 to 1
17 scale air flow test where we learned what these flows
18 really looked like because you have got to understand
19 them, and it is not easy. And with a large bundle like
20 this we could map in very great detail the cross-flows
21 and the axial flows.

22 Pressure drop tests -- and let me show you an
23 example of those.

24 (Slide.)

25 Here is over 200 data points of a friction

1 factor versus the rod bundle Reynolds number for the
2 blanket bundles. There is air data, there is water
3 data, and there is sodium data here, and there is also
4 some other correlations by other people up here at the
5 higher flow zones. But you see very good correspondence
6 and no instabilities in that kind of a rackup of test
7 data. And that is actually used in all of our -- that
8 is the basis for our analysis.

9 MR. WARD: What sort of Reynolds numbers do
10 you have with the plant operation?

11 MR. MARKLEY: If you're at a hundred percent
12 flow, you would be here 10 percent, 1 percent. We have
13 gone down to almost 2/10 of a percent. We expect maybe
14 3 percent as the lowest in our reactor.

15 And then just to summarize one area again --
16 (Slide.)

17 -- I have tried to summarize all of our core
18 pressure drop testing in this sheet, and I've lifted the
19 components, the component parts of those components that
20 you would test, how much they mean in the pressure drop
21 -- this is an approximate value -- the range that we
22 have covered. And in all cases we have gone 100 percent
23 or more down to again much lower than we expect in
24 natural circulation for at least all of the high heat
25 generating type assemblies.

1 The others are either out of the core or very
2 low, but we have still covered a good range there. But
3 we have not gone quite as far, and you can see the
4 status. They are practically all completed except one
5 or two there which will be completed, and certainly this
6 data will be factored into the FSAR work.

7 (Slide.)

8 I then put some more examples in the handout
9 of friction factor data for our fuel bundles.

10 (Slide.)

11 Pressure drop data for the overall fuel
12 assembly. So that you can take these component parts
13 and add them up. They should check to the total
14 pressure drop for a prototypic bundle -- I'm sorry -- a
15 prototypic assembly.

16 Pressure drop data for our control assemblies
17 where we again have over 50 points that we have taken,
18 and I have included that in there, and also some
19 pressure drop data of some of our orifice shield
20 assemblies; but they are all tested and characterized by
21 flow tests.

22 MR. CARBON: Would you comment on what we
23 heard this morning about the pressure drop in FFTF went
24 up 15 percent or something like that? Why was that?

25 MR. MARKLEY: We don't know yet, and they

1 don't either. We are looking at it, and we will
2 certainly try to factor that into our design. We do
3 have fallback methods in case that is a reality.

4 MR. CARBON: Did it occur right after startup
5 or over a period of time?

6 MR. MARKLEY: It would build up slightly, I
7 believe, like a psi per day until it got up to the 10 to
8 15 percent.

9 MR. CARBON: And then just sat there?

10 MR. MARKLEY: Then it would peak out as far as
11 we can see. When it shuts down you would partially lose
12 it, and then it will build a little bit.

13 MR. CARBON: Is it consistent throughout all
14 the fuel or just sporadic?

15 MR. MARKLEY: I think we are working with them
16 trying to get the answers to that at this time, Dr.
17 Carbon, and I'm not sure we have it yet.

18 (Slide.)

19 In conclusion, on --

20 MR. MOELLER: Excuse me. Has that been the
21 experience in France or any of the others?

22 MR. MARKLEY: It has been experienced in a few
23 out-of-pile loops where you had sodium endurance testing
24 in a few cases. At the time we thought it was bearing
25 scoring or something, and we were really trying to

1 decide what it is.

2 MR. CARBON: Excuse me. Still in answer to
3 his question, have they experienced anything like this
4 in Phenix or PFK?

5 MR. MARKLEY: The EBR-2 people were not aware
6 of this and do not think they have experienced it.

7 MR. CARBON: What about the British and the
8 French?

9 MR. MARKLEY: When I talked to the British
10 three or four years ago they did not know of anything of
11 this sort. I talked to the French, and I do not know
12 their experience in that.

13 In conclusion, in the core T&H development
14 testing area we do have a large T&H data base available
15 already. The data is on all components over a wide
16 range of operation, and I tried to illustrate that with
17 our pressure drop testing and our heat transfer data.

18 The uncertainties that we use are based upon
19 this data and have been factored into the PSAR, and all
20 the data will be factored into the FSAR, what little we
21 don't have remaining.

22 (Slide.)

23 And in final conclusion, the reactor flow
24 distributions do meet the component design
25 requirements. The cooling flow paths are well

1 characterized. They are controlled by orifices which
2 have been tested over a very wide range of conditions
3 and are factored into our analyses.

4 We have a large component T&H development base
5 already available. We have a comprehensive design where
6 you look at every assembly, every pin based upon
7 conservative yet realistic limits; and the analysis
8 methods are verified with a large data base, as I showed
9 you one or two examples.

10 MR. BENDER: You have clearly done all you
11 could, all you think you ought to do prior to building
12 the reactor and putting it into operation. What do you
13 envision as other kinds of confirmatory tests that might
14 be needed when the plant starts to go to power or prior
15 to going to power?

16 MR. MARKLEY: We will be running a natural
17 circulation confirmatory test. There are system flow
18 tests, as you know, many of them cold and at heated
19 conditions during startup.

20 MR. BENDER: I'm thinking in terms of just
21 monitoring the flow distribution over the core. You've
22 got the thermocouples which will tell you what is
23 happening when you are at power, but is there anything
24 prior to that that should be done?

25 MR. MARKLEY: I think the testing that we have

1 done certainly gives you an excellent feel for the
2 pressure drop. These are well characterized.

3 MR. BENDER: Well, what I'm trying to find out
4 now is how to look for surprises like the 15 percent
5 change in flow that was observed at FFTF. Would I know
6 about that by something other than thermocouple
7 indications?

8 MR. MARKLEY: Yes. Your flow meters, your
9 pump. You certainly would have a pump that would be
10 affected by that, and your thermocouples.

11 MR. DICKSON: That is not a 15 percent change
12 in flow. That was a 15 percent increase in pressure
13 drop, and it was picked up because the pump did not take
14 care of it.

15 MR. BENDER: Thank you, Paul.

16 MR. MARKLEY: Any other questions?

17 MR. DICKSON: Bob, before you go away, I would
18 like to note one thing that you didn't mention. The
19 Japanese have also seen an out-of-pile test at pressure
20 drop increase in fuel assemblies but not in-pile. But I
21 would like to follow up with Dr. Remick's question that
22 he asked of Dick Doncals.

23 I don't want you to take too much time, but if
24 you can just take a minute to describe where your
25 analytical capability is today compared with where the

1 analytical capability was when Clinch River was started,
2 in other words, that using an FFTF. And also, since you
3 have been a member of the technical interchange with
4 foreign countries, if you could compare our analytical
5 capability, particularly that that the French would like
6 to have, with some of the foreign capability.

7 MR. MARKLEY: Okay. First of all, certainly
8 we also designed FFTF at Westinghouse ARD. A lot of our
9 tools were extensions of the tools used for FFTF core
10 design. I think we have developed them to a much
11 greater extent, and with a lot of data to back up those
12 analytical methods.

13 In summary, I could get into any detail, but I
14 don't think we want to. But we are using a lot of the
15 -- at least in the T&H area and physics and so forth, a
16 lot of the methodology we used to design the FFTF
17 reactor, and we are using that or improvements on it now
18 for Clinch River. This is the same people.

19 MR. DICKSON: I thought you would note that in
20 the FFTF the orificing was done to equilibrate
21 temperatures at the beginning of life. A major advance
22 was thought to have been achieved when we equilibrated
23 temperatures at the end of life, and we are now
24 orificing to maximize lifetime within constraints set by
25 delta t's between assemblies and all transient and

1 safety analyses.

2 MR. MARKLEY: We factored them all in to a
3 prediction of the lifetime, so our flows are determined
4 by optimizing lifetime throughout the plant. We do the
5 entire calculation of that. We have been around that
6 cycle several times, so we feel we can do it.

7 As far as foreign, foreign methodology, yes, I
8 have talked to several -- the Japanese, the Germans and
9 the British. I think they're way ahead in methodology
10 and in the T&H area. That is all I can speak for. I
11 think we in this country have put a lot more into
12 developments of methods and also in testing. We have
13 performed a lot more testing in the core area I believe
14 than those countries.

15 I cannot speak for the French. We were not
16 able -- I have never been able to talk with the French
17 very freely.

18 MR. DICKSON: Is it a fair statement to say
19 that they put in more instrumentation in order to
20 measure temperatures and flows because they have a less
21 degree of certainty in calculating them?

22 MR. MARKLEY: I could only guess on that, and
23 that might be unwise.

24 MR. WARD: Since you --

25 MR. BENDER: That is a two-sided coin. You've

1 got a lot of faith in your computations and are arguing
2 that you don't need this much measurement capability
3 because of it. But I think your case is somewhat
4 self-serving as you presented it.

5 MR. DICKSON: We tend to put forward
6 self-serving cases, but we heartily agree with it.

7 (Laughter.)

8 MR. WARD: Since the assemblies are
9 individually designed or the flow orifice designed and
10 you don't have a thermocouple, let's say, at the outlet
11 of each assembly, it is conceivable that you could get
12 one in. There are controls, mechanical or
13 administrative controls, what have you. You could get
14 one in and operate the reactor, and you would have a
15 much higher sodium outlet temperature there.

16 Now, is there a safety issue there?

17 MR. MARKLEY: We have discriminator posts that
18 you just can't put that assembly in the wrong position.
19 He just can't put it in there.

20 MR. WARD: What if you've got the wrong piece
21 of hardware? I don't know what your orifice plates are,
22 but it is some piece of hardware. What if the incorrect
23 piece of hardware gets in that assembly?

24 MR. MARKLEY: I believe there is very close
25 surveillance and QA for that, so I don't think we expect

1 it. That is very unlikely. It would be very unlikely
2 maybe that that particular assembly didn't have a
3 thermocouple.

4 As far as locations, we do have symmetry in
5 the core, so you do have symmetrical sectors at least
6 covered. If one assembly is not covered here, you have
7 five other assemblies just like it that will have
8 thermocouples over it. So there is a lot of redundancy
9 and duplication from that standpoint.

10 MR. WARD: If the assembly was operating with
11 a low flow and it was undetected, is there a safety
12 issue there?

13 MR. MARKLEY: Certainly if you got low enough
14 flow you would have failures, and then we would have DND
15 systems and cover gas systems that detect that.

16 MR. WARD: And you see that as just an
17 operational issue, or is there a safety issue?

18 MR. MARKLEY: I think it's an operational
19 issue, because we do not see propagation in any sort of
20 these assemblies. Even in the unlikely happening that
21 they would get into trouble, our calculations say they
22 do not. I think Fermi proved that. They had a couple
23 of assemblies where they shut off all the flow, and only
24 those assemblies failed, and it did not propagate beyond
25 that.

1 MR. KERR: But Fermi was operating at fairly
2 low power at the time, as I remember.

3 MR. MARKLEY: It did not propagate at all
4 either, but you are right.

5 MR. CARBON: I would like to add to that that
6 some of us would argue that Fermi, the statistics there
7 don't prove anything. And it is the project's intention
8 that there would not be propagation from some small
9 something up to a major event. But the French and
10 British looked at that quite differently, and it used to
11 be a concern here in the United States that propagation
12 would be something to be quite concerned about. And we
13 have asked them to present a more extensive argument on
14 this in about two or three weeks.

15 MR. WARD: Does this include, for example, can
16 a pin failure -- maybe Mr. Schwallie will be addressing
17 this -- but if there is an individual pin failure, is
18 there a sodium oxide reaction?

19 MR. MARKLEY: Again, we do not think -- and
20 there's a lot of evidence based upon our Argonne
21 National Laboratory work -- that these do not propagate
22 if you have different kinds of failures, gas release or
23 whatever. But I gather that is the subject of another
24 meeting.

25 MR. CARBON: It will be a more extensive

1 meeting.

2 MR. MARKLEY: And incidentally, knowing my
3 discussions with the British, I'm very surprised that
4 they feel that way, because several years ago they did
5 not. They agreed with us on propagation.

6 MR. CARBON: Dave, I didn't want to stop you
7 from asking questions. I simply wanted to tell you that
8 there will be more discussion later on this.

9 MR. MARKLEY: Thank you.

10 MR. SCHWALLIE: My name is Ambrose Schwallie,
11 and I ask you to bear with my head cold today. I
12 apologize for that.

13 (Slide.)

14 The areas that I'm going to talk about in the
15 next half hour is try to give you some confidence in the
16 limits that we talked about and were pointed out by Mr.
17 Baars this morning, to try to tie that back to what they
18 try to serve in terms of what the design can
19 accommodate, and relate that somewhat to the safety
20 situation.

21 I would point out some of the things that
22 we've talked about just briefly in the design
23 description and give you some feel for some of the more
24 pertinent evaluations in terms of the margins as we see
25 them today as contrasted against those design limits and

1 the status of the testing programs. And I'm not going
2 to put too much emphasis on what we have completed but
3 what is ongoing to solidify the design a little bit more.

4 (Slide.)

5 I think at a previous meeting Dr. Dickson
6 talked about core design criteria a little bit. The
7 point I want to make here is that from the RDT standard
8 in terms of the damage severity limits for the core
9 through unlikely events -- and sometimes I will use the
10 terminology "normal upset" and "emergency upset,"
11 referring to anticipated events, and "unlikely" and
12 "emergency" are synonymous.

13 But through this point we tried to design the
14 core such that we preclude failure from any mechanistic
15 phenomena that we would understand. Okay. And in the
16 case of the fuel rod and the blanket rod, we use two
17 techniques.

18 The ductility limited strain criteria is more
19 of a recipe-type criteria that is not so
20 phenomenological in nature but accounts for certain
21 pertinent aspects, namely thermal creep and plasticity,
22 and was derived primarily in the FFTF days, and it has
23 been modified by us to account for a somewhat little
24 more understanding about fuel. But it's basically a
25 recipe that is a designer-oriented quick tool for

1 assessing the design.

2 We have gone to the cumulative damage function
3 technique which is more predictive in its nature and
4 tries to dynamically track the materials properties
5 through time, the fuel performance with time,
6 irradiation effects, fluence effects, hardening, what
7 have you.

8 This technique is being integrated very
9 heavily right now in the national fuel programs in terms
10 of the LIF code and the generation of the data base to
11 try to qualify that technique.

12 (Slide.)

13 In terms of the assembly, what I thought I
14 might do is just walk you through and point out the
15 pertinent features. From the outside of the assembly
16 starting from the bottom to the top this lower inlet
17 nozzle region which extends about in this area, this
18 interfaces with the lower inlet modules. There are two
19 piston rings to try to prevent excess leakage flow from
20 going past the assemblies, up the outside, through the
21 interstitial region of the core. Really, these
22 elongated holes in the inlet slot are such that if the
23 assembly moves up and down from its full seated position
24 to a secondary holddown position, reduced flow would not
25 result.

1 This discriminator post is designed such that
2 if you go into the wrong core position, it will not
3 seat, and this is in a core position that would result
4 in the assembly having less flow than it is supposed to
5 have such that this length is long enough the refueling
6 machine would not let go, it wouldn't seat down, and the
7 interlocks would say I'm locked in a position; you can't
8 let go.

9 This is totally a stainless steel structure
10 316. The duct region itself which is from here to the
11 top of the handling socket is 20 percent cold core
12 material.

13 Now, a little while ago somebody was asking
14 about the core restraint aspects and do we get core
15 compaction against the core thermal rings to do the
16 swelling. This load pad is located well up above the
17 axial blanket region out of the high fuelant region such
18 that we don't get any swelling in stainless steel at
19 that axial elevation above the core.

20 The fluences up in this region are low, only 2
21 times 10²² .

22 MR. SHEWMON: Where are there discontinuities
23 in the length of that then? Where is your fuel?

24 MR. SCHWALLIE: The fuel would -- okay, the
25 fuel region itself, the core region, is about at this

1 elevation down to here. I've got this cut in two here.
2 But this load pad is about four inches above -- the
3 bottom of it is about four inches above the top of the
4 core itself. So we don't really get any gross
5 deformation of the assembly here, and any deformation of
6 the duct that we take down in this region is
7 accommodated by the diameter difference of the duct and
8 the load path.

9 The outlet nozzle of the assembly is welded to
10 the duct. It has a load pad, and it has these sloping
11 features on the top so that that feature, along with the
12 transition from the round to the hex here, provides the
13 camming and gearing so that the assemblies as they come
14 in a little bit misalign from the refueling machine,
15 straighten themselves up and slip into the core. And
16 the inside of the nozzle has a ledge feature for the
17 refueling machine to grab a hold of, and then this
18 scalloped region on the top is put in there so that it
19 is small enough such that if you had a refueling
20 accident and tried to put an assembly down where there
21 was one, it would not go down in and damage the rod
22 bundle, and the scallops would still provide flow access
23 through the assembly.

24 MR. WARD: How do you get -- you have to have
25 rotational orientation. How do you get --

1 MR. SCHWALLIE: If you're just a little bit
2 off-line, the assemblies will clear themselves in such
3 that the load paths line up correctly by slipping past
4 these camming features here. And there is a similar
5 feature here in the transition from round to hex.

6 MR. CARBON: Do you have the same orifice size
7 in each of the fuel assemblies?

8 MR. SCHWALLIE: No. Both the number of plates
9 and the hole diameters themselves vary from each orifice
10 zone to the next.

11 MR. CARBON: How do you know? How can you be
12 certain you've got the right orifice?

13 MR. SCHWALLIE: It is primarily administrative
14 QA control and fabrication.

15 Now, we do do an air flow test when we
16 fabricate each assembly, and that gives us a final
17 confirmation that we have the right orificing with the
18 right assembly and its identification system, which is a
19 notched system which is read both administratively and
20 by the reueling machine.

21 So after fabrication we get a confirmation
22 that the right orifice is in there through that air flow
23 test.

24 MR. CARBON: How sensitive is that test?

25 MR. SCHWALLIE: On FFTF where we have had

1 three discriminator zones it has been very good. As a
2 matter of fact, we have never had a case where we had
3 the wrong orificing in, but I think the air flow testing
4 is within 15 percent of differentiation of flow rates
5 between different orificing zones itself.

6 MR. WARD: And then the size of that
7 discriminator post is tied to that?

8 MR. SCHWALLIE: That's right. That's tied
9 also.

10 MR. WARD: But down in the reactor internals
11 then you've got something that receives that. Is that
12 changeable, or is that fixed with the reactor?

13 MR. SCHWALLIE: You can change LIMs, but
14 suppose we go in with just A-1 and we never decide to
15 change it. That always stays, each zone stays
16 permanent, and it is the female matchup of this male
17 insert.

18 MR. WARD: But if after your first cycle you
19 decide to change the orificing for some design, in your
20 next cycle you have to go in and change those female?

21 MR. SCHWALLIE: No. If I want to allocate
22 flow a little bit differently from zone to zone, I can
23 change --

24 MR. WARD: What if you want to make another
25 zone I guess is what I'm asking.

1 MR. SCHWALLIE: Then you would have to change
2 LIMs.

3 MR. CARBON: What is the maximum flow
4 difference if you have the worst wrong orifice size?
5 What is the flow difference from the biggest orifices to
6 the smallest orifices?

7 MR. MARKLEY: Roughly you have about 150,000
8 pounds per hour in a minimum flow assembly and around
9 200,000 pounds per hour in a maximum flow assembly --
10 fuel assemblies.

11 MR. CARBON: Your delta t is what, 300 degrees
12 or something, so this gives you another hundred degrees,
13 and thus, it doesn't really change things too much?

14 MR. MARKLEY: That prorating or allocating of
15 flow helps your temperature because you put the higher
16 flows in the higher heat generating assemblies and
17 reduce --

18 MR. CARBON: But I mean if you made a mistake
19 and the minimum flow orifices were in the hottest
20 assembly.

21 MR. MARKLEY: Yes. That would give you higher
22 temperatures.

23 MR. CARBON: But only by about 100 degrees.

24 MR. DICKSON: I don't think we would want to
25 make a claim that they would survive. I think we would

1 assume that it would run to overtemperature and would
2 fail sometime during life.

3 MR. WARD: What is the delta t in your air
4 flow tests?

5 MR. SCHWALLIE: I can't be too definitive on
6 the numbers. I'm not sure exactly of the total pressure
7 drop they have been running on FFTF. The air flow
8 testing and water flow testing correlation has been very
9 good in EBR-2 also.

10 MR. CARBON: Excuse me a second. Can I ask
11 the Staff if you looked into the -- explored the quality
12 control aspects of this?

13 MR. STARK: Are you referring to the analysis
14 or the manufacturing itself?

15 MR. CARBON: Everything connected with it.

16 MR. STARK: Well, to date what we have been
17 looking at is largely the analysis of the overall QA
18 program. We have been looking at some components that
19 are manufactured, but I don't think that we have looked
20 at any fuel assemblies yet.

21 MR. CARBON: Have you adopted some sort of
22 position on being satisfied with the procedures that
23 will be followed on that?

24 MR. KING: We have gotten a commitment that
25 this air flow test will be done as one of the last steps

1 of fabrication. We have not reviewed in detail or in
2 fact I think to any extent the fabrication process
3 itself, the QA administrative controls, that kind of
4 thing, other than that we did get the commitment to do
5 this air flow test. I think we consider that more of an
6 OL-type item than a CP item.

7 MR. CARBON: Okay.

8 MR. WARD: That may be true unless you find
9 out at the OL stage that you wished they had more
10 thermocouples in the reactor.

11 MR. SCHWALLIE: Okay. In the bottom of the
12 assembly just above the inlet region or the orifice
13 plates, and then there's this very bulky region here
14 that provides shielding for the permanent reactor
15 structures, nothing too complicated about this. Then
16 just above that is the initiation of the rod bundle
17 region, and there is a key-way assembly design, a rail
18 attachment assembly design. That actually restrains the
19 fuel rods from any axial movement. And then the tube
20 bundle itself is 270 pins with a wire wrap spacing on it.

21 Now, the previous vu-graph I showed you just
22 gave you an example of the kinds of quantified design
23 limits that we used for the fuel rods. In terms of the
24 other assembly structures, the ducts, the outlet nozzles
25 and inlet regions and so forth, we not only look at

1 ductile fracture modes and fatigue effects and brittle
2 effects due to irradiation hardening. That really is
3 only a consequence of the duct, because everything from
4 here down and up above is a very low fluence type
5 situation where you don't lose ductility.

6 But we also worry about the functional aspects
7 of fit, form and function, both in reactor from a core
8 restraint point of view in terms of what that translates
9 into refueling loads, and then the configuration of the
10 assembly in terms of bulging and residual, and
11 transferring the assembly out of reactor. And we worry
12 about that aspect also.

13 (Slide.)

14 In terms of how do we compare with FFTF on an
15 assembly basis, we have six discriminating zones in the
16 fuel; FFTF has three. And that is just primarily
17 because of our core arrangement and the larger core
18 size. In terms of lower shielding, we are about the
19 same. They were a little bit more than us because of
20 the requirement at one time to have the closed loops in
21 FFTF for specialized testing.

22 We have a little bit bigger outside dimension
23 across the load pad, and that is primarily because we
24 need a little more meat for the larger core and the
25 seismic load kilo-carrying capability. The load pad

1 thickness being a little bit thicker gives a little bit
2 more room for the ducts to bulge outward.

3 We have a little more axial room at the top of
4 our tube bundle between the top of it and the handling
5 socket than FFTF does, and that is just anticipation of
6 a little bit more higher burnup eventually.

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

1 We have a fixed load pad at the top. FFTF had
2 a floating color and that was primarily put in back in
3 the days of the evolution of the interation, or the
4 understanding of creep and swelling, the core restraint
5 and pipe calculations. We don't need that and they're
6 not going to have it in their next build. And we have
7 got a little bit more misalignment capability than they
8 have in terms of the refueling grapppler mismatch. But
9 that is just to allow for a larger core.

10 So, all other aspects in terms of the wire
11 wrap lead and the pin pitch to diameter ratio and that
12 kind of thing and the inside -- the cross-dimension of
13 the duct and the wall thickness of the duct and so
14 forth, we are identical to them.

15 (Slide.)

16 In terms of our fuel rod, we've talked about
17 most of the features and most of this has been mentioned
18 today, but very simply, it is a hermetically sealed
19 component, welded with tubing and cladding 15 mil wall
20 thickness as it is welded to a top and bottom end cap.
21 The wire wrap is welded at each end. From the bottom
22 end cap you've got 14 inches of blanket material with
23 three foot of actual active core, another 14 inches of
24 axial blankets, a spring to keep everything tight,
25 closed pack during shipping. Just a tube to transmit

1 the forced to the top end caps, and then this tag gas
2 capsule assembly that upon welding or sealing of the pin
3 we rupture the diaphragm and release the xenon-crypton
4 tag gas mixture into the pin and it becomes part of the
5 bond gas, and then each assembly has a unique tag gas
6 composition.

7 Our fuel is a dished fuel such that when the
8 fuel comes to hot conditions, there is no doming of the
9 fuel to elongate the stack. We have a 91.3 percent
10 theoretical density with about a five to six and a half
11 mil gap. That is a diametral gap between the pellets
12 and the cladding. The blanket pellets above and below
13 are 96 percent density with a 10 mil gap. The 10 mil
14 gap is primarily there to allow for the migration of
15 cesium fission products in the upper region of the fuel
16 column. Everything else, I think, is pretty
17 self-explanatory. The cladding is 20 percent CW 316.

18 MR. BENDER: Can I ask my question now?

19 MR. SCHWALLIE: Sure.

20 MR. BENDER: Do you pre-pressurize the fuel?

21 MR. SCHWALLIE: No, we don't.

22 MR. BENDER: There is nothing in there that is
23 under-documented?

24 MR. SCHWALLIE: Our glove box is welded at
25 atmospheric pressure.

1 MR. BENDER: And they contain what, a mixture
2 of argonne?

3 MR. SCHWALLIE: The fuel gas is helium.

4 MR. BENDER: What happens with burnup to the
5 gap? Does it change with time?

6 MR. SCHWALLIE: Yes.

7 MR. BENDER: Can you tell us a little bit
8 about its behavior?

9 MR. SCHWALLIE: Sure. What happens is in
10 Clinch River, first of all, from a design standpoint,
11 smear density is the controlling parameter in terms of
12 overall fuel performance in a global nature. And smear
13 density as we talked about it this morning is the total
14 void available inside the pin for a swelling
15 combination. What happens is on your ascent to power,
16 the fuel will thermally expand out toward the cladding,
17 but you do not close the gap until you restructure the
18 void deployment that you build into the fuel and create
19 a central void.

20 Now, you can do that within two to three days
21 of full power operation, and then as you burn up and,
22 say, get the 2 percent burnup, you will have pretty much
23 fully restructured the fuel. You've got about a 20 to
24 30 mils central void in the center. And the fuel will
25 be in contact with the cladding at that point in time.

1 And then from that point on, you start getting fuel clad
2 and mechanical interaction until about 5 to 6 percent
3 burnup. The cladding reaches a fluence, then it starts
4 to swell a little bit.

5 So that is the relieving mechanism plus a
6 radiation creep, which is very good for us in a
7 relieving sense from the secondary stress levels. That
8 off-balances the differential growth between the fuel
9 cladding and time, and we would predict that we would
10 maintain fuel-clad contact over three-quarters of the
11 fuel height throughout lifetime to the end of life from
12 about 2 percent burnup, on.

13 MR. BENDER: Now, the fission gas pressure
14 builds up in the system, does it not?

15 MR. SCHWALLIE: That's right.

16 MR. BENDER: Does it exert enough external
17 pressure or internal pressure to cause the gap to open
18 up?

19 MR. SCHWALLIE: No. The stainless steel is
20 very stable. We don't have any of the zircalloy type
21 irradiation creep instability problems that you might
22 have in another reactor.

23 MR. BENDER: And the cladding is strong enough
24 to hold the pressure?

25 MR. SCHWALLIE: That's right. One of our

1 design-imposed constraints is that that balance of
2 fission gas pressure under steady state operation, we
3 never want the stress level greater than the
4 proportional elastic limit. That kind of keeps us clean
5 from a lot of considerations.

6 What we are off-balancing is the stress
7 rupture capability of the cladding in time under that
8 internal pressurization.

9 MR. BENDER: How about the ratcheting
10 phenomena? Are any of those of concern in this
11 particular fuel?

12 MR. SCHWALLIE: We haven't seen it in our
13 testing programs. Just one test we did to try to
14 address that about a year and a half ago is we took some
15 pins of varying burnups in EBR-2, cycled the pins from
16 about 100 to 150 percent over power for 54 cycles. And
17 we got -- we couldn't measure the strain difference
18 prior to and after testing.

19 MR. BENDER: Thank you.

20 MR. SHEWMON: Staying on those two subjects
21 for a minute, you've never seen any fragmentation of
22 your pellets?

23 MR. SCHWALLIE: Yes. When we do destructive
24 exam, we crack the pellets very severely.

25 MR. SHEWMON: And they never get out of whack

1 and out of orientation and give a local strain to the
2 cladding?

3 MR. SCHWALLIE: The only time we ever -- not
4 an oxide fuel. We have never been able to see localized
5 stress concentrations other than in some very early days
6 in carbide fuel when we had sodium-bonded pins and we
7 had very large fuel clad gaps, totaling an applicable
8 situation to here where you've got a big pellet chip in
9 that annulus and carbide fuel being very, very hard and
10 very, very stiff, did give rise to a breach mechanism of
11 the cladding.

12 In oxide fuel we have never seen fuel
13 fragments or anything like that, and we have tests where
14 we have known that we have -- in the radiation program
15 we have rogue pellets, so to speak. We speak of an
16 off-normal pellet as a rogue, and what you get is you
17 tend to get a lot of elasticity of the fuel itself. The
18 fuel has pretty good radiation creep characteristics to
19 allow it to hot press, so to speak.

20 MR. SHEWMON: A different question. You've
21 got a quarter of an inch of stagnant sodium between your
22 sub-assemblies, apparently, that being something like
23 the offset of your subassembly shims up top. Has that
24 caused any sort of problem or extra transient when you
25 change power? Or if the temperature doubles?

1 MR. SCHWALLIE: We refer to that as the
2 interstitial flow throughout the core region, and we
3 modeled that and we predict its behavior, both where it
4 goes and what its temperature seeks, and what you find
5 is flow is -- first of all, leakage flow is very low,
6 and what you find is wherever it goes it takes on the
7 temperature of the duct structure that is next to you.

8 MR. SHEWMON: So that is basically stagnant
9 sodium convecting?

10 MR. SCHWALLIE: It kind of perks its way up
11 very slowly.

12 MR. SHEWMON: Okay.

13 (Slide.)

14 MR. SCHWALLIE: Okay, in terms of rod
15 internals in FFTF -- we have a different plutonium
16 concentration than in FFTF, and our EBR-2 data base is
17 primarily on 25 percent plutonium, and I will come back
18 to that a little bit later. We have a little bit higher
19 pellet density than FFTF. We found that it was a little
20 bit better to put our void in the side of the plenum
21 rather than in the pellet itself, so we translated it to
22 a little bit smaller diameter than FFTF. The
23 combination of the two gives you the same smear density.
24 We have axial blankets. FFTF only had a
25 couple insulated pellets to make the damage transition

1 from the top fuel pellet to an inconel reflector that
2 they have on the top of their pin, above and below.
3 That is reflected here (indicating). We have a bigger
4 fission gas plenum than FFTF, and of course, our rod is
5 longer.

6 MR. WARD: The fission gas plenum, does that
7 count as part of the smear void?

8 MR. SCHWALLIE: No, the smear is totally an
9 area concept, not a volume concept.

10 (Slide.)

11 Okay. In terms of the blanket assembly, --

12 MR. WARD: It is a cross-sectional area?

13 MR. SCHWALLIE: Yes, a cross-sectional area.
14 Now, in terms of the blanket assembly, externally they
15 look the same. The inlet nozzle is just a little bit
16 different. The orifice plates are in the bottom of the
17 shield region. The primary difference is in the tube
18 bundle itself.

19 (Slide.)

20 The blanket rods, there are 61 of them in the
21 assembly. They are 506 in diameter, 15 mil wall
22 cladding. The big feature is a four-inch axial pitch on
23 the wire wrap, and that is primarily due to a desire on
24 the part of mitigating the gradients of cross-radial
25 blanket assemblies. The four-inch wire wrap pitch gives

1 you very good distribution across the assembly so that
2 in the outer rows you try to get the hot and cold flow
3 communicating so the temperature gradient across it from
4 a bowing standpoint is mitigated.

5 The pin pitch to diameter ratio is very much
6 tighter. This is a 33-mil wire wrap as compared to 55
7 mils for the fuel. Again, though, just a stack of
8 pellets with a spring and a spacer, and these also have
9 tag gases in them. So that if they fail, we can detect
10 them, also.

11 MR. EBERSOLE: Does that wire wrap form the
12 actual spatial separation itself?

13 MR. SCHWALLIE: Yes.

14 MR. EBERSOLE: Is there any potential for
15 gnawing over the years, or chewing up that 15 mil cover?

16 MR. SCHWALLIE: Yes, we learned our lessons
17 there. In the early days of EBR-2 when we went to
18 61-pin bundles we always had a concern of introducing
19 too much bundle duct into action. In other words, where
20 you wanted to make loose bundles so that when we got a
21 lot of swelling we didn't pinch the pins too much.

22 What we found is we made them too loose and we
23 did get vibration and wear and we chewed some cladding
24 up. The fix is if you stay, as a rule of thumb, below 6
25 mils per ring of fuel total porosity, you can preclude

1 that, and we have done that in EBR-2 and the bundles
2 have worked very well.

3 We have looked at bundles out of FFTF; one of
4 the lead assemblies that was in there that has had over
5 100 days of full flow conditions on it, and it is very
6 clean. And, of course, the French experience has been
7 very good that way, also. So we have got that problem
8 licked, but we did have it at one time.

9 MR. WARD: You seem to be able to recount
10 French experience on some issues and not on other issues.

11 MR. SCHWALLIE: Well, I think what comes
12 primarily from in the fuel business we have quite a bit
13 of interaction with them from time to time. Different
14 disciplines interact a little bit differently in terms
15 of the interaction of the base programs.

16 (Slide.)

17 I thought I would just show you what a shield
18 assembly looks like and what its functions are.
19 Actually, it is the shield of permanent reactor
20 structures. They are very simple in external
21 appearance, just like a fuel and a blanket. They have
22 for a tube bundle just solid rods, just for shielding
23 purposes, and we double-decked these rods in certain
24 locations, 14 of them on two sides of the core protect
25 some baffle welds.

1 And then the other function is that we have
2 the center of several of these assemblies dedicated to
3 having a tube on the inside. That contains surveillance
4 specimens to get lead information on ductility and so
5 forth of the permanent reactor structures. So it is
6 basically a shielding and surveillance function, and
7 also, to transmit the forces of core restraint loads out
8 to the core former rings.

9 (Slide.)

10 In terms of some design evaluations, in terms
11 of the cladding on the fuel for the two limits that I
12 talked about for steady state operation we've got about
13 a 35 percent margin on the CDF technique, 75 percent on
14 the constrained technique including transients through
15 the unlikely events. We have got 2 percent margin on
16 the ductility limit. This should be CDF and this is
17 ductility-limited strain.

18 We analyzed the wire wrap through time, and we
19 have two concerns; one is we don't stretch it too much,
20 and the other is that it doesn't get too loose versus
21 time. So we talk in terms of keeping the stress levels
22 pretty low, and also, its ductility-limited strain. And
23 then we don't want any wire slackening such that you get
24 wire movement up and down the pin.

25 MR. BENDER: Excuse me. Have you had any

1 experience with wires breaking?

2 MR. SCHWALLIE: We have never been able to --
3 there are two cases that I'm aware of. When we took the
4 bundle apart we have broken wire; one was on the fuel
5 and one was on a blanket. But my opinion is that we
6 broke them when we were taking them off because we were
7 trying to strip the duct off the tube bundle. When we
8 -- let me back up a second.

9 When we take these assemblies out of the
10 reactor, we do six-position neutron radiography of the
11 assemblies, and you can see the outside rows of the
12 assemblies very plainly, or the fuel pins. We go to
13 pull the duct off and it is tight, and we have actually
14 had to slit -- and both of these bundles we had to end
15 up slitting the duct to get it off, and after the fact
16 we found a wire on an outside pin, but we could never
17 see it broken on the radiographs and I think we broke
18 them when we were trying to strip the duct off.

19 MR. BENDER: If wires did break, what would be
20 their behavior in the flowing sodium? Would they just
21 stay where they are?

22 MR. SCHWALLIE: I think certainly, after we
23 got into where we had a bundle, a positive bundle
24 interaction effect with the multiple contact -- you have
25 contact with the pin continuously along that wire's

1 length. I wouldn't project that it would move. I think
2 it might move if it broke, and if there was a little
3 pre-stress left in it you might expect it to give a
4 little bit. But it is sort of like a spring; it has a
5 permanent set and as you wrap it I wouldn't expect it to
6 move much. The ones that were broke, they just stayed
7 there; they didn't coil up or anything.

8 MR. BENDER: There are advance fuels coming
9 down the pike. What is the nature of the things you can
10 see further down the line?

11 MR. SCHWALLIE: Well, from a fuel lifetime
12 point of view, my biggest concern has been the
13 deformation in that in the three 16 cladding, higher
14 fluences will swell a lot, and the advance alloys,
15 alloys that are lower swelling will certainly mitigate
16 that problem. And that the wire wrap will probably work
17 fine as long as we can keep the overall deformation of
18 the assembly below, say, two wire diameters. That is,
19 the interaction between the bundle and the duct.

20 We do have fallback positions in the program.
21 We do have derivative assemblies in FFTF right now that
22 could eventually be utilized as an alternate spacing
23 mechanism.

24 MR. BENDER: Well, I've heard talk of thinner
25 cladding. Is that real or just one part of the passing

1 parade?

2 MR. SCHWALLIE: I don't think personally it is
3 too real. I think the way to go is we might increase
4 the smear density in the fuel a little bit more, or we
5 find that smear density would go a little lower but
6 thinning the cladding below 15 mils doesn't have a lot
7 of practicality in my opinion, primarily from a
8 fabrication point of view and the defects that you get.

9 MR. BENDER: Thank you.

10 MR. WARD: One other question. What are the
11 heat transfer characteristics of that wire wrap? Does
12 it act as a fin, or does it cause a hot spot on the
13 cladding?

14 MR. SCHWALLIE: What you get is if you can
15 imagine an azimuthal profile of the temperature as you
16 go around the pin and you start under the wire, you will
17 get roughly a 50 to 100 degree, depending upon where you
18 are in the pin and what the heat flux is at that point,
19 you will get a 50 to 100 degree hot spot. Then as you
20 go away from it and you start dropping around, you will
21 get in the middle of the subchannel and so forth. So
22 you do get this cusp type temperature distribution
23 around the pin.

24 MR. SCHWALLIE: All of the hot spot
25 temperatures that Mr. Markley discussed earlier were

1 under the wire wrap.

2 (Slide.)

3 In terms of bundle duct interaction, we don't
4 want to get too loose, we don't want to get too tight.
5 This is the limit that we learned out of EBR-2 that was
6 good to stay away from, from a looseness point of view.
7 And we tried to stay within one wire wrap diameter on
8 bundle tightness.

9 (Slide.)

10 I have similar information for the blanket
11 assemblies but I think I will skip it because of the
12 time.

13 (Slide.)

14 In terms of the development programs, these
15 are in a global nature the status of the activities that
16 have occurred up to now. Some of these tests were
17 listed by Bob Markley. I list them because I am
18 interested from, not a hydraulic point of view, for
19 example, on these flow and vibration tests, but I'm
20 interested in vibration characteristics of the
21 assemblies. And again, that goes to the amount of
22 porosity you put into the bundle.

23 All of our out of reactor testing is done from
24 our vantage point. We would consider our steady state
25 irradiation program in EBR-2 on reference fuel to be

1 complete. Of course, we will be getting FFTF data and
2 we have completed the transient testing on TREAT reactor
3 on the other two reference pins.

4 We have got a lot of information on both the
5 mechanical properties and their dependency with time and
6 irradiation effects, and we have correlations that
7 describe the swelling in reactor deformation and
8 post-irradiation properties of different heats of steel
9 so that we can encompass what our steel is going to
10 behave like.

11 And we have also got quite a bit of experience
12 now on run beyond breach experience in EBR-2.

13 MR. WARD: How long -- let's say the cladding
14 breach occurs and we have this system for detecting it.
15 How long is it before you know you have it, and what
16 sort of damage can you do to the fuel pin in the
17 meantime?

18 MR. SCHWALLIE: There are two aspects. If we
19 have had plenum breaches not in the fuel region itself
20 in EBR-2 our experience has been that they do not result
21 in fuel-sodium contact leakers of any kind. We have
22 logged some sodium in some pins but nothing happens; we
23 get no DND signal release out of them at all. The gas
24 comes out, the covered gas system says yes, we let it
25 run and they are very stable.

1 The other thing, if we get breaches in the
2 fuel region itself, what we find in oxide fuel is that
3 you generally get a very thin, intergranular crack
4 through the cladding. Now, if you are not in a region
5 where you had clad swelling so that the fuel is still
6 pushing out and it is the driving force, we can run
7 about 20 to 25 days in EBR-2 and we get a DN signal,
8 provided we haven't had a shutdown during that time.

9 If we have a shutdown, we find that going down
10 and logging sodium and coming back to power with some
11 fuel-sodium reaction we open up the breach and we get a
12 bigger DN signal than we had when we shut down. There
13 are pins in EBR-2 that have not had shutdowns, and we
14 can usually run 25 days with confidence. And we have
15 had a couple of subassemblies that have been in a high
16 swelling regime that have run 96 days. So we are kind
17 of optimistic.

18 We're also finding that the kinetics of
19 fuel-sodium reaction are pretty slow, and its burnup is
20 dependent upon the amount of free oxygen that is
21 available on the pin surface at that time. But it is
22 not accelerated; it doesn't just happen in a matter of
23 hours. It takes a couple of days.

24 Okay, I have a similar kind of slide on the
25 blanket development testing.

1 (Slide.)

2 Just a couple to point out because blankets
3 were so much different and FFTF didn't have them. We
4 went ahead and did some of this bundle compaction
5 testing to try to determine the stiffness of that bundle
6 and how it might interact from a pinch plane point of
7 view of the wire and pin against the duct.

8 That kind of testing was done for the fuel in
9 FFTF. We have also done flow and vibration testing on
10 the blanket since it was different. We have done some
11 duct load pad crush tests to see how the bundles react
12 to it.

13 And we have done some cladding rupture testing
14 because of the larger diameter cladding, and this test
15 here was an irradiated duct out of EBR-2 to try to get
16 -- for a long time people thought that there was no
17 ductility left in the irradiated material and we
18 demonstrated that there was plenty of ductility left to
19 handle any kind of deformation that we got from our
20 seismic loadings.

21 (Slide.)

22 The emphasis today in the testing program of
23 the fuels program is to try to link our EBR-2
24 understanding to FFTF to account for the things that now
25 we have got long pins instead of short pins, we've got

1 different fluence to burnup ratios, different chemistry
2 and so forth. We have three tests in FFTF; two of them
3 are in there now, this one is going in in May that has
4 axial blankets and 33 percent fuel. So that through
5 these three tests we can directly relate our plutonium
6 difference to the 25 percent data base that we have.
7 These two assemblies will also give us information in
8 that they have axial blankets, also.

9 We have some experience to date -- there was a
10 test done in EBR-2 that had both 30 and 40 percent
11 plutonium in there, and the destructive examination data
12 on that to date says that within the scatter statistical
13 behavior of each of the kinds of phenomenon that are
14 sensitive to plutonium concentration, there is no
15 significant difference.

16 Again, these tests will address that. And
17 then the reload fuel for FFTF is about 30 percent
18 plutonium, so we're getting a large amount of data to
19 extrapolate off of that.

20 In terms of this linkability here, two things
21 are going on there. And this is primarily not only
22 steady state. We are reproducing a lot of the fluence
23 to burnup tests that were done in EBR-2 but this is also
24 testing FFTF rods at comparable ramp rates as they are
25 done for EBR-2 rods to see if long fuel columns behave

1 any differently than short fuel columns.

2 We do have somewhat of a lack of overpower
3 transient data for slow overpowers, and this is below 10
4 cents per second. I described this test to you. This
5 was a blanket test.

6 MR. CARBON: Excuse me, Mr. Schwallie, could
7 you wind up rather quickly?

8 MR. SCHWALLIE: Yes, no problem. This
9 operational reliability testing program was to get from
10 .1 to 10 percent ramp rate data to go along with the 50
11 cent up to \$3.00 per second ramp rate data we have. Two
12 tests were done last week and were taken to 60 percent
13 overpower in EBR-2 and did not fail, so we got a factor
14 of 4 on a 14 percent overpower capability at Clinch
15 River.

16 This FCCT testing is fuel cladding transient
17 testing; that is, ex-reactor testing of cladding that
18 has been irradiated both next to fuel and not next to
19 fuel so we can get the fuel adjacency effect that Mr.
20 Baars talked about this morning. And we will be doing
21 three tests at 10 cents a second to see how it
22 correlates with the EBR-2 data.

23 We have an active RBCB program in EBR-2, and
24 we have three blanket tests for FFTF. These two are in
25 the reactor, and this is an instrumented assembly that

1 will be going in about a year or year and a half from
2 now, and we will do a natural circulation simulation on
3 a blanket assembly in FFTF. It is a fully instrumented
4 assembly.

5 (Slide.)

6 The next slide just summarizes that testing
7 program. I don't think we need to spend much time on
8 it, but everything is in place to answer the questions
9 and address the concerns that the staff had.

10 (Slide.)

11 In terms of my overall conclusions, we do have
12 a design basis that is relatable back to the regulatory
13 guides and the damage severity limits that the core has
14 to survive under. The analysis and testing that has been
15 done to date shows that there's a very high probability
16 of this core performing acceptably and meeting its goal
17 lifetimes, and that the testing programs are in place to
18 gain the understanding that some people think we might
19 not have.

20 MR. REMICK: What are you trying to accomplish
21 in the RBCB test in EBR-2?

22 MR. SCHWALLIE: One of the big things we're
23 trying to do is from an operational point of view, we
24 would like to use the DND system, the delayed neutron
25 detection system, as a diagnostic to give us information

1 on that breach in the core.

2 What we've found so far is that we can relate
3 DN signal strength to breach size. The amount of
4 exposed fuel that is available to coolant.

5 MR. REMICK: Are you looking at propagation or
6 is that pretty well settled?

7 MR. SCHWALLIE: No. I think propagation, as
8 far as I'm concerned, is a dead issue. We are primarily
9 just wanting to get experience on the kinetics of that
10 fuel-sodium reaction and how it translates into
11 diagnostic information.

12 This also has very important application for
13 the reactor maintenance. We are also trying to see if
14 we actually do put plutonium into the system. That is
15 another positive thing that has come out of the RBCB
16 program in EBR-2; that we have yet to elevate the
17 plutonium level in EBR-2 with all of the tests that we
18 have done. We don't apparently create a maintenance
19 problem with RBCB type operations.

20 MR. WARD: The reason, I guess, propagation
21 you say is a dead issue -- is that mainly because the
22 failed rod doesn't swell up and interfere with the flow
23 in the rest of the assembly?

24 MR. SCHWALLIE: That is primarily it. Plus,
25 you tend to -- first of all, the nature of the breaches

1 we get, we don't get rapid gas ejection. If you fail in
2 a plenum region it is generally a micro-fissure
3 inter-granular type thing, and the gas just comes
4 blowing down very slowly. If you fail in the fuel
5 region, it is generally because you've got fuel-cladding
6 interaction and the fuel is plugging up the breach, so
7 to speak, and the gas doesn't come out quick, either.

8 MR. WARD: How much of the favorable overall
9 characteristics is due to your helical flow? I think
10 you mentioned you have got a backup fuel design that
11 would have not wire wraps but some other type.

12 MR. SCHWALLIE: Grids.

13 MR. WARD: Should we be concerned about
14 whether there might be more of a failure of flow
15 reduction in propagation reaction?

16 MR. SCHWALLIE: I think grids have a little
17 bit more concern to me from a blockage, debris
18 retention, point of view than the wire wrap does.

19 MR. CARBON: Any other questions?

20 (No response.)

21 Let us take a break, then.

22 (A short recess was taken.)

23 MR. CARBON: Let's go on with the meeting.
24 I've been requested to announce that if we go beyond
25 7:00 o'clock we should warn people in the garage that

1 the garage downstairs closes at 7:00. But if we are to
2 stay on schedule, we will be done before 7:00.

3 MR. CLARE: I will do my very best. The
4 subject I would like to address at this point is what I
5 have called fluid-system interfaces, which is
6 alternatively on the agenda called fluid circuitry
7 interfaces. I am not certain that there is any real
8 difference.

9 What I will do is to step briefly through each
10 of the major fluid systems in the plant and identify the
11 interfaces that that fluid system has with other fluids,
12 including gases, environments, et cetera, and identify
13 in a general sense -- and I believe that is all that
14 time would allow for -- the kind of approach, the
15 features that we have to assure that whatever the
16 interactions might be at that interface, will be
17 acceptable.

18 (Slide.)

19 And the first system that I will address is
20 the primary sodium coolant system. And it has three
21 other fluids that it has interfaces with. And I might
22 note that I will address the argonne cover gas last, so
23 it will not show up until we get to the last viewgraph.

24 Of course, a principal interface with the
25 primary coolant system is the sodium coolant system, and

1 that interface is through the passive boundary of the
2 intermediate heat exchanger.

3 Now, one of the principal things we do on that
4 interface is to maintain the pressure of the
5 intermediate heat transport system greater than the
6 pressure of the primary heat transport system, which
7 means that if a leak should develop, any leakage would
8 be from the non-radioactive sodium system into the
9 radioactive sodium system, thereby reducing any
10 consequences in terms of leakage of radioactive material
11 out towards the environment.

12 We do have leakage detection that will tell us
13 when any significant volume of IHTS sodium has leaked
14 into the primary heat transport system, and there is a
15 very considerable volume beyond the detection capability
16 to accommodate that in terms of an expansion of the
17 volume of the PHTS. So that there is no immediate hazard
18 from whatever leakage might occur.

19 MR. MOELLER: Excuse me, when you say that is
20 a passive boundary, what do you mean by that?

21 MR. CLARE: I mean it is a tube, a solid steel
22 tube. There are no valves, for example, leakage paths
23 from the original design standpoint. It would have to
24 be a structural failure of some sort in order for the
25 fluids to intermix.

1 MR. MOELLER: Okay.

2 MR. CLARE: We do have also on the primary
3 sodium coolant system an interface with Nak, and before
4 I go further, let me talk briefly about Nak. A question
5 that has come up a couple of times in prior meetings.
6 Nak is a eutectic mixture of sodium and potassium.

7 (Slide.)

8 22 percent sodium, 78 percent potassium by
9 weight. The melting temperature is 9 degrees
10 Fahrenheit, the boiling temperature is just a bit below
11 the boiling temperature of sodium. The Nak boiling
12 temperature being 18 degrees F. Any mixing of sodium
13 and Nak would not result in a chemical reaction, would
14 not result in an adverse effect on the process equipment.

15 There would be an increase in the Nak melting
16 temperature as we moved away from the eutectic point.
17 Similarly, there would be a decrease in the sodium
18 melting temperature as we add Nak.

19 Now, the fact of the matter is that when we
20 look at our systems there is very, very little Nak
21 compared to the sodium systems that it interfaces with.
22 So there would, in fact, be very little effect in terms
23 of a decrease in the sodium melting temperature. There
24 might be some increase in Nak melting temperature, but
25 even that, within the volume that could be accommodated,

1 would be essentially insignificant.

2 MR. SHEWMON: Why did you use Nak?

3 MR. CLARE: We used Nak principally because of
4 this temperature.

5 MR. EBERSOLE: I figured you did. Now, when
6 you mix sodium with it, that temperature is going to go
7 up, isn't it?

8 MR. CLARE: That is correct.

9 MR. EBERSOLE: Will that cause some problems
10 in the instrumentation?

11 MR. CLARE: No, it would not. The statement
12 about adverse effect on process equipment is essentially
13 true. Now, if there were large amounts -- let's assume
14 I approach pure sodium. That theoretically could become
15 a problem. However, one would detect any leakage before
16 any significant percentage increase in the sodium
17 content, and you might increase this to 20 degrees
18 Fahrenheit, but there would be no significant difference.

19 MR. SHEWMON: The Nak is what you cool your
20 cold trap with? Is that right?

21 MR. CLARE: The Nak is what we cool our cold
22 trap with. It is also the secondary coolant in what we
23 call our direct heat removal service. The interface
24 there is in a heat exchanger; shell and tube heat
25 exchanger. We call it the overflow heat exchanger.

1 MR. MOELLER What is the sodium melting
2 temperature?

3 MR. CLARE: For pure sodium, I believe that's
4 218 degrees.

5 MR. REMICK: What are the limitations on the
6 amount of Nak you can get into sodium and still
7 operate? Is it an activation problem? Primarily, a
8 long-term activation problem?

9 MR. CLARE: Getting Nak into sodium would
10 result in some activation products we would not
11 otherwise expect in any significant quantity. Is that a
12 problem? That would be a slight operational problem and
13 it wouldn't even be a very significant one from that
14 standpoint. So it is not even clear that for the small
15 amount of Nak that one might expect to leak that it is a
16 problem at all.

17 MR. REMICK: So there is no limitation on the
18 leakage of Nak in the sodium?

19 MR. CLARE: Well again, we will detect it, and
20 we can detect it by detecting the levels in the
21 expansion tanks on the Nak system. And we would expect
22 to detect very few gallons going into a million gallons
23 of primary sodium.

24 MR. SHEWMON: Is there any straightforward way
25 you could get sodium out of Nak, or I'm sorry, sodium

1 out of the Nak, or potassium out of sodium?

2 MR. DICKSON: Distillation is the only way.
3 You might have noticed that the Nak systems are all at
4 higher pressure, so you would almost never expect sodium
5 to leak into the Nak, raising the boiling point. Any
6 interface would leak Nak in, and the quantity of primary
7 sodium is so vast compared with the quantity of Nak that
8 you would never get into any activation problem that you
9 would notice in consideration of the design basis amount
10 of fission products that you assume is in the sodium.

11 MR. BENDER: Does the potassium influence the
12 corrosion characteristics of the sodium at elevated
13 temperatures at all?

14 MR. CLARE: To my knowledge, it does not.
15 There have been successful operations of Nak-cooled
16 reactors before, with no specific problems.

17 MR. BENDER: I know, but I wasn't sure what
18 the temperature was.

19 MR. CLARE: I don't know the exact
20 temperature, but to my knowledge, there are no such
21 effects.

22 MR. SHEWMON: I would be willing to bet you
23 even more money than a dime that it's just about like
24 sodium, and once you get the oxygen out, why, you're in
25 good shape.

1 MR. BENDER: You're a good enough authority
2 for me.

3 MR. CLARE: Now, the third interface that I
4 have identified here is that of the nitrogen environment
5 in the RCB cells, and all of our primary sodium, piping
6 and components are located in inerted cells within the
7 reactor containment building. And, of course, the
8 piping and the components provide a passive boundary to
9 those cells.

10 There is sodium leakage detection in each of
11 the cells to tell us should there even be a tiny leak of
12 sodium, and in addition, the inerted environment in the
13 cell, along with the liner, a carbon steel liner which
14 completely surrounds the cell or completely lines the
15 cell I should say, completely surrounds the primary heat
16 transport system equipment, avoids any sodium-concrete
17 reaction.

18 This type of provision I assume we will
19 discuss in detail next month when we discuss the
20 containment philosophy.

21 Now, the other point I have identified for
22 this interface has to do with the separation of any
23 leaked sodium in that cell from any cooling water that
24 is separated by yet another passive boundary. And just
25 to note quickly without going into detail that we have

1 the additional protection of being able to detect,
2 isolate and drain away any water that might have leaked
3 from the water cooler for that particular cell for the
4 remote case that we would even have any sodium leakage
5 into the cell.

6 (Slide.)

7 Now, the second fluid system that I will
8 address is the intermediate sodium cooling system. Now
9 again, following out the heat transport system, the
10 principal interface is with our steam water system,
11 through the passive boundary of the steam generator
12 modules. I will discuss at length in my next
13 presentation the features we have for leak detection and
14 leakage accommodations which include rupture discs,
15 reaction production separation and collection system,
16 and a dump system and safety relief systems to relieve
17 the water on the water side.

18 Now, some of the intermediate sodium piping
19 runs in the same inerted cells in the containment people
20 as the primary heat transport system, and we have the
21 identical protection against any leakage into that cell
22 for the intermediate that we do for the primary.

23 In addition, a major portion of the
24 intermediate sodium equipment is located in an air
25 environment in the steam generator building cells. Now,

1 the key difference between these cells and these cells
2 (indicating) is that the sodium out in the air
3 environment is not radioactive, and therefore, there is
4 no particular need to absolutely prevent the release of
5 any sodium-sodium reaction products from those cells.

6 The equipment, of course, provides a passive
7 boundary, and in the intermediate building we also
8 provide very sensitive leak detection. As leakage
9 accommodation, we have catch pans in the bottom of the
10 cells to collect any leakage and protect any concrete
11 below the equipment. On some of the catch pans where
12 there would be the greatest accumulation of sodium, we
13 have fire suppression decks which are -- think of them
14 as a sheet metal cover over the catch pan, which will
15 act, by reducing the amount of air access to the sodium,
16 to reduce both the amount of burning and the duration of
17 burning for the pool fire that would result from the
18 collection of sodium in the catch pan.

19 Another important feature we have is loop
20 separation. Each of the three heat transport loops is
21 located in a completely environmentally separated set of
22 cells from the other heat transport loops. So a sodium
23 fire that results from leakage in one loop would not
24 carry over in any direct way and affect the other loop.

25 However, we do relieve the pressure in any one

1 of those cells which can release aerosols from the
2 building, and of course, depending upon meteorological
3 conditions, there could be some aerosol carryover into
4 some other portion of the building. And we have
5 qualified our equipment, we have specified that the
6 equipment will be qualified as necessary to operate in
7 that sodium aerosol environment.

8 Now, another sodium coolant system that we
9 have in the plant is the sodium system that cools the
10 ex-vessel storage tank, and that is our version of a
11 spent fuel pool that you would have in a light water
12 plant. It is a tank on the outside. It appears much
13 like our reactor vessel, and in it we store any spent
14 fuel which has been discharged from the reactor.

15 Because we are dealing with radioactive sodium
16 in this case, we will bring radioactive sodium into this
17 vessel as a result of refueling. We contain that sodium
18 system in the same type of lined inerted cells that we
19 have for the primary coolant system, and all of the
20 provisions are identical.

21 MR. WARD: Why don't you use Nak in the
22 ex-vessel storage tank? I should think there might be
23 some advantage to that in freezing temperatures.

24 MR. CLARE: One could, but the way we transfer
25 both new and spent fuel is we carry the fuel assembly in

1 a little pot of sodium, and since we're going to be
2 interchanging it with the reactor, it makes more sense
3 to keep this sodium.

4 Now, the EVS' sodium coolant system is itself
5 cooled by three Nak coolant system, and these Nak
6 coolant systems have the same sorts of protection from
7 the radioactive system as does the intermediate heat
8 transport system from the primary heat transport
9 system. Pressures are maintained so leakage will be
10 towards the radioactive source.

11 Leakage detection, leakage accommodation --
12 the Nak itself is located in a combination of nitrogen
13 environment and air environment, and when it's in a
14 nitrogen environment, it has the same sort of protection
15 as the sodium does; when it's in an air environment it
16 has essentially the same protection as the intermediate
17 heat transport system sodium.

18 MR. AXTMANN: On the previous slide you listed
19 an aerosol mitigation system. Could you describe that
20 in a sentence or two?

21 (Slide.)

22 MR. CLARE: The aerosol mitigation system per
23 se is merely a system which we provide while providing
24 some cell pressure relief and we don't design the
25 building as a high pressure containment sort of building

1 so we do have to vent the building. At the same time,
2 we want to limit the amount of venting and limit the
3 amount of aerosol that may be released to the
4 environment which can then carry over into other parts
5 of the plant.

6 So, it principally will consist of some
7 combinations of louvers, dampers, et cetera, which can
8 be closed at some appropriate time after the pressure
9 has been relieved.

10 MR. EBERSOLE: But your rupture discs, they
11 discharge into some space, which I take it is of limited
12 volume.

13 MR. CLARE: Yes, they discharge into the
14 reaction product separation tank, and I will be covering
15 that in another schematic later.

16 MR. MOELLER: On the right hand, what did RCB
17 stand for?

18 MR. CLARE: Reactor containment building.

19 MR. MOELLER: Thank you.

20 (Slide.)

21 MR. CLARE: The final point I will cover is
22 relative to the argonne cover gas system, and all of our
23 liquid-metal systems are capped with their free surfaces
24 exposed to an argonne atmosphere. So we have an argonne
25 cover gas on the primary and the intermediate system.

1 The EVST sodium coolant system I have left off for
2 purposes of space. The EVST Nak coolant system. But it
3 would fall into the same situation.

4 We also have argonne in our fuels handling
5 cell, and this is because in the fuel handling cell we
6 would be handling spent fuel assemblies which are
7 essentially covered with a film of sodium. So we want
8 to maintain that as an inert environment.

9 There, of course, is a direct interface with
10 the coolant, the liquid-metal coolant, in every case.
11 And, of course, the pressure is the same in the cover
12 gas as it is in the sodium. Most of the systems are at
13 about one atmosphere.

14 The key difference being that in the
15 intermediate sodium coolant system you will recall I
16 said we wanted to keep the intermediate pressure higher
17 than the primary pressure in the intermediate heat
18 exchanger, and we do that by pressurizing the cover
19 gas. So it is significantly greater than one
20 atmosphere. In fact, our nominal setpoint for that
21 would be 93 psi.

22 In essentially all cases, we monitor the
23 purity of the argonne cover gas, principally from the
24 standpoint of radioactivity. Also, we look at such
25 things as oxygen content, water vapor. We can sample

1 the cover gas, and then we have various means of
2 processing the cover gas, depending on what it might be
3 postulated to contain.

4 In the case of the primary system, as we
5 discussed a few minutes ago, there could be leaking in
6 fuel pins which would result in fission gas bubbling up
7 through the sodium and entering the argonne cover gas.
8 Therefore, we have a radioactive argonne processing
9 system that will remove those fission gases. And that
10 is by use of a cryogenic still.

11 MR. REMICK: Question. What do you do with
12 the gases after you take them out through the cryogenic
13 still? Do you release them to atmosphere, or are you
14 going to bottle them up and store them in perpetuity?

15 MR. CLARE: We bottle them up and store them,
16 but not for perpetuity. What we do is we accumulate
17 them for about a period of a year. After a year, we
18 drain the still bottle into what we call the noble gas
19 storage vessel. Throughout the following year, we
20 release that radioactive gas through another rad waste
21 system, which we call CAPS, the cell atmosphere
22 processing system. That system contains cryogenic
23 charcoal debris beds which will provide some additional
24 holdup, and then they are vented to atmosphere.

25 MR. REMICK: And what comes out the venting?

1 Is it mostly cesium?

2 MR. CLARE: No, these are noble gases. It
3 would be crypton and xenon.

4 MR. REMICK: What is the longest term of the
5 half life?

6 MR. CLARE: I believe the xenon is the
7 longest-lived isotope or has the longest lived isotope,
8 but I would have to check the numbers to be sure.

9 MR. REMICK: Well, am I correct cesium comes
10 out of the cover gas also, or am I incorrect in that?

11 MR. CLARE: Cesium will not come out of the
12 cover gas. The cesium will stay with the sodium and it
13 will be plated out. Most of it, we would assume, is
14 going to be plated out in our cold trap, or at various
15 cold surfaces in the system. We would not expect that
16 with the cover gas.

17 I mentioned the cold trap briefly before, and
18 it is just a situation that -- it is a component where
19 we cool the sodium down and trap out any impurities that
20 might be in it.

21 Note that for the intermediate sodium system,
22 the cover gas, the argonne, is non-radioactive, so that
23 is simply a once-through system. We shove the argonne
24 in, and if we need to vent it we just vent it to the
25 environment.

1 The EVST coolant system -- we do monitor that
2 system but by and large, that is a once-through system.
3 We vent it to the environment through the cryogenic
4 charcoal beds of CAPS that I mentioned a few minutes ago.

5 The fuel handling cell is a rather large cell,
6 and it has a lot of penetrations. So there is some
7 potential for ingressive oxygen and water, and we have a
8 special atmosphere purification unit that cryogenically
9 removes oxygen and water from the argonne atmosphere
10 there.

11 MR. WARD: The argonne doesn't get exposed to
12 neutrons anywhere? You don't get any argonne 41?

13 MR. CLARE: We do get a small amount of
14 argonne 41, but it is not a large amount. And to the
15 extent that it exists, it will just stick with the
16 argonne itself. It just stays in the system.

17 MR. REMICK: Do you happen to know what the
18 gaseous effluent from CRBR would be compared with a
19 current BWR?

20 MR. CLARE: I know that the doses are very
21 much smaller, principally because our iodine will hold
22 up in our cold trap just like the cesium. It is very
23 tightly tied to the sodium, and also, tritium releases
24 are very low for this plant. So from an overall
25 radiological standpoint, this plant has a much lower

1 normal off-site dose than a light water plant. I can't
2 give you a quantification of that.

3 That, then, completes the overview of the
4 fluid systems interfaces.

5 MR. CARBON: Any further questions?

6 (No response.)

7 Thank you, Mr. Clare. The next topic on plant
8 materials, none of the people scheduled to speak are
9 here, so we will completely drop it and move on then to
10 the final topic, the steam generator accidents and
11 consequences. And I understand Mr. Stark will speak for
12 Mr. Beckner.

13 MR. STARK: This is Richard Stark again.
14 Unfortunately, Dick Beckner couldn't make it down in the
15 snow. I, nevertheless, met with Dick yesterday when we
16 had a kind of dry run, and I'm going to attempt to
17 summarize what I believe are the bottom line items of
18 the staff findings.

19 I would like to start off by saying first of
20 all, I want to compare the safety function of the Clinch
21 River Breeder Reactor steam generators to those of a
22 light water plant. A PWR steam generator typically
23 provides three safety functions. One is decay heat
24 removal, one is it plays a significant role in the steam
25 line break accident, and the third one is if you do have

1 an accident that involves the steam generator, usually
2 you have radioactive isotopes, so you have a radioactive
3 penalty to pay with it.

4 Looking at each one of these three items, the
5 Clinch River Breeder Reactor steam generator is used for
6 decay heat removal, so in that respect it is similar to
7 a light water plant. The second item on the steam break
8 accident -- it is not similar. The steam line break
9 accident in this particular plant is just a very minor
10 accident. As a matter of fact, it's an extremely small
11 accident for two principal reasons.

12 One is this particular reactor has a very
13 small negative temperature coefficient as far as
14 reactivity is concerned, and that alone would do it.
15 Another item is with the intermediate loop and the
16 primary loop and the steam generator being the third
17 loop, the loop times along, there is well over a
18 100-second delay time from the time you have this rapid
19 cooldown until it is sensed in the core.

20 The rods or a scram -- the PBS system would
21 scram the reactor in three to four seconds based upon a
22 steam flow mismatch, so for several reasons this is not
23 a significant concern.

24 The last item I was talking about the
25 radioactive consequences. Aside from a small amount of

1 tritium, the intermediate loop is non-radioactive. So
2 therefore, any leak that would go from the water side
3 into the sodium side, while it would be a violent
4 chemical action, is essentially non -- has no
5 radioactive consequences.

6 MR. MOELLER: You mentioned the tritium. Does
7 the tritium permeate?

8 MR. STARK: Through the I jets, that is
9 correct. The staff nevertheless looked at some
10 accidents and we analyzed small leaks and large leaks,
11 and the bottom line on small leaks is they are picked up
12 by hydrogen and oxygen monitors in the intermediate loop
13 and the consequences are insignificant.

14 The large leaks -- there is a rupture disc
15 into a steam to water reaction product system; I think
16 it is called SWRPS or something, and that handles and
17 deals with the reaction product.

18 It appears from what we have looked at that
19 the pressure pulse is such that the intermediate loop is
20 not challenged. There are rupture discs on the
21 evaporators and the superheater, and it looks like there
22 is also capability in the expansion tank. There is a
23 lot of buffers there and a lot of relief mechanisms that
24 will protect the IHX, which is the primary boundary
25 between the intermediate loop and the primary loop.

1 The IHX design pressure is on the order of 700
2 psi. All of these rupture discs rupture in the order of
3 300 to 325 psi, I believe.

4 In addition to that, it looks -- this is
5 another matter, but we have looked at the test plan and
6 it is a pretty good test plan. The steam generators in
7 the past have had not a very good history, but it looks
8 like the applicant is certainly trying to test it and
9 trying to get a lot of test history.

10 In addition to that, we do have an in-service
11 inspection program that is tied to this, monitoring the
12 steam generator. And there are a few other design
13 features which I'm sure the applicant will tell you
14 about.

15 In a PWR the water -- the steam comes in on
16 the shell side and evaporates on the shell side. All of
17 the good steam is boiled off and anything that
18 precipitates out falls down to the tube sheet, and
19 therefore, it collects all of the precipitates. I guess
20 they are all bad.

21 This particular steam generator is different
22 in that the water flows through the tubes, and the
23 sodium goes in the shell side. And all the separation
24 tends to take place in another tank, which is the steam
25 drum. So, therefore, the steam generator should be

1 spared from that particular item.

2 But in general, we think that from a safety
3 standpoint it looks as though the accidents involving
4 the steam generator have acceptable consequences. It
5 looks as though the applicant is trying to make a
6 reliable steam generator just from a commercial
7 operation standpoint, looking at the history that PWR
8 has. And we find from a safety standpoint that it is
9 acceptable, and I hope from a commercial standpoint that
10 he has good success.

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

1 MR. SHEWMON: What is the allowable leak rate,
2 or what happens if a leak does come in one steam
3 generator?

4 MR. STARK: That is the small break accident.
5 As I said, there are some sensors. Unfortunately, I
6 don't have all of the details, but the Applicant senses
7 for the presence of hydrogen and oxygen in the
8 intermediate loop and then takes the appropriate action,
9 shuts the plant down and fixes that particular leak. He
10 doesn't continue it. And I guess he will address this
11 in greater detail.

12 As I said, unfortunately our reviewer is not
13 here, and I'm trying to just give you the bottom line.

14 MR. EBERSOLE: In a bad failure what keeps the
15 failure from progressing to a failure when you might
16 generate a fire in the vicinity of the first failure?

17 MR. STARK: I'm not sure I can answer that
18 precisely, but we have looked at accidents that have
19 happened and have gone back to Fermi, and looking at the
20 whole history of leaks that we have seen. The Applicant
21 proposes three complete breaks in tubes, one followed by
22 another and then followed by another one. And at least
23 from an experience standpoint we feel that this
24 envelopes all of the experience -- more than envelopes.
25 What has been experienced in the past -- and I

1 am going to have to ask the Applicant to address that --
2 the real reason.

3 MR. EBERSOLE: It looks like it ought to be
4 autocatalytic and could just progress to something very
5 bad indeed. I mean having broken one and now two.

6 MR. STARK: It doesn't, but I don't know why.

7 MR. MOELLER: Recently I saw a news release or
8 something of a leak in the French Phenix. Was that in a
9 steam generator?

10 MR. STARK: Yes, it was. I think it happened
11 in December.

12 MR. MOELLER: You've looked at that, or will
13 someone tell us why we won't have one here?

14 MR. STARK: The Applicant's going to do a
15 better job than I have. What we have looked at, the
16 steam generators have had a lot of these little
17 problems; and as I indicated, from a reliability
18 standpoint it is something we are trying to look at and
19 make sure it is factored in. It has no safety
20 implications. And Phenix fixed it, and they are back up
21 again and running, and they were down for just a short
22 period of time, a couple of weeks, I imagine.

23 I know people are looking at steam generators
24 both from a safety standpoint and from a commercial
25 reliability standpoint. From a safety standpoint we

1 feel very good, and from a reliability standpoint it
2 appears that the Applicant is really trying to test this
3 particular steam generator as much as he can; and I
4 certainly hope he is successful in it because it will
5 help to demonstrate a good plant later on from a
6 commercial standpoint.

7 MR. CARBON: Just as a point of information,
8 have you looked at the several leaks that have taken
9 place in the PFR steam generator from the safety
10 standpoint?

11 MR. STARK: We have been aware of them, and we
12 have looked at the consequences, and we have looked at
13 the impact on Clinch River; and as I have indicated, we
14 don't see a safety problem.

15 MR. CARBON: Any further questions?

16 MR. STARK: That is all we have, and what I
17 would like to do is I would like to excuse ourselves
18 since we are all Washington-based now, and try to get
19 home.

20 MR. SHEWMON: One more question. If I wanted
21 to find a description of the neutronic safety-related
22 control system, where would I find it?

23 MR. DICKSON: Chapter 15 of the PSAR.

24 MR. STARK: He's talking about neutronic
25 control.

1 MR. DICKSON: Related to this accident?

2 MR. SHEWMON: Related to neutronics.

3 MR. DICKSON: Chapter 7.

4 MR. SHEWMON: Chapter 7 doesn't do much, and
5 it refers me to 3.2, and 3.2 is a misprint. So maybe
6 before you quit you can show me where in 7.

7 MR. CLARE: We can try to do that. The
8 control would be divided into two sections. In Chapter
9 7 you will find a discussion of the instrumentation of
10 control equipment itself, wires, transistors and those
11 kinds of things. In Chapter 4, 4.2.3, you will find the
12 discussion of the physical control rod and those kinds
13 of things.

14 MR. CARBON: Does anyone have any other
15 questions to address to the Staff?

16 (No response.)

17 MR. STARK: Thank you.

18 MR. CLARE: I hope I can deliver on all the
19 promises that I and others have made for what this
20 presentation will contain.

21 The subject is steam generator leaks.

22 (Slide.)

23 What do they look like, and when they happen
24 how do we accommodate them.

25 To begin with, I thought we could look just

1 conceptually at what are the kinds of problems that one
2 might get into as a result of steam generator tube
3 leaks. And Mr. Stark touched on them briefly.

4 The first is that if you do have a steam
5 generator leak, you would be in a situation where you
6 were shutting down the reactor with less shutdown heat
7 removal capacity than you might otherwise have.

8 The second is that because of the vigorous
9 reaction between water and sodium, mechanical loadings
10 on the primary and intermediate coolant boundaries could
11 be generated, and specifically, the intermediate heat
12 exchanger, the separation between the two boundaries is
13 of most interest. And then as a by-product of the
14 chemical reaction, hydrogen is generated, so that
15 reaction product needs to be dealt with in order to
16 avoid any adverse consequences.

17 Now, to address the first of these potential
18 indirect effects just simply and directly, we have a
19 multiple heat transport system, heat removal pads, and
20 operator flexibility to isolate, repair or replace a
21 leaking steam generator, as well as the direct heat
22 removal service which is a heat removal path from the
23 reactor which is totally independent of the steam
24 generators, all of which serves to mitigate the effects
25 of any steam generator tube leak on shutdown heat

1 removal system capacity.

2 Now, I will talk in a little more detail about
3 the latter two effects, and I will note for your
4 reference that this was discussed in somewhat more
5 detail by Paul Dickson in a June 25, 1982 meeting of the
6 CRBRP subcommittee.

7 (Slide.)

8 Now, we have three levels of protection
9 provided against the effects of steam generator tube
10 leaks. The first of these is leak detection from which
11 the operator can detect a leak and manually shut down
12 the reactor.

13 (Slide.)

14 And what I've drawn over on this other
15 vu-graph is a part of our heat transport system, a part
16 of one of our heat transport loops. What we have is an
17 intermediate heat transport system, sodium, that comes
18 into the superheater and comes down through the
19 superheater, and then there are actually two
20 evaporators. I've only shown one to keep things
21 simplified on the drawing.

22 The sodium goes through the evaporator and
23 back to the intermediate heat exchanger. We have leak
24 detectors on the piping, both exiting the superheater
25 and exiting the evaporator. In addition, we have vents

1 at the top of each of these units that vents a small
2 flow of sodium from the unit, collecting any gas
3 accumulation that might happen at the top of the heat
4 exchanger during normal operation, and we monitor those
5 areas. And what we do is to look for either oxygen or
6 hydrogen which would be the products of any sodium-water
7 reaction, and take the appropriate operator reaction in
8 response to it.

9 Now, there was a question -- and I think Dr.
10 Shewmon asked about it -- about what would be an
11 acceptable leak. There are three sorts of alarms, if
12 you will, that will tell the operator to do different
13 things. And I might note that these are preliminary
14 kind of procedure thoughts that we have at this point in
15 time.

16 The first alarm that we get in the system will
17 come at a level of about 2 times 10⁻⁵ pounds of water
18 per second -- a very, very small leakage rate. That is
19 not even a pinhole. At that point the operator will not
20 shut down the reactor. He will proceed to try to
21 understand what is going on using his various leak
22 detectors and try to be sure he knows exactly where the
23 leak is.

24 MR. SHEWMON: That was 10⁻⁵ gallons per
25 minute?

1 MR. CLARE: 10^{-5} pounds per second.

2 MR. SHEWMON: I will be glad when SI units
3 come to this field, but go ahead.

4 (Laughter.)

5 MR. CLARE: 10^{-2} grams per second. How's
6 that?

7 MR. MOELLER: Now, you say you will pinpoint
8 where the leak is. How does he do that?

9 MR. CLARE: He will not pinpoint it in terms
10 of a particular tube or even where within a unit, but he
11 will make certain that he knows which module it is in by
12 looking at which detector is giving him the strongest
13 signal.

14 Now, at a leakage rate between 10^{-2} and
15 10^{-1} -- and I'm sorry, it is pounds per second, and I
16 don't have a quick conversion to grams -- the operator
17 will begin to take this leak very seriously, and once he
18 has confirmed the leak, he will prepare to and go ahead
19 and shut down the reactor. So that would be at about
20 the limit at which we would operate the plant without
21 immediately scrambling.

22 MR. SHEWMON: You have done enough work so
23 that you feel that the growth of the void is still slow
24 up beyond that limit, or how do you pick that as an
25 action point?

1 MR. DICKSON: I want to add, one of the
2 problems with experience with little leaks is when you
3 shut down and close up, you can't find them at all. So
4 it isn't a matter of operating them and saying it's no
5 problem. Below this you know you can't detect it, so
6 all you do is shut down and then come back up again. So
7 you have to wait until it has gotten large enough to do
8 something.

9 MR. SHEWMON: But this is a singularly
10 unspecific detection system, and all it does is to say
11 there's a hole in the steam generator some place. And
12 you can then go back and do what?

13 MR. DICKSON: Which is why you wait until the
14 leak is large enough to be able to detect it, after you
15 have taken the water out and can go inside and inspect
16 it.

17 MR. SHEWMON: Do you detect with an eddy
18 current?

19 MR. DICKSON: Eddy current and pressure. Both
20 are means of detecting the leak.

21 MR. SHEWMON: So you're looking through 10,000
22 tubes with a probe to try to find something, is that it?

23 MR. CLARE: We are pressurizing the tubes,
24 yes. And that is why we at the very least want to know
25 what module it is in. We wouldn't want to go through

1 all three of them in a particular loop.

2 Now, the second level of protection that we
3 have is an expansion tank rupture disc on each loop with
4 automatic water dump.

5 Now, what this is is a rupture disc which
6 looks at the cover gas pressure in the expansion tank,
7 and just a few minutes ago I mentioned a 93 psi cover
8 gas, and that is what is contained in that tank, and the
9 tank level is used as a way to control volume as the
10 sodium heats up and expands and cools down and contracts.

11 If the pressure in the system reaches 150 psi,
12 a good 50 psi greater than the normal pressure here,
13 this rupture disc will burst, and it merely vents gas to
14 something called a sodium dump tank which I haven't even
15 shown here, and it's just a big, empty tank filled with
16 nitrogen which will then come back and equalize with the
17 argon.

18 At that point there will be a signal which
19 automatically dumps the water in the evaporators into
20 the evaporator dump tank, which again is just an
21 empty tank which is there to receive the water from the
22 evaporator, and that relieves the driving pressure to
23 push the water into the sodium, and reduces the reaction
24 to a lower level, and would in the long run, if the
25 operator didn't ramp the plant down, very quickly result

1 in a scram. So, in effect, the plant will scram in the
2 event this rupture disc bursts from a slow buildup of
3 the pressure in the system to about 150 psi.

4 And we would expect that to occur relatively
5 quickly if you were to get a leak of the size of
6 approaching a pound per second, to give you a feeling
7 for what kind of a leak that is.

8 Now, the third level of protection is what we
9 call the main rupture discs, the result of the bursting
10 of which is that we have an automatic reactor shutdown
11 tied into our plant protection system, and also the same
12 kind of water dump I've talked about before.

13 What those rupture discs are are pairs of
14 reverse buckling rupture discs at the outlet -- excuse
15 me -- at the inlet of the superheater and at the outlet
16 of each of the evaporators. And this is actually not a
17 properly drawn figure, because the rupture disc is
18 actually on the side of the T that looks directly into
19 the shell side of the steam generator module, so the
20 pressure wave will come out through the sodium, directly
21 strike the rupture disc, and then the reaction products
22 from the reaction are vented into this reaction product
23 separator tank.

24 The gaseous reaction products then are
25 separated and just taken out of the steam generator

1 building through a vent. There is a small rupture disc
2 with a low set point, a few psi, on that line which
3 merely protects the inert environment that we maintain
4 in this tank prior to any accident occurring.

5 Again, should any one of these three sets of
6 rupture discs on any loop be ruptured, there would be an
7 automatic plant scram, an automatic dump of the water
8 side in that particular loop.

9 This collection of equipment that I have just
10 discussed is what we call the sodium-water reaction
11 pressure relief system or SWRPRS, sometimes abbreviated
12 SWRPS.

13 (Slide.)

14 Now, the important question then is how big do
15 you have to make the system; what is the phenomenology
16 of the leak; how do you evaluate whether or not you've
17 got the right system. And what we do is to define a
18 design basis accident for the SWRPRS which serves also
19 as the design basis accident for the primary and
20 intermediate coolant boundaries in the mechanical
21 loading. And we suggested that using engineering
22 judgment, considering reactor experience, which is
23 admittedly limited, a very extensive experimental data
24 base, and some analysis results. And I will run through
25 some of that with you, summarize it briefly. And again,

1 I would refer you to the June 25th transcript for more
2 detail.

3 The important parameters of the design basis
4 accident is the size of the leak, how much water is
5 leaking per second into the sodium, and that tells you
6 how much energy will be given off; and then, of course,
7 if there is more than one tube leaking, how many of them
8 leak; and then perhaps a not so obvious parameter is the
9 timing. And the reason that the timing is important is
10 because only extremely rapid events and the propagation
11 in terms of enlarging the water flow rate is important,
12 only that very short propagation is important because of
13 the rapid pressure relief.

14 Now, let me give you a feeling for that. If I
15 were to get a complete double end rupture of one tube,
16 the pressure pulse would arrive at the rupture disc, and
17 the rupture disc would be burst. To the extent that the
18 pressure is relieved down so that it stays around the
19 300 to 400 psi range in a matter of tens of
20 milliseconds; so anything that occurs beyond seconds is
21 clearly out of the range of interest. So let's take a
22 look at the phenomenology.

23 What I have tried to draw here is a
24 cross-section of a steam generator tube. And as a bit
25 of a reminder, each steam generator tube is 5/8 of an

1 inch in diameter, the wall is about 109 mills as
2 fabricated. We have allowances for degradation over
3 life, and what we count on is 77 -- there should be a
4 zero in there -- 77 mills of wall thickness at end of
5 life.

6 Now, the types of failures that one would
7 expect to occur will be a small pinhole type failure
8 that originally occurs, and the smallest people have
9 measured any particular leak is down in the order of
10 just where the sensitivity of a leak detection system
11 begins, this 10⁻⁵ pounds per second.

12 At that point we would expect plugging to be
13 experienced. We would see a leak for a little while,
14 but then the reaction products and the sodium and what
15 not would plug up that crack, and it would stop leaking,
16 and we might see it again. However, after a while there
17 would be some reaction products, a reaction wastage
18 erosion, et cetera, and it would begin to eat away at
19 that leak site until at some point we had a fairly large
20 area of erosion around the leak site.

21 Now, the process to come from this point down
22 to this point would be on the order of hours to days to
23 months, and it is uncertain to that extent how long it
24 would take. It depends upon the configuration of the
25 original leak and what the conditions happen to be. For

1 example, the conditions in a superheater where you have
2 less dense water coming through your leak is -- well, I
3 should say steam leaking through the leak -- is less of
4 a severe situation than where you actually have
5 subcooled water coming through if it were an evaporator.

6 Now, what happens when you get sufficient
7 degradation in the area of the tube is you get a stress
8 rupture when that wall gets so thin that it no longer
9 can contain the say 1500 psi that it sees on the inside
10 of the tube, 1500 psi or greater, and then what you get
11 is a blowout of the bottom of that crater. And from
12 experiments we know that that is on the order of 50
13 mills through the orifice with the degraded area being
14 some three times that in diameter.

15 A leak of that size in the evaporator where
16 the subcooled water is inside the tube would be on the
17 order of 15 grams per second. Now, that is what we call
18 a precursor failure. That is not an event which is
19 large enough to lead to an immediate burst of a rupture
20 disc. It would gradually begin to pressurize the system
21 as we introduced hydrogen.

22 (Slide.)

23 However, this is the kind of thing where, as
24 Mr. Ebersole pointed out, we would have a reaction near
25 the adjacent tubes. So what kinds of mechanisms then

1 are there that could cause tube-to-tube failure
2 propagation.

3 We believe there are three important ones to
4 be considered. Wastage and corrosion of the tube, that
5 breaks down the material or takes it away. Now, we have
6 done numerous experiments in this country and abroad on
7 that question, and indeed wastage and corrosion will
8 take place. Wastage we find to be most rapid, and it
9 will occur on the order of 1 to 5 mills per second
10 maximum. And if you think about our 100 mill wall
11 thickness, it takes tens of seconds to do significant
12 degradation to that tube, and that then gets beyond the
13 range of consideration where it's important for the
14 sizing of our reaction product system.

15 The third mechanism is the one we think is
16 most important to look at, and it is stress rupture.
17 And when we say stress rupture what we really mean is
18 we're going to overheat a tube to the point at which its
19 material property is degraded so that it can no longer
20 contain the stress, the pressure internal to the tube,
21 and it would rupture in a tensile sort of way.

22 Experimentally we have observed that stress
23 ruptures on the order of 10 seconds -- actually I
24 believe the shortest has actually been 16 seconds --
25 after the precursor leak has begun. We have done a

1 bounding analysis, and in the bounding analysis we
2 assumed we had a piece of the tube wall. We assumed it
3 was an adiabatic piece of steel, no heat being removed
4 from it, and we put it in instantaneous continuous flame
5 on one side of it. That was at the temperature that one
6 would get if one had a stochastic mixture of water and
7 sodium. And that temperature is 2700 degrees
8 Fahrenheit. And given the thickness of the steel, it
9 would take on the order of 1 second to heat that wall up
10 to the point where it would no longer contain the water
11 pressure.

12 So the experiment says this is indeed a
13 bounding analysis in the sense -- and it is much shorter
14 by an order of magnitude compared to anything we have
15 seen in real life.

16 Now, I also mentioned that size was important,
17 and what we have found from experiment -- and it made
18 sense -- is that stress rupture failures are limited in
19 size, and when we get one of these failures it is a
20 splitting of the tube. The tube will split open, a
21 fish-mouth, if you will, from the overheating.
22 Typically we will see a 45 degree opening in the tube.
23 And perhaps the most important thing is that the extent
24 of that in an axial direction along the tube is only
25 about an inch and a half at maximum. And this is the

1 part that makes sense logically.

2 The reaction zone which is heating the tube up
3 is only present in one particular spot at one particular
4 point in time, and indeed, the material is cooler when
5 you get away from it. It is cooler not only because the
6 flame front isn't there; it is being continuously cooled
7 by sodium flowing up around the tube, at least until the
8 bubble pushes the sodium away, and it's also being
9 cooled by the water of the steam on the inside.

10 In any case, we have never experienced in any
11 of our tests a leak greater than the equivalent of 50
12 percent of a double-ended guillotine rupture. The water
13 flow from the tube has never been greater than 50
14 percent.

15 (Slide.)

16 So if we just put a picture up of what I've
17 just talked about --

18 MR. MOELLER: Excuse me. It's never been
19 greater than 50 percent? What is typical? I mean has
20 it --

21 MR. CLARE: Typical is more between 10 and 30
22 percent.

23 MR. MOELLER: Thank you.

24 MR. CLARE: Although there haven't been that
25 many, I should point out.

1 The kind of situation then we're talking about
2 is where we have this precursor failure where we have
3 hundreds or tenths of a pound per second of water
4 impinging with its reaction zone on some adjacent tube,
5 a relatively small reaction. Then if we were to get one
6 of these stress ruptures, we would relieve a much
7 greater amount of water into the sodium, and we would
8 get a large reaction zone around that failure.

9 It would be a very dynamic environment. We
10 have flowing sodium on the outside. We have the
11 reaction zone. There would not be a stable situation.
12 However, we have said let's assume that before we can
13 vent the water down, and let's assume before the bubble
14 pushes all the sodium away, that the reaction indeed
15 overheats some other tube -- and let me pick this one
16 over here -- and this one fails, and we call that a
17 secondary failure. And then we could continue going
18 from there.

19 (Slide.)

20 However, we again drop back --

21 MR. CARBON: Would you leave that up just a
22 second? I'm not sure of your sequence.

23 (Slide.)

24 Is P your precursor failure?

25 MR. CLARE: Yes.

1 MR. CARBON: And then you have a primary
2 failure on a different tube? I'm not sure what you're
3 saying.

4 MR. CLARE: That is correct. The water
5 leaking out of this tube creates a reaction which
6 overheats the adjacent tube. That adjacent tube
7 sustains the stress rupture that I talked about, and
8 then it creates a larger reaction. Then if one goes
9 ahead and postulates the additional failure of another
10 tube, then one would get a secondary failure.

11 MR. CARBON: But the primary tube which had
12 the leak in the first place isn't the one that failed?

13 MR. CLARE: Well, it has the original pinhole
14 type leak. If you were to consider a weld defect, for
15 example, where there was a small leak or some other
16 material, a stochastic failure type of thing, this is
17 the precursor.

18 MR. DICKSON: It failed up to the point of the
19 blowout that he described. That raised the leak rate up
20 to the 15 grams per second.

21 MR. CARBON: And then you assume from there on
22 a bigger failure takes place?

23 MR. DICKSON: Yes. By virtue of the flame
24 front on it heating.

25 (Slide.)

1 MR. CLARE: This is the precursor here, a 50
2 mill hole roughly.

3 MR. CARBON: But then you get a bigger failure
4 in F .
t

5 MR. CLARE: Yes. This is the tens of a
6 percent of a double-ended rupture typically.

7 MR. MOELLER: Now, if it fails, if it causes a
8 secondary failure two or three tubes away, why doesn't
9 it just cause a propagation of failures in a whole
10 cluster of tubes?

11 MR. CLARE: In a theoretical sense it can do
12 that, and the question then comes down to a sense of
13 timing and what one actually experiences in life. And
14 indeed, because there was a question about that, there
15 has been a vast experimental program, not necessarily a
16 well-integrated one, however, in the past.

17 MR. DICKSON: Could I add something to that?
18 In that very much disrupted zone the mechanism that was
19 going on is the erosion and corrosion that he showed
20 takes tens of seconds, and we're assuming here that the
21 next rupture is another stress rupture, and that can
22 only occur out at the flame front because there is no
23 high temperature well inside the disrupted zone. It's
24 only a flame front where the two products are
25 interacting.

1 MR. MOELLER: Thank you.

2 MR. BARD: But it still could. It might very
3 well involve several tubes.

4 MR. CLARE: That is conceivable. But again,
5 let's look at the --

6 MR. WARD: In fact, it's almost inconceivable
7 that it would involve just one, isn't it?

8 MR. CLARE: The effects will certainly be felt
9 by more than one tube. The question is from the
10 standpoint of timing and the simultaneous nature that is
11 needed in order for this to be a significant problem.
12 And I will go back to the point that what we are really
13 interested in is something probably less than a second,
14 but let's be generous and expand our horizon to several
15 seconds.

16 MR. MOELLER: On these experiments will you
17 please tell us how they were done or how many tubes
18 there were? Were they at temperature and so forth?

19 MR. CLARE: I will try to do that, and if you
20 will allow me, I will focus on the U.S. tests. I have
21 other information and tables that I could get to on the
22 foreign tests, but I would have to dig that out.

23 Now, there have been some 63 tests related to
24 sodium-water reactions throughout the world in the last
25 20 years or so. Now, I will point out that that is a

1 different number from what Paul Dickson presented in
2 June of last year.

3 (Slide.)

4 There are two reasons for that. One is I have
5 been somewhat more generous to myself and included tests
6 that he may not have considered large sodium-water leak
7 tests, and an example would be where we have injected
8 inert gas into a sodium-filled circuit to try to
9 understand the behavior of a rupture disc. Also, there
10 have been additional tests done since June.

11 Now, an important point about that is that
12 there have been secondary failures in only four tests
13 out of all 63. Specifically in the U.S. there have been
14 nine tests performed in large leak test rate out in
15 California, those tests specifically designed to be
16 prototypic of CRBRP; and we had two tests there that
17 produced secondary failures.

18 Now, let me tell you about those tests. There
19 were two series of LLTR tests. The first series used
20 the test article, which was originally built by Atomic
21 International, and I believe it began operation in
22 1968. The modular steam generator, which is a 158-tube
23 steam generator, otherwise prototypic of our steam
24 generator, the sizing of the tubes and the material, et
25 cetera.

1 The way the test was conducted there was the
2 water tubes were capped off at the bottom, and a plenum
3 of water was put essentially beyond the upper tube
4 sheet, so you did have water in all of your tubes except
5 in one location where you had the stagnant water in the
6 one location principally coming from the bottom, and at
7 least in some of the tests in some cases it came from
8 the top.

9 We put in the tube which one used to simulate
10 the original leak, so there was a special tube run in so
11 that you could turn on the water and dump it into the
12 sodium and let it run. On the sodium side we just had
13 stagnant sodium in there to a reservoir and also to a
14 rupture disc system. That didn't relieve the pressure.

15 So then using various tests at various
16 conditions, and the conditions did simulate CRBRP
17 operating conditions up to close to 1000 degrees as low
18 temperature, as I believe 500 degrees were so with water
19 pressures on the order of 2000 psi which we might see in
20 various degrees of subcooling, steam superheat, et
21 cetera -- the whole range of conditions.

22 The second series of large leak tests was done
23 in a similar manner, but they used a special steam
24 generator unit for the purpose which was half the height
25 of the current CRBRP steam generator but otherwise the

1 same, about 750 tubes four feet in diameter -- very
2 similar from that standpoint.

3 Now, there were two tests in the series that
4 produced secondary failures. The secondary failures
5 occurred in tens of seconds. Again, the shortest one
6 occurred in 16 seconds. And indeed, in one of these
7 tests there were additional failures. They occurred
8 well beyond that, and in fact, the next failure beyond
9 this, beyond the secondary failure in this test occurred
10 as an additional failure in the tube that was put into
11 purposely leak.

12 Now, in every one of these tests you have to
13 put one in that you make leak when you want it to leak,
14 and that tube was the source of the third failure.

15 But again, the important point is --

16 MR. WARD: That is interesting because that is
17 apparently right next to -- obviously right next to the
18 primary failure.

19 MR. CLARE: That is correct.

20 MR. WARD: And this argument about it is more
21 likely that the secondary failures are going to be out
22 at some distance where the flame front is doesn't hold.

23 MR. DICKSON: That argument applies to a quick
24 rupture which would occur from the stress rupture
25 effect. To have a leak within that erosion zone after

1 tens of seconds corresponds to an erosion-corrosion type
2 of rupture which could occur anywhere, and you would
3 expect it to be fairly close.

4 MR. WARD: And the secondary failures weren't
5 stress failures.

6 MR. CLARE: The secondary failures in all
7 cases were stress failures. But the point is, number
8 one, they were not full double-ended ruptures; they were
9 more like 10 percent, 20 percent of a rupture.

10 MR. WARD: Well, if they are stress failures,
11 don't they involve the flame front then?

12 MR. DICKSON: No. You could erode the wall
13 away until it could no longer handle the stress.

14 MR. CLARE: In tens of seconds corrosion can
15 be involved. If you will recall, I talked about the
16 timing in tens of seconds that could occur, and that is
17 the point Paul is making, is that given that you extend
18 that time frame, then that could have been the
19 mechanism. Indeed, wastage when you go long enough is
20 often combined with stress rupture. When you waste away
21 enough of the tube, you then get the stress rupture.

22 MR. MOELLER: How did you fix up the precursor
23 tube to be sure it leaked and initiated the event?

24 MR. CLARE: The way it was done -- and I don't
25 have the exact details with me -- we actually drilled a

1 50 mill hole in the tube and then otherwise covered it
2 up, prevented the water from getting to it, and then
3 allowed the water to come flying in through the hole.

4 MR. MOELLER: Okay. Now, with the other tubes
5 around it, was there any care -- well, I'm sure there
6 was care -- but did you try to select tubes that were
7 brand new or tubes that had been used for some purpose
8 for a while or what?

9 MR. CLARE: I don't know that there was any
10 particular attempt to choose a tube in any condition or
11 another. It was a typical tube. The one thing that was
12 done is the orientation of that leak was chosen to
13 optimize based upon earlier laboratory scale tests the
14 impingement of the reaction zone on the target tube.
15 And, in fact, I believe in many cases the bench test,
16 the laboratory scale tests said that this is not the
17 worst configuration.

18 (Slide.)

19 In fact, the worst configuration is when you
20 are impinging over here on this tube. So the target
21 tube was selected to be some adjacent tube where we
22 could optimize that reaction time.

23 MR. DICKSON: And if I could add, although
24 they were new tubes, they were minimum tube wall as
25 simulating an end-of-life condition.

1 MR. MOELLER: That is helpful.

2 (Slide.)

3 MR. CLARE: So now if we consider the
4 experimental results, the analytical results, the
5 understanding of the phenomenology, the kind of failure
6 that we might expect to happen in this plant -- and this
7 has been borne out by the in-reactor events that have
8 occurred, and there have been some -- we would expect a
9 small leak, likely a detectable leak. But if you assume
10 the leak was not detected, you would assume a gradual
11 rise, possibly a fraction of an EDEG secondary failure
12 after which you would burst the expansion tank rupture
13 disc, the water side would be vented, and you would
14 never see a burst of the main rupture disc and SWRPRS.

15 On the other hand, if you assume that some
16 secondary failure occurred with a large enough water
17 release, you could get a rupture of your main rupture
18 discs with that initial failure after your precursor,
19 and you would expect that to occur in tens of seconds,
20 indeed probably minutes after the blowout on the
21 precursor.

22 (Slide.)

23 However, to be conservative what we have done
24 is to define a design basis sodium-water reaction event
25 which includes a precursor, and I will come back to the

1 pressure in a minute, followed by a primary failure not
2 equivalent to 10 percent or 50 percent of a double-ended
3 rupture, but one equivalent to a double-ended rupture --
4 we will call that time zero -- followed by a secondary
5 failure at 1 second, followed by a tertiary failure at 2
6 seconds. So that's pop, pop, pop on double-ended
7 ruptures.

8 Now, we define this precursor in such a way to
9 maximize the mechanical loadings on the system, and we
10 have done sensitivity studies to assure ourselves that
11 this is the case. And what we do is we assume that this
12 precursor is just right so that we raise the system
13 pressure to 325 psig, which is just at the bursting
14 point of the rupture disc, the main rupture discs, but
15 we do it so rapidly that the expansion tank rupture disc
16 does not rupture. And therefore, we do have this
17 overpressure condition at the time this double-ended
18 rupture occurs. And that is our design basis leak.

19 (Slide.)

20 Now, just for some perspective --

21 MR. EBERSOLE: Is that conservative, or could
22 you argue that it is just lifting the set point to the
23 point where you will get an immediate response of the
24 rupture disc?

25 MR. CLARE: That was a question we asked

1 ourselves, and I said we did sensitivity studies. We
2 wanted to evaluate that. I will talk about our
3 evaluation techniques in a few minutes.

4 But having done the sensitivity studies, we
5 find that this indeed gives us the highest pressure
6 downstream. It turns out that from the double-ended
7 rupture you get such a rapid peak anyway that this
8 doesn't affect the rupture time.

9 Schematically, if you think of this as the
10 water flow rate and think of the double-ended rupture as
11 coming very rapidly, we do have the precursor leak which
12 may take tens of seconds, one double-ended rupture
13 followed by a second, followed by a third. This is
14 contrasted with a more plausible leak where you might
15 get a single fraction of a double-ended rupture. Very
16 likely you would rupture one of your rupture discs here,
17 but based upon the test data you say well, maybe you
18 would have another one. In fact, all of these have
19 happened, a minute or two minutes past the point of the
20 initial rupture in our experiments.

21 (Slide.)

22 Let's compare this design basis event with the
23 foreign events that have been considered in the design
24 of those reactors, and we find that that comparison is
25 very favorable.

1 The U.K. uses essentially an identical design
2 basis accident as we use. In Germany and France they
3 use only one tube rupture as a design basis. Japan we
4 don't quite understand. We know they use one tube for
5 the licensing process, but we know that they otherwise
6 consider one followed by three others. And although we
7 don't know the exact timing between those others, we
8 know they are not considered to be simultaneous.

9 And then, of course, what we have is three
10 tubes at a one-second interval.

11 (Slide.)

12 Taking that then as our design basis accident,
13 we evaluate the effects on the system. We do that using
14 a computer code called TRANSWRAP -- transient
15 sodium-water reaction analysis program. For the purpose
16 of the evaluation we select the worst leak location and
17 the worst initial conditions for the leak based upon the
18 sensitivity studies. And the results of those
19 sensitivity studies are that the leak is in the
20 evaporator where the water is subcooled, and that,
21 therefore, gives us the highest mass flow rate for any
22 particular leak size of the tube. And we find that the
23 highest, that the worst combination of pressure and
24 subcoolant occurs at some slight delay after loss of
25 offsite power where we have already started a transient

1 in the steam generator system.

2 The actual leak rate of the water through the
3 tube, the failed tube, again is assumed to be a
4 double-ended rupture. This is established using the
5 RELAP code. Of course, that is a well-validated GE code
6 used in the water reactor business.

7 The phenomenology that is assumed in TRANSWRAP
8 is that there is a hydrogen yield of 65 percent, and
9 what we typically find in the experiments is that that
10 yield will be somewhere between 35 and 50 percent. I
11 believe the British used 55 percent in their
12 calculations, and the Germans perhaps used 60. We are
13 at the high end of that range.

14 Of course, the hydrogen yield is only one part
15 of the story. If you're trying to figure out how fast
16 this bubble is expanding and what the pressures are down
17 in the system, we need to know what temperature the
18 hydrogen is at, and we assume 1700 degrees which bounds
19 our experimental results. And this combination does do
20 a good job of predicting the events that we have seen in
21 the experiments. It bounds those experimental results.

22 We model the rupture disc with dynamic elastic
23 plastic rupture disc behavior. We actually model in a
24 stress-strain sort of sense the behavior of the two in
25 series rupture discs. As the stress increases, they

1 begin to buckle backwards. They contact the knife edge,
2 which will eventually tear the disc open, and then after
3 some hold time tears the rupture disc open allowing the
4 sodium to pass through. That is all discretely modeled
5 in the TRANSWRAP code, and we have validated that model
6 against the experimental results in the large leak test
7 facility.

8 (Slide.)

9 The mechanical loadings from the event are
10 also predicting using TRANSWRAP, and TRANSWRAP actually
11 uses the water hammer model that comes from the computer
12 code HITRAN, which is an old standby developed by the
13 Army Corps of Engineers.

14 Sodium is treated as a compressible fluid. It
15 is a one-dimensional code. For sodium hammer the
16 friction effects of the fluid are modeled. The strain,
17 which would dissipate the energy as the wave propagates
18 down the piping, is not accounted for; so by the time
19 the pressures get down to the intermediate heat
20 exchanger, which again is the critical boundary, we have
21 very conservatively treated it, and much of the energy
22 which would have been dissipated is still contained in
23 our predicted pressure pulse.

24 Again, the TRANSWRAP results are validated as
25 being conservative, using the data from the large leak

1 test facility which did have rupture discs and did have
2 runs of sodium piping to try to be sure we can predict
3 this type of behavior.

4 (Slide.)

5 So then as a summary, we have conservatively
6 selected a sodium-water reaction event as our design
7 basis, and we have a validated computer code which we
8 used to conservatively model the consequences of that
9 design basis event.

10 Now, I have just a few words to try to address
11 the additional questions that were raised in the request
12 that we come here and speak on this subject. And a key
13 one of those questions was what about steam generator
14 reliability.

15 (Slide.)

16 We have looked at that for the purpose of
17 doing a number of these sensitivity studies we have done
18 on the plant on reliability, availability, et cetera;
19 but because the steam generator modules are first of a
20 kind components, there has not been extensive
21 operational or testing data in terms of many, many years
22 of actual operations; so we don't have a statistical
23 data base. However, what we have done is to survey
24 various steam generators and fossil fuel plants, LWR
25 plants, and what data does exist for steam generators

1 for both thermal and fast reactor units and test units.

2 And I might note that there have been some 18
3 years of testing with steam generators similar to the
4 one we're going to have in the plant. The modular steam
5 generator that I mentioned earlier was first put into
6 testing by AI in 1968. It will be 20 years before we
7 put that unit in operation in the plant. We haven't
8 accumulated 20 years yet. We will before we start up
9 the plant.

10 Engineering judgment was applied to all of
11 this data to derive failure parameters that we used in
12 our reliability studies, and this next vu-graph gives
13 those.

14 (Slide.)

15 This is a very small leak, one which could be
16 detected prior to the bursting of the expansion tank
17 rupture disc. The medium leak is one that would result
18 in rupturing of the intermediate -- excuse me -- of the
19 expansion tank rupture disc, and the larger leak is one
20 which we are sure would rupture the main rupture discs
21 and relieve the system.

22

23

24

25

1 Now, if you are interested in how you convert
2 -6
3 10 hours per module to years in a plant with nine
4 modules, let me do that for you. This is about once
5 every two years, this is about once every ten years, and
6 this is about once every 40 years.

7 Our understanding of this is that it is kind
8 of a lower limit of a conservative limit of the
9 probability of leaks based upon the data we have
10 available. I might note that the Phenix experiment
11 suggests that this is indeed conservative. They've been
12 operating that plant since 1974, and to the best of my
13 knowledge they have sustained two steam generator leaks.

14 MR. SHEWMON: The British, on the other hand,
15 had a fair amount of trouble on this.

16 MR. CLARE: That's right. And the Staff said
17 I would address this, didn't they? PFR had a much
18 different steam generator than the one we have, and they
19 have indeed had considerable problems with it. To begin
20 with, they built their units out of stainless steel -- I
21 forget the number -- 221 or 321; and they found that
22 their welding process was not necessarily very
23 reliable. And we have taken the specific actions of
24 developing the new weld process, and I think you have
25 probably seen some discussion of that in one of the
26 prior meetings with your working group, and we are using

1 ferritic 2 1/4 chrome one moly material, which based
2 upon our experience, as well as others, is probably the
3 best material to use.

4 MR. SHEWMON: Well, your reason why you think
5 you've got a better design in the system than the
6 British is that you aren't using welded 321?

7 MR. CLARE: Well, it is that we have
8 specifically put together a weld configuration which is
9 highly reliable. These are the principal differences,
10 and I don't know all of the details between the units.
11 And we are using a material which would be less subject
12 to attack from reaction products.

13 MR. SHEWMON: What did the French use in their
14 material, do you know?

15 MR. CLARE: They have used a couple of
16 different materials. They have some stainless steel and
17 some ferritic, and I don't have all of the details.

18 MR. DICKSON: I wanted to add one thing. The
19 British experience is that most of their leaks occurred
20 in their welds, and those were tube-to-tube sheet welds,
21 and that seemed to be where the problem existed. We
22 have eliminated that, not just as a weld technique but
23 as a design concept.

24 MR. LONGENECKER: The French used 316 in the
25 superheater, and the used 2 1/4 one moly in the

1 evaporator, and they have had leaks in the ferritic
2 units; and they think their problem is they didn't
3 stress relieve the welds.

4 The British problem, the same configuration,
5 they've got stainless steel units. In the superheater
6 and the reheater they didn't stress relieve their U-tube
7 ferritic unit. When they developed the first leaks they
8 weren't very big, and they got some constant sodium
9 hydroxide. They shut down. By the time they did that
10 the caustic had been transported over to the other
11 units, and now what they're getting is just a continual
12 succession of very small leaks in the austenitic units.
13 So what they are doing is they are building new ones out
14 of 9 chrome one moly.

15 They did three things wrong which we have
16 corrected. One is they used some bad materials. They
17 used some dirty 2 1/4 chrome one moly. When they tested
18 they didn't stress relieve nor did they have a
19 volumetric inspection of the tube-to-tube sheet weld.
20 And the third one is they didn't really do any testing
21 for any of the operating phenomena like flow-induced
22 vibration.

23 So what we have done is go to the vacuum arc
24 remelt forgings and very pure tubing, and do the rod
25 anode inspection on the internal bore weld that we

1 have. And we have told you today about some of the
2 testing.

3 The testing that we still have to do besides
4 the prototype is the full-scale flow-induced vibration
5 model in water to make sure we have taken care of all
6 three.

7 MR. SHEWMON: When you say dirty you mean the
8 vacuum arc? You're thinking of oxide occlusions
9 primarily?

10 MR. LONGENECKER: Yes.

11 MR. CARBON: Put this in context, would you,
12 please, John. It is my impression that the British have
13 some pretty capable technical people, and yet -- and
14 they were trying to build this steam generator for the
15 big unit. They thought they had all of their problems
16 solved and ran into all kinds of difficulties.

17 Is this because of a normal learning cycle, or
18 did they goof, or did they not test enough?

19 MR. LONGENECKER: I think the principal -- it
20 is hard to tell back that far because everyone has
21 different views on what their hindsight was. But I
22 think the general consensus is that they thought at the
23 time that they could dump before they got very much
24 caustic in the unit so that they could use stainless
25 steel. They didn't know -- the use of those ferritics

1 was so new at the time, they really didn't have a very
2 good data base on the stress relief. And we have done a
3 pretty extensive program, like about seven or eight
4 years' worth, through Oak Ridge National Lab and
5 Combustion Engineering on our 2 1/4 one moly learning
6 all of the phenomena.

7 The other was that they didn't do enough
8 preservice inspection to determine whether they had any
9 leaks. Had they done the kind of tests that we do to
10 pressure, I think they would have found that they
11 probably did -- the Russians did; they put the units
12 into service anyway, the ones that they had leaking.

13 What that led to, the leaks happened so early
14 in the service that they weren't really accustomed to
15 reading their hydrogen and oxygen monitors, and so when
16 they started getting the leaks, they ran for about six
17 weeks seeing the leaks. By the time they found out how
18 many they had, they had formed caustic, and it didn't
19 take much to get over to the reheaters.

20 The Russians, on the other hand, did dump on
21 the order of 400 pounds of reaction products into the
22 sodium side. They had ferritic units 2 1/4 chrome one
23 moly, cold-trapped them out and fixed the units and went
24 back up. So primarily it was just bad judgment in using
25 an austenitic material.

1 MR. CLARE: I might note in all of those
2 events we're talking about we did not or they did not
3 get the kind of energetic reaction in terms of a very
4 rapid millisecond type of propagation that would give
5 you any problem in terms of pressure pulses on your
6 current boundaries.

7 MR. MOELLER: Earlier, a couple of slides
8 back, you went past rather fast for me. This TRANSWRAP
9 computer code was well proven?

10 MR. CLARE: Yes.

11 MR. MOELLER: And that we could have faith in
12 it? Now, why should we have a warm feeling about it?

13 MR. CLARE: It has been validated by using it
14 to predict both before and after the leak tests that
15 have been performed in this large leak test rig that I
16 talked about.

17 MR. MOELLER: In the sodium-water?

18 MR. CLARE: In the sodium-water both for
19 smaller leaks and for larger leaks.

20 MR. MOELLER: And it has been shown to yield
21 pretty good correlations?

22 MR. CLARE: That's correct in terms of, for
23 example, rupture discs, burst times, burst pressures,
24 peak pressures, on down the line.

25 MR. MOELLER: All right. Thank you.

1 MR. DICKSON: It is conservative in some
2 areas. There is a loss around every elbow that is not
3 predictable and not in the code. But there is some loss
4 that varies depending upon a variety of conditions, and
5 that is not in the code at all. So when he says it is
6 validated, it is validated to the extent it does not
7 underpredict.

8 MR. CARBON: Were there further questions? If
9 not, thank you, Mr. Clare, and thank all of you for your
10 fine effort and presentations today.

11 Mr. Chairman, I turn it back to you.

12 MR. RAY: Thank you, Max.

13 I might comment that while grueling, it was a
14 very interesting presentation.

15 We will recess now until 8:30 tomorrow morning.

16 (Whereupon, at 6:30 p.m., the meeting was
17 recessed, to be reconvened at 8:30 a.m., the following
18 day, Saturday, February 12, 1983.)

19
20
21
22
23
24
25

NUCLEAR REGULATORY COMMISSION

This is to certify that the attached proceedings before the

in the matter of: ACRS/274th General Meeting

Date of Proceeding: February 11, 1983

Docket Number: _____

Place of Proceeding: Washington, D. C.

were held as herein appears, and that this is the original transcript thereof for the file of the Commission.

Ray Hear

Official Reporter (Typed)

Ray Hear

Official Reporter (Signature)

STAFF REVIEW OF PSAR CHAPTER 2

- o STAFF DISCUSSED HYDROLOGY, GEOLOGY, SEISMOLOGY, GEOGRAPHY IN NUREG-0786 SITE SUITABILITY REPORT FOR THE CLINCH RIVER BREEDER REACTOR PLANT.

- o STAFF REVIEWERS HAVE COMPLETED SER SECTION FOR THE CHAPTER 2 REVIEW.

- o THE SRP IS APPLICABLE TO CRBR FOR THE CHAPTER 2 REVIEW.

- o STAFF CONCLUSION - NO OPEN ITEMS.

CRBRP BRIEFING FOR
ADVISORY COMMITTEE ON
REACTOR SAFEGUARDS (ACRS)

**ACCOMMODATION OF NATURAL
PHENOMENA IN CRBRP DESIGN**

Presented by

ROBERT E. PALM

CIVIL/STRUCTURAL ENGINEERING MANAGER
BURNS AND ROE, INC.
ORADELL, NEW JERSEY

FEBRUARY 11, 1983

NATURAL PHENOMENA

- **TORNADO**
- **PRECIPITATION**
- **FLOOD**
- **EARTHQUAKE**

DESIGN BASIS TORNADO

- SAFETY RELATED STRUCTURES DESIGN TO WITHSTAND TORNADO EFFECTS
- DESIGN TORNADO IN ACCORDANCE WITH REGULATORY GUIDE 1.76 - REGION I
- TORNADO EFFECTS COMBINED WITH OTHER LOADS
- WIND VELOCITY = 360 MPH
 - ROTATIONAL VELOCITY = 290 MPH
 - TRANSLATIONAL VELOCITY = 70 MPH
- PRESSURE DROP = 3.0 PSI
- VELOCITY PRESSURES DETERMINED IN ACCORDANCE WITH ANSI A58.1

TORNADO MISSILE PROTECTIVE DESIGN

- SPECTRUM OF MISSILES IDENTIFIED
- MINIMUM THICKNESS OF EXTERIOR CONCRETE = 2'-3"
 - GREATER THAN MINIMUM 2'-0" REQUIRED BY SRP
- MISSILE PROTECTIVE STRUCTURES PROVIDED AT CRITICAL OPENINGS
- METHOD OF ANALYSIS DESCRIBED IN PSAR SECTION 3.5
 - PENETRATION INTO STEEL AND CONCRETE STRUCTURES
 - PREVENTION OF SCABBING IN CRITICAL AREAS
 - OVERALL AND LOCALIZED STRUCTURAL RESPONSE EVALUATED TO ASSURE STRUCTURAL INTEGRITY

DESIGN FOR MAXIMUM PRECIPITATION

- DRAINAGE FACILITIES DESIGN FOR 100 YEAR STORM
 - 3.5 INCHES PER HOUR MAXIMUM
- CRBRP DESIGN EVALUATED FOR EFFECTS OF PROBABLE MAXIMUM PRECIPITATION (PMP)
 - MOST CRITICAL STORM FOR LOCAL SITE CONDITIONS
 - 14 INCHES PER HOUR MAXIMUM
 - 29.5 INCHES IN 8 HOURS
- 6 INCH MAXIMUM LOCAL FLOODING ALLOWED IN PLANT AREA
 - BUILDING ENTRIES 12 INCHES ABOVE GRADE
- 8 INCH MAXIMUM PONDING ON ROOFS
 - EXCESS DISCHARGED BY OVERFLOWS TO GRADE
 - CURBS PROVIDED AROUND ROOF OPENINGS
- EQUIVALENT 80 INCH SNOWFALL DEPTH ACCOMMODATED IN DESIGN
 - 40 PSF ROOF LOAD

DESIGN FOR FLOODS


- PROBABLE MAXIMUM FLOOD (PMF)
 - MAXIMUM ELEVATION = 779.8 FT. INCLUDES 40 MPH WIND AND WAVE RUNUP
- MAXIMUM FLOOD LEVEL AT SITE = 809.2 FT.
 - BASED ON UPSTREAM DAM FAILURE COMBINED WITH 1/2 PMF
 - (DETAILS TO BE PRESENTED LATER BY TVA)
- PLANT GRADE AT ELEVATION 815 FT.
- STRUCTURES DESIGNED FOR MAXIMUM GROUNDWATER LEVEL OF 809 FT.
 - HYDROSTATIC EFFECTS
 - WATERTIGHTNESS

EARTHQUAKE DESIGN


- TECTONIC PROVINCE APPROACH FOR DETERMINATION OF SSE
 - IN ACCORDANCE WITH IOCFR100, APPENDIX A
- LARGEST HISTORICAL EARTHQUAKE IDENTIFIED AS GILES COUNTY, VIRGINIA, 1897
 - NRC CLASSIFIED THIS EARTHQUAKE AS INTENSITY VIII
- CORRELATION OF INTENSITY TO ACCELERATION RESULTS IN SSE = 0.25 G
- EARTHQUAKE ASSUMED TO OCCUR AT THE CRBRP SITE
- OBE = 1/2 SSE = 0.125 G
- SEISMIC DESIGN OF STRUCTURES, COMPONENTS AND SYSTEMS IN ACCORDANCE WITH APPLICABLE CODES, REGULATORY GUIDES AND SRP

SUMMARY AND CONCLUSIONS

- **CONSERVATIVE DESIGN BASES HAVE BEEN ESTABLISHED FOR POTENTIAL EVENTS FROM NATURAL PHENOMENA.**
- **THE CRBRP DESIGN ACCOMMODATES EACH OF THESE EVENTS**



Tennessee Valley Region



WATERSHED

POTENTIAL SOURCES OF FLOODING

EXAMINED IN DETAIL

- STORMS -

PRIMARY WATERCOURSE - CLINCH RIVER

ADJACENT WATERCOURSE - TENNESSEE RIVER

- SEISMIC-INDUCED DAM FAILURE -

NOT EXAMINED IN DETAIL

- SNOW MELT/ICE JAMS

-- TEMPERATE CLIMATE --

- LAND SLIDES

-- SLIDE VOLUME POTENTIAL LIMITED --

4

DEFINITIONS

PMP - RAINFALL DEPTH

FOR A PARTICULAR SIZE BASIN
APPROACHES THE UPPER LIMIT
FOR A SPECIFIED DURATION
PRESENT CLIMATE CAN PRODUCE

PMF - MOST SEVERE FLOOD

CAN REASONABLY BE PREDICTED
OCCUR FROM HYDROMETEOROLOGICAL CONDITIONS
ASSUMES
OCCURRENCE OF PMP CRITICALLY CENTERED
SEQUENCE OF RELATED METEOROLOGIC AND HYDROLOGIC FACTORS
TYPICAL OF EXTREME STORMS

PMP

9 DAY STORM

*3-DAY ANTECEDENT STORM	6.9 INCHES
*3-DAY DRY PERIOD	0
*3-DAY MAIN STORM	<u>17.2 INCHES</u>
*TOTAL	24.1 INCHES

*AVERAGE ON 17,310 SQUARE-MILE WATERSHED ABOVE WATTS BAR DAM

NRC CRITERIA

FLOODS FROM SEISMIC EVENTS

ALTERNATIVE 1 - DAM FAILURE CAUSED BY SAFE SHUTDOWN
EARTHQUAKE (SSE)
COINCIDENT WITH 25-YEAR FLOOD

ALTERNATIVE 2 - DAM FAILURE CAUSED BY OPERATING BASIS
EARTHQUAKE (OBE)
COINCIDENT WITH $\frac{1}{2}$ PMF

NORRIS BACKGROUND INFORMATION

CONCRETE GRAVITY DAM
COMPLETED IN 1936
LENGTH - 1860 FEET
HEIGHT - 265 FEET

OVERFLOW SPILLWAY
SLUICES
NONOVERFLOW SECTIONS ON EACH SIDE

ORIGINALLY DESIGNED FOR AN EARTHQUAKE ACCELERATION OF 0.1g
THROUGHOUT ITS HEIGHT





Figure 2.4-28. Norris Dam - Plan Elevations and Sections


6650-39

6650-41



PLAN
(ASSUMED AFTER FAILURE)

SECTION A-A
ASSUMED POSITION OF FAILED SPILLWAY
(NON-OVERFLOW DAM & POWERHOUSE ASSUMED SIMILAR)



ELEVATION

Figure 2.4-30 Norris Dam - Analysis for OBE & One Half PMF-Assumed Condition of Dam After Failure

2.4-150

6650-42

2.4-151




Figure 2.4-31 Norris Dam-SSE+25 Year Flood Judged Condition of Dam After Failure

MAJOR ELEMENTS

NORRIS FAILURE FLOOD ANALYSIS

WATERSHED FLOWS IN $\frac{1}{2}$ PMF OR 25-YEAR FLOOD


-- WATERSHED MODEL --

OUTFLOW FROM BREACHED NORRIS DAM


-- RATING CURVES --

COMBINED FLOWS AT SITE


-- UNSTEADY FLOW ANALYSIS --



Headwater Rating Curves - Norris Dam



NORRIS DAM DISCHARGE
IN OBE FAILURE WITH 1/2 PMF



FLOOD ELEVATIONS

PLANT GRADE ELEVATION = 815

<u>EVENT</u>	<u>CRBR ELEVATION</u>	
	<u>MILE 16</u>	<u>MILE 18</u>
PMF	777.2	778.8
OBE FAILURE WITH $\frac{1}{2}$ PMF	798.2	804.3
SSE FAILURE WITH 25-YEAR FLOOD	790.5	796.3

SENSITIVITY ANALYSIS

<u>POSTULATED FAILURE MODE</u>	<u>CRBR ELEVATION</u>	
	<u>MILE 16</u>	<u>MILE 18</u>
OBE CONDITIONS WITH 1/2 PMF		
VANISHMENT OF 3 BLOCKS (38-40) TO GROUND LEVEL (168-FOOT WIDTH)	802.2	808.4
OVERTURNING OF BLOCKS 37-43 (370-FOOT WIDTH) WITH 925 DEBRIS LEVEL	805.3	811.9
OVERTURNING OF BLOCKS 33-44 (665-FOOT WIDTH) WITH 945 DEBRIS LEVEL	802.6	808.9
INSTANT VANISHMENT OF ENTIRE DAM (NO DEBRIS)	811.0	818.0

CRBRP RESERVE SEISMIC MARGINS

ADVANCED REACTORS DIVISION
WESTINGHOUSE ELECTRIC CORPORATION
MADISON, PENNSYLVANIA 15663-0158

February 11, 1983




CRBRP RESERVE SEISMIC MARGINS

- Reserve seismic margin: seismic reserve strength/capability available when calculated effects (stress, functional performance) due to all loadings equal allowable limits (code, performance)
- Nominal margin: S_u/S_a when $S_a = \sigma_s + \sigma_n$
- Reserve margin earthquake: 0.25g x reserve seismic margin

Sources:

- Conservative predictions of building and equipment response
- Conservative definitions of structural and functional performance limits

RESERVE SEISMIC CAPABILITY OF CRBRP SYSTEM EVALUATION PROCEDURE



EQUIPMENT STRUCTURAL RESERVE CAPABILITY STRUCTURAL STRENGTH RESERVE CAPABILITY

- Material minimum strength assumptions:
 - Code minimum strength
 - Average strength for seismic
 - Ratio of average to minimum 1.20
- Code design stress limits
 - Service Limit Level D allowable membrane tensile stress = $0.7 S_u$
 - Ratio of ultimate strength to allowable stress 1.43

STRUCTURAL STRENGTH NOMINAL MARGIN = 1.72

EQUIPMENT STRUCTURAL RESERVE CAPABILITY SYSTEM SEISMIC RESPONSE CONSERVATISM


- System damping assumptions:
 - R.G. 1.61 3% damping value
 - Test results, 5% damping value
 - Peak response ratio 3% versus 5% 1.2
- Development of ground accelerogram:
 - NRC SRP rule on spectra enveloping
 - Artificial response spectra conservatism 1.05
- Reduction of floor response spectra due to inelastic action of building 1.05
- Development of design response spectra:
 - Envelop upper and lower bounds of soil moduli
 - Peaks widened and higher due to uncoupling
 - Spectra smoothed to eliminate valleys and spectral fluctuations 1.1
- Development of design histories:
 - Possible frequency variations of building
 - Vary Δt , compress and expand history
 - Develop spectra-consistent histories 1.1

SYSTEM SEISMIC RESPONSE CONSERVATISM:

$$(1.2)(1.05)^2(1.1) = \underline{1.45}$$

CRITERIA RESPONSE SPECTRUM ENVELOPING WITH HORIZONTAL E-W MOTION, SSE-7% DAMPING


ACCELERATION (G)



SSE E-W HORIZONTAL + TORSIONAL COMBINED - DESIGN AND ORIGINAL T.H. RESPONSE SPECTRA AT R.V. SUPPORTS, EL. 800 FT.

(3% CRITICAL DAMPING)

ACCELERATION (G)




SSE EW COMBINED HORIZONTAL AND TORSION- DESIGN AND SYNTHESIZED RESPONSE SPECTRA



(3% CRITICAL DAMPING)

ACCELERATION (G)



EQUIPMENT STRUCTURAL RESERVE CAPABILITY STRUCTURAL RESERVE SEISMIC MARGIN

- NUREG/CR-2137:
 - Nominal margin (NM) = $S_u/S_a = S_u/\sigma_s + \sigma_n$
 - Seismic - only margin = M_s
 - $M_s = (S_u - S_a)/\sigma_s + 1 = 1/k (NM-1) + 1$
- Structural strength nominal margin = 1.72
- Conservative assumption of $k = \sigma_s/S_a = 60\%$ to 90%
- Structural strength reserve seismic margin:
 $1/0.6 (1.72-1) + 1 = 2.2$ for $k = 60\%$; $1/0.9 (1.72-1) + 1$
 $= 1.8$ for $k = 90\%$
- Seismic response conservatism = 1.45

EQUIPMENT STRUCTURAL RESERVE SEISMIC MARGIN
= 2.61 to 3.19

EQUIPMENT STRUCTURAL RESERVE CAPABILITY CONTAINMENT STRUCTURAL RESERVE SEISMIC MARGIN

- Nominal margin (NM) on buckling = 1.9
- Seismic - only margin, $M_s = 1/k (NM-1) + 1$
- Ratio of seismic to total loadings, $k = 70\%$
- Containment buckling strength reserve seismic margin
= $1/0.7 (1.9-1) + 1 = 2.29$
- System seismic response conservatism = 1.45

EQUIPMENT STRUCTURAL RESERVE
SEISMIC MARGIN = 3.32

**EQUIPMENT FUNCTIONAL RESERVE CAPABILITY
SHUTDOWN SYSTEM FUNCTIONAL
RESERVE SEISMIC MARGIN**

- Design capacity in excess of requirements:
 - Scram insertion performance evaluated for SSE of 0.33g 1.32
- Conservative system response requirements:
 - Worst case rod positions and minimum rod worths 1.10
- Friction coefficient (1.0 versus 0.45) 2.2
- Impact damping 1.07
- Shutdown system functional reserve seismic margin = 3.42
- System seismic response conservatism = 1.45

**EQUIPMENT FUNCTIONAL RESERVE
SEISMIC MARGIN = 5.0**

EQUIPMENT FUNCTIONAL RESERVE CAPABILITY RUPTURE DISCS FUNCTIONAL RESERVE SEISMIC MARGIN

- Evaluation based on worst loop
- Zero time rupture disc rating = 339 psi
- Five year aging effects (creep, corrosion, stress relieving)
= 43 psi
- Rupture disc rating after five years = 296 psi
- Steady-state operating pressure = 219 psi
- Allowable pressure for seismic = 77 psi
- Pressure due to 0.25g SSE = 45 psi
- Rupture discs functional reserve seismic margin
= $1 + 32/45 = 1.71$
- Seismic response conservatism = $1.2 (1.05)^2 = 1.32$

EQUIPMENT FUNCTIONAL RESERVE SEISMIC MARGIN = 2.26

EQUIPMENT FUNCTIONAL RESERVE CAPABILITY DIRECT HEAT REMOVAL SERVICE (DHRS) COMPONENTS

- Overflow Heat Exchanger
- EVS (Ex-Vessel Storage Sodium Cooler)
- Air Blast Heat Exchanger
- EM Pumps*
- NaK Expansion Tank
- Sodium Piping
- Critical valves (evaluation in progress)

*Limiting component

EQUIPMENT FUNCTIONAL RESERVE CAPABILITY DHRS EM PUMPS FUNCTIONAL RESERVE SEISMIC MARGIN

- Calculated design margin based on yield criterion 1.01
- Material minimum strength assumptions 1.20
- Structural strength functional margin
- = $1.01 (1.2) = 1.21$
- Ratio of seismic to total loadings, $k = 32\%$
- EM Pumps functional reserve seismic margin
- = $1/0.32 (1.21-1) + 1 = 1.66$
- System seismic response conservatism = 1.45

EQUIPMENT FUNCTIONAL RESERVE SEISMIC MARGIN = 2.41


SEISMIC TESTING FOR CLASS 1E EQUIPMENT

- Qualify to IEEE std. 344-1975
- Single frequency tests
- Multiple frequency tests
- Single frequency plus multiple frequency
- Multiple frequency and recommended single frequency

EXAMPLE OF COMPARISON OF TRS/RRS FOR TESTED EQUIPMENT

- Reactor shutdown and isolation equipment
- Housed in cabinets and whole cabinet shake table tested
- Both sine beat unidirectional and multiple frequency biaxial motion
- Cabinet rotated 90°
- Functioned properly during and after testing
- TRS conservatively enveloped RRS
- Additional conservatism by enveloping horizontal RRS, 10% IEEE-323 margin and use of design spectra


PRIMARY REACTOR SHUTDOWN SYSTEM COMPARATOR/BUFFER CABINET AND LOGIC CABINET ASSEMBLIES



Damping 5%

SSE - Horizontal

PRIMARY REACTOR SHUTDOWN SYSTEM COMPARATOR/BUFFER CABINET AND LOGIC CABINET ASSEMBLIES



Damping 5%

SSE - Vertical

EXAMPLE OF RESERVE SEISMIC MARGIN FOR TESTED EQUIPMENT

- Seismic response conservatism for testing:
 - Development of ground accelerogram 1.05
 - Reduction of floor response spectrum 1.05
 - Development of required response spectra 1.1
 - IEEE-323 margin 1.1
- Total seismic response conservatism = 1.33
- Margin from TRS/RRS enveloping:
 - Ratio of ZPA = 2.85
 - Ratio of maximum peak = 1.54

RESERVE SEISMIC MARGIN on
ZPA = 3.79 x margin to fragility
RESERVE SEISMIC MARGIN on
peak = 2.05 x margin to fragility

BUILDINGS AND STRUCTURES RESERVE SEISMIC CAPABILITY STRUCTURAL STRENGTH RESERVE SEISMIC MARGIN


- Load factors for service loads (OBE):
 - OBE load factor in load combination = 1.9 (1.0 for SSE)
 - Design controlled by service loads
 - Loading produced by OBE > 50% SSE
 - Result in reserve strength at least 1.05
- Strength reduction factors:
 - ACI Code limits below ultimate capacity
 - Reduction factors range from 0.75 to 0.90
 - Result in reserve strength at least 1.11
- Material minimum strength assumptions:
 - Reinforcing steel yield strength 5% to 15% higher than specified
 - Concrete design based on 28 day strength
 - 25% concrete strength increase due to aging in one year
 - Result in reserve strength at least 1.12
- Redundant structural components:
 - Interconnected buildings on common foundation mat
 - Multiple interconnected cells
 - Estimated margin due to redundant path load 1.05

STRUCTURAL STRENGTH RESERVE SEISMIC MARGIN = 1.37

BUILDINGS AND STRUCTURES RESERVE SEISMIC CAPABILITY SEISMIC RESPONSE CONSERVATISM

- Development of ground accelerogram 1.05
 - Reduction of response spectrum due to inelastic action:
 - Substantial reserve strength in inelastic range
 - Energy absorption due to concrete cracking and yielding of reinforcing steel
 - Newmark's inelastic design spectra (NUREG/CR-0098)
 - Reduction of spectral accelerations below 33 Hz
 - Reduction is function of ductility factor and frequency
 - NUREG/CR-0098 ductility factor (μ) between 2 and 3 for structures housing Class I equipment
 - Reduction for 2Hz to 8Hz range = $1/(2\mu-1)^{1.2}$
 - Elastic input accelerations reduced by 45% to 58%
 - Results in reserve margin of 1.73 to 2.24
- BUILDINGS AND STRUCTURES SEISMIC RESPONSE CONSERVATISM = 1.82 to 2.35

RESERVE SEISMIC CAPABILITY OF CRBRP RESERVE SEISMIC MARGINS



CONSERVATISM IN RESERVE SEISMIC CAPABILITY

- Assumption of calculated stress equal to allowable stress for equipment
- Design of most equipment controlled by OBE
- OBE = 50% SSE but OBE equipment loads > 50% SSE
- Use of linear-elastic dynamic and stress analyses
- Reduction of floor response spectra due to inelastic action of building
- Reduction for ductility factor of equipment
- Envelope spectra for multiple-support system
- Response spectrum versus time history analysis
- Exclusion of non-structural elements
- Redundance of structural elements
- Ground response spectra with high amplifications
- Absolute combination of seismic loads with other loads
- Conservatism by designer action and duplication for design simplification
- Load factors on dead and live loads for buildings
- Building serviceability requirements (shielding, stiffness, TMBDB, tornado missile)

CONCLUSIONS

- Reserve Seismic Capability of CRBRP System Equipment:
 - Structural Reserve Seismic Margin = 2.6 to 3.2
 - Reserve Margin Earthquake = 0.65g to 0.80g
 - Functional Reserve Seismic Margin = 2.4
 - Reserve Margin Earthquake = 0.60g
 - Reserve Seismic Capability of CRBRP Buildings and Structures:
 - Reserve Seismic Margin = 2.5 to 3.2
 - Reserve Margin Earthquake = 0.62g to 0.80g
- CRBRP SEISMIC CAPABILITY = AT LEAST 0.60g

CLINCH RIVER BREEDER REACTOR PLANT



BRIEFING FOR:


**ADVISORY COMMITTEE ON
REACTOR SAFEGUARDS (ACRS)
FULL COMMITTEE**

SEISMIC MARGIN

PRESENTED BY:

G. H. CLARE
LICENSING MANAGER,
CRBRP PROJECT
WESTINGHOUSE
ADVANCED REACTORS DIVISION
OAK RIDGE SITE

FEBRUARY 11, 1983



SUPERIMPOSED RESULTS FOR OAK RIDGE

FIGURE 10

SEISMIC MARGIN

- ESTIMATES OF 0.25g SSE RECURRENCE FREQUENCY RANGE FROM 10^{-3} TO 10^{-4} PER YEAR
- AN EARTHQUAKE WITH ACCELERATION TWICE THAT OF THE SSE WOULD HAVE A RECURRENCE FREQUENCY SIGNIFICANTLY LESS THAN 10^{-4} PER YEAR
- MARGIN ASSESSMENTS INDICATE CRBRP COULD BE SHUTDOWN AND MAINTAINED IN A SAFE CONDITION FOR EARTHQUAKES WITH A RECURRENCE FREQUENCY SIGNIFICANTLY LESS THAN 10^{-4} PER YEAR

CRBR FUEL, BLANKET AND CONTROL ASSEMBLY
MECHANICAL DESIGN

PRESENTATION TO ACRS - 2/11/83

BY - M. TOKAR - NRC
- R. BAARS - LANL

SCOPE OF STAFF REVIEW

- o MECHANICAL DESIGN OF FUEL, BLANKET AND CONTROL PINS AND ASSEMBLIES, INCLUDING:
 - DESIGN CRITERIA/LIMITS
 - DESIGN METHODS
 - STEADY STATE CONDITIONS
 - TRANSIENT CONDITIONS

- o DEVELOPMENT TESTING, INCLUDING
 - IN-REACTOR
 - EX-REACTOR
 - STEADY STATE
 - TRANSIENT

- o REVIEWED BY LANL

ACCEPTANCE CRITERIA

- o CONFORMANCE WITH CRBR PRINCIPAL DESIGN CRITERIA:
 - #8 - REACTOR DESIGN
- o CONFORMANCE WITH INTENT OF SRP 4.2 "FUEL SYSTEM DESIGN"
- o COMPLETENESS AND ADEQUACY (BASIS) OF APPLICANTS':
 - DESIGN CRITERIA/LIMITS
 - DESIGN METHODS
 - CONCEPTUAL DESIGN
- o ADEQUATE DEVELOPMENT TESTING TO SUPPORT THE DESIGN/CRITERIA/LIMITS/METHODS

FAVORABLE FACTORS
FOR SUCCESS OF SYSTEM

- o MASSIVE LMFBR TEST PROGRAM SHOWS MIXED OXIDE FAILURES
VERY RARE FOR CRBR GOAL EXPOSURE
- o OPERATION IS FAR FROM COOLANT SATURATION, LESSENING
THE CHANCE OF COOLING DISCONTINUITY
- o PROPOSED SCRAM TRIP SETTINGS TERMINATE ABNORMAL
OCCURRENCES FAR SHORT OF SIGNIFICANT FUEL DAMAGE
OR DISRUPTION
- o LOW SMEAR DENSITY OF FUEL (85%) - ABOUT TWICE THE
RELATIVE VOLUME TO ACCOMMODATE RADIAL EXPANSION
AS LWR FUELS
- o FALLBACK POSITIONS OF REDUCED POWER, EXPOSURE AND
OPERATING TEMPERATURE ARE AVAILABLE
- o OPERATING DATA ON SIMILAR (FFTF) SYSTEM AVAILABLE
BY FSAR

CRITERIA ISSUES
COOLABLE GEOMETRY LIMITS

- o NO BASIS PROVIDED TO SUPPORT CLADDING MELTING LIMIT FOR ENSURING COOLABLE GEOMETRY

- o VIOLABLE NO-BOILING GUIDELINE INADEQUATE -
NO INFORMATION AS TO HOW CASES INVOLVING BOILING WOULD BE EVALUATED

- o NEITHER CLADDING NOR COOLANT TEMPERATURE BASED LIMITS ADEQUATELY GUARD AGAINST MOLTEN FUEL EXPULSION FOR OVER POWER CONDITIONS

RESOLUTION: APPLICANTS HAVE COMMITTED TO ADDRESS ALL OF THESE ISSUES AND DOCUMENT A COMPREHENSIVE BASIS FOR COOLABLE GEOMETRY LIMITS FOR REVIEW BY THE STAFF PRIOR TO FSAR SUBMITTAL.

METHODS ISSUES
FUEL EVALUATION MODELS

- o CUMULATIVE DAMAGE FUNCTION MODEL
 - MODEL HAS NOT BEEN QUALIFIED TO INTEGRAL ROD TEST DATA
 - MODEL DOES NOT ADDRESS FUEL ADJACENCY EFFECT
 - STATISTICAL APPROACH DOES NOT COVER DATA VARIANCE

- o DUCTILITY LIMITED STRAIN MODEL
 - MODEL SHOULD BE REQUALIFIED TO INTEGRAL ROD TEST DATA
 - MARGIN TO FAILURE NOT ESTABLISHED
 - MODEL UNCERTAINTIES NOT ESTABLISHED

RESOLUTION: APPLICANT HAS COMMITTED TO ADDRESS CDF ISSUES BY SUBMITTAL OF THE FSAR.

DATA BASE ISSUES

- o ATYPICAL FACTORS
 - FLUENCE/BURNUP
 - SHORT RODS
 - TRANSIENT TEST RADIAL POWER DEPRESSION
 - NO PRECONDITIONING IN TRANSIENT TESTS

- o COVERAGE
 - 32% PLUTONIUM
 - BLANKET RODS
 - SLOW OVERPOWER
 - UNDERCOOLING AT END-OF-LIFE

- o CLADDING
 - FUEL ADJACENCY EFFECT
 - RESPONSE AT HIGH FLUENCE AND HIGH TEMPERATURE

RESOLUTION: APPLICANT HAS ACTIVE COMPREHENSIVE PROGRAM TO ADDRESS THESE ISSUES. THESE ISSUES ARE ENUMERATED AS THE PRESENT STATUS OF THE DATA BASE FOR WHICH WE HAVE DOCUMENTATION.

CONCLUSION

PROSPECTS FOR SUCCESS OF THE CRBR FUEL SYSTEM JUSTIFY ISSUANCE OF CONSTRUCTION PERMIT.

HOWEVER, ABILITY TO CLEARLY DEMONSTRATE ACCEPTABILITY OF THE SYSTEM FOR AN OPERATING LICENSE WITHOUT RESORTING TO FALLBACK POSITIONS DEPENDS ON ADDRESSING IDENTIFIED ISSUES.

BASIS FOR CONCLUSIONS

- o PREVIOUSLY ENUMERATED FAVORABLE FACTORS.
- o ALL OF THE FOREGOING ISSUES ARE PRIMARILY RELEVANT TO THE ABILITY TO EVALUATE FUEL PERFORMANCE, NOT TO FUEL PERFORMANCE ITSELF.
- o PROGRAMS ARE UNDER WAY, OR HAVE BEEN COMMITTED BY THE APPLICANT, TO RESOLVE THE ISSUES BY FSAR SUBMITTAL.
- o THE AVAILABILITY OF FALLBACK POSITIONS ALLOWS DEFERRAL OF RESOLUTION TO THE FSAR.

CRBR NUCLEAR DESIGN

SER SECTION 4.3

AERS MEETING

FEBRUARY 11, 1983

W. L. BROOKS

CORE PERFORMANCE BRANCH

USNRC

SAFETY EVALUATION REPORT

SECTION 4.3

DESIGN BASES

- PRINCIPAL DESIGN CRITERIA

DESIGN DESCRIPTION

REACTIVITY CONTROL SYSTEM

POWER DISTRIBUTIONS

REACTIVITY COEFFICIENTS

INSTRUMENTATION

CORE STABILITY

ANALYTICAL METHODS

PRINCIPAL DESIGN CRITERIA AFFECTING THE CORE

● PDC 8 - REACTOR DESIGN

PDC 9 - INHERENT REACTOR PROTECTION

PDC 10 - SUPPRESSION OF REACTOR POWER OSCILLATIONS

PDC 11 - INSTRUMENTATION AND CONTROLS

PDC 18 - PROTECTION SYSTEM FUNCTION

PDC 23 - PROTECTION SYSTEM REQUIREMENTS FOR

REACTIVITY CONTROL MALFUNCTIONS


● PDC 24 - REACTIVITY CONTROL SYSTEM REDUNDANCY
AND CAPABILITY

PDC 25 - COMBINED REACTIVITY CONTROL SYSTEMS
CAPABILITY

PDC 57 - REACTIVITY LIMITS

PDC 58 - PROTECTION AGAINST ANTICIPATED

OPERATIONAL OCCURRENCES









- | | |
|---|---|
|  156 FUEL ASSEMBLIES |  6 ALTERNATE FUEL BLANKET ASSEMBLIES |
|  76 INNER BLANKET ASSEMBLIES |  6 SECONDARY CONTROL ASSEMBLIES |
|  126 RADIAL BLANKET ASSEMBLIES | 312 RADIAL SHIELD ASSEMBLIES |
| |  9 PRIMARY CONTROL ASSEMBLIES |

FIGURE 4.3-1. Clinch River Breeder Reactor Core Layout

REACTIVITY CONTROL SYSTEM

RELEVANT CRITERIA

- 23
- 24
- 25
- 57
- 58

DESIGN BASES

CALCULATION METHODS

RESULTS AND CONCLUSION

POWER DISTRIBUTIONS AND INSTRUMENTATION

RELEVANT CRITERIA

- 8
- 11
- 18

DESIGN BASES

CALCULATION METHODS

RESULTS AND CONCLUSIONS

REACTIVITY COEFFICIENTS AND CORE STABILITY

RELEVANT CRITERIA

- 9
- 10

DOPPLER COEFFICIENT

OTHER COEFFICIENTS

CORE STABILITY

CALCULATION METHODS

EFFECT OF BOWING

ANALYTICAL METHODS

SUMMARY OF METHODS

COMMITMENTS

CRBR REACTOR THERMAL - HYDRAULIC DESIGN

PRESENTATION TO ACRS - 2/11/83

BY T. KING - NRC

SCOPE OF STAFF REVIEW

- 1) THERMAL/HYDRAULIC DESIGN OF IN-VESSEL COMPONENTS, INCLUDING:
 - DESIGN CRITERIA/LIMITS
 - DESIGN METHODS
 - STEADY STATE CONDITIONS
 - TRANSIENT CONDITIONS

- 2) DEVELOPMENT AND STARTUP TESTING
 - STEADY STATE
 - TRANSIENT

- 3) REVIEW AND INDEPENDENT ANALYSIS BY:
 - BNL
 - ANL
 - BARTHOLD & ASSOC.

ACCEPTANCE CRITERIA

- CONFORMANCE WITH CRBR PRINCIPAL DESIGN CRITERIA:
 - #8 - REACTOR DESIGN
 - #60- FLOW BLOCKAGE

- CONFORMANCE WITH SRP SECTION 4.4 "THERMAL HYDRAULIC DESIGN"

- COMPLETENESS AND ADEQUACY OF APPLICANTS':
 - o DESIGN CRITERIA/LIMITS
 - o DESIGN METHODS
 - o CONCEPTUAL DESIGN

- ADEQUATE DEVELOPMENT TESTING TO SUPPORT THE DESIGN/CRITERIA/LIMITS/METHODS

- CONFIRMATION OF APPLICANTS' ANALYSIS BY SELECTED INDEPENDENT OVERCHECKS

MAJOR SAFETY FEATURES OF DESIGN

- o PROVIDE FOR DECAY HEAT REMOVAL VIA NATURAL CIRCULATION

- o PREVENTS SIGNIFICANT GAS ENTRAINMENT BY:
 - VENTING POTENTIAL GAS COLLECTION AREAS
 - SUPPRESSING VORTEX FORMATION AND TURBULANCE IN THE UPPER PLENUM

- o MINIMIZES THE POTENTIAL FOR FLOW BLOCKAGE BY:
 - PROVIDING DISCRIMINATION FEATURES TO PREVENT ASSEMBLY PLACEMENT IN A CORE LOCATION OF HIGHER POWER THAN WHAT IT IS ORIFICED FOR.
 - PROVIDING MULTIPLE FLOW PATHS TO THE ASSEMBLY INLET NOZZLES.
 - PROVIDES CORE INLET STRAINERS WHICH WILL FILTER OUT PARTICLES LARGER THAN 1/4 INCH.
 - PROVIDING INLET NOZZLE OPENINGS WHICH ALLOW ASSEMBLY VERTICLE MOTION WITHOUT CUTTING OFF FLOW.

- o PROVIDES MONITORING INSTRUMENTATION FOR CORE ASSEMBLY OUTLET TEMPERATURES.

- o REQUIRES PREVENTION OF INADVERTENT CONTROL ROD FLOATATION DURING REFUELING.

- o REQUIRES SUFFICIENT FLOW TO ALL PERMANENT AND REMOVEABLE CORE COMPONENTS TO MAINTAIN THEM WITHIN THEIR STRUCTURAL LIMITS FOR ALL STEADY STATE AND TRANSIENT OPERATION

- o ORIFICING DESIGN WHICH PROVIDES SHIELDING TO CORE SUPPORT STRUCTURE.

ITEMS TO BE RESOLVED AS PART OF
FINAL DESIGN

- o PRIMARY CONTROL ROD FLOATATION
- o AFFECT OF OBSERVED FFTF CORE ΔP
INCREASE ON CRBR DESIGN
- o AFFECT OF LATEST POWER TO MELT DATA
ON CRBR FUEL DESIGN
- o CORRECT METHODOLOGY FOR APPLICATION
OF HCF's.


INDEPENDENT OVERCHECK ANALYSIS

- o STEADY STATE, FULL POWER CORE CONDITIONS

- o NATURAL CIRCULATION:
 - COMPARISON WITH APPLICANTS' BASE CASE
 - COMPARISON WITH FFTF RESULTS


- o DHRS:
 - COMPARISON WITH APPLICANTS' BASE CASE
 - COMPARISON WITH FFTF DATA


- o FOLLOW ON WORK IN SUPPORT OF OL REVIEW:
 - SENSITIVITY STUDY ON BASE CASE
NATURAL CIRCULATION CALCULATIONS
 - SENSITIVITY STUDY ON BASE CASE DHRS
CALCULATIONS
 - ANALYSIS OF NATURAL CIRCULATION TRANSIENT
FROM REFUELING CONDITIONS




STATION BLACKOUT - COOLANT TEMPERATURE FOR HOT FUEL PIN

Fuel Assembly Outlet Temperature






STATION BLACKOUT - COOLANT TEMPERATURE FOR HOT INNER BLANKET PIN



DHRS DESIGN BASIS ACCIDENT - BULK UPPER PLENUM SODIUM TEMPERATURE



DHS EVENT - SENSITIVITY OF BULK UPPER PLENUM SODIUM TEMPERATURE TO VARIATIONS IN "SHORT CIRCUIT" FLOW FRACTION

CONCLUSION

- o DESIGN HAS HIGH PROBABILITY MEETING CRITERIA.

- o FALLBACK OF REDUCED POWER, FLOW OR BURNUP EXIST IF COMPLICATIONS ARISE DURING FINAL DESIGN.

- o THEREFORE, STAFF CONSIDERS DESIGN ACCEPTABLE FOR CP.

FACTORS WHICH INDICATE DESIGN IS ACCEPTABLE FOR CP

- o INCORPORATES FEATURES TO:
 - MINIMIZE THE POTENTIAL FOR FLOW BLOCKAGE
 - PREVENT SIGNIFICANT GAS ENTRAINMENT
 - MONITOR ASSEMBLY OUTLET TEMPERATURES
 - ALLOWS DECAY HEAT REMOVAL VIA NATURAL CIRCULATION
- o FLOW DISTRIBUTION, ΔP 's FRICTION FACTORS, GAS ENTRAINMENT ARE SUPPORTED BY EXTENSIVE WATER AND SODIUM DEVELOPMENT TESTING.
- o FFTF FUEL DESIGN AND IN-VESSEL THERMAL HYDRAULICS DESIGN IS SIMILAR TO CRBR AND CONTINUED FFTF OPERATION WILL PROVIDE DATA DIRECTLY APPLICABLE TO CRBR.
- o STAFF'S INDEPENDENT CALCULATIONS INDICATE THAT APPLICANTS' DESIGN METHODS PROVIDE A REASONABLE ESTIMATE OF SYSTEM PERFORMANCE.
- o APPLICANT HAS COMMITTED TO TESTING DURING INITIAL STARTUP TO:
 - CONFIRM NATURAL CIRCULATION PREDICTION
 - CONFIRM DHRS PERFORMANCE
 - MEASURE SELECTED IN-VESSEL TEMPERATURE AND VIBRATIONS.
- o PRELIMINARY SAFETY ANALYSIS HAS BEEN DONE WITH CONSERVATIVE ASSUMPTIONS:

- ADDITIONAL DECAY HEAT
- HCF
- ADDITIONAL ΔP
- THDV + 20 F CONDITIONS FOR PERMANENT COMPONENTS
- UPPER BOUND ON PHYSICAL PROPERTIES
- ETC.

CRBRP REACTOR DESIGN

**Presented To ACRS
Washington, DC
February 11, 1983**

Westinghouse Electric Corporation
Advanced Reactors Division
Madison, PA 15663



REACTOR TOPICS

1. Introduction
Mr. Robert M. Vijuk
Manager, Nuclear Systems
Engineering
2. Reactor Vessel and Internals
Design
Dr. Frank J. Baloh
Manager, Reactor Enclosure and
Lower Internals
3. Core Nuclear Design
Mr. Richard A. Doncals
Manager, Nuclear Analysis
4. Core Thermal and Hydraulic
Design
Mr. Robert A. Markley
Manager, Thermal and Fluid
System Engineering
5. Fuel and Blanket Design
Mr. Ambrose L. Schwallie
Manager, Fuel and Removable
Assembly Design

REACTOR VESSEL AND INTERNAL DESIGN

 **ARD**

8254-3

PRESENTATION OUTLINE


0 GENERAL OVERVIEW

- CLOSURE HEAD (5 MIN)
- REACTOR VESSEL (5 MIN)
- LOWER INTERNALS (5 MIN)


0 UIS DESIGN (15 MIN)

- FUNCTIONAL REQUIREMENTS
- DESIGN DESCRIPTION
- PERTINENT DESIGN CONSIDERATIONS

CRBRP REACTOR VESSEL



REACTOR CLOSURE HEAD ASSEMBLY



PERSONNEL PLATFORM

EVTM NOZZLE

TYPICAL HEATERS

RISERS

SHIELD PLATES

REFLECTOR PLATES

SUPPRESSOR PLATE

LARGE ROTATING PLUG

INTERMEDIATE ROTATING PLUG

SMALL ROTATING PLUG

BLANKET INSULATION

REACTOR VESSEL SUPPORT ASSEMBLY


IVTM NOZZLE


PLUG DRIVE

DIP SEAL


REACTOR VESSEL

WARD






LOWER INTERNALS SYSTEM CORE SUPPORT STRUCTURE




WHAT DOES IT DO? UIS FUNCTIONAL REQUIREMENTS

- Maintain control rod alignment with core
- Provide cross flow protection for control rod drivelines
- Mix core outlet flow
- Mitigates transients in PHTS hotleg
- Provide secondary core holddown
- Position and support above-core instrumentation


UPPER INTERNALS STRUCTURE




ELEVATION SCHEMATIC OF THE UPPER INTERNALS STRUCTURE



WARD




Core Secondary Holddown, a View Looking up into the Mixing Chamber with a Core Map Superimposed



UIS CHIMNEY MECHANICAL SUPPORT BETWEEN THE LOWER AND UPPER PLATES

WARD



8213-4

Figure 10

UIS MATERIALS SELECTION

ⓂARD

- 316 stainless steel
 1. Compatibility with liquid sodium
 2. Well developed fabrication technology
 3. Creep rupture allowable superior to that for 304 SS
- Alloy 718
 1. Compatibility with liquid sodium
 2. High fatigue strength at high cycles (10^8 to 10^9) at high temperature
 3. Commercially available ;in product forms required
 4. Essentially no cobalt
 5. Adequate material property data base
 6. Fabricable into required configurations

HANDOUT
MATERIAL.

ONLY

REACTOR T&H DEVELOPMENT TESTING

INLET REGION

<u>TEST TITLE</u>	<u>SUPPORTING INFORMATION</u>	<u>STATUS</u>
● HEDL INLET PLENUM FEATURE TEST - 1/4 SCALE	CHARACTERIZATION OF INLET PLENUM AND LOWER INTERNAL T&H PERFORMANCE	COMPLETED
● HEDL INLET PLENUM FEATURE MODEL PARTICLE MOBILITY AND BUBBLE DISPERSION TESTS	PARTICLE TRANSPORT AND BUBBLE BREAKUP CHARACTERISTICS	COMPLETED
● WARD INLET PLENUM FEATURE TEST - 1/21 SCALE	VISUALIZATION OF INLET PLENUM FLOW PATTERNS - DETERMINATION OF MIXING AND TRANSPORT TIMES	COMPLETED
● HEDL PISTON RING LEAKAGE TESTS	PISTON RING LEAKAGE RATES	COMPLETED
● WARD LIM ORIFICING TESTS	FLOW CONTROL TO BLANKET ASSEMBLIES, REMOVABLE RADIAL SHIELDS AND BYPASS	80% COMPLETED
● WARD LIM CHARACTERIZATION TESTS	FLOW DISTRIBUTION AND PRESSURE DROP IN LIM	COMPLETED
● WARD LIM ORIFICE LIFE TEST	ORIFICE LIFETIME CHARACTERISTICS	COMPLETED
● HEDL RRSA ORIFICE TESTS IN WATER	CHARACTERIZATION OF ORIFICE PLATES	COMPLETED

REACTOR T&H DEVELOPMENT TESTING

OUTLET REGION

<u>TEST TITLE</u>	<u>SUPPORTING INFORMATION</u>	<u>STATUS</u>
● HEDL INTEGRAL REACTOR FLOW MODEL, OUTLET PLENUM FEATURE FLOW AND VIBRATION TEST - PHASE I TESTING	PLENUM VELOCITY PATTERNS, MIXING AND 4P CHARACTERISTICS, VIBRATION, GAS ENTRAINMENT AND STRIPING	COMPLETED
● HEDL INTEGRAL REACTOR FLOW MODEL, OUTLET PLENUM FEATURE FLOW AND VIBRATION TEST - PHASE II TESTING	HYDRAULIC AND VIBRATION CHARACTERISTICS OF UPPER INTERNALS	HYDRAULIC COMPLETED VIBRATION IN FABRICATION
● BCL OUTLET PLENUM STRATIFICATION TEST	FLOW DISTRIBUTION AND TEMPERATURE RESPONSE TO TRANSIENT OPERATION	COMPLETED
● ANL 1/10 SCALE OUTLET PLENUM TESTS	TEMPERATURE DISTRIBUTION AND RESPONSE AT STEADY STATE AND TRANSIENT OPERATION	COMPLETED
● ANL 1/15 SCALE OUTLET PLENUM TESTS	TRANSIENT TESTS IN WATER AND SODIUM	COMPLETED
● ANL CHIMNEY VIBRO-IMPACT TESTS	FULL-SCALE FLOW INDUCED VIBRATION OF UIS CHIMNEY	80% COMPLETED
● HEDL FUEL TRANSFER AND STORAGE ASSEMBLY	HEAT TRANSFER CHARACTERISTICS OF STORED FUEL ASSEMBLY	COMPLETED

REACTOR T&H DEVELOPMENT TESTING
STRIPING TESTS

<u>TEST TITLE</u>	<u>SUPPORTING INFORMATION</u>	<u>STATUS</u>
● HEDL IRFM STRIPING TESTS	STRIPING DATA ON: CHIMNEY AND INSTRUMENT POST, CONTROL ROD SHROUD TUBE, UPPER INTERNALS STRUCTURE AND BYPASS, REMOVABLE RADIAL SHIELD, BLANKET AND FUEL NOZZLES, CORE BARREL, FORMER RINGS, HORIZONTAL BAFFLE, LINER AND SUPPRESSOR PLATE, OUTLET NOZZLES, ETC.	COMPLETED
● A'NL STRIPING TESTS	STRIPING DATA ON: MIXING TEES, SEVEN NOZZLE ASSEMBLY WITH PORTION OF UPPER INTERNALS	COMPLETED IN PROGRESS
● WARD STRIPING TESTS	STRIPING DATA ON: SEVEN ASSEMBLY OUTLET NOZZLE FEATURE TEST, SEVEN ASSEMBLY OUTLET NOZZLES TEST, LOCAL INTERSTITIAL FLOW STRIPING TEST, INTERSTITIAL FLOW-WATER TABLE TESTS, THERMAL STRIPING TESTS IN SODIUM - DUNK AND ROTATING CYLINDER	COMPLETED 80% COMPLETED COMPLETED COMPLETED COMPLETED

CORE NUCLEAR DESIGN



8254-4


CRBRP NUCLEAR DESIGN

Outline

- **Reactor description and design basis**
- **Critical experimental program**
- **Reactor design areas supported by critical experiments**
- **Summary**

CLINCH RIVER BREEDER REACTOR CORE LAYOUT

WARD



○ 156 FUEL ASSEMBLIES

▨ 76 INNER BLANKET ASSEMBLIES

▩ 126 RADIAL BLANKET ASSEMBLIES

⦿ 6 ALTERNATE FUEL BLANKET ASSEMBLIES


⦿ 15 CONTROL ASSEMBLIES

312 RADIAL SHIELD ASSEMBLIES

CRBRP FUEL MANAGEMENT

FIRST ROW OF RADIAL
BLANKETS ARE REPLACED
AS A BATCH AFTER FOUR
YEARS OF OPERATION


SECOND ROW OF RADIAL
BLANKETS ARE REPLACED
AFTER FIVE YEARS OF
OPERATION




IN ALTERNATING YEARS OF
THE EQUILIBRIUM CYCLES,
THESE SIX INNER BLANKET
ASSEMBLIES ARE REPLACED
WITH SIX FRESH FUEL
ASSEMBLIES

ALL FUEL AND INNER
BLANKET ASSEMBLIES
REPLACED AS A BATCH AT
TWO YEAR INTERVALS

CRBRP CONTROL ASSEMBLIES



CRBRP NUCLEAR EXPERIMENTAL PROGRAM



WARD






Figure 14 Zero Power Plutonium Reactor

REACTOR DESIGN AREAS SUPPORTED BY CRITICAL EXPERIMENTS

Power Reactor Design Parameter

- Fuel enrichment
- Power distribution
- Control rod margin
- Reactivity coefficient
 - Doppler
 - Sodium void
 - Core restraint (expansion)
 - CDA-related
- Other performance data
 - Breeding ratio
 - Temperature defect
 - Ex-core detector capability
 - Fast flux/fluence

Critical Experiment Data Source

Critical fuel loading, Doppler and core expansion worth, core conversion ratio

Isotopic fission and capture rate distributions, gamma heating, blanket spiking studies

Control rod subcritical reactivity worth

Small heated-sample U238 Doppler worth

Large zone-voiding reactivity worth

Small-sample worth distributions

Sodium void worth, fuel and steel slumping worth

C238/F239

Doppler worth, core expansion worth

Control rod worth with ex-core detectors

Neutron energy spectrum, spectral indices

FUEL ENRICHMENT PHILOSOPHY

Guarantee that the reactor can be maintained at hot-full-power conditions throughout each design burnup cycle

Nominal excess reactivity:

- Cold-critical eigenvalue, K_{EFF}
- Cold-to-hot temperature defect
- Fuel burnup reactivity deficit
- Mid-term refueling reactivity addition

Uncertainties:

- Criticality prediction
- Fuel burnup reactivity swing
- Temperature defect
- Fissile loading and core geometry tolerances
- Impurities
- Refueling worth

CRITICAL EIGENVALUE PREDICTIONS VERSUS EXPERIMENTAL VALUES

	Calculated k_{eff}	Experimental k_{eff}	C/E
ZPPR-7A	0.99019	1.00045	0.9897
ZPPR-7B	0.98924	1.00083	0.9884
ZPPR-7C	0.99089	1.00161	0.9893
ZPPR-7D	0.99347	1.00110	0.9924
ZPPR-7F	0.98873	1.00079	0.9880
ZPPR-7G	0.98858	1.00075	0.9878
ZPPR-8F	0.99156	1.00090	0.9907

Mean = 0.9895

$1\sigma = \pm 0.0016$

CRBRP FUEL ENRICHMENTS

Cycles	Pu/(Pu + U)
1 & 2	32.8
Equilibrium	33.0

Beginning of Life Fissile Plutonium Inventory, 1498 kg

POWER CALCULATION COMPONENTS

$$\text{Linear power (kW/ft)} = \frac{\text{Reactor power (kW)} \cdot \text{region power fraction}}{\text{no. of rods} \cdot \text{length of rod (ft)}} \cdot F_R^N \cdot F_Z^N \cdot 1.15 \cdot (1 + 3\sigma)$$

Where F_R^N is the normalized radial power distribution

F_Z^N is the normalized axial power distribution

1.15 is a 15% overpower-margin multiplier

$1 + 3\sigma$ represents the 3σ power envelope




Figure 6.4. ZPPR-11 Phase B Midplane Calculation-to-Experimental Ratio for ²³⁵U (n, f)

REACTION RATE CALCULATION TO EXPERIMENT RATIOS

<u>Reaction</u>	<u>ZPPR-11B Beginning Of Life C/E $\pm 1\sigma$</u>	<u>ZPPR-11C End Of Life C/E $\pm 1\sigma$</u>
Fuel		
Pu ²³⁹ (n,f)	1.000 \pm .019*	1.000 \pm .019
U ²³⁵ (n,f)	1.057 \pm .026	1.043 \pm .026
U ²³⁸ (n,f)	0.879 \pm .034	0.922 \pm .034
Inner Blanket		
Pu ²³⁹ (n,f)	1.014 \pm .023	0.989 \pm .023
U ²³⁵ (n,f)	1.050 \pm .026	1.022 \pm .026
U ²³⁸ (n,f)	1.093 \pm .041	0.983 \pm .032
U ²³⁸ (n,capt)	1.055 \pm .025	1.088 \pm .025


*Uncertainty includes statistical deviation in foil C/E's plus estimated systematic uncertainty in measurement

**FUEL REGION POWER UNCERTAINTY FROM
REACTION RATE UNCERTAINTIES**

Component	1 σ (%)	Power Fraction
Pu ²³⁹ fission	$\pm 1.9\%$.765
U ²³⁵ fission	2.6	.005
U ²³⁸ fission	3.4	.065
Other fission	5.0	.065
Gamma heating	8.0	.10

Resulting 3 σ uncertainty is $\pm 5.5\%$

**PEAK LINEAR POWER DISTRIBUTION (KW/FT)
 (3 σ + 15% OVERPOWER CONDITIONS) FUEL AT BOCI
 (EXCEPT REFUEL CHANNELS) INNER BLANKETS AT EOC4
 (NOTE: THESE VALUES DO NOT OCCUR SIMULTANEOUSLY)**



SUMMARY OF USE OF ZPPR CONTROL ROD WORTH DATA IN CRBRP DESIGN

<u>Experiment</u>	<u>Application</u>
3R4, 6R7F, 6R7C bank worths in ZPPR-11B	Bias factors
Asymmetric-group rod worths	Verify that control rod worth bias is not substantially different in faulted (stuck rod) shutdown configuration
Pin control rod mockup	Pin versus plate extrapolation effects, evaluate B ¹⁰ enrichment effects
Pin bunching	Evaluate capability of relatively simple central-rod calculational model to account for control rod worth reduction associated with absorber-pin bunching
Axial worth profile	Verify RZ calculations and chopped cosine approximation
Fuel/blanket interchange worth	Assess CRBRP mid-term refueling worth uncertainty


WARD

ZPPR-11 CONTROL ROD BANK WORTHS

	ZPPR-11B Beginning Of Life			ZPPR-11C End Of Life		
	Calculated*	Measured	C/E	Calculated*	Measured	C/E
	Worth \$	Worth \$		Worth \$	Worth \$	
3R4	3.33	3.34	0.997	6.17	6.27	0.984
6R7F	12.97	12.42	1.044	15.81	15.36	1.029
6R7C	16.95	16.28	1.041	16.71	16.19	1.032

*Calculations with 4 mesh per ZPPR-drawer

Ⓜβ_{EFF} = 0.003426 (ZPPR-11B)
0.003540 (ZPPR-11C)



1-13 Zone 1 through Zone 13

B Blanket Ring 1

Fig. 3.1 ZPPR-11E Radial Sodium Void Zones

HETEROGENEOUS CRBRP SODIUM VOID REACTIVITY (\$) END OF CYCLE FOUR

FLOWING SODIUM ONLY (APPROXIMATELY 82% OF THE TOTAL)

	ENDF/B-3	ENDF/B-3 BIASED	ENDF/B-4	ENDF/B-4 BIASED	UNCERTAINTY $\pm 1 \sigma$
36- inch fuel	1.15\$	1.50	1.90	1.49	$\pm .28$
Lower axial blanket	-.17	-.19	-.15	-.14	$\pm .03$
Upper axial blanket	<u>-.17</u>	<u>-.19</u>	<u>-.16</u>	<u>-.16</u>	$\pm .03$
Total	.81	1.12	1.59	1.19	

ZPPR-11B FUEL U²³⁸ DOPPLER CONSTANT
-T dk/dT

Measured fuel U ²³⁸ Doppler	-0.00332
Calculated Doppler	-0.00327
C/E	0.986


SUMMARY

Bias factors and uncertainties in calculated CRBRP nuclear parameters are based on an extensive zero power critical experimental data base

Experiments include:

- Critical fuel loading
- Power distribution parameters
- Control rod worth characteristics
- Reactivity feedback effects

CORE THERMAL AND HYDRAULIC DESIGN




8254-5



CRBPP CORE T&H ANALYSIS AND DESIGN OUTLINE

- CORE T&H DESCRIPTION AND BASES
 - FLOW PATHS
 - DESIGN DATA
 - FLOW ALLOCATIONS
- PERFORMANCE PREDICTIONS
 - STEADY STATE
 - DESIGN TRANSIENTS
- T&H DEVELOPMENT TEST PROGRAMS/DATA
- CONCLUSIONS

CRBRP SCHEMATIC FLOW PATHS





CRBR PRINCIPAL CORE T&H DESIGN DATA

	Fuel	Blanket
Rods per assembly	217	61
Rod diameter (in.)	0.230	0.506
Pitch-to-diameter ratio	1.25	1.07
Wire wrap axial pitch (in.)	12	4
Axial lengths (in.):		
Lower axial blanket	14	} 64
Active core	36	
Upper axial blanket	14	
Fission gas plenum	48	48


CRBRP FLOW ALLOCATION



TOTAL REACTOR FLOW
(100%)



ORIFICING ZONES



• PIN LIFE-TIME/TRANSIENT REQUIREMENTS
• STRIPPING
• ASSEMBLY OUT-LET TEMP.

PIN LIFE-TIME/TRANSIENT REQUIREMENTS

• LIFETIME
• SCRAM
• FLOTATION REQUIREMENTS

• LIFETIME
• OUTLET TEMP.

TEMPERATURE LIMIT

DATA AND CALCULATIONS

MAJOR FLOW PATH (FLOW ALLOCATION)

BASIS FOR FLOW ALLOCATION




CRBR PRINCIPAL CORE T&H PERFORMANCE DATA

REACTOR INLET TEMPERATURE		730°F	
REACTOR OUTLET TEMPERATURE		995°	
REACTOR DESIGN FLOW		41.446×10^6 LB/HR	
REACTOR VESSEL NOZZLE-TO-NOZZLE PRESSURE DROP		123 PSI	
	<u>FUEL</u>	<u>INNER BLANKET</u>	<u>RADIAL BLANKET</u>
NUMBER OF ORIFICING ZONES	5 - 6	3 - 2	4
RANGE OF MAXIMUM HOT ROD CLADDING TEMPERATURES (2σ), °F	1201 - 1312	1057 - 1262	989 - 1228
MAXIMUM FISSION GAS PRESSURE (2σ), PSIA	962	249	273
MAXIMUM FLOW VELOCITY IN BUNDLE (FT/SEC)	23	18	13
MAXIMUM MIXED MEAN EXIT TEMPERATURE (NOMINAL), °F	1123	1029	1003
MAXIMUM TEMPERATURE GRADIENT (NOMINAL), °F		273 (FUEL/RADIAL BLANKET)	




CORE ASSEMBLIES MIXED MEAN OUTLET TEMPERATURES - BOC1 (THDV - °F)






ENVELOPE OF FUEL, INNER BLANKET MAXIMUM CLADDING ID TEMPERATURES FOR FIRST CORE (PEOC-2 σ)

XX — ASSEMBLY NUMBER
XXXX — TIME AT MAXIMUM
XXXX — MAXIMUM CLAD ID TEMP. ($^{\circ}$ F)





CLADDING TEMPERATURE/PRESSURE HISTORY IN F/A #101, O. Z. 1



DESIGN TRANSIENTS
WORST CASE UNDERCOOLING EVENT
CRBRP THREE-LOOP NATURAL CIRCULATION
TRANSIENT - MAXIMUM CLADDING/COOLANT TEMPERATURE (°F)
AND TIME OF OCCURRENCE (SEC.)

W

● PRESENTED IN CRBRP-ARD-0308

<u>ASSEMBLY</u>	<u>NOMINAL</u>		<u>3σ</u>	
	<u>TEMP.</u>	<u>TIME</u>	<u>TEMP.</u>	<u>TIME</u>
FA-52	1299	178	1565	180
IB-99	1229	222	1544	239
RB-203	1279	275	1556	389


ACCEPTANCE CRITERION: $T_{MAX} < \text{BOILING}$

$T_{SAT.} = 1720^{\circ}\text{F}$
{

- AT TOP OF FUEL ACTIVE REGION
- ZERO FLOW
- ZERO COVER GAS PRESSURE
- MINIMUM OPERATION POOL LEVEL



MEASURED AND PREDICTED SODIUM TEMPERATURES AT TOP OF THE FUEL SECTION, TX1016, FOR ROW 2 FCTA-FFTF (Test Initiated From 100% Power/100% Flow)





TRANSIENT REACTOR/CORE DESIGN REQUIREMENTS SUMMARY

- PROPER INTERFACE REQUIREMENTS HAVE BEEN ESTABLISHED
- COMPATIBLE STEADY STATE OPERATING CONDITIONS HAVE BEEN ESTABLISHED (E.G., THROUGH ORIFICING)
- ALL DESIGN BASIS ACCIDENTS (OVERPOWER AND UNDERCOOLING) HAVE BEEN EVALUATED ON A CONSERVATIVE BASIS AND MEET THE DESIGN GUIDELINES OF:
 - NO BOILING
 - NO CLAD MELTING
 - ACCEPTABLE LIFETIME/STRUCTURAL INTEGRITY



CORE T&H DEVELOPMENT TEST PROGRAMS

- FUEL ASSEMBLY
- BLANKET ASSEMBLY
- CORE PRESSURE DROP
- EXAMPLES OF DATA

OUT-OF-PILE T&H DEVELOPMENT TESTING
FOR FUEL ASSEMBLIES



<u>TEST TITLE</u>	<u>SUPPORTING INFORMATION</u>	<u>STATUS</u>
● ORNL 19 AND 61-ROD BUNDLE HEAT TRANSFER - SODIUM	W/W BUNDLE TEMPERATURE DISTRIBUTION OVER WIDE OPERATING RANGE, INCLUDING TRANSIENTS	COMPLETED
● HEDL 217-ROD LOW FLOW HEAT TRANSFER - SODIUM	LOW FLOW BUNDLE TEMPERATURE DISTRIBUTION	COMPLETED
● HEDL 217-ROD BUNDLE MIXING - H ₂ O	DETAILED BUNDLE MIXING	COMPLETED
● ANL 91-ROD BUNDLES MIXING - H ₂ O	BUNDLE SWIRL AND MIXING	COMPLETED
● MIT FUEL BUNDLE T&H	FLOW SPLIT, ΔP, FLOW DISTRIBUTION AND MIXING	IN PROGRESS
● WARD 11:1 SCALE WIRE WRAP BUNDLE AIR FLOW	DETAILED S/C AXIAL AND CROSS FLOW CHARACTERIZATION AND MIXING	COMPLETED
● HEDL CRBR ASSEMBLY FLOW AND VIBRATION	VERIFICATION OF FLOW AND VIBRATION CHARACTERISTICS	COMPLETED
● HEDL FFTF ASSEMBLY/BUNDLE FLOW	BUNDLE PRESSURE DROP	COMPLETED
● HEDL INLET/OUTLET NOZZLE AND ORIFICE FLOW	CAVITATION AND ΔP CHARACTERIZATION	90% COMPLETED
● EBR-II ORIFICE CAVITATION PROOF TEST	FLOW CONTROL ORIFICE LIFETIME/CAVITATION	IN PROGRESS
● HEDL ASSEMBLY OUTLET NOZZLE INSTRUMENTATION	CORRELATE T/C OUTLET TEMPERATURE MEASUREMENTS	TESTING COMPLETE



OUT-OF-PILE T&H DEVELOPMENT TESTING
FOR BLANKET ASSEMBLIES

<u>TEST TITLE</u>	<u>SUPPORTING INFORMATION</u>	<u>STATUS</u>
● WARD FULL SCALE 61-ROD ASSEMBLY HEAT TRANSFER - SODIUM	W/W BUNDLE TEMPERATURE DISTRIBUTION OVER WIDE OPERATING RANGE, INCLUDING TRANSIENTS	95% COMPLETED
● MIT BLANKET BUNDLE T&H - H ₂ O	FLOW SPLIT, ΔP, FLOW DISTRIBUTION AND MIXING	IN PROGRESS
● WARD 5:1 SCALE WIRE WRAP BUNDLE AIR FLOW	DETAILED S/C AXIAL AND CROSS FLOW CHARACTERIZATION	COMPLETED
● HEDL ASSEMBLY FLOW AND VIBRATION - H ₂ O	VERIFICATION OF ΔP AND VIBRATION CHARACTERISTICS	COMPLETED
● WARD FULL SCALE BUNDLE PRESSURE DROP - SODIUM AND WATER	BUNDLE ΔP OVER WIDE FLOW RANGE	COMPLETED
● WARD BLANKET FLOW ORIFICING CHARACTERIZATION	PRESSURE DROP CHARACTERIZATION	PLANNED
● HEDL ASSEMBLY OUTLET NOZZLE CHARACTERIZATION	CORRELATE T/C OUTLET TEMPERATURE MEASUREMENT	TESTING COMPLETE




WARD BLANKET ASSEMBLY HEAT TRANSFER TEST

RANGE OF TEST PARAMETERS

● POWER INPUT	17 to 880 Kw
● FLOW	2 to 140 GPM
● REYNOLDS NUMBER	500 to 26000
● POWER-TO-FLOW RATIO	100 to 300°F
● POWER INPUT GRADIENT	1:1 to 4.6:1 (MAX:MIN)

CONDITIONS SIMULATED

- ADIABATIC BOUNDARIES
- INTER-ASSEMBLY HEAT TRANSFER EFFECTS:
 - AUXILIARY COOLING
 - AUXILIARY HEATING
- TRANSIENT AND NATURAL CIRCULATION




NORMALIZED ROD POWER PER ROW

Predicted Vs. Measured Temperature Profiles - Input 2.8/1 Gradient - 440 KW
Re 13,000




**BLANKET HEAT TRANSFER TEST
PREDICTED VS.
MEASURED PEAK
NORMALIZED TEMPERATURE
RISE**



(W)

FRICTION FACTOR TEST DATA FOR TIGHT PITCH TO DIAMETER ROD BUNDLES WITH 4 IN. WIRE WRAP SPACER LEAD





CORE PRESSURE DROP TEST RESULTS

- RANGE OF DATA AND STATUS
- TYPICAL EXAMPLES OF TEST DATA/CORRELATIONS/RESULTS


CORE PRESSURE DROP TESTING - STATUS

Ⓜ

COMPONENT	ΔP AT 100% FLOW (PSI)	RANGE OF TEST DATA (%)	TEST STATUS
CORE			
FUEL: INLET-ORIFICE-SHIELD	35.5	1.5 - 120	COMPLETE
ROD BUNDLE	58.4	0.5 - 120	COMPLETE
ROD BUNDLE INLET AND OUTLET	1.8	1.5 - 120	COMPLETE
OUTLET NOZZLE	1.8	1.5 - 120	COMPLETE
INNER BLANKET: INLET-ORIFICE-SHIELD	37.7	2 - 120	PLANNED
ROD BUNDLE	60.4	0.2 - 100	COMPLETE
ROD BUNDLE INLET AND OUTLET	1.4	2 - 120	COMPLETE
OUTLET NOZZLE	0.9	2 - 120	COMPLETE
RADIAL BLANKET: INLET-ORIFICE-SHIELD	63.5	2 - 120	PLANNED
ROD BUNDLE	32.6	0.15 - 135	COMPLETE
ROD BUNDLE INLET AND OUTLET	0.7	2 - 120	COMPLETE
OUTLET NOZZLE	0.4	2 - 120	COMPLETE
PRIMARY CONTROL: INLET-ORIFICE-SHIELD	94	2 - 200	COMPLETE
ROD BUNDLE	3.0	2 - 200	COMPLETE
ROD BUNDLE INLET AND OUTLET	0.9	2 - 200	COMPLETE
OUTLET NOZZLE	7.1	2 - 200	COMPLETE
SECONDARY CONTROL: INLET-ORIFICE-SHIELD	75	18 - 125	COMPLETE
ROD BUNDLE	2.5	18 - 125	COMPLETE
OUTLET	28	18 - 125	COMPLETE
REMOVABLE RADIAL SHIELD: OVERALL	30	30 - 120	COMPLETE
PISTON RINGS	100	30 - 120	COMPLETE


(2)

FRICTION FACTOR DATA AND CORRELATION FOR 217 PIN WIRE WRAP SPACED FUEL ASSEMBLY






OVERALL FUEL ASSEMBLY LOSS COEFFICIENT AS A FUNCTION OF REYNOLDS NUMBER FROM CRBRP FUEL ASSEMBLY FLOW AND VIBRATION TEST



PRIMARY CONTROL ASSEMBLY ROD BUNDLE FRICTION FACTOR



1-0999



PERCENT OF DESIGN FLOW (ZONE 1)

100
50
20
10
5
2


FUEL ASSEMBLY INLET NOZZLE SHIELD-ORIFICE LOSS COEFFICIENTS
FOR A RANGE OF ORIFICE STACK DESIGNS AS A FUNCTION OF REYNOLDS NUMBER

INLET NOZZLE SHIELD-ORIFICE LOSS COEFFICIENT, K

ORIFICE STACK DESIGN
NUMBER OF PLATES
HOLE DIAMETER (IN)
6 0.508
5 0.508
4 0.548
3 0.548
2 0.548

$$K = \frac{\Delta P}{(\rho V^2 / 2g)}$$

1.0
10
100
10⁴
10⁵
10⁶
INLET NOZZLE REYNOLDS NUMBER, (RE)





CORE T&H DEVELOPMENT TESTING
CONCLUSIONS

- 1) LARGE CORE T&H DATA BASE AVAILABLE
- 2) DATA ON ALL REACTOR COMPONENTS - OVER WIDE RANGE OF OPERATION, E.G., ΔP , HEAT TRANSFER DATA
- 3) UNCERTAINTIES USED FOR PSAR BASED ON AVAILABLE EXPERIMENTAL DATA
- 4) ALL DATA WILL BE FACTORED INTO FSAR INPUT



CONCLUSIONS

- REACTOR FLOW DISTRIBUTION MEETS COMPONENT DESIGN REQUIREMENTS
- COOLING FLOW PATHS WELL CHARACTERIZED, ORIFICE CONTROLLED,
TESTED, MODELED
- LARGE COMPONENTS T&H DEVELOPMENT DATA BASE
- COMPREHENSIVE DESIGN WITH CONSERVATIVE, YET REALISTIC, LIMITS
- ANALYTICAL METHODS VERIFIED WITH LARGE DATA BASE

**FUEL AND
BLANKET DESIGN**



8254-6

CRBRP CORE MECHANICAL DESIGN FUEL, BLANKET, SHIELD

- Bases
- Description
- Evaluations
- Testing programs


DAMAGE SEVERITY LIMITS

<u>Event Category</u>	<u>Damage Severity Level (RDT C-16-1)</u>	<u>Design Limit</u>
Normal operation	No significant loss of effective lifetime	Ductility limited strain $\leq 0.2\%$ (normal creep & plasticity) Power-to-melt Proportional elastic limit One wire diameter-flow channel closure
Anticipated events (Upset)	No reduction of effective lifetime below the design values	Ductility limited strain $\leq 0.3\%$ Cumulative damage function ≤ 1.0 (creep rupture, plasticity, fatigue damage)
Unlikely events (Emergency)	A general reduction in the fuel burnup capability and, at most, a small fraction of fuel rod cladding failures	
Extremely unlikely events (Faulted)	Maintain coolable configuration	Cladding solidus, no Na boiling*

*PSAR guideline



CRBRP FUEL ASSEMBLY






CRBRP FUEL ASSEMBLY COMPARISON WITH FFTF

<u>Design Parameter</u>	<u>CRBRP Value</u>	<u>FFTF Value</u>	<u>Reason for Difference</u>
Types of discriminators (orificing zones)	6	3	Core arrangement and core size
Lower shielding length (inches)	20.0 (1 piece)	21.5 (3 piece)	FFTF closed loop cooling not required in CRBRP
Duct load pad (inches):			
-Outside dimension	4.745	4.715	Accommodate larger seismic loads in larger core
-Wall thickness	0.205	0.190	} Provide more space for irradiation induced deformation in higher burnup reloads
Fuel rod growth clearance (inches)	2.10	1.00	
Type of top load pad (outlet nozzle)	Fixed	Floating collar	} Evolution of creep and swelling equations for core restraint
Misaligned grapple pickup capability (inches)	1.75	1.25	

CRBRP FUEL ROD




CRBRP FUEL ROD COMPARISON WITH FFTF

<u>Design Parameter</u>	<u>CRBRP Value</u>	<u>FFTF Value</u>	<u>Reason for Difference</u>
Pellet PuO ₂ content	0.93	0.225/0.275	More power per assembly in CRBRP heterogeneous core
Pellet density (percent of theoretical)	91.3	90.4	} Reduced FCMI for same smeared density
Pellet diameter (inch)	0.1935	0.1945	
Axial blanket stack lengths (inch)	14.0	0.8	Breeding requirements of CRBRP
Incone reflector lengths (inch)	0.0	5.7	Shielding provided by axial blankets
Fission gas plenum length (inch)	48.0	42.0	Provide more space for accomodation of fission gas in higher burnup reloads
Overall rod length (inch)	114.4	93.4	As above




CRBRP BLANKET ASSEMBLY






CRBR BLANKET ROD



REMOVABLE RADIAL SHIELD ASSEMBLY



DESIGN EVALUATIONS - KEY FUEL RESULTS

Cladding damage

- Cladding damage is within design limits
 - 35 percent margin on steady-state cumulative damage
 - 75 percent margin on steady-state ductility limited strain
 - 2 percent margin on steady-state and transient ductility limited strain
 - 8 percent margin on steady-state and transient ductility limited strain

Wire wrap

- Maximum wire wrap stress and strain are below limits of 21 ksi and 0.6%
- Maximum wire slack is 0.1 inch; acceptable

Bundle/duct interaction

- Maximum bundle/duct interference of 0.020 inches below limit of 0.056 inches
- The maximum bundle/duct clearance of 0.04 inches is less than the 0.054 inches (6 mils/ring) limit

Duct dilation

- The maximum duct dilation is ~ 80 mils which is less than the limit of 108 mils

DESIGN EVALUATIONS - KEY BLANKET RESULTS

Cladding damage

- Cladding damage is within design limits
 - 68 percent margin on steady-state cumulative damage (Radial)
 - 250 percent margin on steady-state ductility limited strain (Radial)
 - 9 percent margin on steady-state and transient ductility limited strain (Inner)
 - 600 percent margin on steady-state and transient ductility limited strain (Radial)
 - Margins are not reduced due to FCMI from a mid-life power jump

Wire wrap

- Maximum wire wrap stress and strain are below limits of 21 ksi and 0.3%
- Maximum wire slack is < 0.1 inch

Bundle/duct interaction

- Maximum bundle duct interference of ~ 0.013 inches is below the design guideline 0.033 inch
- Maximum bundle/duct clearance of ~ 0.065 mils. Adequate based on testing
- Adequacy of design due to unique blanket features (stiffness) to be obtained from EBR-II and FFTF irradiation testing (WBA-40, 41, 45)

Duct dilation

- The maximum duct dilation is 67 mils for the IBA and 82 mils for the RBA which is less than the limit of 108 mils

STATUS OF DEVELOPMENT TESTING FOR BLANKET SUPPORT

<u>Title</u>	<u>Supporting Information</u>	<u>Status</u>
R.B. heat transfer test	Verification of heat transfer behavior	Testing > 90% complete
Blanket rod irradiation testing in EBR-II	Verification of steady-state performance	Two tests complete, post-test evaluations complete
Blanket assembly irradiation testing in FFTF	Verification of steady-state performance	Two experiments in FFTF, instrumented blanket test being fabricated
Blanket flow control testing	Provide orificing data	Testing complete
Blanket bundle compaction test	Verification of rod bundle behavior	Testing complete
Blanket mechanical testing	Verification of design adequacy	Testing complete
Blanket assembly flow and vibration testing	Verification of flow vibration characteristics	Testing complete
Duct load pad strength and bending stiffness test	Verification of duct behavior	Testing 80% complete
Cladding rupture test	Verification of cladding behavior	Testing complete
EBR-II duct crushing test	Verification of irradiated duct behavior	Testing complete

KEY FUEL AND BLANKET ONGOING DEVELOPMENT TESTING

- Effects of axial blankets on fuel pins
 - CRBR-1, CRBR-3, CRBR-5, D9-4, AB-1
- 33% Pu content in CRBRP fuel
 - PIE of ANL-08 (30-40% Pu)
 - CRBR-3 and CRBR-5 experiments
 - FFTF reload fuel ~ 30% Pu
- Link FFTF data base to EBR-II data base
- Slow overpower transient response
 - WSA-10 and WBA-24 tests completed
 - Operational reliability testing program in EBR-II
 - Slow ramp rate FCTT testing
 - TREAT transient testing
- RBCB testing in EBR-II
- FFTF blanket confirmatory testing
 - WBA-40, WBA-41, WBA-45/46

SUMMARY OF DEVELOPMENT PROGRAMS

- EBR-II fuel and blanket steady-state testing completed
- TREAT testing of reference EBR-II fuel rods completed
- Major FCTT testing completed - testing to link different heats of materials is ongoing
- Slow overpower and RBCB testing in EBR-II (ORT) ongoing
- Future TREAT testing of FFTF and CRBRP prototype rods is planned and ongoing

DEVELOPMENT TESTING FOR FUEL SUPPORT

<u>Title</u>	<u>Supporting Information</u>	<u>Status</u>
Assembly flow and vibration	Verification of flow, vibration characteristics	Complete
Inlet/outlet nozzle feature tests	Verification of design adequacy	Complete
Fuel transient performance	Verification of transient performance	EBR-II/TREAT testing partially completed, FFTF and CRBRP testing to be done in EBR-II and TREAT
Fuel steady-state irradiation	Verification of steady-state performance	EBR-II testing complete, FFTF testing initiated
Reference cladding/duct material	Irradiation induced swelling, in-reactor deformation, post-irradiation tensile properties, post-irradiation fracture, cumulative damage	EBR-II testing essentially complete; FFTF testing planned
Run beyond cladding breach	Establish feasibility and allowable operating time of breached rods/assemblies	EBR-II irradiations in progress

CONCLUSION

- The fuel and blanket design limits have been derived from damage severity limits
- Analysis and testing to date have shown that core design limits are met
- Major testing programs are complete. Extension of the EBR-II and TREAT data base to CRBRP specific design is ongoing

**CLINCH RIVER BREEDER
REACTOR PLANT**



BRIEFING FOR:

**ADVISORY COMMITTEE ON
REACTOR SAFEGUARDS (ACRS)
FULL COMMITTEE**

FLUID SYSTEM INTERFACES

PRESENTED BY:

**G. H. CLARE
LICENSING MANAGER,
CRBRP PROJECT
WESTINGHOUSE
ADVANCED REACTORS DIVISION
OAK RIDGE SITE**

FEBRUARY 11, 1983

PRIMARY SODIUM COOLANT SYSTEM

N_2 ENVIRONMENT IN RCB CELLS

- PASSIVE BOUNDARY
- Na LEAKAGE DETECTION
- LEAK ACCOMMODATION
- N_2 ISOLATED FROM COOLING WATER BY
 - PASSIVE BOUNDARY
 - ISOLATION VALVES
 - H_2O LEAKAGE DETECTION (MOISTURE DETECTOR AND LEVEL DETECTOR)
 - LEAKAGE COLLECTION (DRAIN LINES FROM COOLERS)

INTERMEDIATE SODIUM COOLANT SYSTEM

- PASSIVE BOUNDARY (IHX)
- (P)IHTS > (P)PHTS
- LEAK DETECTION
- LEAK ACCOMMODATION

NaK COOLANT SYSTEMS - DHRS AND COLD TRAPS

- PASSIVE BOUNDARY (OHX AND COLD TRAPS)
- (P)NaK > (P)Na
- LEAK DETECTION
- COLD TRAP? NaK ISOLATED FROM COOLING WATER BY DOWTHERM COOLANT LOOP

SODIUM - NaK COMPATIBILITY

- NaK IS 22 W/O Na AND 78 W/O K (EUTECTIC MIXTURE)
 - MELTING TEMPERATURE $\sim 9^{\circ}\text{F}$
 - BOILING TEMPERATURE (1 ATM) $\sim 1518^{\circ}\text{F}$
- MIXING OF Na AND NaK WOULD RESULT IN
 - NO CHEMICAL REACTION
 - NO ADVERSE EFFECT ON PROCESS EQUIPMENT
 - INCREASE IN NaK MELTING TEMPERATURE
 - DECREASE IN Na MELTING TEMPERATURE

INTERMEDIATE SODIUM COOLANT SYSTEM

AIR ENVIRONMENT IN SGB CELLS

- PASSIVE BOUNDARY
- LEAK DETECTION
- CATCH PANS
- FIRE SUPPRESSION DECKS
- LOOP SEPARATION
- CELL PRESSURE RELIEF
- AEROSOL MITIGATION
 - EQUIPMENT QUALIFICATION

STEAM/WATER SYSTEM

- PASSIVE BOUNDARY (SG MODULES)
- LEAK DETECTION
- LEAKAGE ACCOMMODATION
 - EXPANSION TANK RUPTURE DISKS
 - MAIN RUPTURE DISKS
 - REACTION PRODUCT SEPARATION SYSTEM
 - WATER DUMP SYSTEM
 - SAFETY RELIEF VALVES

N₂ ENVIRONMENT IN RCB CELLS

- PASSIVE BOUNDARY (PIPING)
- Na LEAKAGE DETECTION
- LEAK ACCOMODATION
- N₂ ISOLATED FROM COOLING WATER BY
 - PASSIVE BOUNDARY
 - ISOLATION VALVES
 - H₂O LEAKAGE DETECTION (MOISTURE DETECTOR AND LEVEL DETECTOR)
 - LEAKAGE COLLECTION (DRAIN LINES FROM COOLERS)

EVST SODIUM COOLANT SYSTEM

N₂ ENVIRONMENT IN RCB CELLS

- PASSIVE BOUNDARY
- Na LEAKAGE DETECTION
- LEAK ACCOMADATION
- N₂ ISOLATED FROM COOLING WATER BY
 - PASSIVE BOUNDARY
 - LEAKAGE DETECTION (MOISTURE DETECTOR AND LEVEL DETECTOR)
 - LEAKAGE COLLECTION (DRAIN LINES FROM COOLERS)

NaK COOLANT SYSTEMS

- PASSIVE BOUNDARY (SODIUM COOLERS)
- (P)NaK > (P)Na
- LEAK DETECTION
- LEAK ACCOMMODATION
- NaK ISOLATED FROM N₂ ENVIRONMENT BY
 - PASSIVE BOUNDARY
 - LEAK DETECTION
 - LEAK ACCOMODATION
- NaK ISOLATED FROM AIR ENVIRONMENT BY
 - PASSIVE BOUNDARY
 - LEAK DETECTION
 - LEAK ACCOMMODATION

ARGON COVER GAS

PRIMARY SODIUM COOLANT SYSTEM

- DIRECT INTERFACE WITH Na COOLANT FREE SURFACE
- (P)ARGON > 1 ATM (EQUAL TO THE SODIUM PRESSURE AT FREE SURFACE)
- PURITY MONITORING
- RADIOACTIVE ARGON PROCESSED TO REMOVE FISSION GAS

INTERMEDIATE SODIUM COOLANT SYSTEM

- DIRECT INTERFACE WITH Na COOLANT FREE SURFACE
- (P)ARGON > 1 ATM (EQUAL TO THE SODIUM PRESSURE AT FREE SURFACE)
- PURITY MONITORING
- NON-RADIOACTIVE

FUEL HANDLING CELL

- DIRECT INTERFACE WITH Na COOLANT FREE SURFACE
- (P)ARGON > 1 ATM
- ATMOSPHERE PURIFICATION UNIT REMOVES O₂ AND H₂O

EVST SODIUM COOLANT SYSTEM

- DIRECT INTERFACE WITH Na COOLANT FREE SURFACE
- (P)ARGON > 1 ATM (EQUAL TO THE SODIUM PRESSURE AT FREE SURFACE)
- PURITY MONITORING

**CLINCH RIVER BREEDER
REACTOR PLANT**

BRIEFING FOR:

**ADVISORY COMMITTEE ON
REACTOR SAFEGUARDS (ACRS)
FULL COMMITTEE**

STEAM GENERATOR LEAKS

PRESENTED BY:

G. H. CLARE
LICENSING MANAGER,
CRBRP PROJECT
WESTINGHOUSE
ADVANCED REACTORS DIVISION
OAK RIDGE SITE

FEBRUARY 11, 1983



THE INDIRECT EFFECTS OF STEAM GENERATOR TUBE LEAKS COULD POTENTIALLY IMPACT SAFETY

- REACTOR SHUTDOWN WITH LESS SHUTDOWN HEAT REMOVAL CAPACITY
- MECHANICAL LOADINGS ON THE PRIMARY AND INTERMEDIATE COOLANT BOUNDARIES
- HYDROGEN GENERATION


MULTIPLE HTS HEAT REMOVAL PATHS AND OPERATOR FLEXIBILITY TO ISOLATE, REPAIR, OR REPLACE A LEAKING STEAM GENERATOR MODULE AND THE DHRS (INDEPENDENT OF STEAM GENERATORS) MITIGATE THE EFFECTS OF SG TUBE LEAKS ON SHRS CAPABILITY.

THREE LEVELS OF PROTECTION ARE PROVIDED AGAINST THE EFFECTS OF SG TUBE LEAKS

- LEAK DETECTION WITH MANUAL REACTOR SHUTDOWN
- EXPANSION TANK RUPTURE DISKS WITH AUTOMATIC WATER DUMP
- MAIN RUPTURE DISKS WITH AUTOMATIC REACTOR SHUTDOWN AND WATER DUMP

SODIUM WATER REACTION PRESSURE RELIEF SYSTEM (SWRPRS)

CRBRP SODIUM WATER REACTION PRESSURE RELIEF SYSTEM




**THE DESIGN BASIS ACCIDENT FOR SWRPRS
AND THE PRIMARY AND INTERMEDIATE
COOLANT BOUNDARIES WAS SELECTED
USING CONSERVATIVE ENGINEERING
JUDGEMENT CONSIDERING REACTOR
EXPERIENCE, EXPERIMENTAL DATA, AND
ANALYSIS RESULTS**

- SIZE OF LEAK(S)
- NUMBER OF LEAKS
- TIMING

**ONLY EXTREMELY RAPID EVENT
PROPAGATION IS PERTINENT
DUE TO RAPID PRESSURE RELIEF
(FEW SECONDS)**

DEVELOPMENT OF SWR PRECURSOR




THREE MECHANISMS CAN CAUSE TUBE-TO-TUBE FAILURE PROPAGATION


- WASTAGE
 - CORROSION
 - STRESS RUPTURE (OVERHEATED TUBE)
- EXPERIMENTAL — TENS OF SECONDS
- EXPERIMENTAL — ≈ 10 SECONDS
- BOUNDING ANALYSIS — ≈ 1 SECOND

**STRESS RUPTURE FAILURES ARE LIMITED
IN SIZE: 45° GAP, 1 1/2 INCHES LONG,
LESS THAN 50% DEG.**


**PRIMARY
FAILURE**



**PRECURSOR
FAILURE**



**SECONDARY
FAILURE**



SWR EXPERIMENT SUMMARY


- 63 LARGE LEAK TESTS
- SECONDARY FAILURE IN 4 TESTS ONLY
- NINE U.S. TESTS (LLTR) SPECIFICALLY CRBRP PROTOTYPIC—TWO TESTS PRODUCED SECONDARY FAILURES
- SECONDARY FAILURES OCCURRED IN TENS OF SECONDS

DESIGN BASIS SODIUM WATER REACTION EVENT

- PRECURSOR - SODIUM PRESSURE - 325 PSIG
- PRIMARY FAILURE - 1 EDEG @ T = 0
- SECONDARY FAILURE - 1 EDEG @ 1 SEC.
- TERTIARY FAILURE - 1 EDEG @ 2 SEC.

PLAUSIBLE EVENT VS DESIGN BASIS EVENT

WATER INJECTION
(NUMBER OF TUBES - EDEG)



COMPARISON WITH FOREIGN SWR DESIGN EVENTS

COUNTRY	FAILURE SIZE	NUMBER OF FAILURES	INTERVAL BETWEEN FAILURES
• UK	1 EDEG	3*	1 SEC
• GERMANY	1 EDEG	1	NA
• FRANCE	1 EDEG	1	NA
• JAPAN	1 EDEG	4**	UNKNOWN
• US	1 EDEG	3	1 SEC

*NOT A LICENSING DESIGN BASIS ACCIDENT

**ONLY (1) ONE FOR LICENSING PURPOSES

LARGE SWR EVENTS ARE CONSERVATIVELY EVALUATED USING THE TRANSWRAP COMPUTER CODE

- WORST LEAK LOCATION AND INITIAL CONDITIONS BASED ON SENSITIVITY STUDIES (EVAPORATOR AFTER LOSS OF OFFSITE POWER)
- LEAK RATES ESTABLISHED USING RELAP 4/MOD 5
- ASSUMED HYDROGEN YIELD OF 65% AND 1700°F REACTION ZONE TEMPERATURE WHICH BOUNDS EXPERIMENTAL RESULTS
- DYNAMIC ELASTIC-PLASTIC RUPTURE DISK RESPONSE MODEL BASED ON EXPERIMENTAL RESULTS

MECHANICAL LOADINGS FROM SWR EVENTS ARE CONSERVATIVELY PREDICTED USING TRANSWRAP

- SODIUM COMPRESSIBILITY MODEL
- ONE-DIMENSIONAL "SODIUM
HAMMER" MODEL
- FRICTION EFFECTS MODEL
- ENERGY CONSUMED IN PIPING
STRAIN IS NOT ACCOUNTED FOR

**VALIDATED USING EXPERIMENTAL
DATA FROM THE LARGE LEAK TEST
RIG PROGRAM.**

SUMMARY

- THE DESIGN BASIS SWR EVENT IS CONSERVATIVE RELATIVE TO EXPERIMENTAL & ANALYTICAL EVIDENCE
 - PRECURSOR PRESSURE
 - SIZE OF FIRST FAILURE
 - TIMING AND SIZE OF SECOND FAILURE
 - EXISTENCE OF THIRD FAILURE
 - COMPARED WITH FOREIGN DESIGN BASIS EVENTS
- THE TRANSWRAP COMPUTER CODE IS USED TO CONSERVATIVELY MODEL THE CONSEQUENCES OF THE DESIGN BASIS SWR EVENT
 - LEAK RATE
 - REACTION PRODUCTS
 - MECHANICAL LOADS

STEAM GENERATOR MODULE FAILURE RATE ESTIMATES

- THE STEAM GENERATOR MODULE ARE FIRST-OF-A-KIND COMPONENTS, AND THERE IS NOT EXTENSIVE OPERATIONAL NOR TESTING DATA FROM SIMILAR COMPONENTS IN SIMILAR ENVIRONMENTS.

BASIS

- THE FOLLOWING TYPES OF UNITS WERE INCLUDED IN THE REVIEW OF HISTORICAL EXPERIENCE OF TUBE FAILURES:
 - FOSSIL-FUELED PLANTS
 - LWR PLANTS
 - SODIUM-HEATED STEAM GENERATORS, INCLUDING BOTH THERMAL AND FAST-REACTOR POWERED UNITS, AND VARIOUS TEST UNITS.
- ENGINEERING JUDGEMENT WAS USED TO DERIVE THE CRBRP STEAM GENERATOR FAILURE PARAMETERS FROM THE HISTORICAL DATA.

CRBRP STEAM GENERATOR MODULE FAILURE RATE ESTIMATES FOR RELIABILITY STUDIES

- WATER-TO-SODIUM LEAKAGE
 - SMALL LEAK: $\lambda = 7.0 \times 10^{-6}$ HR-MODULE;
LEAK RATE LESS THAN .01 LB/SEC
 - MEDIUM LEAK: $\lambda = 1.4 \times 10^{-6}$ HR-MODULE;
LEAK RATE BETWEEN .01 AND 5 LB/SEC
 - LARGE LEAK: $\lambda = 0.28 \times 10^{-6}$ HR-MODULE;
LEAK RATE GREATER THAN 5 LB/SEC