

Mr. Terry L. Patterson  
Division Manager - Nuclear Operations  
Omaha Public Power District  
Fort Calhoun Station FC-2-4 Adm.  
Post Office Box 399  
Hwy. 75 - North of Fort Calhoun  
Fort Calhoun, Nebraska 68023-0399

Dear Mr. Patterson:

SUBJECT: FORT CALHOON STATION, UNIT NO. 1 - AMENDMENT NO. 161 TO FACILITY  
OPERATING LICENSE NO. DPR-40 (TAC NO. M77351 AND M77421)

The Commission has issued the enclosed Amendment No. 161 to Facility Operating License No. DPR-40 for the Fort Calhoun Station, Unit No. 1. This amendment consists of changes to the Technical Specifications (TS) in response to your application dated December 19, 1990, and June 1, 1992, as supplemented by letters dated February 1, 1993, and February 25, 1994.

The amendment revises the TS by changing the pressure-temperature limits in TS 2.1.2 and makes the limits valid for 20 effective full-power years (EFPY) of operation. The amendment also modifies TS 2.1.1 to change the minimum requirements for starting a non-operating reactor coolant pump (RCP) and modifies TS 2.3(3) to change the requirements for disabling high-pressure safety injection (HPSI) pumps during scheduled heatup and cooldown operations. Lastly, the amendment modifies TS 2.1.6 to change the power-operated relief valve (PORV) limiting conditions of operation (LCO) and surveillance requirements. The amendment request was filed in response to Generic Letter 90-06.

A copy of our related Safety Evaluation is also enclosed. A Notice of Issuance will be included in the Commission's next biweekly Federal Register notice.

Sincerely,

ORIGINAL SIGNED BY:  
Steven Bloom, Project Manager  
Project Directorate IV-1  
Division of Reactor Projects - III/IV/V  
Office of Nuclear Reactor Regulation

9403300075 940323  
PDR ADOCK 0500285  
P PDR

Enclosures:

- 1. Amendment No. 161 to DPR-40
- 2. Safety Evaluation

cc w/enclosures:

See next page

DISTRIBUTION:

Docket File NRC & LPDR PD4-1 r/f OC/LFMB (4503)  
J. Roe E. Adensam W. Beckner C. Grimes (11E22)  
P. Noonan ACRS (10) OGC (15B18) S. Bloom  
D. Hagan (3206) G. Hill (2) P. Harrell, RIV OPA (2G5)  
D. Pickett L. Lois R. Jones, SRXB J. Tsao

\*See previous concurrence

|      |          |           |          |         |          |
|------|----------|-----------|----------|---------|----------|
| OFC  | LA:PD4-1 | PM:PD4-1  | SRXB*    | OGC*    | D:PD4-1  |
| NAME | PNoonan  | SBloom/vw | TCollins | MZobler | WBeckner |
| DATE | 3/17/94  | 3/17/94   | 3/11/94  | 3/15/94 | 3/23/94  |
| COPY | YES/NO   | YES/NO    | YES/NO   | YES/NO  | YES/NO   |

NRC FILE CENTER COPY

280000

DFOI



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555-0001

March 23, 1994

Docket No. 50-285

Mr. Terry L. Patterson  
Division Manager - Nuclear Operations  
Omaha Public Power District  
Fort Calhoun Station FC-2-4 Adm.  
Post Office Box 399  
Hwy. 75 - North of Fort Calhoun  
Fort Calhoun, Nebraska 68023-0399

Dear Mr. Patterson:

SUBJECT: FORT CALHOUN STATION, UNIT NO. 1 - AMENDMENT NO. 161 TO FACILITY  
OPERATING LICENSE NO. DPR-40 (TAC NO. M77351 AND M77421)

The Commission has issued the enclosed Amendment No. 161 to Facility Operating License No. DPR-40 for the Fort Calhoun Station, Unit No. 1. This amendment consists of changes to the Technical Specifications (TS) in response to your application dated December 19, 1990, and June 1, 1992, as supplemented by letters dated February 1, 1993, and February 25, 1994.

The amendment revises the TS by changing the pressure-temperature limits in TS 2.1.2 and makes the limits valid for 20 effective full-power years (EFPY) of operation. The amendment also modifies TS 2.1.1 to change the minimum requirements for starting a non-operating reactor coolant pump (RCP) and modifies TS 2.3(3) to change the requirements for disabling high-pressure safety injection (HPSI) pumps during scheduled heatup and cooldown operations. Lastly, the amendment modifies TS 2.1.6 to change the power-operated relief valve (PORV) limiting conditions of operation (LCO) and surveillance requirements. The amendment request was filed in response to Generic Letter 90-06.

A copy of our related Safety Evaluation is also enclosed. A Notice of Issuance will be included in the Commission's next biweekly Federal Register notice.

Sincerely,

A handwritten signature in cursive script, appearing to read "Steven Bloom".

Steven Bloom, Project Manager  
Project Directorate IV-1  
Division of Reactor Projects - III/IV/V  
Office of Nuclear Reactor Regulation

Enclosures:

1. Amendment No. 161 to DPR-40
2. Safety Evaluation

cc w/enclosures:  
See next page

Mr. Terry L. Patterson  
Omaha Public Power District

Fort Calhoun Station, Unit 1

cc:

Mr. Michael F. McBride, Esq.  
LeBoeuf, Lamb, Leiby & MacRae  
1875 Connecticut Avenue, NW  
Washington, D.C. 20009-5728

Mr. Jack Jensen, Chairman  
Washington County Board  
of Supervisors  
Blair, Nebraska 68008

Mr. Raymond P. Mullikin, Resident Inspector  
U.S. Nuclear Regulatory Commission  
Post Office Box 309  
Fort Calhoun, Nebraska 68023

Mr. Charles B. Brinkman, Manager  
Washington Nuclear Operations  
Combustion Engineering, Inc.  
12300 Twinbrook Parkway, Suite 330  
Rockville, MD 20852

Regional Administrator, Region IV  
U.S. Nuclear Regulatory Commission  
611 Ryan Plaza Drive, Suite 1000  
Arlington, Texas 76011

Harold Borchert, Director  
Division of Radiological Health  
Nebraska Department of Health  
301 Centennial Mall, South  
Post Office Box 95007  
Lincoln, Nebraska 68509

Mr. James W. Chase, Manager  
Fort Calhoun Station  
Post Office Box 399  
Fort Calhoun, Nebraska 68023