

LICENSEE EVENT REPORT

CONTROL BLOCK: [ ] (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 M I D C C 1 2 0 0 - 0 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 [ ] [ ] 5  
7 8 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58

CON'T  
0 1 REPORT SOURCE L 6 0 5 0 0 0 0 3 1 5 7 0 1 1 1 9 8 3 8 0 2 0 8 8 3 9  
60 61 DOC. ET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 DURING NORMAL OPERATION, THE CONTAINMENT GASEOUS RADIATION MONITOR CHANNEL (ERS-1305)  
0 3 WAS DECLARED INOPERABLE, DUE TO A FAIL HIGH CONDITION. TO PERMIT TROUBLESHOOTING OF  
0 4 ERS-1305, THE CONTAINMENT AIR PARTICULATE MONITOR CHANNEL ERS-1301 HAD TO BE REMOVED  
0 5 FROM SERVICE, MAKING THIS EVENT NON-CONSERVATIVE WITH RESPECT TO TECHNICAL SPECIFICA-  
0 6 TION 3.3.2.1, TABLE 3.3-3, ITEM 3.c. THE PUBLIC HEALTH AND SAFETY WERE NOT AFFECTED.  
0 7  
3 8

0 9 SYSTEM CODE B B 11 CAUSE CODE E 12 CAUSE SUBCODE F 13 COMPONENT CODE INSTRU 14 COMP SUBCODE E 15 VALVE SUBCODE Z 16  
9 10 11 12 13 14 15 16 17 18 19 20

17 LER/RO REPORT NUMBER 8 3 21 22 EVENT YEAR 8 3 23 SHUTDOWN METHOD [ ] 24 SEQUENTIAL REPORT NO. 0 0 6 26 OCCURRENCE CODE 0 3 29 REPORT TYPE L 30 REVISION NO. 0 32

ACTION TAKEN A 13 FUTURE ACTION Z 19 EFFECT ON PLANT Z 20 SHUTDOWN METHOD Z 21 HOURS 0 0 0 0 0 22 ATTACHMENT SUBMITTED N 23 NPRD-4 FORM SUB. Y 24 PRIME COMP. SUPPLIER A 25 COMPONENT MANUFACTURER E 0 7 1 0 27

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 INVESTIGATION REVEALED THE CAUSE OF THE FAIL HIGH CONDITION WAS A FAILED DETECTOR.  
1 1 THE DETECTOR WAS REPLACED, THE RADIATION MONITOR CHANNEL WAS CALIBRATED, VERIFIED TO  
1 2 BE OPERATING CORRECTLY AND RETURNED TO SERVICE.  
1 3  
1 4

1 5 FACILITY STATUS E 28 % POWER 1 0 0 29 OTHER STATUS NA 30 METHOD OF DISCOVERY B 31 DISCOVERY DESCRIPTION OPERATOR OBSERVATION 32  
8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

1 6 ACTIVITY CONTENT Z 33 Z 34 AMOUNT OF ACTIVITY NA 35 LOCATION OF RELEASE NA 36  
8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

1 7 PERSONNEL EXPOSURES NUMBER 0 0 0 37 TYPE Z 38 DESCRIPTION NA 39  
8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

1 8 PERSONNEL INJURIES NUMBER 0 0 0 40 DESCRIPTION NA 41  
8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

1 9 LOSS OF OR DAMAGE TO FACILITY TYPE Z 42 DESCRIPTION NA 43  
8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

2 0 PUBLICITY ISSUED N 44 DESCRIPTION NA 45  
8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

8302160337 830208  
PDR ADOCK 05000315  
S PDR

R. A. PALMER

PHONE 616/465/5901

GPO 91-7-328