

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 M I D C C 1 2 0 1 0 - 1 0 0 0 0 0 - 1 0 0 3 4 1 1 1 1 4 5
7 8 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 29 37 CAT 38

CON'T
0 1 R E P O R T S O U R C E L 6 0 5 0 0 0 3 1 5 7 0 1 1 2 0 8 3 8 0 2 0 3 8 3 9
7 8 9 10 DOCKET NUMBER 58 59 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)
0 2 DURING NORMAL OPERATIONS, FIRE DOOR #385 WAS FOUND UNLATCHED. THIS CONSTITUTED AN
0 3 INOPERABLE PENETRATION FIRE BARRIER, NONCONSERVATIVE TO T.S. 3.7.10. ACTION
0 4 REQUIREMENTS WERE MET. PUBLIC HEALTH AND SAFETY WERE NOT AFFECTED. SIMILAR
0 5 OCCURRENCES WERE; 82-793 AND 83-014.
0 6
0 7
0 8

0 9 SYSTEM CODE A B 11 CAUSE CODE E 12 CAUSE SUBCODE Z 13 COMPONENT CODE X X X X X X 14 COMP SUBCODE Z 15 VALVE SUBCODE Z 16
7 8 9 10 11 12 13 14 15 16 17 18 19 20
17 LER/RO REPORT NUMBER 18 3 21 EVENT YEAR 22 8 3 23 SHUTDOWN METHOD 24 0 0 8 25 OCCURRENCE CODE 26 0 3 27 REPORT TYPE 28 L 29 REVISION NO. 30 0
ACTION TAKEN 31 E 32 FUTURE ACTION 33 Z 34 EFFECT ON PLANT 35 Z 36 SHUTDOWN METHOD 37 Z 38 HOURS 39 0 0 0 40 ATTACHMENT SUBMITTED 41 N 42 NPRO-4 FORM SUB. 43 N 44 PRIME COMP. SUPPLIER 45 A 46 COMPONENT MANUFACTURER 47 X 9 9 9 26

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)
1 0 FIRE DOOR #385 WOULD NOT LATCH DUE TO INSUFFICIENT CLOSER MECHANISM FORCE. THE
1 1 DOOR CLOSER MECHANISM WAS ADJUSTED AND THE DOOR OPERATED SATISFACTORILY.
1 2
1 3
1 4

1 5 FACILITY STATUS 16 E 17 % POWER 18 10 10 19 OTHER STATUS 20 NA 21 METHOD OF DISCOVERY 22 A 23 DISCOVERY DESCRIPTION 24 RP TECHNICIAN OBSERVATION
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30
1 5 RELEASED OF RELEASE 31 Z 32 AMOUNT OF ACTIVITY 33 NA 34 LOCATION OF RELEASE 35 NA
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30
1 7 PERSONNEL EXPOSURES 36 NUMBER 37 0 0 0 38 TYPE 39 Z 40 DESCRIPTION 41 NA
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30
1 7 PERSONNEL INJURIES 42 NUMBER 43 0 0 0 44 DESCRIPTION 45 NA
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30
1 7 LOSS OF OR DAMAGE TO FACILITY 46 TYPE 47 Z 48 DESCRIPTION 49 NA
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30
1 7 PUBLICITY 50 ISSUED DESCRIPTION 51 N 52 NA
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30

8302160342 830208
PDR AD0CK 05000315
S PDR

PAUL CARTEAUX

PHONE: 616-465-5901

NRC USE ONLY