NRC FORM 366 (7-77) U.S. NUCLEAR REGULATORY COMMISSION

# LICENSEE EVENT REPORT

CONTROL BLOCK: [ ] (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | M A P P S 1 (2) | 0 0 - 0 0 0 0 0 - 0 0 (3) | 4 1 1 1 1 (4) | (5)
LICENSEE CODE — LICENSE NUMBER — LICENSE TYPE — CAT

CON'T
01 | REPORT SOURCE L (6) | 0 5 0 0 0 2 9 3 (7) | 0 8 1 7 8 2 (8) | 0 8 3 0 8 2 (9)
DOCKET NUMBER — EVENT DATE — REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 | On 8/17/82, during performance of Temporary Procedure 82-25, "SSW/RBCCW Heat Exchanger
03 | Performance Test" shutdown conditions were used to check individual SSW Pump flows
04 | and the investigation revealed that PNPS Tech Spec. Section 4.5.1.b was deemed insuf-
05 | ficiently conservative in establishing RBCCW heat removal capability. Successful
06 | completion of Surveillance Procedure 8.5.3.2, written to Tech Spec criteria, was in-
07 | adequate proof of satisfying FSAR RBCCW heat removal requirements. This event caused
08 | no threat to the public because sufficient flow to RBCCW had been proven on 8/15/82.

09 | SYSTEM CODE S D (11) | CAUSE CODE D (12) | CAUSE SUBCODE Z (13) | COMPONENT CODE Z Z Z Z Z Z (14) | COMP. SUBCODE Z (15) | VALVE SUBCODE Z (16)

(17) LER/RO REPORT NUMBER: EVENT YEAR 8 2 | — | SEQUENTIAL REPORT NO. 0 2 6 | / | OCCURRENCE CODE 0 1 | REPORT TYPE T | — | REVISION NO. 0

ACTION TAKEN H (18) | FUTURE ACTION G (19) | EFFECT ON PLANT Z (20) | SHUTDOWN METHOD Z (21) | HOURS (22) 0 0 0 0 | ATTACHMENT SUBMITTED N (23) | NPRD-4 FORM SUB. N (24) | PRIME COMP. SUPPLIER N (25) | COMPONENT MANUFACTURER Z 9 9 9 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 | Inappropriate translation of FSAR Section 10.5.5.3 into Tech. Spec. criteria is the
11 | direct cause. An immediate Administrative requirement to use both T.P. 82-53 (a
12 | revision of TP 82-25 with FSAR heat removal capability criteria) and Surv. #8.5.3.2
13 | for any required testing will insure proper performance until Tech. Spec. revisions
14 | can be accomplished.

15 | FACILITY STATUS G (28) | % POWER 0 0 0 (29) | OTHER STATUS (30) N/A | METHOD OF DISCOVERY C (31) | DISCOVERY DESCRIPTION (32) Special Test Results

16 | ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY (35) N/A | LOCATION OF RELEASE (36) N/A

17 | PERSONNEL EXPOSURES NUMBER 0 0 0 (37) | TYPE Z (38) | DESCRIPTION (39) N/A

18 | PERSONNEL INJURIES NUMBER 0 0 0 (40) | DESCRIPTION (41) N/A

19 | LOSS OF OR DAMAGE TO FACILITY TYPE Z (42) | DESCRIPTION (43) N/A

20 | PUBLICITY ISSUED N (44) | DESCRIPTION (45) | NRC USE ONLY

8209130013 820830
PDR ADOCK 05000293
S PDR

NAME OF PREPARER G. G. Whitney PHONE 617-746-7900

GPO 917-928