Southern California Edison Company 23 PARKER STREET IRVINE, CALIFORNIA 92718 March 28, 1994 WALTER C. MARSH MANAGER OF NUCLEAR REQUILATORY AFFAIRS U. S. Nuclear Regulatory Commission Attention: Document Control Desk Washington, D.C. 20555 Gentlemen: Docket Nos. 50-361 and 50-362 Subject: Safety-Related Setpoint Program San Onofre Nuclear Generating Station Units 2 and 3 Reference: April 24, 1990 letter from F. R. Nandy (SCE) to Document Control Desk (NRC), Subject: Docket Nos. 50-361 and 50-362, Electrical Safety System Inspection, San Onofre Nuclear Generating Station, Units 2 and 3 This letter documents the status of the safety-related setpoint program at San Onofre Units 2 and 3. Following the October 30 through November 30, 1989, Electrical Safety Systems Functional Inspection (SSFI) conducted by the NRC. Southern California Edison (SCE) initiated a comprehensive program to reevaluate all safety-related setpoints. The Units 2 and 3 setpoint program originally identified 101 calculations associated with safety-related setpoints. To date, 94 of the calculations have been completed. The remaining calculations, which are associated with the Radiation Monitoring Systems (RMS), have been deferred as part of a program to upgrade the RMS hardware at San Onofre Units 2 and 3. Setpoint changes resulting from these calculations will be available for use by the completion of the Cycle 9 refueling outage for each unit. Results of the Safety Related Setpoint Program Evaluation Most of the safety-related setpoint calculations found the setpoints to be conservative, and no corrective action was required. Nonconformance reports were generated in cases where the existing plant setpoints were not conservative with respect to the calculated setpoints. Of the setpoints which were determined to be non-conservative, most corrective actions involved only revision of the existing setpoints and procedures. Two of the setpoint calculations identified larger than expected instrument uncertainties. These calculations were associated with the Subcooling Margin Monitor (SMM) alarm, and the Open Permissive Interlock (OPI) for the Shutdown Cooling (SDC) system suction valves. Both of the systems were evaluated and determined to be operable. SCE is reviewing the benefit of reducing the uncertainty by replacing certain SMM and SDC suction valve OPI transmitters with more accurate instruments. If SCE concludes this upgrade has enough 9403300178 940328 ADOCK 05000361