

SEP 9 1982

Docket No. 50-293

Boston Edison Company M/C Nuclear  
ATTN: Mr. William D. Harrington  
Senior Vice President, Nuclear  
800 Boylston Street  
Boston, Massachusetts 02199

Gentlemen:

Subject: Inspection 50-293/82-16

This refers to your letter dated August 6, 1982 (BECO Ltr. No. 82-207), in response to our letter dated July 7, 1982.

Thank you for informing us of the corrective and preventive actions documented in Attachment A to your letter concerning the health physics violation. These actions will be examined during a future inspection of your licensed program.


Our review of Attachment B to your letter indicated a need to further clarify your understanding of the cause and corrective actions regarding either uncorrected or recurring problems. We have discussed these issues in a meeting on August 16, 1982 between Mr. J. Johnson of this office and Mr. J. Ballentine of your staff. This meeting helped to clarify your understanding of 1) the specific condition of out of date procedures in the station, and 2) the failure to perform an adequate review of procedure No. 2.2.85.g, Fuel Pool Cooling and Filtration System.

Furthermore, with regard to the matters discussed, we understand that by September 1, 1982, you will inspect all accessible areas of the station and remove all posted procedures not specified by procedure No. 1.3.8, Document Control, and ensure that those specified by procedure No. 1.3.8 are the latest approved revisions. This action will be reviewed during a future inspection of your licensed activities.

Your cooperation with us in this matter is appreciated.

Sincerely,

Original Signed By:



Richard W. Starostecki, Director  
Division of Project and Resident  
Programs

8209130039 820909  
PDR ADOCK 05000293  
Q PDR

OFFICIAL RECORD COPY

IECI

SEP 9 1982

cc:

- A. V. Morisi, Manager, Nuclear Operations Support
- R. D. Machon, Nuclear Operations Manager - Pilgrim Station
- Joanne Shotwell, Assistant Attorney General (w/cy of Licensee's Response)
- Jon N. Bonsall, Chairman, Department of Public Utilities (w/cy of Licensee's Response)
- Plymouth Board of Selectmen (w/cy of Licensee's Response)
- Plymouth Civil Defense Director (w/cy of Licensee's Response)
- Senator Edward P. Kirby (w/cy of Licensee's Response)
- Public Document Room (PDR)
- Local Public Document Room (LPDR)
- Nuclear Safety Information Center (NSIC)
- NRC Resident Inspector
- Commonwealth of Massachusetts (2)

bcc:

Region I Docket Room (w/concurrences)

OFFICE	RI:DPRP	RI:DPRP	RI:DPRP				
SURNAME	Briggs/clc	Elsasser	Brunner				
DATE	9/1/82	9/2/82	9/8/82				