

McGUIRE NUCLEAR STATION

Calculational Methodology For Equipment Qualification Radiation Dose

This report illustrates the model used for calculating dose rates and integrated doses for equipment qualification purposes. Information pertaining to releases of radioisotopes are from NUREG 0588 and NUREG 0737. The Core isotopic inventory is calculated using the ORIGEN computer code for maximum equilibrium concentrations at maximum fuel burnup. See Table 1 for the list of major radioisotopes important to radiation dose.

I. Containment

i. a. Gamma Dose Inside Containment

The source terms used to calculate radiation dose rates inside containment are: 100% noble gases, 50% iodines and 1% remaining fission products both in the containment atmosphere and in the liquid of the containment sump. Concentrations of radioisotopes in the atmosphere and in the sump are listed in Table 1. Source Strengths and energies are included in this table. It is assumed that these fission products are instantaneously released into the containment free volume and distributed throughout upper and lower containment.

The containment is modeled as a right-circular cylinder 55.77 feet in radius, 106.2 feet in height or a free volume of 1.038 ft.³. For conservatism, the detector point representing equipment inside of containment is chosen at the centerline. (r, z, θ) = 0, 53 feet, 0°. A dose rate of 5.06×10^6 Rads/hour is calculated using the KAP-VI computer code assuming no credit for decay, shielding, leakage, plateout or washout by sprays. This dose rate is determined to be the maximum value at any location within containment post-accident.

Source terms and dose rates are generated at this containment location for times following the DBA to account for radioactive decay. Dose rates are normalized to the maximum time-zero value and integrated using trapezoidal methodology for one year post-accident. This integration factor (20.9) times the time zero dose rate represents the one year integrated dose inside of containment (1.06×10^8 Rads). In this way, a time dependent fraction of the one-year accident dose can be plotted vs. time for equipment qualification duration less than one year, See Figure 6, (for 30 days the integration fraction is .7 or 70% of the one-year dose = 7.4×10^7 Rads). The Reactor Building is sectioned into radiation zones to account for variations in the 40-year normal operating dose. The sum of this 40-year dose and the post-accident dose is added to give the total integrated dose to equipment. See Table 2 "Reactor Building," Example 1 and Figure 1 for radiation dose data.

I. b. Inside Containment Compartment Doses

For equipment located inside of lower containment compartments, i.e., accumulator tank rooms, credit is taken for concrete shielding from the containment atmosphere activity. Analysis performed assumed source terms the same as in Section I. a. Two independent calculations were performed using different analysis; point kernal methodology using KAP-VI as in Section I. a. and volume adjusted semi-infinite cloud methodology from Regulatory Guide 1.4. Both analyses gave results of 5.5×10^5 Rads/Hour dose rate at time = 0 hours post-accident. Since the same source of activity is used for the accumulator room, the fraction of the one-year integrated dose, Figure 6, can be used for equipment qualified for times less than one year. The one-year integrated dose is the product of the integration factor times the T = 0 hour dose rate: $5.5 \times 10^5 \times 20.9 = 1.2 \times 10^7$ Rads.

See example 4 for tables corresponding to the accumulator tank room dose data.

I. c. Beta Dose In-Containment

A beta dose calculation was performed assuming an infinite uniform cloud containing concentrations equivalent to those used in Section I. a. above. The calculation uses the beta dose equation in Regulatory Guide 1.4 with average beta energies per isotope from ORNL/NUREG/TM-102.

The one-year accident dose from beta radiation was calculated to be 8.4×10^8 Rads. Based on guidance from IE Bulletin 79-01B and NUREG-0588, 70 mils thickness of cable insulation is sufficient to reduce the beta dose to approximately one-tenth of the gamma dose and therefore can be considered negligible.

All Class 1E equipment located inside containment that is required to mitigate a LOCA, MSLB, or HELB has sufficient shielding to prevent the exposure of any organic materials associated with this equipment to a beta radiation environment.

II. Reactor Building Annulus

The equipment located in the annulus, i.e., between the containment shell and Reactor Building wall, will be subjected to radiation exposure from the in-containment atmosphere and from containment leakage into the Annulus. The source terms for in-containment exposure are the same as Section I above. The geometry of the source is separated into three zones: sources inside of the cranewall, sources outside of the cranewall, and sources in the containment dome. Detector points are distributed at various elevations inside of the annulus to account for the three source geometries and credit is taken for the 3 feet thick concrete cranewall and the 1" steel containment shell shielding.

Annulus gaseous activity is determined as in Section I above. Radio-isotopes are distributed equally throughout the annulus volume and a dose rate is calculated at detector point locations vertically distributed throughout the annulus. The total integrated dose to equipment in the Annulus is the sum of exposure from in-containment activity,

gaseous activity in the annulus and exposure from 40 years of normal operation. See example 2.

III. Auxiliary Building

Sources of exposure in the Auxiliary Building are from recirculating Reactor sump liquids through the safety injection, containment spray and residual heat removal systems.

Fractions of core radioisotopes in the liquid containing systems are:

- 100% noble gases
- 50% iodines
- 1% remaining fission products

(See sump concentrations at T = 0 time in Table 1)

A 10-minute delay time is assumed for the start of recirculation, after which, the only method of removal is decay.

Shielding models for piping and components for each room are developed for use in the computer codes SHIELD and KAP-VI. Average dose rates are calculated for 10-minute decayed liquid activity in each room affected by the LOCA. (See example 3).

A normalized dose rate decay curve from a standard geometry model is integrated over the one-year post-accident, the sum of which gives an integrating factor to be applied to the maximum dose rate in each room to give the one-year integrated dose. It was shown that the 10-minute delay time has a negligible effect on this integration factor compared to the in-containment model. Therefore, Figure 6 can be used for equipment qualification times less than one year post-accident for equipment located inside of the Auxiliary Building affected by recirculating sump liquids.

IV. Areas Affected by In-Containment Radiation Streaming Outside of Containment

The McGuire Reactor Building has two personnel access hatches which lack Reactor Building concrete shielding. Personnel access hatches were modeled to reflect radiation streaming exposure to areas adjacent to these "openings". Areas affected are the spent fuel pool area and the lower electrical penetration room. (See Table 4 and Figure 5 for radiation data.)

V. Auxiliary Building Ventilation

Sources of activity in Auxiliary Building results from the use of the Annulus Ventilation System. Due to containment leakage, and the need to maintain a negative pressure in the annulus, post-accident periodic purges are necessary through the VE System filter bed. The 4" equivalent carbon bed is assumed to remove 100% of the iodine. The only method of removal is through decay of the isotopes of iodine. In the same way as Section I and III, the integrated dose to the area affected by the VE filters is plotted versus time for equipment operating for less than one-year post-accident (Figure 7).

The second source of activity results from containment bypass leakage into the Auxiliary Building through the Reactor Building concrete wall. A special computer code, BPAUX was developed to give the Auxiliary Building Ventilation System, VA, filter bed loading as a function of time post-accident. The resultant equipment exposure is the sum of the effects of annulus purge and bypass leakage (See Table 3, el. 767 and Figure 4 for radiation dose data.)

An additional calculation was performed for a source of activity in the VA filter bed assuming leakage from ECCS components. This source was considered negligible compared to bypass leakage.

McGUIRE NUCLEAR STATION

Examples of Radiation Data Reported in NUREG 0588 Response

1. Equipment ID: Valve Motor (Table 5)
Operators (Upper Containment)

Manufacturer: Limitorque Model #SMB

Radiation Accident environment for operation time post-accident of 5 minutes. Assuming 1 hour time duration see Figure 6 for the fraction of the 1-year dose.

Read ~ .035 from Figure 6

Next, find radiation zone on Figure 2 where valve operator is located.

Read: Zone 23 E1. 778+10

Next, find on Table 2, the Zone number and Reactor Building elevation.

| | |
|---|---------------------|
| Read: Normal operating 40-year dose (Rads) | LOCA Dose (Rads) |
| 5.0×10^4 | $1.0E8$ |

Next, multiply the 1-year LOCA dose by the fraction of the 1-year integrated dose.

$$1.0E8 \times .035 = 3.5 \times 10^6 \text{ Rads}$$

Add 40-year normal operating dose to this value to obtain the Total Integrated Dose (TID) for this equipment:

1 Hour Post-LOCA Dose + 40-Year Normal Operating Dose = TID

$$3.5 \times 10^6 \text{ Rads} + 5 \times 10^4 \text{ Rads} = 3.6 \times 10^6 \text{ Rads}$$

or 4×10^6 Rads reported in 0588 submittal.

2. Equipment ID: Transmitter-Pressurizer Level (Table 8)
Manufacturer: Barton
Model #764 (Lot 2)

Operability required in accident environment = 2 weeks

See Figure 6 for the fraction of the one-year integrated dose

Read: ~ 0.6

Next, see manufacturer's file for location of equipment and radiation zone. (Table 8)

Read: Radiation Zone 8a
Elevation 738+3

See Table 2 for Zone 8a, elevation 738+3.

| | | |
|-------|---|---------------------|
| Read: | Normal Operating 40-Year Dose (Rads) | LOCA Dose (Rads) |
| | 2.0E4 | 2.0E7 |

Next, multiply the fraction of the one-year integrated dose times the one year LOCA dose to obtain the 2-week accident dose:

$$2.0 \times 10^7 \text{ Rads} \times 0.6 = 1.2 \times 10^7 \text{ Rads}$$

Add the 40-year normal operating dose to get the total integrated dose:

$$1.2 \times 10^7 \text{ Rads} + 2.0 \times 10^4 \text{ Rads} = 1.2 \times 10^7 \text{ Rads or}$$

1.4×10^7 Rads as reported in NUREG 0588 response.

3. Equipment Located in the Annulus: Table 6

Equipment ID: Transmitter - RCS Pressure (WR)

Manufacturer: Rosemount Model # 1153 GA9

Operability required in accident environment = 2 weeks

See Figure 6 for the fraction of the LOCA dose absorbed in 2 weeks or 336 hours.

Read: ~ 0.6 from Figure 6

Next, find location and elevation of the equipment in the Annulus. (From equipment qualification file).

Zone 10, elevation 738 + 3

| | | |
|-------|---|---------------------|
| Read: | Normal Operation 40-year dose (Rads) | LOCA Dose (Rads) |
| | 1.0E4 Rads | 2.0E7 |

Now, multiply the LOCA dose times the fraction of the one year integrated dose, to get the 2 week dose.

$$2.0E7 \times .6 = 1.2 \times 10^7 \text{ Rads}$$

Now, add the 40-year normal operating dose to the post-accident dose to get the total integrated dose.

$$1.2 \times 10^7 \text{ Rads} + 1.0 \times 10^4 \text{ Rads} = 1.2 \times 10^7 \text{ Rads}$$

as reported in NUREG 0588 response.

4. Equipment located in the Auxiliary Building effected by post-LOCA recirculating fluid. Table 7.

Containment spray pump motoes

Manufacturer: Westinghouse, Buffalo

Model # - 73F56019-1573, -2573, -3573, -4573.

See Figure 3 for radiation zone number for elevation 695

Read: Zone 3

See Table 3, Zone 3, elevation 695 for the Auxiliary Building

| Read: DBA-LOCA Dose (Rads) | Normal Operating 40-year Dose (Rads) |
|-------------------------------|---|
| 5.2×10^5 | 1.0×10^3 |

This equipment is qualified for the entire one-year post-LOCA, therefore add both values to get:

TID = 5.2×10^5 Rads

?
 1.09E7 1.93E7 2.38E7 1.26E5 6.45E7 8.49E7
 IS DATA RIGHT? INPUT 0 TO KEEP OR NUMBER TO CHANGE
 ?
 0 INPUT 7 THROUGH 12
 ?
 8.64E7 4.48E6 1.09E8 1.18E3 4.65E5 1.11E8
 IS DATA RIGHT? INPUT 0 TO KEEP OR NUMBER TO CHANGE
 ?
 0 INPUT 13 THROUGH 18
 ?
 6.31E7 1.19E3 1.37E8 1.50E8 1.46E8 1.49E8
 IS DATA RIGHT? INPUT 0 TO KEEP OR NUMBER TO CHANGE
 ?
 0 INPUT 19 THROUGH 24
 ?
 1.72E8 1.15E3 4.35E7 1.45E9 3.73E7 1.44E8
 IS DATA RIGHT? INPUT 0 TO KEEP OR NUMBER TO CHANGE
 ?
 0 INPUT 25 THROUGH 30
 ?
 9.20E7 1.34E8 1.90E8 2.96E8 1.79E3 1.11E5
 IS DATA RIGHT? INPUT 0 TO KEEP OR NUMBER TO CHANGE
 ?
 0 INPUT 31 THROUGH 36
 ?
 9.22E8 1.12E6 2.77E7 7.47E5 8.03E7 1.35E7
 IS DATA RIGHT? INPUT 0 TO KEEP OR NUMBER TO CHANGE
 ?
 0 INPUT 37 THROUGH 42
 ?
 1.33E8 1.51E8 1.37E7 5.53E5 6.32E6 1.65E8
 IS DATA RIGHT? INPUT 0 TO KEEP OR NUMBER TO CHANGE
 ?
 0 INPUT 43 THROUGH 48
 ?
 6.0E6 1.69E3 1.05E8 1.59E8 1.54E9 1.43E2
 IS DATA RIGHT? INPUT 0 TO KEEP OR NUMBER TO CHANGE
 ?

Table I

CORE EQUIVALENT ACTIVITY
 (CURIE)

See table listing below for radionuclide index
 (number)

0 INPUT 55 THROUGH 60
 ?
 6.34E7 7.86E7 6.12E5 1.90E8 2.71E7 6.23E7
 IS DATA RIGHT? INPUT 0 TO KEEP OR NUMBER TO CHANGE
 ?
 0 INPUT 61 THROUGH 66
 ?
 3.78E7 1.69E3 1.55E3 0. 0. 0.
 IS DATA RIGHT? INPUT 0 TO KEEP OR NUMBER TO CHANGE
 ?
 0 INPUT 67 THROUGH 72
 ?
 5+0.
 IS DATA RIGHT? INPUT 0 TO KEEP OR NUMBER TO CHANGE
 ?
 0 ALL INPUT ASSUMED IN UC1/ML INPUT APPROPRIATE CONFAU =
 ?
 3.402E-5 Containment Free Volume Confauc =
 OPERATION MODE = 1.0 (DECAY RUN) 2.0 (DEMIL RUN)
 ?
 1.0 ARE THERE ANY CHANGES TO REY OR H
 Y
 ?
 3+5 20E-01 6E-5 21E-01 22E1.0
 ARE THERE ANY CHANGES TO PEV OR H
 N
 DECAI TIME (HOURS)=
 ?
 0.0

$\frac{Dose_{air}}{10^6 \text{ micro} \mu\text{Ci}/\text{hr}^3 \times 60 \text{ min} \times 20.48 \text{ ft}^3 / \text{ft}^3} = \frac{\mu\text{Ci}/\text{cc}}{\text{hr}}$
 T=0 hour Source Terms
 ENERGY 1.32E-01 5.15E-01 9.97E-01 1.39E+00 2.02E+00 2.99E+00

TABLE 1

PRINT TABLE OF CALCULATED ISOTROPIC ACTIVITIES? 1=YES
 ?
 Multiplied by REvalues
 after decay
 1 INPUT ACTIVITY(MCROCURIES/HOUR)
 ENERGY

| | | |
|--------|-----------|----------|
| SR85 | 4.05E+02 | 1.00E+00 |
| R88 | 4.29E-02 | 1.00E-02 |
| RB88 | 2.19E+01 | 1.00E+00 |
| RB89 | 2.86E+01 | 1.00E+00 |
| SR89 | 2.94E+01 | 1.00E+00 |
| SR90 | 1.52E+00 | 1.00E+00 |
| SR91 | 3.71E+01 | 1.00E+00 |
| SR92 | 4.01E+01 | 1.00E+00 |
| Y 90 | 1.58E+00 | 1.00E+00 |
| Y 91 | 3.78E+01 | 1.00E+00 |
| Y 91A | 2.15E+01 | 1.00E+00 |
| Y 92 | 4.01E+01 | 1.00E+00 |
| Y 93 | 4.66E+01 | 1.00E+00 |
| Z895 | 5.10E+01 | 1.00E+00 |
| NB95 | 4.97E+01 | 1.00E+00 |
| TC99n | 5.07E+01 | 1.00E+00 |
| HD99 | 5.95E+01 | 1.00E+00 |
| RH103A | 4.975E+01 | 1.00E+00 |
| RH106 | 1.48E+01 | 1.00E+00 |
| RU103 | 4.97E+01 | 1.00E+00 |
| RU106 | 1.27E+01 | 1.00E+00 |
| I 130 | 2.45E+01 | 1.00E+00 |
| I 131 | 1.56E+03 | 1.00E+00 |
| I 132 | 2.28E+03 | 1.00E+00 |
| I 133 | 3.23E+03 | 1.00E+00 |
| I 134 | 3.50E+03 | 1.00E+00 |
| I 135 | 3.03E+03 | 1.00E+00 |
| TE125A | 3.78E-02 | 1.00E+00 |
| TE127 | 2.90E+00 | 1.00E+00 |
| TE127A | 3.81E-01 | 1.00E+00 |
| TE129 | 9.42E+00 | 1.00E+00 |
| TE129A | 2.54E+00 | 1.00E+00 |
| TE131 | 2.75E+01 | 1.00E+00 |
| TE131A | 4.59E+00 | 1.00E+00 |
| TE132 | 4.52E+01 | 1.00E+00 |
| TE133A | 5.14E+01 | 1.00E+00 |
| CS134 | 4.65E+00 | 1.00E+00 |
| CS126 | 1.32E+00 | 1.00E+00 |
| CS137 | 2.15E+00 | 1.00E+00 |
| CS138 | 5.31E+01 | 1.00E+00 |
| SA137N | 2.04E+00 | 1.00E+00 |
| SA139 | 5.75E+01 | 1.00E+00 |
| SA140 | 5.61E+01 | 1.00E+00 |
| L4140 | 5.75E+01 | 1.00E+00 |
| CE141 | 5.24E+01 | 1.00E+00 |
| CE142 | 4.86E+01 | 1.00E+00 |
| CE143 | 3.02E+01 | 1.00E+00 |

TABLE 1

| | | |
|--------|----------|----------|
| KR87 | 1.52E+03 | 1.00E+00 |
| KR88 | 2.16E+03 | 1.00E+00 |
| KR89 | 2.67E+03 | 1.00E+00 |
| XE131H | 2.08E+01 | 1.00E+00 |
| XE133 | 6.46E+03 | 1.00E+00 |
| XE133H | 9.22E+02 | 1.00E+00 |
| XE135 | 2.32E+03 | 1.00E+00 |
| XE135H | 1.29E+03 | 1.00E+00 |
| XE137 | 5.75E+03 | 1.00E+00 |
| XE138 | 5.27E+03 | 1.00E+00 |
| MN54 | 0.0 | 1.00E+00 |
| MN56 | 0.0 | 1.00E+00 |
| C052 | 0.0 | 1.00E+00 |
| C060 | 0.0 | 1.00E+00 |
| FE59 | 0.0 | 1.00E+00 |
| CR51 | 0.0 | 1.00E+00 |
| CU54 | 0.0 | 1.00E+00 |
| HF181 | 0.0 | 1.00E+00 |
| NP239 | 0.0 | 1.00E+00 |

DO YOU WISH TO RUN AGAIN? 1=YES 2=NO

?

TABLE 1

ALL INPUT ASSUMED IN UC1/AL * INPUT APPROPRIATE CONTINUOUS
 $\frac{1 * 10^6 \text{ neut}/\text{cc}}{25.30093 * (20.48)^{1.4473}}$ * input w C_i = $\mu\text{Ci}/\text{cc}$
 4.121E-4 Summ Liquid Content = 1.0 (DECAY RUN) 2.0 (DEMFILE RUN)
 OPERATION MODE = 1.0 (DECAY RUN) 2.0 (DEMFILE RUN) 4.0 (DECAY DEMFILE)

?

ARE THERE ANY CHANGES TO RECY OR N
 N
 ARE THERE ANY CHANGES TO PC? Y OR N
 N
 DECAY TIME (HOURS)=

?

0.0
 SPECIFIC ACTIVITY BY ENERGY
 (GAMMAS/CC-SEC) (MEV)

TOTALS 0.0-0.3 0.3-0.7 0.7-1.2 1.2-1.7 1.7-2.1 >2.4
 TOTALS 4.62E+09 7.88E+09 5.33E+09 2.07E+09 2.07E+09 3.63E+08
 ENERGY 1.29E-01 5.15E-01 3.97E-01 1.39E+00 2.02E+00 2.93E+00

Containment Sump

T=0 hour Source Terms

| | | | |
|--------|----------|----------|----------|
| BR83 | 2.25E+03 | 5.99E-01 | 1.00E+00 |
| BR84 | 3.94E+03 | 3.94E+03 | 1.00E+00 |
| BR85 | 4.91E+03 | 4.91E+03 | 1.00E+00 |
| RR86 | 5.20E-01 | 5.20E-01 | 1.00E+00 |
| R888 | 2.66E+02 | 2.66E+02 | 1.00E+00 |
| RB89 | 3.46E+02 | 3.46E+02 | 1.00E+00 |
| SR89 | 3.56E+02 | 3.56E+02 | 1.00E+00 |
| SR90 | 1.95E+01 | 1.95E+01 | 1.00E+00 |
| SR91 | 4.50E+02 | 4.50E+02 | 1.00E+00 |
| SR92 | 4.87E+02 | 4.87E+02 | 1.00E+00 |
| Y 90 | 1.92E+01 | 1.92E+01 | 1.00E+00 |
| Y 91 | 4.58E+02 | 4.68E+02 | 1.00E+00 |
| Y 91H | 2.60E+02 | 2.60E+02 | 1.00E+00 |
| Y 92 | 4.87E+02 | 4.87E+02 | 1.00E+00 |
| Y 93 | 5.65E+02 | 5.65E+02 | 1.00E+00 |
| Z995 | 6.19E+02 | 6.19E+02 | 1.00E+00 |
| AB95 | 6.02E+02 | 6.02E+02 | 1.00E+00 |
| TC99H | 6.14E+02 | 6.14E+02 | 1.00E+00 |
| AB99 | 7.09E+02 | 7.09E+02 | 1.00E+00 |
| RH103A | 6.92E+02 | 6.92E+02 | 1.00E+00 |
| RH106 | 1.80E+02 | 1.80E+02 | 1.00E+00 |
| RU103 | 6.02E+02 | 6.02E+02 | 1.00E+00 |
| RU106 | 1.54E+02 | 1.54E+02 | 1.00E+00 |
| A 130 | 2.97E+02 | 2.97E+02 | 1.00E+00 |
| A 131 | 1.90E+04 | 1.90E+04 | 1.00E+00 |
| A 132 | 2.75E+04 | 2.75E+04 | 1.00E+00 |
| A 133 | 3.22E+04 | 3.22E+04 | 1.00E+00 |
| A 134 | 4.25E+04 | 4.25E+04 | 1.00E+00 |
| A 135 | 3.67E+04 | 3.67E+04 | 1.00E+00 |
| YE125H | 4.56E-01 | 4.56E-01 | 1.00E+00 |
| TE127 | 3.39E+01 | 3.39E+01 | 1.00E+00 |
| TE127H | 4.52E+00 | 4.52E+00 | 1.00E+00 |
| TE129 | 1.14E+02 | 1.14E+02 | 1.00E+00 |
| TE129A | 3.08E+01 | 3.08E+01 | 1.00E+00 |
| TE131 | 3.33E+02 | 3.33E+02 | 1.00E+00 |
| TE131A | 5.57E+01 | 5.57E+01 | 1.00E+00 |
| TE132 | 5.48E+02 | 5.48E+02 | 1.00E+00 |
| TE134 | 6.23E+02 | 6.23E+02 | 1.00E+00 |
| CE134 | 5.65E+01 | 5.65E+01 | 1.00E+00 |
| CS136 | 2.26E+01 | 2.26E+01 | 1.00E+00 |
| CS137 | 2.51E+01 | 2.51E+01 | 1.00E+00 |
| CS138 | 5.80E+02 | 5.80E+02 | 1.00E+00 |
| BA137H | 2.47E+01 | 2.47E+01 | 1.00E+00 |
| BA139 | 6.97E+02 | 6.97E+02 | 1.00E+00 |
| BA140 | 6.99E+02 | 6.99E+02 | 1.00E+00 |

TABLE 1

| | | |
|--------------------------------------|-----------------|-----------------|
| PR144 | 3.70E+02 | 1.00E+00 |
| KR83H | 4.45E+03 | 1.00E+00 |
| KR95 | 2.30E+02 | 1.00E+00 |
| KR85M | 2.98E+03 | 1.00E+00 |
| KR87 | 1.84E+04 | 1.00E+00 |
| KR99 | 2.61E+04 | 1.00E+00 |
| KR89 | 3.24E+04 | 1.00E+00 |
| XE131H | 2.52E+02 | 1.00E+00 |
| XE133 | 7.84E+04 | 1.00E+00 |
| XE135H | 2.82E+04 | 1.00E+00 |
| XE135H | 1.56E+04 | 1.00E+00 |
| XE137 | 6.97E+04 | 1.00E+00 |
| XE139 | 5.39E+04 | 1.00E+00 |
| MN54 | 0.0 | 1.00E+00 |
| MN55 | 0.0 | 1.00E+00 |
| CC52 | 0.0 | 1.00E+00 |
| CC60 | 0.0 | 1.00E+00 |
| FE59 | 0.0 | 1.00E+00 |
| CS51 | 0.0 | 1.00E+00 |
| CU64 | 0.0 | 1.00E+00 |
| HF181 | 0.0 | 1.00E+00 |
| NP239 | 0.0 | 1.00E+00 |
| DO YOU WANT TO RUN AGAIN? Y=YE5 N=N0 | ? | 1.00E+00 |

TABLE 1

READY

LOGOFF
RGE9371 LOGGED OFF Y60 AT 15:27:37 PM FEBRUARY 4, 1993
LAST STEP COMPLETION CODE 442 000 000

TABLE 2
REACTOR BUILDING
Radiation Data

| <u>Elevation</u> | <u>Zone</u> | <u>Normal Oper. Dose Rate (R/Hr.)</u> | <u>Normal Oper. 40 Yr. Dose (Rads)</u> | <u>LOCA Dose Rate (R/Hr.)</u> | <u>LOCA Dose¹ (Rads)</u> | <u>TID² (Rads)</u> |
|------------------|-------------|---|--|-----------------------------------|---|-----------------------------------|
| 696 + 11 | 1 | 2.9E2 | 1.0E7 | 4.8E6 | 1.0E8 | 1.1E8 |
| 725 + 0 | 2 | 2.9E1 | 2.0E7 | 4.8E6 | 1.0E8 | 1.2E8 |
| | 3 | 2.9E0 | 1.0E6 | 4.8E6 | 1.0E8 | 1.0E8 |
| | 4 | 2.9E-2 | 1.0E4 | 1.0E6 | 2.0E7 | 2.0E7 |
| 738 + 3 | 5 | 1.4E1 | 5.0E6 | 4.8E6 | 1.0E8 | 1.0E8 |
| | 6 | 5.7E1 | 2.0E7 | 4.8E6 | 1.0E8 | 1.2E8 |
| | 7 | 2.9E-1 | 1.0E5 | 4.8E6 | 1.0E8 | 1.0E8 |
| | 8 | 5.7E-2 | 2.0E4 | 4.8E6 | 1.0E8 | 1.0E8 |
| | 8a | 5.7E-2 | 2.0E4 | 6.0E5 | 2.0E7 | 2.0E7 |
| | 9 | 5.7E-1 | 2.0E5 | 4.8E6 | 1.0E8 | 1.0E8 |
| | 10 | 2.9E-2 | 1.0E4 | 1.0E6 | 2.0E7 | 2.0E7 |
| 767 + 11 | 11 | 1.4E1 | 5.0E6 | 4.8E6 | 1.0E8 | 1.0E8 |
| | 12 | 5.7E0 | 2.0E6 | 4.8E6 | 1.0E8 | 1.0E8 |
| | 13 | 5.7E1 | 2.0E7 | 4.8E6 | 1.0E8 | 1.2E8 |
| | 14 | 2.9E-1 | 1.0E5 | 4.8E6 | 1.0E8 | 1.0E8 |
| | 15 | 5.7E1 | 2.0E7 | 4.8E6 | 1.0E8 | 1.2E8 |
| | 16 | 5.7E-2 | 2.0E4 | 4.8E6 | 1.0E8 | 1.0E8 |
| | 17 | 2.9E-2 | 1.0E4 | 1.5E6 | 3.0E7 | 3.0E7 |
| 778 + 10 | 18 | 1.0E1 | 3.5E6 | 4.8E6 | 1.0E8 | 1.0E8 |
| | 19 | 2.9E-1 | 1.0E5 | 4.8E6 | 1.0E8 | 1.0E8 |
| | 20 | 1.4E1 | 3.0E6 | 4.8E6 | 1.0E8 | 1.0E8 |
| | 21 | 5.7E0 | 2.0E6 | 4.8E6 | 1.0E8 | 1.0E8 |
| | 22 | 5.7E-2 | 2.0E4 | 4.8E6 | 1.0E8 | 1.0E8 |

TABLE 2

TABLE 2 (Sheet 2)

REACTOR BUILDING

Radiation Data

| <u>Elevation</u> | <u>Zone</u> | <u>Normal Oper. Dose Rate (R/Hr.)</u> | <u>Normal Oper. 40 Yr. Dose (Rads)</u> | <u>LOCA Dose Rate (R/Hr.)</u> | <u>LOCA Dose¹ (Rads)</u> | <u>TID² (Rads)</u> |
|--------------------|-------------|---|--|-----------------------------------|---|-----------------------------------|
| 778+10 | 23 | 1.4E-1 | 5.0E4 | 4.8E6 | 1.0E8 | 1.0E8 |
| | 24 | 2.9E-2 | 1.0E4 | 1.5E6 | 3.0E7 | 3.0E7 |
| 841 + 10 | 25 | 1.4E1 | 5.0E6 | 4.8E6 | 1.0E8 | 1.1E8 |
| | 26 | 1.4E-1 | 5.0E4 | 4.8E6 | 1.0E8 | 1.0E8 |
| | 27 | 5.7E-2 | 2.0E4 | 4.8E6 | 1.0E8 | 1.0E8 |
| | 28 | 2.9E-2 | 1.0E4 | 2.2E6 | 4.5E7 | 4.5E7 |
| 842 + 5 & Above | 29 | 1.4E-1 | 5.0E4 | 4.8E6 | 1.0E8 | 1.0E8 |
| | 30 | 2.9E-2 | 1.0E4 | 4.8E6 | 1.0E8 | 1.0E8 |

NOTES: ¹Use Figure 5.6-1 to determine fraction of 1-year dose.

²TID = Total Integrated Dose. Equal to total of 40-year normal operating dose plus 1-year LOCA dose.

TABLE 3
AUXILIARY BUILDING
Radiation Data

| <u>Elevation</u> | <u>Zone</u> | <u>Max. Dose Rate (R/Hr.)</u> | <u>DBA-LOCA^{1, 2} Dose (Rads)</u> | <u>Normal Oper. 40 Yr. Dose (Rads)</u> | <u>TID³ (Rads)</u> |
|------------------|-------------|-------------------------------|--|--|-----------------------------------|
| 695 + 0 | 1 | 2.8E4 | 6.0E5 | 1.0E5 | 7.0E5 |
| | 2 | 1.5E4 | 3.2E5 | 1.4E5 | 4.6E5 |
| | 3 | 2.4E4 | 5.2E5 | 1.0E3 | 5.2E5 |
| | 4 | 4.1E3 | 8.8E4 | 1.0E3 | 9.0E4 |
| | 5 | 2.8E2 | 5.9E3 | 1.0E3 | 7.0E3 |
| | 6 | ----- | ----- | 1.4E5 | 1.4E5 |
| | 7 | ----- | ----- | 1.0E5 | 1.0E5 |
| | 8 | ----- | ----- | 4.6E5 | 4.6E5 |
| | 9 | ----- | ----- | 5.0E3 | 5.0E3 |
| 716 + 0 | 10 | 1.7E4 | 3.5E5 | 2.0E4 | 3.7E5 |
| | 11 | 8.6E4 | 1.8E6 | 2.0E4 | 1.8E6 |
| | 12 | 3.1E4 | 7.2E5 | 2.0E4 | 7.4E5 |
| | 13 | 1.7E3 | 3.4E4 | 2.0E4 | 5.4E4 |
| | 14 | 1.1E1 | 2.4E2 | 3.5E4 | 3.5E4 |
| | 15 | 1.3E4 | 2.8E5 | 1.0E3 | 2.8E5 |
| | 16 | 5.6E2 | 1.2E4 | ----- | 1.2E4 |
| | 17 | 2.3E2 | 5.0E3 | 5.0E3 | 1.0E4 |
| | 18 | 2.3E4 | 5.0E5 | 2.0E4 | 5.2E5 |
| | 19 | 2.3E2 | 5.0E3 | 2.0E4 | 2.5E4 |
| | 20 | 2.5E3 | 5.3E4 | 3.5E4 | 8.8E4 |
| | 21 | 1.4E1 | 3.0E2 | 1.0E3 | 1.3E3 |
| | 22 | 4.6E0 | 1.0E2 | 1.0E3 | 1.1E3 |
| | 23 | 2.7E0 | 5.7E1 | 1.0E3 | 1.1E3 |
| | 24 | 4.6E1 | 9.8E2 | 1.0E3 | 2.0E3 |
| | 25 | ----- | ----- | 1.0E3 | 1.0E3 |
| | 26 | 1.5E-1 | 5.0E0 | 5.0E2 | 5.0E2 |
| | 27 | 4.0E4 | 7.5E5 | 1.1E8 | 1.1E8 |

TABLE 3 (Sheet 4)
AUXILIARY BUILDING
Radiation Data

| <u>Elevation</u> | <u>Zone</u> | <u>Max. Dose Rate (R/Hr.)</u> | <u>DBA-LOCA^{1,2} Dose (Rads)</u> | <u>Normal Oper. 40 Yr. Dose (Rads)</u> | <u>TID³ (Rads)</u> |
|----------------------|-------------|-------------------------------|---|--|-------------------------------|
| 750 + 0 (Cont'd) | 81 | 1.6E2 | 3.4E3 | 1.0E3 | 4.4E3 |
| | 82 | 4.7E0 | 1.0E1 | 1.0E3 | 1.0E3 |
| | 83 | 4.7E1 | 1.0E2 | 1.0E3 | 1.1E3 |
| | 84 | 4.7E2 | 1.0E3 | 1.0E3 | 2.0E3 |
| | 85 | 1.4E4 | 3.0E5 | 5.0E3 | 3.1E5 |
| | 86 | ----- | ----- | 3.6E5 | 3.6E5 |
| | 87 | ----- | ----- | 1.7E8 | 1.7E8 |
| | 88 | 2.1E4 | 3.9E5 | 8.4E4 | 4.8E5 |
| | 89 | ----- | ----- | 5.0E3 | 5.0E3 |
| | 90 | ----- | ----- | 2.9E6 | 2.9E6 |
| | 91 | ----- | ----- | 4.4E6 | 4.4E6 |
| | 92 | ----- | ----- | 1.0E3 | 1.0E3 |
| | 93 | ----- | ----- | 3.5E2 | 3.5E2 |
| 767 + 0 ² | 94 | 4.2E-6 | 2.3E-5 | 1.0E3 | 1.0E3 |
| | 95 | 5.6E-3 | 1.3E0 | 3.5E2 | 3.5E2 |
| | 96 | 1.8E-1 | 2.5E1 | 3.5E2 | 3.8E2 |
| | 97 | 3.8E3 | 1.6E6 | 3.5E2 | 1.6E6 |
| | 98 | 8.03 | 3.1E3 | 3.5E2 | 3.5E3 |
| | 99 | 1.1E3 | 3.0E5 | 3.5E2 | 3.0E5 |
| | 100 | 3.3E5 | 2.0E8 | ----- | 2.0E3 |

NOTES: ¹Use Figure 5.0-1 to determine fraction of 1-year dose except for zones on Elevation 767+0.

²for zones on Elevation 767+0 use Figure 5.0-2 to determine fraction of 1-year dose.

³TID = Total Integrated Dose. Equal to total of 40-year normal operating dose plus 1-year DBA-LOCA dose.

TABLE 3 (Sheet 5)

AUXILIARY BUILDING

Radiation Data

| <u>Elevation</u> | <u>Zone</u> | <u>Max. Dose Rate (R/Hr.)</u> | <u>DBA-LOCA¹,² Dose (Rads)</u> | <u>Normal Oper. 40 Yr. Dose (Rads)</u> | <u>TID³ (Rads)</u> |
|-------------------------------|-------------|-------------------------------|--|--|-------------------------------|
| 767 + 0 ² (Cont'd) | 101 | 1.2E3 | 6.0E5 | 1.0E3 | 6.0E5 |
| | 102 | 1.0E2 | 5.2E4 | 1.0E3 | 5.3E4 |
| | 103 | 6.5E3 | 3.3E6 | 1.0E3 | 3.3E6 |
| | 104 | 1.1E3 | 5.4E5 | 1.0E3 | 5.4E5 |
| | 105 | 6.5E3 | 3.3E6 | 1.0E3 | 3.3E6 |
| | 106 | 3.8E3 | 2.0E6 | 1.0E3 | 2.0E6 |
| | 107 | 5.2E2 | 2.7E5 | 1.0E3 | 2.7E5 |
| | 108 | 6.2E-2 | 1.2E1 | 1.0E3 | 1.0E3 |
| | 109 | 4.6E4 | 2.4E7 | 1.0E3 | 2.4E7 |
| | 110 | 8.5E5 | 4.7E-3 | 1.0E3 | 1.0E3 |
| | 111 | 3.0E-4 | 5.5E-1 | 1.0E3 | 1.0E3 |
| | 112 | 3.5E-3 | 4.9 | 3.5E2 | 3.5E2 |
| | 113 | 2.5E-2 | 4.6 | 2.0E2 | 2.0E2 |
| | 114 | ----- | ----- | 3.5E2 | 3.5E2 |

TABLE 3

NOTES: ¹Use Figure 5.0-1 to determine fraction of 1-year dose except for zones on Elevation 767+0.²for zones on Elevation 767+0 use Figure 5.0-2 to determine fraction of 1-year dose.³TID = Total Integrated Dose. Equal to total of 40-year normal operating dose plus 1-year DBA-LOCA dose.

TABLE 4
DIESEL GENERATOR DATA
Radiation Area

| <u>Elevation</u> | <u>Zone</u> | <u>Max. Dose Rate (R/Hr.)</u> | <u>DBA-LOCA¹ Dose (Rads)</u> | <u>Normal Oper. 40 Yr. Dose (Rads)</u> | <u>TID² (Rads)</u> |
|------------------|-------------|-------------------------------|---|--|-------------------------------|
| 736 +6 | 1 | 4.5 | 100 | 3.5E2 | 4.5E2 |
| | 2 | 4.5E2 | 1.0E4 | 3.5E2 | 1.0E4 |
| | 3 | 1.8E3 | 4.0E4 | 3.5E2 | 4.0E4 |
| | 4 | 2.8E3 | 6.0E4 | 3.5E2 | 6.0E4 |
| | 5 | 1.8E3 | 4.0E4 | 3.5E2 | 4.0E4 |
| | 6 | 4.5E1 | 1.0E3 | 3.5E2 | 1.4E3 |
| | 7 | 1.4 | 30 | 3.5E2 | 3.8E2 |
| | 8 | 9.1E2 | 2.0E4 | 3.5E2 | 2.0E4 |
| | 9 | 6.8E1 | 1.5E3 | 3.5E2 | 1.9E3 |
| | 10 | 4.5E1 | 1.0E3 | 3.5E2 | 1.4E3 |
| | 11 | 4.5 | 100 | 3.5E2 | 4.5E2 |
| | 12 | 4.5 | 100 | 3.5E2 | 4.5E2 |
| | 13 | 2.3 | 500 | 3.5E2 | 8.5E2 |
| | 14 | 1.4 | 30 | 3.5E2 | 3.8E2 |

NOTES: ¹Use Figure 5.0-1 to determine fraction of 1-year dose.

²TID = Total Integrated Dose. Equal to total of 40-years normal operating dose plus 1-year DBA-LOCA dose.

FROM: NUREG 0588
ATTACHMENT 1

TABLE 5

McGUIRE NUCLEAR STATION - UNITS 1 AND 2
SUMMARY OF ENVIRONMENTAL QUALIFICATION OF CLASS 1E EQUIPMENT
LOCATED INSIDE CONTAINMENT

Page 16
Rev. 0

EQUIPMENT ID: Valve Motor
(1) Operators
(Upper Containment)

MANUFACTURER: Limitorque

MODEL #: SMB

| ACCIDENT ENVIRONMENT (2) | ENVIRONMENT TO WHICH QUALIFIED | OPERABILITY REQUIRED IN ACCIDENT ENVIRONMENT(3) | OPERABILITY DEMONSTRATED | ACCURACY REQUIRED (% OF SPAN) | ACCURACY DEMONSTRATED (% OF SPAN) |
|--|---|--|--------------------------|----------------------------------|--------------------------------------|
| Temp: 180°F Press: 14.8 psig RH: 100% Rad: 4X10 ⁶ R Chem Spray: Boric acid and sodium tetraborate soln. | Temp: 340°F Press: 105 psig RH: 100% Rad: 2X10 ⁸ R Chem Spray: Boric acid and sodium hydroxide soln. 3000 ppm Boron, 10.5 pH | 5 min. (Notes 7 and 8) | 30 days post DBE | N/A | N/A |

From the Manufacturer's File Location:
Radiation Zone 23
Elevation 778+10

QUALIFICATION REPORT (4): Limitorque Test Report: B0058, January 11, 1980

METHOD: Test

TABLE 6

McGUIRE NUCLEAR STATION - UNITS 1 AND 2
SUMMARY OF ENVIRONMENTAL QUALIFICATION OF CLASS 1E EQUIPMENT
LOCATED IN THE ANNULUS

EQUIPMENT ID: Transmitter-RCS Pressure (WR)

MANUFACTURER: Rosemount

MODEL #: 1153GA9

TABLE 6

| ACCIDENT ENVIRONMENT (1) | ENVIRONMENT TO WHICH QUALIFIED | OPERABILITY REQUIRED IN ACCIDENT ENVIRONMENT | OPERABILITY DEMONSTRATED (2) | ACCURACY REQUIRED (% OF SPAN) | ACCURACY DEMONSTRATED (% OF SPAN) |
|---|---|---|---------------------------------|----------------------------------|--------------------------------------|
| Temp: 142°F RH: 100% Rad: 1.2×10^7 R | Temp: 350°F RH: 100% Rad: 4×10^7 R | 2 weeks post DBE | 1 year post DBE | ± 10% | ± 8% Upper Range |

From the Manufacturer's File
Radiation Zone: 10
Elevation: 738+3

QUALIFICATION REPORT: Test Report RMT Report #3788, Rev. A

METHOD: Similarity & Type Test

TABLE 7

MC GUIRE NUCLEAR STATION - UNITS 1 AND 2
SUMMARY OF ENVIRONMENTAL QUALIFICATION OF CLASS 1E EQUIPMENT
LOCATED OUTSIDE CONTAINMENT AND EXPOSED TO THE POST-LOCA RECIRCULATION ENVIRONMENT

Page 4
Rev. 0

EQUIPMENT ID: Containment Spray Pump Motors (1) MANUFACTURER: Westinghouse, Buffalo MODEL #: 73F56019-1S73, 73F56019-2S73, 73F56019-3S73, 73F56019-4S73

| RECIRCULATION RADIATION ENVIRONMENT (TID) (2) | RADIATION LEVEL TO WHICH QUALIFIED (TID) |
|---|--|
| 5.2X10 ⁵ RAD | 2X10 ⁸ RAD |

From the Manufacturer's File
Radiation Zone: 3
Elevation: 695

QUALIFICATION REPORT: WCAP 8754 Rev. 1, WCAP 7829

METHOD: Test and Analysis

TABLE 8

McGUIRE NUCLEAR STATION - UNITS 1 AND 2
SUMMARY OF ENVIRONMENTAL QUALIFICATION OF CLASS 1E EQUIPMENT
LOCATED INSIDE CONTAINMENT

Page 2
Rev. 0

EQUIPMENT ID: Transmitter - Pressurizer
(1) Level (Lower Containment)
(Unit 1)

MANUFACTURER: Barton

MODEL #: 764 (Lot 2)


| ACCIDENT ENVIRONMENT (2) | ENVIRONMENT TO WHICH QUALIFIED | OPERABILITY REQUIRED IN ACCIDENT ENVIRONMENT(3) | OPERABILITY DEMONSTRATED | ACCURACY REQUIRED (% OF SPAN) | ACCURACY DEMONSTRATED (% OF SPAN) |
|--|--|---|--------------------------|-------------------------------|-----------------------------------|
| Temp: 327°F Press: 14.8 psig RH: 100% Rad: 1.4X10 ⁷ R Chem Spray: Boric acid and sodium tetraborate soln. | Temp: 380°F Press: 75 psig RH: 100% Rad: 5X10 ⁷ R Chem Spray: Boric acid and sodium hydroxide soln. 2750 ppm Boron 8.5 pH | 2 weeks post DBE | 4 months post DBE | ± 25% | Max. Error 15% |

From Manufacturer's File:
Radiation Zone: 8a
Elevation: 738+3

QUALIFICATION REPORT (4): WCAP 9885

METHOD: Test

Radiation Zone Map
Diesel Generator Area
Elevation 736 + 6 m



Sonbit

47

10

(46)

**S. EMERGENCY
PERSONNEL**

r34 8 ANNULUS ACCESS

FL EL 733+8


UNIVERSITY LIBRARIES


600


۱۰

5

Radiation Zone Map
 Reactor Building
 Elevation 738 + 3
MCGUIRE NUCLEAR STATION
 Figure 1









Radiation Zone Map,
Reactor Building
Elevation 778 + 10
McGUIRE NUCLEAR STATION



Figure 2

Figure 3






Radiation Zone Map
Auxiliary Building
Elevation 695 + 0




McGUIRE NUCLEAR STATION

Figure 3

enbit





Radiation Zone Map
Auxiliary Building
Elevation 767 + 0



McGUIRE NUCLEAR STATION
FIGURE A





FIGURE 6
REACTOR & AUXILIARY BUILDING INTEGRATION FRACTIONS



AUXILIARY BUILDING INTEGRATED FRACTIONS

