OPERATING DATA REPORT

DOCKET NO. 50-261
BATE 830202
COMPLETED BY H. Ray Norris
TELEPHONE 803-383-4524

Notes There are presently 157

spent fuel assemblies in the

OPERATING STATUS

2 Reporting Period

1. Unit Name: H. B. Robinson Unit No. 2

830101, 0000/830131, 2400

- trepresentation		connt funi non'	1
3. Licensed Thermal Power (MWt): 23	spent fuel pool.		
4. Nameplate Rating (Gross MWe):7			
5. Design Electrical Rating (Net MWe):7			
6. Maximum Dependable Capacity (Gross MWe)			
7. Maximum Dependable Capacity (Net MWe):	665		
If Changes Occur in Capacity Ratings (Items No change	Number 3 Through 7) Sind	ce Last Report, Give Re	easons:
	ugh the unit is no		
agency, the power level is pres	ently reduced due	to steam genera	ator con-
siderations.			
	This Month	Yrto-Date	Cumulative
11. Hours In Reporting Period	744	744	104430
12. Number Of Hours Reactor Was Critical	720.3	720.3	77559.97
13. Reactor Reserve Shutdown Hours	18.13	18.13	1325.9
14. Hours Generator On-Line	705.52	705.52	75541.56
15. Unit Reserve Shutdown Hours	0	0	23.20
16. Gross Thermal Energy Generated (MWH)	1227907.4	1227907.4	151992446
17. Gross Electrical Energy Generated (MWH)	394960	394960	48903723
18. Net Electrical Energy Generated (MWH)	370696	370696	46242793
19. Unit Service Factor	94.83	94.83	72.33
20. Unit Availability Factor	94.83	94.83	72.36
21. Unit Capacity Factor (Using MDC Net)	74.92	74.92	66.59
22. Unit Capacity Factor (Using DER Net)	71.18	71.18	63.26

24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each):

Type two 4-23-83, four week steam generator inspection outage

8302170070 830209 PDR ADDCK 05000261 R PDR

23. Unit Forced Outage Rate

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-261 UNIT NAME H. B. Robinson 830202 DATE COMPLETED BY H. Ray Norris TELEPHONE 803-383-4524

REPORT MONTH __January

No.	Date	Type1	Duration (Hours)	Reason	Method of Shutting Down Reactor ³	Licensee Event Report #	System Code4	Component Code 5	Cause & Corrective Action to Prevent Recurrence
12-1	830101	F	13.33	A	3		НВ	INSTRU	A faulty fuse holder caused the power solenoid for "C" MSIV to de-energize closing the MISV which caused a low-low level in "C" S/G and subsequent unit trip. The fuse holder was replaced.
1-1	830107	F	25.15	А	1		HH	HTEXCH	#5 feedwater heater tube leaks. Twenty-four tubes required plugging. The unit's return to service was delayed 5.57 hours due to a reactor trip caused by a momentary spurious safeguards actuation signal.

F: Forced S: Scheduled

Reason:

A-Equipment Failure (Explain) B-Maintenance of Test

C-Refueling

D-Regulatory Restriction E-Operator Training & License Examination

F-Administrative

G-Operational Error (Explain) H-Other (Explain)

3 Method:

1-Manuel

2-Man al Scram.

3-Autematic Scram.

4-Othe (Explain)

Exhibit G - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG-0161)

Exhibit 1 - Same Source

(9/77)

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-261

UNIT H. B. Robinson

DATE 830202

COMPLETED BY H. Ray Norris

TELEPHONE 803-383-4524

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)	DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
1	66	17.	561
2	420	18	560
3	523	19	453
4	558	20	472
5	558	21	561
6	559	22	539
7	423	23	529
8		24	562
9	331	25	562
10	560	26	562
11	562	27	562
12	561	28	562
13	563	29	564
14	563	30	563
15	563	31	563
16	483		

INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

(9/77)