LICENSEE EVENT REPORT

	Z. EIGENGEE EVENT HEIGHT
•	CONTROL BLOCK: [] [] [] (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)
0 1 7 8	N C B E P 2 0 0 - 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5 5 HICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58
CON'T 0 1 7 8	REPORT SOURCE LL 6 0 5 0 - 0 3 2 4 7 0 11 1 4 8 3 8 0 2 0 9 8 3 9 EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10 [Routine surveillance during plant operation revealed that primary containment atmos-
0 3	phere oxygen analyzer, 2-CAC-AT-1263-2, indicated a .5% step increase in drywell
0 4	oxygen concentration. On January 24, 1983, 1263-2 indicated a 1.0% step increase in
0 5	drywell oxygen concentration. At the time of these events, redundant instrument,
03	[2-CAC-AT-1259-2, was showing an expected indication of drywell oxygen concentration.
0 7	This event did not affect the health and safety of the public.
0 8	Technical Specifications 3.3.5.3, 3.6.6.4, 6.9.1.9b
7 8 0 9 7 B	SYSTEM CODE CODE SUBCODE COMPONENT CODE SUBCODE SUBCOD
1 0	These events resulted from a zero shift in the 1263-2 instrument. In each case the
1 1	[1263-2, Model No. F3M3, was calibrated and returned to service. These type CAC
1 2	monitors are being replaced in accordance with an approved plant modification.
1 3	
7 8	9 80
1 5	FACILITY STATUS NO POWER OTHER STATUS 30 METHOD OF DISCOVERY DESCRIPTION 32 E 28 0 9 8 29 NA LA 31 Operator Surveillance 80
	ACTIVITY CONTENT RELEASE OF RELEASE AMOUNT OF ACTIVITY 35 2 33 Z 34 NA 9 10 11
1 7 7 8	0 0 0 (37) Z (38) NA 9 PERSONNEL INJURIES NUMBER DESCRIPTION (41) 0 0 0 (40) NA
7 8	9 11 12 LOSS OF OR DAMAGE TO FACILITY (43) TYPE DESCRIPTION Z (42) NA PDR ADOCK 05000324 S PDR
7 8	PUBLICITY ISSUED DESCRIPTION 45 NA
	M. I. Pastva Ir. 819-457-9521