NRC FORM 366 (7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

Line	Field	Entry
01	LICENSEE CODE (2)	I L Z I S 2
	LICENSE NUMBER (3)	0 0 - 0 0 0 0 0 - 0 0
	LICENSE TYPE (4)	4 1 1 1 1
	CAT (5)	
CON'T 01	REPORT SOURCE (6)	L
	DOCKET NUMBER (7)	0 5 0 0 0 3 0 4
	EVENT DATE (8)	0 8 0 4 8 2
	REPORT DATE (9)	0 9 0 3 8 2

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

During normal power operation, Unit Two pressurizer level Channel 2L-461 was observed to vary only ½% for each 1% variation of channels 2L-459 & 460. This was non-conservative for pressurizer high level Rx trip. Since the redundant level channels were operating conservatively, the health and safety of the public were not affected.

Line 09 Field	Entry
SYSTEM CODE (11)	I A
CAUSE CODE (12)	E
CAUSE SUBCODE (13)	E
COMPONENT CODE (14)	I N S T R U
COMP. SUBCODE (15)	T
VALVE SUBCODE (16)	Z

LER/RO REPORT NUMBER (17)	Entry
EVENT YEAR	8 2
	—
SEQUENTIAL REPORT NO.	0 1 9
	/
OCCURRENCE CODE	0 3
REPORT TYPE	L
	—
REVISION NO.	0

Field	Entry
ACTION TAKEN (18)	A
FUTURE ACTION (19)	Z
EFFECT ON PLANT (20)	Z
SHUTDOWN METHOD (21)	Z
HOURS (22)	0 0 0 0
ATTACHMENT SUBMITTED (23)	N
NPRD-4 FORM SUB. (24)	Y
PRIME COMP. SUPPLIER (25)	N
COMPONENT MANUFACTURER (26)	B 0 8 0

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

The cause for the out-of-tolerance on the transmitter (Barton#386) was determined to be a failed strain gauge. The strain gauge was replaced and the transmitter recalibrated. This has not been a recurring problem. No further action on this item is required.

Line	Field	Entry
15	FACILITY STATUS (28)	E
	% POWER (29)	1 0 0
	OTHER STATUS (30)	NA
	METHOD OF DISCOVERY (31)	A
	DISCOVERY DESCRIPTION (32)	Operator Observation
16	ACTIVITY RELEASED (33)	Z
	CONTENT OF RELEASE (34)	Z
	AMOUNT OF ACTIVITY (35)	NA
	LOCATION OF RELEASE (36)	NA
17	PERSONNEL EXPOSURES NUMBER (37)	0 0 0
	TYPE (38)	Z
	DESCRIPTION (39)	NA
18	PERSONNEL INJURIES NUMBER (40)	0 0 0
	DESCRIPTION (41)	NA
19	LOSS OF OR DAMAGE TO FACILITY (43) TYPE (42)	Z
	DESCRIPTION	NA
20	PUBLICITY ISSUED (44)	N
	DESCRIPTION (45)	NA
	NRC USE ONLY	

8209130175 820903
PDR ADOCK 05000304
S PDR

NAME OF PREPARER: P. F. Cantwell

PHONE: 312-746-2084-507