

MAR 23 1994

DSS

Docket Nos. 50-317
50-318

Mr. Robert E. Denton
Vice President - Nuclear Energy
Baltimore Gas and Electric Company
Calvert Cliffs Nuclear Power Plant
1650 Calvert Cliffs Parkway
Lusby, Maryland 20657 - 4702

Dear Mr. Denton:

Subject: **NRC Inspection Report 50-317/93-33 and 50-518/93-33**

This letter refers to your March 9, 1994 correspondence, in response to our January 25, 1994 letter.

Thank you for informing us of the corrective and preventive actions documented in your letter. These actions will be examined during a future inspection of your licensed program.

Your cooperation with us is appreciated.

Sincerely,

Curtis J. Cowgill, Chief
Projects Branch No. 1
Division of Reactor Projects

9403310106 940323
PDR ADOCK 05000317
Q PDR

IE01
11

MAR 23 1994

Mr. Robert E. Denton

2

cc w/encl:

G. Detter, Director, Nuclear Regulatory Matters (CCNPP)

R. McLean, Administrator, Nuclear Evaluations

J. Walter, Engineering Division, Public Service Commission of Maryland

K. Burger, Esquire, Maryland People's Counsel

R. Ochs, Maryland Safe Energy Coalition

K. Abraham, PAO (2)

Public Document Room (PDR)

Local Public Document Room (LPDR)

Nuclear Safety Information Center (NSIC)

NRC Resident Inspector

State of Maryland (2)

MAR 23 1994

Mr. Robert E. Denton

3

bcc w/encl:

Region I Docket Room (with concurrences)

C. Cowgill, DRP

L. Nicholson, DRP

R. Fuhrmeister, DRP

P. Wilson - Calvert Cliffs

R. Capra, NRR

D. McDonald, NRR

RI:DRP
LNicholson

03/23/94

RI:DRP *u*
CCowgill

03/23/94

OFFICIAL RECORD COPY

a:RL9333

ROBERT E. DENTON
Vice President
Nuclear Energy

Baltimore Gas and Electric Company
Calvert Cliffs Nuclear Power Plant
1630 Calvert Cliffs Parkway
Lusby, Maryland 20657
410 586-2200 Ext. 4455 Local
410 260-4455 Baltimore



March 9, 1994

U. S. Nuclear Regulatory Commission
Washington, DC 20555

ATTENTION: Document Control Desk

SUBJECT: Calvert Cliffs Nuclear Power Plant
Unit Nos. 1 & 2; Docket Nos. 50-317 & 50-318
Reply to Notice of Violation Inspection Report Nos. 50-317(318)/93-33
Failure to Adequately Implement Foreign Material Controls

REFERENCE: (a) Letter from Mr. C. J. Cowgill (NRC) to Mr. R. E. Denton (BGE),
dated January 25, 1994, NRC Region I Resident Inspection Report
Nos. 50-317/93-33 and 50-318/93-33

In response to Reference (a), please find Attachment (1) detailing our response to the cited violation concerning foreign material controls.

Should you have any questions regarding this matter, we will be pleased to discuss them with you.

Very truly yours,

RED/WDM/wdm/bjd

Attachment

cc: D. A. Brune, Esquire
J. E. Silberg, Esquire
R. A. Capra, NRC
D. G. McDonald, Jr., NRC
T. T. Martin, NRC
P. R. Wilson, NRC
R. I. McLean, DNR
J. H. Walter, PSC

9403160150

ATTACHMENT (1)

REPLY TO NOTICE OF VIOLATION
INSPECTION REPORT NOS. 50-317(318)/93-33

FAILURE TO ADEQUATELY IMPLEMENT FOREIGN MATERIAL CONTROLS

IV. CORRECTIVE ACTIONS WHICH WILL BE TAKEN TO AVOID FURTHER VIOLATIONS

Site supervision will continue to emphasize the importance of Foreign Material Exclusion (FME) standards. This will be accomplished through enhanced training, aggressive self-assessment, and increased emphasis on emergent FME issues at management and supervisory forums. We are conducting more periodic surveillances of work in progress, and we are stressing prompt correction of identified deficiencies. Management will ensure supervisors and workers are held strictly accountable for performance in this area.

V. DATE WHEN FULL COMPLIANCE WILL BE ACHIEVED

Full compliance was achieved on November 20, 1993 upon correction of the cited deficiencies in the Spent Fuel Pool area.