

Appendix

NOTICE OF VIOLATION

Wisconsin Electric Power Company  
Point Beach Nuclear Power Plant

Docket No. 50-266  
Docket No. 50-301

As a result of an inspection conducted on July 16, 1982, by the South Carolina Department of Health and Environmental Control at the Barnwell, South Carolina waste disposal site, and in accordance with the NRC Enforcement Policy, 47 FR 9987 (March 9, 1982), the following violation was identified:

10 CFR 30.41(a) states that no licensee shall transfer byproduct material except as authorized pursuant to Section 30.41 of Part 30.

Condition No. 26 of South Carolina Radioactive Material License No. 097 issued to Chem-Nuclear Systems limits the volume of liquid that may be present in waste packages received at the burial site.

Contrary to the above, one of nine 55-gallon drums from the Point Beach Nuclear Power Plant was found to contain liquid exceeding the specified limit when the drum was inspected at the burial site on July 16, 1982.

This is a Severity Level IV violation (Supplement V).

Pursuant to the provisions of 10 CFR 2.201, you are required to submit to this office within thirty days of the date of this Notice a written statement or explanation in reply, including for each item of noncompliance: (1) corrective action taken and the results achieved; (2) corrective action to be taken to avoid further noncompliance; and (3) the date when full compliance will be achieved. Consideration may be given to extending your response time for good cause shown.

\_\_\_\_\_  
Dated

\_\_\_\_\_  
R. L. Spessard, Director  
Division of Project and  
Resident Programs