

# DUKE POWER COMPANY

# OCONEE NUCLEAR STATION

# IMPLEMENTING PROCEDURES



Revision 83-1 January 10, 1983



# Table of Contents (Implementing Procedures - Continued)

CP/0/B/2003/02	Estimate of Failed Fuel Based on I-131 Concentration (12/15/82)
CP/1&2/A/2002/05	Post Accident Caustic Injection into the Low Pressure Injection System (01-26-81)
CP/3/A/2002/05 *	Post Accident Caustic Injection into the Low Pressure Injections System (01-26-81)
CP/2/A/2002/04B	Post Accident Liquid Sampling of the Low Pressure Injection System (12/01/81)
CP/3/A/2002/04B	Post Accident Liquid Sampling of the Low Pressure Injection System (12/01/81)
CP/0/A/2004/2E	Post Accident Determination of Boron Concentration Using Carminic Acid (07/09/82)
CP/0/A/2004/3C	Post Accident Determination of Chloride by Specific Ion Electrode Using Beckman 4500 Meter - (07/09/82)
CP/0/A/2005/2D	Post Accident Determination of Gamma Isotopic Activity (07/09/82)
CP/0/B/4003/01 ·	Procedure for Environmental Surveillance Following a Large Unplanned Release of Gaseous Radioactivity - (12/09/82)
CP/O/B/4003/02	The Determination of Plume Direction and Sector(s) to be Monitored Following a Large Unplanned Release of Gaseous Activity - (10/15/82)
HP/0/B/1009/09	Procedure for Determining the Inplant Airborne Radioiodine Concentration During Accident Conditions - (07/09/81)
HP/O/B/1009/10	Procedure for Quantifying Gaseous Releases Through Steam Relief Valves Under Post- Accident Conditions - (05/06/82)
HP/0/B/1009/11	Projection of Offsite Dose from the Uncon- trolled Release of Radioactive Materials Through a Unit Vent - (12/23/82)
HP/0/B/1009/12	Distribution of Potassium Iodide Tablets in the Event of a Radioiodine Release - (08/13/82)

# Table of Contents (Implementing Procedures - Continued)

HP/O/B/1009/13	Procedure for Implementation and Verification for the Availability of a Back-Up Source of Meteorological Data - (04/23/82)
HP/0/B/1009/14	Project Offsite Dose from Releases other than Through a Vent - (12/20/82)
HP/O/B/1009/15	Procedure for Sampling and Quantifying High Level Gaseous Radioiodine and Particulate Radioactivity - (07/15/82)
HP/O/B/1009/16	Procedure for Emergency Decontamination of Personnel and Vehicles on-site and from Off-site Remote Assembly Area - (9/16/82)
IP/0/B/1601/03	Environmental Equipment Checks - (12/08/82)

# INFORMATION ONLY

Form 34731 (10-81) (Formerly SPD-1002-1)

DUKE POWER COMPANY
PROCEDURE PREPARATION
PROCESS RECORD

(1) ID No: <u>CP/O/B/200</u>3/02 Change(s) 0 to 1 Incorporated

.)	STATION: Oconee Nuclear Station	
)	PROCEDURE TITLE: Estimate of Failed Fuel	Based on I-131 Concentration
)	PREPARED BY: Lent four	DATE: 12-9-82
)	REVIEWED BY: MICHOSE	DATE: 12/10/82
	Cross-Disciplinary Review By:	N/R: Line
)	TEMPORARY APPROVAL (IF NECESSARY):	
	By:(SRO)	Date:
	Зу:	Date:
)	APPROVED BY: Pull There	Date: 12/15/22
)	MISCELLANEOUS:	
(	Reviewed/Approved By: 6. January	Date: 12/9/3_
	Reviewed/Approved By:	Date:

## DUKE POWER COMPANY

#### OCONEE NUCLEAR STATION

# ESTIMATE OF FAILED FUEL BASED ON I-131 CONCENTRATION

# 1.0 Purpose

This procedure describes the method for calculating the number of failed fuel pins and the percent failed fuel for four fuel conditions using the I-131 concentration (in  $\mu\text{Ci/ml}$ ) in the Reactor Coolant System (RCS).

# 2.0 Limits and Precautions

- 2.1 The numbers obtained by using this procedure are at best, estimates only.
- 2.2 All formulas quoted are based upon equilibrium full power core iodine. If fuel damage is suspected to have occurred during times of reduced power or near the time of significant power change, the core I-131 inventory must be adjusted by using Enclosure 10.2. This is the correction factor Y.
- 2.3 All values given are normalized to volumes of coolant at normal reactor coolant system pressure and temperature. To correct for other RCS system temperatures or RCS sample temperatures, use Enclosure 10.1. This is the correction factor X.
- 2.4 The decay of Te-131 to I-131 has been neglected as insignificant in this analysis.
- 2.5 Iodine spiking may occur after a shutdown or significant power change. Data from other nuclear power plants have shown that the iodine spiking process has been observed to occur during a period of 1 to 3 days after the change or shutdown. However, the spike seems to peak during the period from 4 to 8 hours after the change. I-131 concentrations can increase by a factor of 2 to 25 above the equilibrium levels during these times, although an increase over a factor of 10 is unusual and would only be seen at a shutdown. Increases by a factor of 2 to 3 are typical for a significant power decrease (i.e., 100% to 50% power). Do not misinterpret this temporary change for fuel failure if there is no other evidence of fuel damage. Other evidence of fuel damage can be constituted by any indication of inadequate core cooling, loose parts indication, high incore thermocouple indication, etc.

- 2.6 If estimates for fuel failure are needed for fuel conditions other than those covered by the four cases described below, or if more accurate fuel failure data is needed, see Section 7.0 of this procedure.
- 2.7 The following four cases cover a very board range of core conditions. Choose the one that best suits the existing conditions.
- 2.8. Follow up as necessary with Babcock and Wilcox site managers depending on the plant situation.

# 3.0 Case I - Normal Operation

3.1 Initial Conditions

17 4 4 4

11 1/4 1

- 3.1.1 The conditions which pertain to Case I Normal operation are as follows:
  - 3.1.1.1 Normal reactor operation at any power or snutdown with no unusual conditions prior to shutdown.

    Adequate core cooling has been maintained.
- 3.2 Procedure
  - 3.2.1 If 3.1.1 describes the core conditions, use the following formulas to calculate the range of failed fuel values. Evaluate correction factors X and Y by using Enclosures 10.1 and 10.2.
    - 3.2.1.1 (Measured I-131 concentration uCi/ml)(X)(Y) =

3.5 x 10<sup>-3</sup> µCi/ml

- = Number of failed pins (Max. expected and best estimate)
- 3.2.1.2 (Measured I-131 concentration uCi/ml)(X)(Y) =

4.9 x 10<sup>-3</sup> µCi/ml

- = Number of failed pins (Min. expected)
- 3.2.1.3 (Measured I-131 concentration \( \mu \text{Ci/ml} \) (\( \mathbf{X} \) (\( \mathbf{Y} \))

1.8 µCi/ml

- = Percent failed fuel (Max. expected and best estimate)
- 3.2.1.4 (Measured I-131 concentration uCi/ml)(X)(Y) =

2.5 µCi/ml

= Percent failed fuer (Min. expected)

NOTE:

Values for I-131 concentration in  $\mu\text{Ci/ml}$  for Oconee at normal operating conditions are between 1.0 x 10<sup>-3</sup> and 5.0 x 10<sup>-1</sup>  $\mu\text{Ci/ml}$ .

- 4.0 Case II Macroscopic Clad Damage
  - 4.1 Initial Conditions
    - 4.1.1 The conditions which pertain to Case II Macroscopic clad damage are as follows:
      - 4.1.1.1 Normal reactor operation at any power, or shutdown where some mechanical clad failure (i.e., a loose part monitor indication) or a flow induced failure is suspected. The core has adequate cooling and no significant fuel overtemperature is observed.
  - 4.2 Procedure
    - 4.2.1 If 4.1.1 best describes the core conditions, use the following formulas to calculate the range of failed fuel values. Evaluate correction factors X and Y by using Enclosure 10.1 and 10.2.
      - 4.2.1.1 (Measured I-131 concentration uCi/ml)(X)(Y) = 5.5 x  $10^{-2}$  uCi/ml
        - = Number of failed pins (Max. expected)
      - 4.2.1.2 (Measured I-131 concentration  $\mu \text{Ci/ml}$ )(X)(Y) = 16.5 x 10<sup>-2</sup>  $\mu \text{Ci/ml}$ 
        - = Number of failed pins (Best estimate)
      - 4.2.1.3 (Measured I-131 concentration  $\mu \text{Ci/ml}$ ) (Y) = 27.4 x  $10^{-2} \mu \text{Ci/ml}$ 
        - = Number of failed pins (Min. expected)
      - 4.2.1.4 (Measured I-131 concentration  $\mu Ci/ml$ )(X)(Y) =

27.9 μCi/ml

= Percent failed fuel (Max. expected)

4.2.1.5 (Measured I-131 concentration  $\mu\text{Ci/ml}$ )(X)(Y) =

83.7 µCi/ml

= Percent failed fuel (Best estimate)

4.2.1.6 (Measured I-131 concentration  $\mu Ci/m1$ )(X)(Y) =

139.5 µCi/ml

= Percent failed fuel (Min. expected)

- 5.0 Case III Severe Fuel Overtemperature
  - 5.1 Initial Conditions
    - 5.1.1 The conditions which pertain to Case III Severe Fuel Overtemperature are as follows:
      - 5.1.1.1 TMI type accident where there has been an abnormal shutdown and it is suspected that the fuel has been at least partially uncovered for a period of time greater than a few minutes. Voiding in the core is detected by high incore thermocouple readings and loss of margin to saturation. Fuel clad oxidation is detected by excess hydrogen in the containment or in the reactor coolant sample; however, no fuel melting is suspected.
  - 5.2 Procedure
    - 5.2.1 If 5.1.1 best describes the core conditions, use the following formulas to calculate the range of failed fuel values. Evaluate correction factors X and Y by using Enclosures 10.1 and 10.2.
      - 5.2.1.1 (Measured I-131 concentration uCi/mI)(X)(Y) =

2.4 µCi/ml

= Number of failed pins (Max. expected)

5.2.1.2 (Measured I-131 concentration uCi/ml)(X)(Y) =

2.9 µCi/ml

= Number of failed pins (Best estimate)

5.2.1.3 (Measured I-131 concentration uCi/ml)(X)(Y) =

3.2 µCi/ml

= Number of failed pins (Min. expected)

5.2.1.4 (Measured I-131 concentration uCi/ml)(X)(Y) =

1255 µCi/ml

= Percent failed fuel (Max. expected)

5.2.1.5 (Measured I-131 concentration  $\mu Ci/ml$ )(X)(Y) =

1535 µCi/ml

= Percent failed fuel (Best estimate)

5.2.1.6 (Measured I-131 concentration  $\mu$ C1/m1)(X)(Y) =

1675 µCi/ml

= Percent failed fuel (Min. expected)

- 6.0 Case IV Fuel Melting
  - 6.1 Initial Conditions
    - 6.1.1 The conditions which pertain to Case IV Fuel Melting, are as follows:
      - 6.1.1.1 Severe accident where there has been an abnormal shutdown and the core is uncovered for a long period of time. Incore thermocouple temperature readings are above 2300°F for a long period of time. Fuel melting is suspected (i.e., fuel temperature exceeds 5000°F) and is verified by the inability to operate the incore instrumentation system properly.
  - 6.2 Procedure
    - 6.2.1 If 6.1.1 best describes the core conditions, use the following formulas to caluclate the failed fuel values. Evaluate correction factors X and Y by using Enclosures 10.1. and 10.2.
      - 6.2.1.1 (Measured I-131 concentration  $\mu\text{Ci/ml}$ )(X)(Y) =

5.5 µCi/ml

= Number of failed pins (Best estimate)

6.2.1.2 (Measured I-131 concentration  $\mu \text{Ci/ml}$ )(X)(Y) =

2790 µCi/ml

= Percent of failed fuel (Best estimate)

# 7.0 Case V - Other Fuel Conditions

7.1 If fuel conditions other than those described above exist, or if a more detailed failed fuel estimation is desired for either emergency or normal operation, contact the appropriate B&W Site Managers or the Crisis Management Center for assistance.

# 8.0 Data Disposition

. . . . .

- 8.1 When plant conditions dictate that the Technical Support Center (TSC) is not necessary to the Safe Operation of ONS:
  - 8.1.1 Deliver Enclosures 10.4 10.7 to the Station Chemist in the Technical Services Building. Deliver a copy to the Primary Chemistry Supervisor.
- 8.2 When plant conditions, addressed in the Emergency Plan, dictate that the TSC be manned:
  - 8.2.1 Deliver Enclosures 10.4 10.7 to the Station Chemist in the TSC. Deliver a copy of Enclosures 10.4 10.7 to the Power Chemistry Supervisor in the Operational Support Center (OSC).
- 8.3 After completing failed fuel calculations, compare data with the guidelines given in Enclosure 10.8 to determine appropriate Station Emergency Action Level (EAL). Appropriate EAL and supporting data should be recorded in comments section of Enclosures 10.4 - 10.7 and delivered in accordance with 8.1.1 and 8.1.2.

# 9.0 References

- 9.1 Letter of 4/14/82 from R. Michael Glover to C. C. Jennings, Subject: "Failed Fuel Estimating"
- 9.2 ONS Emergency Plan, Section II.D
- 9.3 MNS Administrative Procedure AP/0/A/5500/33
- 9.4 ONS FSAR

#### 10.0 Enclosures

- 10.1 De sity Correction Factor, (X)
- 10.2 Core I-131 Inventory Correction Factor, (Y)
- 10.3 Examples
- 10.4 Failed Fuel Calculations Case I
- 10.5 Failed Fuel Calculations Case II

- 10.6 Failed Fuel Calculations Case III
- 10.7 Failed Fuel Calculations Case IV
- 10.8 Emergency Action Levels

# ENCLOSURE 10.1

# DENSITY CORRECTION FACTOR

(X)

Find the appropriate RC System temperature at the time of accident. Find the approximate temperature at which the RC samples are taken. The intersection of both numbers is the density correction factor, X.

NOTE: Normal RC System sample temperature is approximately 90°F. Use this temperature if no other information is available.

RCS Sample Temperature °F

		80	90	100
	100	.996	.998	1
	150	.983	.985	.987
	200	.966	. 968	.970
	250	.945	.947	.949
200	300	.921	.923	.924
RCS Temperature	350	.894	.895	.897
	400	.862	.864	.865
	450	.827	.828	.830
	500	.787	.788	.790
	550	.739	.740	.741
	560	.728	.729	.731
	570	.717	.718	.719
	580	.706	.708	.708
	590	.693	.694	. 695
	600	.680	.681	.683

## ENCLOSURE 10.2

## CORE I-131 INVENTORY CORRECTION FACTOR

(Y)

# 10.2.1 Situation 1:

Use the following equation to calculate (Y) at power operation (except 0%) where the power level has not changed more than  $\pm$  10% within the last 22 days.

Eq. 10.2.1.1 
$$Y = \frac{100}{PL}$$

Where: Y = the Core I-131 inventory correction factor.

PL = the power level, in %, at the suspected time of fuel failure.

# 10.2.2 Situation 2:

Use the following equation to calculate (Y) at times other than covered by Situation 1 above.

Eq. 10.2.2.1 
$$Y = \frac{100}{(PL_i)(e^{-\lambda t}) + (PL_f)(1-e^{-\lambda t})}$$

Where: Y = the core I-131 inventory correction factor.

PL; = the initial power level before the power change.

 $PL_f$  = the final power level before/at the suspected time of fuel failure

λ = the decay constant for I-131, 0.084 day 1

t = t1 + t2

 $t_1$  = the median time, in days, to make the power change from  $PL_i$  to  $PL_f$ .

t<sub>2</sub> = the time, in days, after the final power level (PL<sub>f</sub>) is reached that the fuel failure is suspected to have occurred.

# Problem 1

- a. Power level has been decreased from 85% to 50%.
- b. This power change took four hours and occurred between 1200 and 1600. Tayon at 50% is 570°F.
- c. At 1800 a loose part monitor alarm goes off indicating a loose object in the core. The reactor is not tripped.
- A Chemistry team is immediately dispatched to take a sample RC System as failed fuel is suspected.
- e. Chemistry sample indicates I-131 concentration is 10.0 μCi/ml.
  - Part 1. Determine the best estimate of the number of failed pins.
  - Part 2. Determine the best estimate of percent failed fuel.

# Solution

This is Case II, Section 4.0

Use equation 4.2.1.2 for Part 1

Use equation 4.2.1.5 for Part 2

Part 1. Measured I-131 concentration  $\mu Ci/ml$  (X)(Y) = Number of failed pins 16.5 x 10<sup>-2</sup>  $\mu Ci/ml$ 

Determine X: Enclosure 10.1

Tavg is 570°F at 50%. Assume RCS Sample Temperature is 90°F Therefore, X = .718

Determine Y: Enclosure 10.2

$$\lambda_{I} = .0864 \text{ day}^{-1}$$

$$t = \frac{(4)}{2} + (2) = 4 \text{ hours}$$

Remember, t is the median time to make a power change plus the difference between the time when the damage is suspected and the time the new power level is reached.

Convert t to days t = 4 hours  $x = \frac{1 \text{ day}}{24 \text{ hrs.}} = .167 \text{ days}$ 

$$Y = \frac{100}{(85)e^{-(.0864 \text{ day}^{-1})(.167 \text{ day})} + (50) 1-e^{-(.0864 \text{ day}^{-1})(.167 \text{ day})}}$$

$$Y = \frac{100}{(85)(.9857) + (50)(.0143)} = 1.183$$

Part 1. 
$$\frac{10 \ \mu\text{Ci/ml}}{16.5 \ x \ 10^{-2} \ \mu\text{Ci/ml}}$$
 (.718) (1.183) = 51.5  $\cong$  52 failed pins Answer

Part 2. Measured I-131 Concentration 
$$\mu$$
Ci/ml (X)(Y) = % failed fuel 83.7  $\mu$ Ci/ml

$$\frac{10 \text{ } \mu\text{Ci/ml}}{83.7 \text{ } \mu\text{Ci/ml}}$$
 (.718) (1.183) = 0.1% failed fuel

Answer

# Problem 2

- a. The reactor has just tripped instantly from 100% power due to a malfunctioning instrument. There were no unusual conditions prior to the trip.
- b. Taug is now 557°F at 0% power.
- c. The operator, while having no reason to suspect failed fuel, is curious about the amount of failed fuel present now following the trip.
- d. A Chemistry team is sent to take an RC sample 12 hours after the trip.
- e. The Chemistry sample gives an I-131 concentration of 2.0 x 10<sup>-2</sup> μCi/ml. (A typical value for a normally operating plant. See Note under Case I, Section 3.0)
- f. Chemistry personnel also indicate that RC sample temperature is 100°F.
  - Part 1. Determine the maximum expected number of failed fuel pins.
  - Part 2. Determine the maximum expected percent failed fuel in the core.

# Solution

This is Case I, Section 3.0

Use equation 3.2.1.1 for Part 1

Use equation 3.2.1.3 for Part 2

Part 1. Measured I-131 concentration  $\mu Ci/ml$  (X)(Y) = Number of failed pins 3.5 x  $10^{-3} \mu Ci/ml$ 

Determine X: Enclosure 10.1

RC Temperature is  $557^{\circ}F$  at 0% RC sample temperature is  $100^{\circ}F$  Therefore,  $X \cong .732$ 

Determine Y: Enclosure 10.2 Situation 2: t = 12 hours  $\times \frac{1 \text{ day}}{24 \text{ hrs.}} = .5 \text{ days}$ 

$$Y = \frac{100}{(100) e^{-(.0864) (.5)} + (0) 1 - e^{-(.0864) (.5)}}$$

Y = 1.044

NOTE: If t = 0 or a sample was taken immediately, Y = 1.0.

Part 1.  $\frac{2.0 \times 10^{-2} \text{ µCi/ml}}{3.5 \times 10^{-3} \text{ µCi/ml}}$  (.732)(1.044) = 4.4

or ≅ 4 to 5 failed pins

Answer

Part 2. Measured I-131 Concentration uCi/ml (X)(Y) = % failed fuel

 $\frac{2.0 \times 10^{-2} \text{ uCi/ml}}{1.8 \text{ µCi/ml}}$  (.732) (1.044) = .0085 % failed fuel

The above numbers are indicative of normal operation.

Answer

NOTE: I-131 spiking may be a problem here. See Section 2.5.

# Problem 3

- a. Power level has been between 50% and 65% for the last 30 days and is presently at 60% at 1800.
- b. TAVG is ≅ 575°F at 60% power.
- c. It is desired to see if any significant failed fuel exists in the core even though no abnormal occurrences have taken place.
- d. At 2200 the same day, a Chemistry sample is taken of the RC system.
- e. The Chemistry sample indicates I-131 concentration is 3.9 x 10<sup>-2</sup> μCi/ml.
  - Part 1. Determine the best estimate of the number of failed pins.
  - Part 2. Determine the best estimate of the % failed fuel.

# Solution

This is Case I, Section 3.0

Use equation 3.2.1.1 for Part 1

Use equation 3.2.1.3 for Part 2

Part 1. Measured I-131 concentration  $\mu Ci/ml$  (X)(Y) = Number of failed pins 3.5 x  $10^{-3} \mu Ci/ml$ 

Determine X: Enclosure 10.1

TAVG is 575°F at 60% power Assure RCS sample temp. of 90°F Therefore, X ≅ .713

Determine Y: Enclosure 10.2

Situation 1

$$Y = \frac{100}{60} = 1.67$$

Part 1. 
$$\frac{3.9 \times 10^{-2} \text{ µCi/ml}}{3.5 \times 10^{-3} \text{ µCi/ml}}$$
 (.713)(1.67) = 13.27

≅ 14 failed pins Answer

Part 2. Measured I-131 Concentration  $\mu Ci/ml$  (X)(Y) = % failed fuel

 $\frac{3.9 \times 10^{-2} \, \mu \text{Ci/ml}}{1.8 \, \mu \text{Ci/ml}} \, (.713)(1.67) = .026\% \, \text{failed fuel}$ 

Answer

The above numbers are acceptable for a normally operating plant.

# Problem 4

- a. The unit has been at 97% power for a month when a depressurization of the RC system occurs.
- b. The reactor trips.
- c. Heavy vibration is observed in the RC pumps.
- d. Thermocouple temperatures over 1000°F are indicated in the core.
- e. High Pressure Injection was delayed and it is suspected the core was uncovered between 30 and 60 minutes before sufficient reactor vessel water level was regained.
- f. The incore instrumentation system is still operable.
- g. The RC sample indicates an I-131 concentration of 3800 μCi/ml.
- h. A Chemistry sample is taken immediately (within the hour) after the trip.
  - Part 1. Determine the maximum expected number of failed pins.
  - Part 2. Determine the maximum expected % of failed fuel.

## Solution

This is Case III, Section 5.0

Use equation 5.2.1.1 for Part 1

Use equation 5.2.1.4 for Part 2

Determine X: Enclosure 10.1

RC Temp.  $T_{AVG}$  at 0% power is 557°F Assume sample temperature of 90°F Therefore,  $X \cong .730$ 

Determine Y: Enclosure 10.2

 $Y = \frac{100}{97} = 1.03$ 

Part 1.  $\frac{3800 \text{ µCi/ml}}{2.4 \text{ µCi/ml}}$  (.730)(1.03) = 1190.5  $\cong$  1191 number failed pins, max. expected Answer

Part 2.  $\frac{3800 \text{ uCi/ml}}{1255 \text{ µCi/ml}}$  (.730)(1.03) = 2.28% failed fuel, max. expected Answer

# ENCLOSURE 10.4

# FAILED FUEL CALCULATIONS

CASE I

UNIT DATE	/TIME	BY	
X =	Y =	I-131	_µCi/ml
Maximum Number of Failed	Fuel Pins (Best Estimate	):	
3.5 E-3 ( ) ( )	•		
Minimum Number of Failed	Fuel Pins:		
4.9 E-3 ( ) ( )			
Maximum % Failed Fuel (B	est Estimate):		
1.3	= 0/		
Minimum % Failed Fuel:			
2.5 ( ) ( )	= %		
COMMENTS:			

Reviewed By\_\_\_\_\_

# ENCLOSURE 10.5

# FAILED FUEL CALCULATIONS

CASE II

UNIT	DATE/TIME		BY	
x =	Y =		I-131	uCi/ml
Maximum Number	of Failed Fuel Pi	ns:		
5.5 E-2 (	) ( ) =			
Best Estimate o	f Failed Fuel Pin	s:		
1.65 E-1	) ( ) =			
Minimum Number	of Failed Fuel Pi	ns:		
2.74 E-1 (	) ( ) =			
Maximum % Faile				
27.9 (	) ( ) =	0/		
Best Estimate F	Tailed Fuel:			
83.7 (	) ( ) =	%		
Minimum % Faile	ed Fuel:			
139.5	) ( ) =	%		
COMMENTS:				
			Reviewed By	

Reviewed By\_\_\_\_

# ENCLOSURE 10.6

# FAILED FUEL CALCULATIONS

CASE III

UNIT	DATE/TIME		BY	
x =	Y =	<u> </u>	I-131	µCi/ml
Maximum Number o	Failed Fuel Pins			
2.4 ( )	( ) =			
Best Estimate of	Failed Fuel Pins:			
2.9	( ) =			
	f Failed Fuel Pins	:		
3.2 ( )	( ) =			
Maximum % Failed				
1255 ( )	( ) =	%		
Best Estimate Fa	iled Fue:			
1535 ( )	( ) =	%		
Minimum % Failed	Fuel:			
10/3	( ) =	oy 70		
COMMENTS:				

# ENCLOSURE 10.7

# FAILED FUEL CALCULATIONS

CASE IV

UNIT	DATE/TIME		ВҮ	
X =	Υ =		I-131	µCi/ml
Best Estimate	of Failed Fuel Pins:			
5.5	) ( ) =			
Best Estimate	of % Failed Fuel:			
2790 (	) ( ) =	%		
COMMENTS:				

Reviewed By\_\_\_\_\_

#### ENCLOSURE 10.8

#### EMERGENCY ACTION LEVELS

(EAL)

Following reactor coolant sampling and completion of the failed fuel calculations, compare I-131 concentrations or percent failed fuel with the following guidelines to determine the appropriate Station Emergency Action Level. Appropriate action level should be highest applicable EAL.

## 1.0 Unusual Event

1.1 Initial indicator is high reactor coolant activity; total activity >  $\underline{224}$  .

Ē

- 1.2 Suspected damage mechanism is mechanical clad failure or flow induced failure.
  - 1.2.1 I-131 concentration in reactor coolant in range of 70 µCi/ml to 350 µCi/ml.

## 2.0 Alert

2.1 Initial indicator is very high reactor coolant activity; total activity >> 224.

Ē

- 2.2 Suspected damage mechanism is mechanical clad failure or flow induced failure.
  - 2.2.1 Total failed fuel exceeds 5%, but less than 25%.
  - 2.2.2 I-131 concentration between 350 and 1770 µCi/ml.

## 3.0 Site Area Emergency

- 3.1 Initially suspected degraded core with possible loss of coolable geometry.
- 3.2 Substantial mechanical clad failure or flow induced failure with total failed fuel > 25%.
  - 3.2.1 I-131 concentration from 1770 to 7000  $\mu$ Ci/ml (7000  $\mu$ Ci/ml equivalent to 100% failure under this damage mechanism).
- 3.3 Substantial damage to clad from severe fuel over temperature (fuel clad oxidation evident from excess hydrogen in containment or reactor coolant, no fuel melt suspected).
  - 3.3.1 I-131 concentration from 1300 to 13,000 µCi/ml (1% to 10% fuel failure under this damage mechanism).

- 3.4 Substantial damage to fuel and clad from fuel melt conditions (incore thermocouple > 2300°F for period of time; fuel temperature > 5000°F).
  - 3.4.1 I-131 concentration from 1180 to 11,800 µCi/ml (0.5% to 5% failed fuel under this damage mechanism).

## 4.0 General Emergency

- 4.1 Initially loss of cladding and primary coolant boundary with potential loss of containment.
- 4.2 Substantial damage to clad from severe fuel overtemperature (fuel clad oxidation evident from excess hydrogen in containment or reactor coolant, no fuel melt suspected).
  - 4.2.1 I-131 concentration > 13,000  $\mu$ Ci/ml (> 10% fuel failure under this mechanism).
- 4.3 Substantial damage to fuel and clad from fuel melt (severe accident where core is uncovered for a period of time and incore temperature > 2300°F for long period; fuel melt suspected by fuel temperature > 5000°F and verified by inoperable incore instrumentation.
  - 4.3.1 I-131 concentration > 11,800 μCi/ml, for this damage mechanism failed fuel > 5%.

C. Gennings

Form SPD-1002-1

# CONTROL COPY INFORMATION ONLY

DUKE POWER COMPANY PROCEDURE PREPARATION PROCESS RECORD (1) ID No: HP/O/B/1009/14
Change(s) 2 to
N/A Incorporated

(2)	STATION: Oconee	
(3)	PROCEDURE TITLE: Projection of Offsite Do	se From Releases Other Than
	Through The Unit Vent	
(4)	PREPARED BY: Sorah A. Coy	DATE: 12-15-82 .
(5)	REVIEWED BY: CT Yours /De Daniel	DATE: 12-17-82
	Cross-Disciplinary Review By:	
(6)	TEMPORARY APPROVAL (IF NECESSARY):	
	By:(SRO)	Date:
	Ву:	Date:
(7)	APPROVED BY: 10mg B. Ohu	Date: 12/20/82
(8)	MISCELLANEOUS:	
	Reviewed/Approved By:	Date:
	Paul mod / Approved But	Datas

#### DUKE POWER COMPANY

#### OCONEE NUCLEAR STATION

#### PROJECTION OF OFF-SITE DOSE FROM RELEASES

#### OTHER THAN THROUGH THE UNIT VENT

# 1.0 Purpose

This procedure should be used for projecting dose commitment from a noble gas or iodine release, other than a unit vent release, during an emergency.

# 2.0 References

- 2.1 Reg Guide 1.109
- 2.2 Reg Guide 1.4
- 2.3 HP/0/B/1009/13, Procedure for Implementation and Verification for the Availability of a Backup Source of Meteorological Data.

## 3.0 Limits and Precautions

- 3.1 It is assumed that a small percentage of the total containment inventory of iodine is released. The iodine whole body dose from a release is very small compared to the iodine thyroid dose. Thus, iodine whole body dose is not considered here.
- 3.2 This procedure applies to releases made from Oconee Nuclear Station only. Many of the values contained in this procedure are site specific.
- 3.3 This procedure considers all releases to be ground level releases.
- 3.4 Enclosure 5.6 should be done in conjuction with the Field Monitoring Coordinator.
- 3.5 Meteorology data needed to calculate offsite dose should be obtained as required by Enclosure 5.1. Data not available from the primary source should be obtained from the backup source. The order of preference for each data point is listed each place meteorological data is required. All meteorology data obtained from the tower or river must be a 15 minute average. National Weather Service (NWS) data is a standard observation and is not a 15 minute average.
  - 3.5.1 Every 15 minutes the wind direction and wind speed will be rechecked in accordance with Enclosure 5.1 to ensure additional sectors have not been affected. Once a sector

has been determined to be affected, it cannot be removed from the list of affected sectors.

3.5.2 The following are conversion formulas for the meteorological data obtained from the National Weather Service:

mph = 1.15 (knots)

 $^{\circ}F = (9/5 ^{\circ}C) + 32$ 

## 4.0 Procedure

4.1 Acquire the following information and record on Enclosure 5.1.

NOTE: The sources of meteorological data are listed in order of preference on Enclosure 5.1.

- 4.1.1 Reactor Unit, date and time of reactor trip.
- 4.1.2 Wind speed (mph).
- 4.1.3 Wind direction in degrees from North (North = 0°).
- 4.1.4 Temperature gradient (ΔT°F).
- 4.1.5 Radiation Monitor reading (R/hr) calculated per Enclosure 5.2.
- 4.1.6 Present date and time.
- 4.1.7 Time meteorology data determined.
- 4.2 Determine the Containment Bui'ding leakage rate (LR) and record it on Enclosure 5.1.
  - 4.2.1 LR is the total leak rate for the containment which is:
    - a) a "best guess" assumption,
    - assumed to be the design leak rate (see note below),
       or
    - c) the measured leak rate where suitable means are available.

Record the leak rate onto Enclosure 5.1.

NOTE: The design leakage rate (LR<sub>DLR</sub>) is determined by,

LR<sub>DLR</sub> = Containment Volume · Design Leak Constant =  $(5.38 \times 10^{10} \text{ ml}) \cdot (\frac{0.0025}{\text{day}}) \cdot \frac{\text{day}}{24 \text{ hr}}$ =  $5.6 \times 10^6 \text{ ml/hr}$  4.3 Determine the X/Q values for each point of interest downwind.

If no points have been requested, use the 1, 2, 5 and 10 mile values.

- 4.3.1 Locate the relative two-hour downwind concentration value (CH) for each point from Enclosure 5.3 and record onto Enclosure 5.1.
- 4.3.2 Convert these values to X/Q by,

$$X/Q = \frac{CH (MPH-Sec/m^3)}{Wind Speed (MPH)}$$

Record X/Q values onto Enclosure 5.1.

- 4.4 Determine the potential whole body dose from submersion in a cloud of noble gas.
  - 4.4.1 Calculate the whole body two (2) hour dose commitment,

$$D_{WB} = DR_{M} \cdot DC \cdot LR \cdot X/Q \cdot U_{NG}$$

Where,

Dwg = Whole body two (2) hour dose commitment

DR = Monitor dose rate (see Encl. 5.2)

DC = Average Decay constant for noble gases =

LR = containment leakage rate in ml/hr-

X/Q = dispersion factor in  $sec/m^3$ 

$$U_{NG} = \frac{(3.74d/sec \cdot uCi)(1.6E-6ergs/MeV)}{2 (100 ergs/g-rad)(1.2E-3g/cm3)(1E6cm3/m3)}$$

Record results on Enclosure 5.1

- 4.5 Determine the potential thyroid dose from uptake of radioiodine.
  - 4.5.1 Locate the time plus one (1) hour after trip on Enclosure 5.5 and record the corresponding Decay Constant on Enclosure 5.1

4.5.2 Calculate a child's thyroid two (2) hour dose commitment using time plus one (1) hour,

DR = DR . DC . LR . X/Q . UI

Where,

DR, = thyroid two (2) hour dose commitment

DR = monitor dose rate (see Encl. 5.2)

DC = Decay Constant in  $\frac{\mu Ci \cdot mrem \cdot hr^2}{ml \cdot pCi \cdot R}$  for time plus

one (1) hour (see Enclosure 5.5)

LR = Leak rate in ml/hr

X/Q = dispersion in sec/m<sup>3</sup>

UI = breathing rate for child

$$(1.17E-4m^3/sec)(1E3 \frac{pCi-rem}{uCi-mrem}) = 1.17E-1$$

#### Record results on Enclosure 5.1

- 4.6 Calculate an adult's thyroid dose by dividing the child's dose by two (2). Report results of all calculations on Enclosure 5.7.
- 4.7 Determine the potentially affected area using Enclosure 5.5. Record sectors on Enclosure 5.7.
- 4.3 Complete Enclosure 5.7 with information from Enclosure 5.1 and submit it to the Offsite Radiological Coordinator or his designee. Include any comments pertinent to the evaluation of offsite hazards.

#### 5.0 Enclosures

- 5.1 Projected Offsite Dose Released from Containment
- 5.2 Survey Instrument Correlation
- 5.3 Table of Two Hour Relative Concentration Factors
- 5.4 Table of Noble Decay Constant (DC)
- 5.5 Table of Todine and Noble Decay Constant (DC)
- 5.6 Evaluation of Plume Location
- 5.7 Dose Assessment Report

Da	vtime - 100	0-1600 hrs.	(Ci	rele sour	ce of data fo	r each point)
					ce of data to	r each point;
•	15 min. per:	lod ending	time			
_			_			
-	Wind Direct:	on (degree	s)			
	Sources	1) Tower	(T)			
		2) River 3) NWS				
T		T	(11)	T	7	
R		R		R	T R	
7.	;	й	;	N	; и	
	71 (°F)					
		1) Tower	(T)			
		2) Assume	(A)	-0.4°F		
I A						
•						
- %	Find Speed (					
	Sources	1) Tower				
		2) River 3) NWS	(R) (Y)			
7		T .	(-1)	T	T	
2		2		2	R	
7 -	;	.,	;	74	;	
Niz	htime - 160	0-1000 hrs.	(Ci	rele sour	en of tare to	r each point)
				1011	ce of data to	r each point)
- 1	5 min. peri	od ending t	ime			
		-	-			

- W							
		on (degree 1) Tower					
	Judices	2) Assume		between (	- 3609		
T		T	,,	T			T
A _	;	A		; A		_;	A
- 1	(35)						
-		1) Tower	(T)				
		2) Assume	(A)	+1.0°F			
T							
A _							
- W	ind Speed (	mph)					
		1) Tower	(T)				
		2) Assume					
T		T		I			T
A	;	A		; A		_;	A
- 7, E -	(°F)	1) +1.0°F			—'		
	Source	1) +1.0 2	(2)				
Ε	The state of the s						
	ind Speed (	mnin)					
	ind Speed (	mph) 1) 1 mph	(E)				
- ¥		1) 1 mph		Ε	;	· _	
- ¥	Source	1) 1 mph E	;	E		E	
- ¥	Source	1) 1 mph E BUIL	; DING		14 7	Ē	
E _	Source;	E BUIL  by complet	DING	ither ste	paor		
E _	Source; ermine DR <sub>m</sub> Containme	E BUIL  by complet	DING ing e	ither ste	p a or	_	R/hr
E Dec	Source; ermine DR <sub>m</sub> Containme	1) 1 mph E  BUIL  by complet  nt high rai	DING ing e	ither ste	paor RIA#_		
E Dec	Source ; ermine DR Containme DR Survey in	BUILD by completent high ran	DING ing e	ither ste	paor RIA #_		
E Dec	Source ; ermine DR Containme DR Survey in	BUILD by completent high ran	DING ing e	ither ste	paor RIA #_		
E Det	Source ; ermine DR Containme DR Survey in a) read b) corr	1) 1 mph E  BUIL  by complet  nt high rai	DING ing e	ither ste	paor RIA #	nclos	
- W E Det A)	Source ; ermine DR Containme DR Survey in a) read b) corr	BUILD by complete  nt high ran  strument #  ing elation va	ing e	ither ste	paor RIA #	nclos	R/hr ure 5.2)

# DOSE CALCULATION

1)	14%		dr (Design basis	TX = 2.050 mI/DT]
2)	CH @		, X/Q =	sec/m <sup>3</sup>
	CH @mi.	=	, X/Q =	sec/m <sup>3</sup>
	CH @mi	=	, X/Q =	sec/m³
	CH @mi		, X/Q =	sec/m <sup>3</sup>
	A. Whole Bo	dy 2 hr. dose	e projection from	noble gases:
	by DwB = DRM	· 1.5448E-2	· LR · X/Q · 2.5E	-7,
	Miles Out		D <sub>wB</sub> 2	hr Dose Commitment
3.	Thyroid 2 hr.	dose project	ion from iodine:	
	DC (for t + 1	hr.)		
	by DR = DR	· DC · LR · S	1/Q · (1.17E-1),	
	W41 Oue	DR_ 2	hr Dose Commitme	ent
	Miles Out			
	4			

# DEFINITIONS

Dun - whole body 2 hour dose commitment

DR, - thyroid 2 hr dose commitment from iodine

LR - containment leakage rate

LR DLR - Design leak rate (5.6 E6ml/hr)

X/Q - "Chi over Q" is downwind concentration correction factor

CH - 2 hr. relative downwind concentration - MPH (X/Q - MPH)

DC - Decay constant

#### HP/0/3/1009/14 Proposed

#### SURVEY INSTRUMENT CORRELATION

Presently, Oconee does not have a high range monitor installed to evaluate the conditions of an airborne release inside the containment. Therefore, the following equation should be used to determine the dose rate:


DR monitor = DR survey · Correlation Value

where:

The correlation value is determined by using the graph on the following page.

DR survey is taken from the 6th floor inside the Auxiliary Building, 1 foot from the reactor wall and 4 feet from the floor.

HP/0/8/1009/14
ENCLOSURE 5.2
SURVEY INSTRUMENT CORRELATION CURVE
TIME VS. CORRELATION FACTOR



TIME (HRS. AFTER TRIP)

Enclos. 5.3

Table of Two-Hour Relative Concentration Factors

Temperature Difference	Distance (Miles)									
Δ1°F	1	2	3	4	5	6	7	8	9	10
-25.0 to -1.3	1.5E-6	9.48 7	5.46-7	4.0E-7	3.42-7	2.9£-7	2.5E-7	2.26-7	2.06-7	1.8E-7
-1.2 to -1.0	5.86-5	1.68-5	8.1E-6	4.9E-6	3.4E-6	2.5€-6	1.9E-6	1.5E-6	1 . 2E-6	1.0E-6
-0.9 to -0.4	1.5E-4	5.66-5	3.1E-5	2.1E-5	1.56-5	1.2£-5	7.6E-6	7.88-6	6.7E-6	5.8E-6
-0.3 to 10.9	2.9E-4	1.2E-4	6.7E-5	4.95-5	3.4E-5	2.7E-5	2.2E-5	1.9E-5	1.6E-5	1.46-5
11.0 to 125.0	6.4E-4	3.16-4	1.8E-4	1°, 3E-4	9.5E-5	7.3E-5	6.1E-5	5.0E-5	4.3E-5	3.6E-5

HP/0/8/1009/14

HP/0/8/1009/14

ENCLOSURE 5.4 RP/0/3/1009/14 NOGLE CECAY CONSTANT(CC)

1	144444444444444444444444444444444444444	101
10	i	1 1
0	THE STATE OF THE PROPERTY OF T	1 7
α		1 -2
FOL	1	1-0-
		10
18	ાં છે.	100
	1 92 per 19 20 per 19 p	318
1 7	To det umpett ampett annert annert annert annert annert annert an automorphism	D M
		1 (1)
		79
14		n err
		9 10
	I with a model a	רא ח
11		
		3
1 X	1 1 km n c admir h n n k 1 m k 5 b a d d d d d d d d n n n e k 1 m n y 6 0 0 0 ((d C k k k m n m m n m m n m n n n n n n n n	100
1 ;		193
	adadadaanaadadadadadadanigaanaadaaaaaaaaaa	
		1111
		110
	11111111111111111111111111111111111111	
1 ::		115

# Enclosure 5.5 RF/0/3/1009/14

# OCCNEE MUCLEAR STATION

ICDINE & MORLE DECAY CONSTANTION 0 - 498 HRS

	HOUR	30	Hone	00	наца	e cc	HOUR	2 95	HCUP	e ac
	0	1.2309E-05	100	5.6493E-05	200	6.7575E-05	300	6.0263E-05	90.1	<b>5.</b> €3333 <b>E-</b> 333
	2	2.72925-05	102	6.4525E-05	202	4.7591E-05	302	6.82755-05	402	5.38155-05
	4	3.4986E-95	104	4 JEZE-05	204	6.76075-05	304	5.0297E-05	404	6.8824E-05
	5	4.0303E-05	106	6.6588E-05	206	6.75225-05	306	6.0298E-05	400	6.88345-15
	9	4.5033E-05	108	5-6619E-95	208	6.7438E-05		-6.8310E-05	408	6.89445-05
	10	4.85225-05	110	6.5648E-05	210	6.7453E-05	310	5.8322E-05	410	4.88E3E-05
	12	5.1300E-05	112	6.6677E-05	212	6.7569E-05	312	6.8334E-05	412	6.8053E-05
	14	5.3531E-05	114	6.4705E-05	214	6.7684E-05	314	5.8346E-05	414	4.8872E-05
	.6	5.5344E-05	116	4.4732E-0	215	5.7699E-05	314	4.8357E-05	416	6.5882E-05
	13	5.0834E-05	.13	6.4759E-05	218	6.7714E-05	318	4.8349E-05	413	4.88912-05
	20	5.8073E-09	1.20	6.6736E-05	220	6.77295-05	320	6.3331E-05	420	5.8901E-05
	2:2	5.9115E-05	122	6.4811E-05	222	6.7744E-05	322	4.8392E-05	422	6.8910E-05
	24	5.9999E-05	124	5.6837E-05	224	6.7758E-05	324	6.3403E-05	124	6.8919E-05
	26	5.0754E-05	125	6.4861E-05	225	6.7773E-05	323	4.8415E-05	426	6.39298-05
	28	6.1403E-05	128	4.6886E-05	228	6.7798E-05	328	6.3424E-05	128	5.8908E-05
	30	6.1963E-05	130	6.4910E-05	220	6.7802E-05	330	4.8438E-05	430	6.89 17E-05
	32	4.2448E-05	132	4.4733E-05	232	6.7814E-05	332	6.8949E-05	132	5.3956E-05
	34	6.2371E-05	134	4.4954E-05	234	6.7931E-05	334	6.3460E-05	434	6.8965E-05
	34	6.3290E-05	136	4-6979E05	230	4.7845E-05	226	4.3471E-05	100	
	30	4.0540E-05	138	5.7001E-05	238	4.7359E-05	328	4.84825-05	136	5.8974E-0E
	40	5.0046E-05	140	6.7023E-05	240	6.7873E-95	340	6.3493E-05	438	6.6993E-15
	42	6.4097E-05	142	6.7045E-05	242	5.7987E-05	342	4.8504E-05	440	6.8773
	:1.1	5.4010E-05	1 44	4.7056E-05	294	6.7901E-05	344		442	6.900Z_ 3
	46	6.451SE-05	146	6.7088E-05	246	6.791SE-05	346	4.0515E-05	242	6.9010E-05
	ch (Z	6.4699E-05	148	5.710GE-05	240	5.7929E-05	349	6.8537E-05		3.90194-05
	50	6.48-71-05	150	3.7129E-05	250	3.79421-05	350	6.8548E-05	448	4.9078E-05
	52	4.4788E-45	152	5.7149E-05	252	3.775JE-05	CEE	.3559E-05	452	±.9007E-05
	34	6.51142-05	154	5.7139E-05	254	5.7969E-05	354	6.8570E-05	454	3.9046E-05
	53	4.5222E-05	136	6.7139E-05	256	6.7783E-05	3150	6.8E80E-05		3.70CEE-05
	53	5.5537E-05	153	4.7208E-05	258	6.7996E-05	358	4.85712-05	458	6.70s+E-05
	60	5.5434E-05	160	5.7228E-05	250	5.8010E-05	350	6.3602E-05		6.907211-05
	62	4.53225-05	162	5.7247E-05	252	6.802DE-05	302	5.861.2E-05	160	6.900111-05
_	5.4	3.5504E-05	164	5.725E-05	254	4.3034E-05	364	6.3622E-05	402	6.70708-05
	పద	5. ZAEOE-05	166	6.7284E-05	250	5.3049E-05	366	6.8633E-95	464	6.90VBE-05
	40	3.5751E-05	168	4.7302E-05	248	6.806ZE-05	348	6.35++E-0E	400	6.9107E-05
	70	6.58175-05	170	6.7321E-05	777	5.8075E-05	270		468	5.9115E-05
	72	3.3879E-05	172	6.7339E-05			372	5.86545-35	4770	3.91240-05
	74	6.3907E-05		5.7357E-05		5.8101E-05		6.3664E-35		
		5.5792E-05		6.7374E-05		6.S114E-05				
		6.404EE-05		6.7392E-05		5.8125E-05		6.8685E-05		
		6.4094E-05		6.7409E-05		6.8139E-05		6.849SE-03		
		5.51425-05		6.7426E-05				5.8705E-05	and the same	
		6.6187E-05	100	6.7444E-05				Control of the Contro	and the second	6.7174E-05
		5.5220E-05		6.7460E-05		6.2177E-05				6.9133E-05
		6.6272E-05		6.74775-05					-95	4.91915-05
		6.63125-05		5.7494E-05		6.8202E-05		6.9746E-95		
	92		192	6.7510E-05				The second secon		₫.9207E-05
		3. a000E-05	194	6.7527E-05						s.721%F
		a.4424E-03	100	6.7540E-05	275			6.87755-05		5.92246
		5.5-E9E-15		6.7559E-05	273	6.8208E-05	396	6.3705E-05	-19.5	5.7222E-63
	_	2.0 0/4-00		3.1 20.72-32	147 4	0.01011-10	7,013	6.8795E-05	70.0	6.9140E-35

#### HP/0/B/1009/14 Proposed

#### EVALUATION OF PLUME LOCATION

- Acquire the following information from Enclosure 5.1 and record on Enclosure 5.7.
  - a) Meteorological Data identify for each point whether data is assumed (A), experiment (E), or measured (T, R or N).
  - b) Thyroid and whole body dose
- 2. Protective action guides submitted to the Offsite Radiological Coordinator are to be made based on the calculated dose on Enclosure 5.1 and the following information.
  - A) For doses:
    - > 5 Rem Whole Body or,
    - > 25 Rem Thyroid

Recommend Evacuation of Population in Affected Area.

3) For doses:

1-5 Rem Whole Body or,

5-25 Rem Thyroid

Recommend evacuation of children and pregnant women, and sheltering of remainder of personnel in the affected area.

- C) For doses:
  - < 1 Rem Whole Body or,
  - < 5 Rem Thyroid

Recommend no action.

- To determine sectors affected, complete one of the options under A or 3
  using meterological data from Enclosure 5.1. Record the sectors affected
  on Enclosure 5.7.
  - A. Daytime (1000-1600 hrs.)
    - Wind speed > 5 mph for tower or river wind direction, use Table 1.

#### HP/0/B/1009/14 Proposed

#### EVALUATION OF PLUME LOCATION

- 2) Wind speed > 5 mph for NWS wind direction, use Table 2.
- 3) Wind speed < 5 mph for tower or river wind direction, assume sector: Al, Bl, Cl, Dl, El, and Fl are affected. Then use Table 1 to determine additional sectors affected.
- Wind speed < 5 mph for NWS wind direction, assume all sectors are affected (Al through F1, A2 through F2).
- B. Nightime (1600 1000 hrs.)

(If river wind direction is unavailable, assume 70° - 210°).

- If river wind direction is between 210° 70°, use Option A (Daytime).
- 2) If river wind direction is between 70° 210°, assume all sectors affected (Al through F1, A2 through F2).

# EP/0/3/1009/14 Proposed

# EVALUATION OF PLUME LOCATION

# TABLE 1

Wind Direction	Sectors Affected	
14°-27°	C1, C2, D1, D2, E1, E2	
27°-42°	C1, D1, D2, E1, E2	
42°-66°	D1, D2, E1, E2	
66°-85°	D1, D2, E1, E2, F2	
35°-104°	D1, D2, E1, E2, F1, F2	
10%°-129°	E1, E2, F1, F2	
129°-156°	A1, A2, E1, E2, F1, F2	
156°-175°	A1, A2, E1, F1, F2	
175°-181°	A1, A2, F1, F2	
181°-219°	A1, A2, B1, B2, F1, F2	
219°-255°	A1, A2, B1, B2	
255°-271°	A1, A2, B1, B2, C1, C2	
271°-297°	31, 32, C1, C2	
297°-312°	B1, B2, C1, C2, D2	
312°-345°	31, 32, C1, C2, D1, D2	
345°-14°	C1, C2, D1, D2	

# HP/0/B/1009/14 Proposed

# EVALUATION OF PLUME LOCATION

# TABLE 2

Wind Direction	Sectors Affected
1°-39°	B1, B2, C1, C2, E1, E2, F1, F2
39°-75°	Al through F1, A2 through F2
75°-91°	A1, A2, C1, C2, D1, D2, E1, E2, F1, F2
91°-117°	Al through F1, A2 through F2
117°-132°	A1, A2, B1, B2, C1, D1, D2, E1, E2, F1, F2
132°-165°	A1, A2, B1, B2, D1, D2, E1, E2, F1, F2
165°-194°	Al through F1, A2 through F2
194°-207°	A1, A2, B1, B2, C1, C2, E1, E2, F1, F2
2079-2229	A1, A2, B1, B2, C1, C2, D2, E1, E2, F1, F2
2229-2469	Al through F1, A2 through F2
246°-265°	A1, A2, B1, B2, C1, C2, D1, D2, E1, F1, F2
265°-284°	A1, A0, B1, B2, C1, C2, D1, D2, F1, F2
284°+309°	Al through F1, A2 through F2
309°-336°	A1, A2, B1, B2, C1, C2, D1, D2, E1, E2
336°-355°	A1, A2, B1, B2, C1, C2, D1, D2, E1, E2, F2
355°-1°	Al through Fl. A2 through F2

# HP/0/B/1009/14 Proposed

# EVALUATION OF PLUME LOCATION

4. Determine Stability Class by completing step (a) below and record on Enclosure 5.7.

a)	ΔΤ	Stability	Class
	-8 to-1.3	A	
	-1.2 to -1.0	C	
	-0.9 to -0.4	D	
	-0.3 to +0.9	Ξ	
	+1.0 to +8	F	

# DOSE ASSESSMENT REPORT

# HP/0/B/1009/14 Proposed

DATE:				
TIME:				
DOSE ASSESSOR:				
WIND DIRECTION		SOURCE _		
WIND SPEED		MPH SOURCE _		
71	°F/120 ft SO	URCE		
STABILITY CLASS	<u> </u>			
DISTANCE TR	TYROID/ADULT	THYROID/CHILD	WHOLE BODY	COMMENTS
.5 mi.				
l mi.				
2 mi.				
3 mi.				
4 mi.			*	
ó mi.				
7 mi.				
3 mi.		4 . 4		
9 mi.				
10 mi.				
Sectors Affect	ed			

# INFORMATION ONLY

# CONTROL COPY INFORMATION ONLY

Form SPD-1002-1

DUKE POWER COMPANY PROCEDURE PREPARATION PROCESS RECORD (1) ID No: HP/O/B/1009/11 Change(s) 3 to N/A Incorporated

TATION: Oconee	
ROCEDURE TITLE: Projection of Offsite D	ose from the Uncontrolled
ease of Radioactive Materials Through a	Unit Vent
REPARED BY: Sorah A Cory	DATE: 12-15-82
EVIEWED BY: CT Youque /DLD	DATE: 12-15-82
ross-Disciplinary Review By:	
MPORARY APPROVAL (IF NECESSARY):	
7:(SRO)	Date:
y:	Date:
PPROVED BY: 1 day Bomen	Date: 12/23/82
ISCELLANEOUS:	
eviewed/Approved By:	Date:
Reviewed/Approved By:	Date:

#### DUKE POWER COMPANY

#### OCONEE NUCLEAR STATION

#### PROJECTION OF OFFSITE DOSE FROM THE UNCONTROLLED

#### RELEASE OF RADIOACTIVE MATERIALS THROUGH A UNIT VENT

#### 1.0 Purpose

This procedure describes the method for calculating the potential offsite dose following an uncontrolled release of radioactive materials through the unit vent.

#### 2.0 References

- 2.1 EPA-520/1-75-001, Manual of Protective Action Guides and Protective Actions for Nuclear Incidents
- 2.2 PT/0/A/230/01, Radiation Monitor Check

#### 3.0 Limits and Precautions

- 3.1 Use actual sample data when possible. Radiation monitor readings are susceptible to several sources of error. When radiation monitor readings are used for downwind concentrations, note this in the report of offsite dose assessment.
- 3.2 Environmental data should be collected and analyzed to verify these calculations. This procedure considers all releases to be ground level releases.
- 3.3 Use the computer code ODCAR2 when possible. It is faster, applies a more accurate conversion factor when changing count rate to concentration, and it generates a more concise report. ODCAR2 integrates dose from the initial release and makes two-hour projections from the time of latest data entry.
- 3.4 Use the manual calculations for times when ODCAR2 is unavailable and if more than one unit is affected.
- 3.5 This procedure applies to releases made from Oconee Nuclear Station only. Many of the values contained in this procedure are site specific.
- 3.6 Enclosure 5.7 should be done in conjunction with the Field Monitoring Coordinator.

- 3.7 Vent releases can occur through more than one unit at a time. Check unit vent monitors on all 3 units during a vent release.
- 3.8 When using this procedure in conjunction with HP/0/8/1009/10, "Procedure for Quantifying Gaseous Releases through Steam Relief Valves and Post-Accident Conditions", ensure that the correct time is used in Steps 4.4.3 and 4.4.4.
- 3.9 Meteorology data needed to calculate offsite dose should be obtained as required by Enclosure 5.1. Data not available from the primary source should be obtained from the back up source. The order of preference for each data point is listed each place meteorological data is required. All meteorology data obtained from the tower or river must be a 15 minute average. National Weather Service (NWS) data is a standard observation and is not a 15 minute average.
  - 3.9.1 Every 15 minutes the wind direction and wind speed will be rechecked in accordance with Enclosure 5.1 to ensure additional sectors have not been affected. Once a sector has been determined to be affected it cannot be removed from the list of affected sectors.
  - 3.9.2 The following are conversion formulas for the meterological data obtained from the National Weather Service.

mph = 1.15 (Knots)

°8 = (9/5 °C) + 32

#### 4.0 Procedure

- 4.1 Obtain the following meteorological information from one of the designated sources and record it on Enclosure 5.1. The sources of data are listed in order of preference on Enclosure 5.1.
  - 4.1.1 Time of reactor trip.
  - 4.1.2 Wind speed in MPH.
  - 4.1.3 Direction from which the wind is blowing in degrees from North.
  - 4.1.4 Temperature gradient (ΔT°F).
  - 4.1.5 Time meteorology data taken.
- 4.2 Obtain results of vent sample analysis and vent flow rate in cfm and record on Enclosure 5.1 for each affected unit.
  - 4.2.1 Date/time of sample.
  - 4.2.2 Gross gas concentration in uCi/ml.

- 4.2.3 Iodine equivalent concentration (or data for calculation).
- 4.2.4 Gamma E-bar value in rav/dis (or data for calculation).

NOTE: Actual sample results may not be available due to adverse plant conditions. If sample results are not available, obtain vent radiation monitor readings from the gas and iodine monitors on the unit involved. Record the date/time of data collection and the monitor readings on Enclosure 5.1 Calculate discharge concentration as shown on Enclosure 5.1.

NOTE: The iodine monitor response is time dependent. Allow sufficient time to elapse between readings in order to obtain adequate change in monitor response.

4.3 Project the impact of the release on the downwind population by using the computer code ODCAR2.

NOTE: In the event that CDCAR2 cannot be used, manually calculate the potential dose by the methods outlined in Steps 4.4 thru 4.6.

NOTE: ODCAR will only calculate for one unit at a time.

- 4.3.1 Using Enclosures 5.1 and 5.2, run ODCAR2 for the unit on which the highest activity is found and obtain a printout of the downwind dose assessment. Then manually calculate potential dose (Step 4.4) from any other affected unit. Add these results onto the printout from ODCAR.
- 4.3.2 Complete Steps 4.5 thru 4.6 of this procedure.
- 4.4 Project the impact of the release on the downwind population by using the manual calculations outlined below.
  - 4.4.1 Determine the X/Q values for each point of interest downwind.

MOTE: If no points have been requested, use the 1, 2, 5 and 10 mile values.

- 4.4.1.1 Locate the relative two hour concentration value (CH) for each point from Enclosure 5.3 and record onto Enclosure 5.4.
- -.4.1.2 Convert these values to X/Q by,

 $X/Q = \frac{CH(MPH-Sec/M^3)}{Wind Speed (MPH)}$ 

#### Record results on Enclosure 5.4.

4.4.2 Calculate the downwind concentrations for gas and 1 dine at 1, 2, 5 and 10 mile points by completing Steps 4.4.2.1 and 4.4.2.2.

4.4.2.1  $Conc_T = Unit 1 (Conc_V \cdot F_V) + Unit 2 (Conc_V \cdot F_V)$   $F_V$ ) + Unit 3 (Conc\_V \cdot F\_V)

where.

Conc<sub>T</sub> = total concentration in unit vents (µCi/ml · cfm)

Conc<sub>v</sub> = vent discharge concentration (µCi/ml)

F<sub>V</sub> = vent discharge flow rate (CFM)

4.4.2.2  $Conc_{DW} = Conc_{T} \cdot X/Q \cdot U_{DWC}$ where,

Conc\_DW = downwind concentration (µCi/ml)

Conc<sub>T</sub> total concentration in unit vents (µCi/ml · cfm)

X/Q = dispersion factor in  $sec/m^3$ 

UDWC = unit conversions derived from  $(2.832E-2m^3/ft^3)$ , (0.017 min/sec) = 4.7E-4

Enclosure 5.4 provides work space for this calculation.

4.4.3 Determine the potential whole body gamma dose downwind using the gas concentrations calculated above and the equation,

 $D_{WB} = U_G \cdot \bar{E} \cdot Conc_{DW} \cdot Time$ 

where,

DwB = whole body gamma dose due to submersion in a cloud of radioactive gas (rem)

U<sub>G</sub> = unit conversion derived from, (2.22E6/dis/µCi min), (cc/1.293E-3g), (60 min/hr.), (1.602E-6 erg/mev),

(g · rem/100 ergs),

 $(1.13 P_t/P_a) \cdot 1/2 = 9.00E2 \frac{\text{dis-rem-cc}}{\mu \text{Ci-hr-Mev}}$ 

Concnw = downwind concentration (µCi/ml)

Time = projected duration of exposure (hrs); use 2 hours unless calculating a release from a steam relief valve.

NOTE: If E cannot be obtained from the sample results, the following values can be used:

Hours from Trip	Ē (Mev/dis)
0-12	0.40
12-48	0.20
48-00	0.10

Record results on Enclosure 5.4.

- 4.4.3.1 Use Enclosure 5.5 as an alternate means of whole body exposure approximation.
- 4.4.4 Determine the potential thyroid dose downwind using the iodine concentrations calculated above and the equation.

D<sub>THY</sub> = U<sub>I</sub> · Conc<sub>DW</sub> · Time

where.

D<sub>THY</sub> = thyroid dose due to uptake of radioactive iodiae (rem)

U<sub>I</sub> = constants derived from a child's breathing rate (1.17E2 cc/sec.), I-131 dose conversion factor (4.39 E-3 mrem/pCi), and conversion of pCi to μCi(10<sup>6</sup>), mrem to rem (10<sup>3</sup>), and hrs. to sec (3600 sec/hr) = 1.86 E6 μci · hr

Concnu = downwind concentration of iodine (µCi/ml)

Time = projected exposure time (hrs); use 2 hours unless calculating a release from a steam relief valve.

Record results on Enclosure 5.4.

- 4.4.4.1 Use Enclosure 5.6 as an alternate means of thyroid exposure approximation.
- 4.5 Calculate an adult's chyroid dose by dividing the child's dose by two (2). Record results of all calculations on Enclosure 5.3.
- 4.6 Determine the potentially affected area using the method outlined in Enclosure 5.7. Record sectors on Enclosure 5.3.
- 4.7 Complete Enclosure 5.8 with information from Enclosure 5.1 and submit it to the Offsite Radiological Coodinator or his designee. Include any comments and information pertinent to the evaluation of offsite hazards.

NOTE: Maintain a file of all worksheets and printouts used in dose calculations.

#### 5.0 Enclosures

1.18

- 5.1 Vent Release Data Sheet
- 5.2 ODCAR2 User's Guide

Appendix A: Sample Run of ODCAR

- 5.3 Table of Two Horr Relative Concentration Factors
- 5.4 Manual Calculation Worksheet
- 5.5 Graph of Noble Gas Concentration vs. Whole Body Dose
- 5.6 Graph of I-131 Concentration vs. Thyroid Dose
- 5.7 Evaluation of Plume Location
- 5.3 Dose Assessment Report

# ENCLOSURE 5.1 HP/0/B/1009/11 VENT RELEASE LATA SHEET

		Date/time	_/	
	Date	time of Rx trip	/	
		METEOROLOGIC	AL DATA	
		(All data is 15	in average except NWS	)
Daytime-1	.000-1600 h	rs (Circle source	of data for each poin	t)
-15 min.	period end	ing time		
	rection (decces 1)	Tower (T) River (R)		
T	3) T	NWS (N)	1	
3	R : V	R : N	R : V	
T A	2)	Assume (A)0		
-wind sn	eed (mph)			
	rces 1) 2)	Tower (T) River (R)		
T	3) T	T (X) SWN	T	
R N	; X	R N;	R N	
Nightaim	e-1600-1000	hrs (circle sour	e of data for each po	int)
	period en			
River Wi	nd Direction	on (If river wind 210°)	direction is unavailab	ole assume
			complete #1 or #2 bel	

#### ENCLOSURE 5.1 HP/0/B/1009/11

-wind direct		grees) Tower (T)			
		Assume (A) - betw	een 0-3	60°	
T	T	T		T	
A	_; A	; A	;	A	
-AT (°F)					
Source	es 1)	Tower (T) Assume (A) - +1.0	or		
		(1)			
T A					
	. (				
-wind speed Sour	cces 1)	Tower (T)			
	2)	Assume (A) -1 mph	t., -		
T.	T	T		T	
A	_; A	; A	;	Α	
River wind		n is between 70°-2 grees)		urces belo experimen	
-wind direc	ction (des				
-wind direc	ction (deg	grees)			
-wind direc	ction (deg	grees) een 0-360° (E)			
-wind direct Source E	ction (deg	grees) een 0-360° (E) E; E_			
-wind direct Source E	ction (des	grees) een 0-360° (E) E; E_			
-wind direct Source EAT (°F) Source E	tion (deg	grees) een 0-360° (E) E; E_			
-wind direct Source EAT (°F) Source E	tion (deg	grees) een 0-360° (E) E; E PF (E)			
-wind direct Source EAT (°F) Source E	tion (deg	grees) een 0-360° (E) E; E PF (E)		experimen ; .E;	
-wind direct Source  EAT (°F) Source  Ewind speed Source	tion (deg	grees) een 0-360° (E) E; E_ PF (E)	on	experimen ; .E;	
-wind direct Source  EAT (°F) Source  Ewind speed Source	tion (deg	grees) een 0-360° (E) E; E_ PF (E)	on.	experimen ; .E;	
-wind direct Source EAT (°F) Source Ewind speed Source E	i (mph) ce 1) 1 mm	grees) een 0-360° (E) E; E PF (E) ph (E); E	on.	experimen ; .E;	

1)

# ENCLOSURE 5.1 HP/0/B/1009/11

2)	I-131 Equiv.	$\underline{\qquad} \mu \text{Ci/ml} - \text{Unit 1} \qquad I_{\underline{E}} = \frac{1}{\text{HL}_{\underline{I}-131}}$
		µCi/ml - Unit 2
		μCi/ml - Unit 3
3)	Gas Ē	Mev/dis (Gamma) - Unit 1
		Mev/dis (Gamma) - Unit 2
		Mev/dis (Gamma) - Unit 3
	Sample Results	Calculated
	(eff )	Hours from Trip/
7 0	$= \frac{\left[\sum_{i=1}^{n} A_{i}\right]}{A_{i}}$	12-48 .2
	ÅE	48-00 .1
		VENT MONITOR DATA
1)	R1A 45 (lo range)	CPM - Unit 1
		CPM - Unic 2
	_	CPM - Unit 3
2)	R1A 46 (hi range)	CPM - Unit 1
		CPM - Unit 2
		CPM - Unit 3
3)	∠RIA 4↔ (iodine)	CPM; Atmin - Unit 1
		CPM; Atmin - Unit 2
		CPM; Atmin - Unit 3
4)	RIA 50 (hi range)	mr/hr - Unit 1
		mr/hr - Unit 2
		mr/hr - Unit 3

#### ENCLOSURE 5.2 HP/0/B/1009/11 ODCAR2 USER GUIDE

#### 1.0 Introduction

The complete code ODCAR2 was designed to calculate offsite dose from gaseous releases through the unit vent. This guide is to aid the user

in running ODCAR2 on VAX. In this guide, computer responses will be

shown inside double bold lines. User responses will be shown underlined. The mark signifies a carriage return.

ODCAR will only calculate for one unit at a time. If more than one unit is affected, use ODCAR for the unit showing the highest activity. Any other unit will be calculated manually and added to the ODCAR results.

#### 2.0 Procedure

- 2.1 Complete VAX LOGON procedure outlined below.
  - 2.1.1 Depress parity and duplex keys.
  - 2.1.2 Pick up receiver and diale when tone is heard, depress data key and return to phone cradle.
  - 2.1.3 Type in a carriage return ( ).
  - 2.1.4 The computer will request: user name:

Answer with: ODC7310

2.1.5 The computer will then request: Password:

Respond by typing: DOSE

- 2.2 Computer will hesitate for a few seconds to load program and read the initial data file.
- 2.3 Computer will then respond with: INITIALIZE (YES OR NO)

Answer YES for first run of the program to initialize data files and history files.

- Answer NO for subsequent runs of the program to allow the computer to account for past history of the release.
  - 2.3.1 If initialized, computer will type: ENTER TIME OF TRIP

    Enter the date and time of the reactor trip.

#### ENCLOSURE 5.1 HP/0/B/1009/11

# CALCULATED DISCHARGE CONCENTRATION

1)	Gas - (Use RIA 56 if on RIA-46 is considered on			ale, use	RIA 45	or	RIA 4	6.
	$Conc_{V} = \frac{(RIA-56 \text{ mr/hr})}{3.2E-2}$	-	uCi/ml, uCi/ml, uCi/ml,	Unit 2				
	$Conc_{V} = \frac{(RIA-45 \text{ cpm})}{1E7}$	-	µCi/ml, µCi/ml, µCi/ml,	Unit 2				
	$Conc_{V} = \frac{(3IA-46 \text{ cpm})}{5E3}$	· <u>=</u>	uCi/ml, uCi/ml, uCi/ml,	Unit 2				
2)	<u>Iodine</u>							
	Conc. = (ARIA 44 CPM)	(1.0E-9) =		µCi/ml,	Unit	1		
				µCi/ml,	Unit	2 .		
			100	uCi/ml,	Unit	3		

#### ENCLOSURE 5.2 HP/0/B/1009/11

Format: month, day, year, time

Example: 11,10,30,0945

2.4 Computer will type:

ENTER WIND SPEED (MPH)

Enter the wind speed in miles per hour.

Example: 12.0

2.5 Computer will type:

ENTER WIND DIRECTION (°FROM NORTH)

Enter wind direction

Example: 127.0

At night when wind direction is 0°-360°, enter 360° into

the computer.

2.6 Computer will type:

ENTER TEMP DIFFERENTIAL (DEG.F)

Enter the temperature differential using degrees Fahrenheit.

Example: -1.6

2.7 Computer will type:

INPUT RELEASE RATE IN CFM

Enter the release flow rate (unit vent flow rate) in cubic feet per minute.

Example: 1.3E3

Exponential notation may be used, but does not have to be.

2.3 Computer will type:

ENTER TIME DATA WAS TAKEN

Enter the time of day (approximately) that all of the data being entered

was collected.

Example: 11,10,30,0945

2.9 Computer will type: RELEASE CONC. IS KNOWN (K) OR UNKNOWN (U)

If release concentration is known, use case (A) below. If the release concentration is not known, skip down to Case (3).

(A) Inter a K if the release concentration is known (such as from unit vent sample results.)

#### ENCLOSURE 5.2 HP/0/B/1009/11

2.9.1 Computer will type:

ENTER GROSS NOBLE GAS CONC.

Example: 1.3 E-2

Use units of microcuries per cubic centimeter.

2.9.2 Computer will type:

ENTER I-131 EQUIV. CONC.

Example: Same as 2.9.1

2.9.3 Computer will type:

ENTER GAS E-BAR

Example: 0.27

NOTE:

This E-Bar number can be obtained from sample

results.

(B) Enter a <u>U</u> if the release concentration is unknown (processs monitor information).

2.9.4 Computer will type:

ENTER GAS LOW RANGE CPM (RIA- 45)

Enter the counts per minute reading from the RIA-45 display.

Example: 1.2 E 4

NOTE: RIA

RIA 45 goes offscale at 1E6 cpm. Enter 1E6 if

RIA-46 is > 100 cpm.

2.9.5 Computer will type:

ENTER GAS HI-RANGE CPM (RIA-46)

Enter counts per minute from RIA-46.

Example: 1.2 E 3

NOTE:

ODCAR does not consider RIA-46 on scale until

> 100 cpm.

2.9.6 Computer will type:

ENTER IODINE CHANGE IN CPA (RIA-44)

Enter the change in counts per minute observed on RIA-44 over a measured period of time.

Example: 1.4 E 4

2.9.7 Computer will type:

ENTER TIME (MINUTES) OF CHANGE

Enter the time in minutes over which the change in RIA-44 took

place.

Example: 10.0

#### ENCLOSURE 5.2 HP/0/B/1009/11

2.10 Computer will now calculate, and update history files: Computer will type:

# WHEN READY FOR PRINTOUT, ADVANCE TO TOP OF PAGE AND ENTER NUMBER 9

Example: 9

. . . .

- 2.11 Computer will print, program will end, and the computer logs off.
- 2.12 When computer has signed off, hang up the phone or start at Step 2.1.3 and continue data entry. Release the phone line at the end of the session (when logged off) by depressing the LOCAL/TALK key.

#### ENCLOSURE 5.2, APPENDIX A

HP/0/B/1009/11

SAMPLE RUN OF ODCAR2

Username: ODC7310

Password:

Welcome to VAX/VMS Version V2.3 on node OCO::

INITIALIZE? (YES OR NO)

YES

ENTER TIME OF TRIP

11 12 80 0900

ENTER TOWER WIND SPEED (MPH)

2.2

ENTER TOWER WIND DIRECTION (DEGREES FROM NORTH)

148

ENTER TEMP DIFFERENTIAL (DEG F)

-1.6

INPUT RELEASE FLOW RATE (CFM)

12000

ENTER TIME DATA WAS TAKEN

11 12 80 1000

RELEASE CONC. IS KNOWN(K) OF UNKNOWN(U)

U

ENTER GAS LOW RANGE CPM (RIA-45)

1.3E6

ENTER GAS HI RANGE CPM (RIA-46)

1.2E4

E. TER IODINE CHANGE IN CPM (RIA-44)

1.5E5

ENTER TIME (MINUTES) OF CHANGE

2.0

WHEN READY FOR PRINTOUT, ADVANCE TO TOP OF PAGE AND ENTER NUMBER 9.

#### ENCLOSURE 5.2, APPENDIX A

#### HP/0/B/1009/11

#### SAMPLE RUN OF ODCAR2

PLUME DIRECTION: 3.28E+02 DEGREES RELEASE FLOW RATE: 1.20E+04 CFM WINDSPEED: 2.2 MPH
DELFA TEMP: -1.6 DEG F NOBLE GAS RELEASE CONC: 2.82E+01 UCL/ML IODINE RELEASE CONC.: 3.62E-04 UCI/ML

TIME OF TRIP: 11/12/80 900 TIME OF SAMPLE: 11/12/80 1000

#### EMERGENCY LEVEL SITE EMERGENCY

DISTANCE	SUBMERSION	SUBMERSION	SUBMERCION	1	PRESENT
DOWNWIND	DOSE RATE	DOSE-TOTAL	DOSE-TOTAL	L + 2 HOURS	CONCENTRATION
(MILES)	(REM/HR)	(REM)	(REM)		(UCI/ML)
1	4.081E-01	4.081E-01	1.224E+00		9.388E-04
2	2.951E-02	2-951E-02	8.853E-02		5.788E-05
3	1.695E-02	1.695E-02	5.085E-02		3.900E-05
4	1.256E-02	1.2562-02	3.767E-02		2.389E-05
5	1.067E-02	1.067E-02	3.202E-02		2.455E-05
ó	9.104E-03	9.104E-03	2.731E-02		2.094E-05
7	7.343E-03	7.848E-03	2.354E-02		1.305E-05
3	6.906E-03	6.906E-03	2.072E-02		1.589E-05
9	6.278E-03	6.278E-03	1.884E-02		1.444E-05
10	5.651E-03	5.651E-03	1.695E-02		1.300E-05
	THYROID	THYROID		PRESENT	
	DOSE-TOTAL	DOSE-TOTAL + :	2 HOURS	CONCENTRATION	
	(REM)	(REM)		(UCI/ML)	
1	2.244E-02	6.733E-02		1.206E-08	
2	1.623E-03	4.368E-03		8.719E-10	
3	9.323E-04	2.797E-03		5.009E-10	
4	6.906E-04	2.072E-03		3.710E-10	
5	5.870E-04	1.761E-03		3.154E-10	
ó	5.007E-04	1.502E-03		2.690E-10	
7	4.316E-04	1.295E-03		2.319E-10	
3	3.798E-04	1.139E-03		2.041E-10	
9	3.453E-04	1.036E-03		1.355E-10	
10	3.108E-04	9.323E-04		1.670E-10	
FORTRAN S	STOP				

FORTRAN STOP | logged out at 18-AUG-1981 07:59:40.80

Enclose 5.3

Table of Two-Hour Relative Concentration factors

Temperature Difference	Distance (Miles)									
Afor	1	2	3	4	5	6	7	8	9	10
-25.0 to -1.3	1.5E-6	9.4E-7	5.4E-7	4.0E-7	3.4E-7	2.9E-7	2.5E-7	2.2E-7	2.0E-7	:.8E-7
-1.2 to -1.0	5.8E-5	1.6E-5	8.1E-6	4.9E-6	3.4E-6	2.5E-6	1.9E-6	1.5E-6	1.2E-6	1.0E-6
-0.9 to -0.4	1.5E-4	5.6E-5	3.16-5	2.1E-5	1.56-5	1.2E-5	7.6E-6	7.8E-6	6.7E-6	5.86-6
-0.3 to +0.5	2.9E-4	1.2E-4	6.71-5	4.9E-5	3.4E-5	2.7E-5	2.2E-5	1.9E-5	1.6E-5	1.42-5
11.0 to +25.0	6.4E-4	3.1E-4	1.86-4	1.38-4	9.56-5	7.3E-5	6.18-5	5.0E-5	4.3E-5	3.6E-5

Enclosure 5.3
HP/0/8/1009/11
Table of Two-Hour Relative
Concentration Factors

# ENCLOSURE 5.4 HP/0/B/1009/11 MANUAL CALCULATION WORKSHEET


Gas =	μCi/ml U-1;	uCi/ml U-2	: uCi/m	1
	uCi/ml U-1;			
	rge Flow Rate:			
	CFM U-1;	CFM U-2:	CFM U-3	
Wind Speed				
	PH (Enclosure 5.1)			
Total Conce	ntration: Conc <sub>T</sub> = U	-1 (Conc. · F.) +	U-2 (Concy · Fy) +	1.3
(Concy · Fy				
Gas =	uCi/ml · cfm			
Iodine =	uCi/ml · cf			
	HCI/III CI	m		
	lative Conc. Factor		3 X/Q - CH/mph = s	e
Two Hour Re		s (CH) = sec-mph/m		e
Two Hour Re	lative Conc. Factor	<u>s</u> (CH) = sec-mph/m ; X/Q =	Sec/m <sup>3</sup>	e
Two Hour Re	lative Conc. Factor	s (CH) = sec-mph/m ; X/Q =; ; X/Q =;	Sec/m <sup>3</sup>	e
Two Hour Re CH @ CH @	Mi =Mi =	<pre>s (CH) = sec-mph/m ; X/Q = ; X/Q = ; X/Q =</pre>	Sec/m <sup>3</sup> Sec/m <sup>3</sup> Sec/m <sup>3</sup>	e
Two Hour Re CH @ CH @ CH @	Mi =Mi =Mi =	<pre>s (CH) = sec-mph/m ; X/Q = ; X/Q = ; X/Q = ; X/Q = ; X/Q =</pre>	Sec/m <sup>3</sup> Sec/m <sup>3</sup> Sec/m <sup>3</sup>	e
Two Hour Re CH @ CH @ CH @	Mi =Mi =	<pre>s (CH) = sec-mph/m ; X/Q = ; X/Q = ; X/Q = ; X/Q = ; X/Q =</pre>	Sec/m <sup>3</sup> Sec/m <sup>3</sup> Sec/m <sup>3</sup>	e
Two Hour Re CH @ CH @ CH @ CH @ Downwind Co	Mi =Mi =	<pre>s (CH) = sec-mph/m ; X/Q = ; X/Q =</pre>	Sec/m <sup>3</sup> Sec/m <sup>3</sup> Sec/m <sup>3</sup> Sec/m <sup>3</sup> (4.7E-4)	ec
Two Hour Re CH @ CH @ CH @ CH @ Downwind Co A) Gas Conc_Dw	Mi =Mi =	<pre>s (CH) = sec-mph/m ; X/Q = Gi/ml @</pre>	Sec/m <sup>3</sup> Sec/m <sup>3</sup> Sec/m <sup>3</sup> Sec/m <sup>3</sup> (4.7E-4)	ec
Two Hour Re CH @ CH @ CH @ CH @ CH @ Conc_DW Conc_DW	Mi =Mi =	<pre>s (CH) = sec-mph/m ; X/Q = Gi/ml @ Gi/ml @</pre>	Sec/m <sup>3</sup> Sec/m <sup>3</sup> Sec/m <sup>3</sup> Sec/m <sup>3</sup> (4.7E-4) Mi	e

#### ENCLOSURE 5.4 HP/0/B/1009/11 MANUAL CALCULATION WORKSHEET

	3)	Iodine						
		Conc <sub>DW</sub> =	ale pui	µС	i/ml@	Mi		
		Conc <sub>DW</sub> =						
		Conc <sub>DW</sub> =		µC	i/ml@	Mi		
		Conc <sub>DW</sub> 2		ис	i/ml@	Mi		
7)	Pote	ential Whole Bo	ody Gamr	ma Dose	: D <sub>WB</sub> = (9	.00 E2) ·	ConcDW .	$\tilde{\mathbf{E}}$ · Time
	Ē =		Mev/d	is	Time =		hours	
	D.wB		Rem	@		_ Mi		
	D. WB		Rem	ġ		_ Mi		
	D.WB		Rem	@		_ Mi		
	D. B		_ Rem	@		_ Mi		
3)	Pot	ential Thyroid	Dose:	D <sub>THY</sub> =	(1.36E6) ·	ConcDW .	Time	
	Time	e =	hours					
	DTH	ү ———	Rem	@		_ Mi		
	D <sub>TH</sub>	Υ ———	Rem	<u>@</u>		_ Mi		
	D <sub>TH</sub>	ү ———	Rem	@		_ Mi		
	DTH	Y ———	Rem	@		_ Mi		


<sup>\*</sup>Ensure correct time is used for steam relief valve release.

ENCLOSURE 5.5
NOBLE GAS CONCENTRATION 75. WEGLE BODY DOSE



ENGLOSURE 5.6

IODINE CONCENTRATION 75. THYROID DOSE



Projected Exposure Duration in Hours

#### ENCLOSURE 5.7 HP/0/B/1009/11 EVALUATION OF PLUME LOCATION

- Acquire the following information from Enclosure 5.1 and record on Enclosure 5.8.
  - Meteorological Data identify for each point whether data is assumed
     (A), experiment (E) or measured (T, R or N).
  - b) thyroid and whole body doses
- Protective action guides submitted to the Offsite Radiological Coordinator are to be made based on the calculated dose on Enclosure 5.1 and the following information.
  - a) For doses:

1. . 4 .

- > 5 Rem Whole Body or,
- >25 Rem Thyroid

Recommend Evacuation of Population in Affected Area.

- b) For doses:
  - 1-5 Rem Whole Body or.
  - 5-25 Rem Thyroid

Recommend evacuation of children and pregnant women, and sheltering of remainder of personnel in the affected area.

- c) For doses:
  - < 1 Rem Whole Body or,
  - < 5 Rem Thyroid

Recommend no action.

 Determine Stability Class by completing step a below and record on Enclosure 5.3.

#### ENCLUSURE 5.7 HP/0/B/1009/11 EVALUATION OF PLUME LOCATION

a)	ΔΤ	Stability Class
	-8 to-1.3	A
	-1.2 to -1.0	C
	-0.9 to -0.4	D
	-0.3 to +0.9	Ε
	+1.0 to +8	2

- To determine the sectors affected, complete one of the options under A or B. Record the sectors affected on Enclosure 5.3.
  - A) Daytime (1000-1600 hrs)
    - 1) wind speed > 5 mph for tower or river wind direction, use Table 1.
    - 2) wind speed > 5 "ph for NWS wind direction, use Table 2.
    - 3) wind speed < 5 mph for tower or river wind direction, assume sectors Al, Bl, Cl, Dl, El, and Fl are affected. Then use Table 1 to determine additional sectors affected.
    - 4) wind speed < 5 mph NWS wind direction, assume all sectors affected (Al through F1, A2 through F2).

TABLE 1

Wind Direction	Sectors Affected						
140-270	C1. C2. D1. D2. E1. E2						
270-430	C1, D1, D2, E1, E2						
420-660	D1, D2, E1. E2						
66°-85°	D1, D2, E1, E2, F2						
85°-104°	D1, D2, E1, E2, F1, F2						
104°-129°	E1, E2, F1, F2						
129°-156°	A1, A2, E1, E2, F1, F2						
156°-175°	A1, A2, E1, F1, F2						
175°-131°	A1, A2, F1, F2						
181°-219°	A1, A2, B1, B2, F1, F2						
219° - 235°	A1, A2, B1, B2						
255°-271°	A1, A2, B1, B2, C1, C2						
271°-297°	B1, 32, C1, C2						
297°-312°	31, B2. C1. C2, D2						
312°-345°	B1, B2, C1, C2, D1, D2						
345°-14°	C1, C2, D1, D2						

#### ENCLOSURE 5.7 HP/0/B/1009/11 EVALUATION OF PLUME LOCATION

#### EVALUATION OF PLUME LOCATION

#### TABLE 2

Wind Direction	Sectors Affected
1°-39°	B1, B2, C1, C2, £1, E2, F1, F2
39°-75°	Al through F1, A2 through F2
75°-91°	A1, A2, C1, C2, D1, D2, E1, E2, F1, F2
91°-117°	Al through F1, A2 through F2
117°+132°	A1, A2, B1, B2, C1, D1, D2, E1, E2, F1, F2
132°-165°	A1, A2, B1, B2, D1, D2, E1, E2, F1, F2
165°-194°	Al through F1, A2 through F2
194°-207°	A1, A2, B1, B2, C1, C2, E1, E2, F1, F2
207°-222°	A1, A2, B1 B2, C1, C2, E2, E1, E2, F1, F2
2220-2460	Al through F1, A2 through F2
246°-263°	A1, A2, B1, B2, C1, C2, D1, D2, E1, F1, F2
265°-284°	A1. A2, B1, B2. C1. C2, D1, D2, F1. F2
284°-309°	Al through F1, A2 through F2
309°-336°	A1, A2, B1, B2, C1, C2, D1, D2, E1, E2
336°-355°	A1, A2, B1, B2, C1, C2, D1, D2, E1, E2, F2
3550-10	Al through F1, 12 through F2

#### 3) Nighttime (1600-1000 hrs)

e", ...

(If river wind direction is upavailable, assume 70°-210°.)

- If river wind direction is between 210°-70°, use Option A (Daytime).
- 2) If river wind direction is between 70°-210°, assume all sectors affected (Al through F1, A2 through F2).

### DOSE ASSESSMENT REPORT

HP/0/8/1009/11

DATE:					
TIME:					
DOSE ASSESSOR					
WIND DIRECTION	1		SOUR	CE	
WIND SPEED_	мрн	SOURCE			
27	°F/120ft	SOURCE			
STABILITY CLAS	SS				
DISTANCE	THYROID/ADULT	THYROID	CHILD	WHOLE BODY	COMMENTS
.5 mi.				استياضا فينست	
I mi.					
2 mi.					
÷ mi.					
5 mi.					
5 mi.					
7 mi.					
3 mi.					
g mi.					
10 mi.			H-HL		
Sectors Affec	ted				