

## Omaha Public Power District

1623 HARNEY ■ OMAHA, NEBRASKA 68102 ■ TELEPHONE 536-4000 AREA CODE 402

September 7, 1982  
LIC-82-317

Mr. Robert A. Clark, Chief  
U. S. Nuclear Regulatory Commission  
Office of Nuclear Reactor Regulation  
Division of Licensing  
Operating Reactors Branch No. 3  
Washington, D.C. 20555


Reference: Docket No. 50-285

Dear Mr. Clark:

Environmental Qualification of  
Safety-Related Electrical Equipment  
at the Fort Calhoun Station

Mr. E. Tourigny of your staff requested the Omaha Public Power District provide a letter documenting the District's response to questions that were discussed during a telephone conversation on September 1, 1982 with Messrs. Patterson and Short of the District regarding the subject issue. Specifically, Mr. Tourigny requested clarification and/or confirmation of information provided on pages 6-119 and 6-120 (System Component Evaluation Work Sheets for auxiliary feedwater solenoid valves HCV-1107B and 1108B) of the District's letter dated April 2, 1982. The District stated during this conversation that all qualification information provided on these sheets is correct, except the "Note 1" comment on both sheets, which incorrectly details that these valves are normally locked open. The District has revised these SCEW sheets accordingly and has completed a review of all other SCEW sheets for other such inconsistencies and typographical errors. A complete, revised Electrical Equipment Qualification manual, which will fully replace the District's last complete submittal of August 26, 1981, including revised pages 6-119 and 6-120, will be provided to the Commission. The District expects to issue this manual revision within the next two months.

Sincerely,

  
W. C. Jones  
Division Manager  
Production Operations

8209130258 820907  
PDR ADOCK 05000285  
P PDR

A048

WCJ/TLP:jmm

cc: LeBoeuf, Lamb, Leiby & MacRae  
1333 New Hampshire Avenue, N.W.  
Washington, D.C. 20036

Mr. E. G. Tourigny, NRC  
Project Manager