

Unit 3

LICENSEE EVENT REPORT

Report No. 3-83-06/1T-0

CONTROL BLOCK: | | | | | | | | | | | ①

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | P | A | P | B | S | 3 | | ② | 0 | 0 | - | 0 | 0 | 0 | 0 | 0 | - | 0 | 0 | | ③ | 4 | 1 | 1 | 1 | 1 | | | ④ | | | | ⑤

CON'T 0 1 | REPORT SOURCE | L | ⑥ | 0 | 5 | 0 | - | 0 | 2 | 7 | 8 | | ⑦ | 0 | 1 | 3 | 1 | 8 | 3 | | ⑧ | 0 | 2 | 1 | 0 | 8 | 3 | | ⑨

0 2 | During local leak rate testing of the B CAD nitrogen injection penetration (N211B) it was determined that the manual test valve was leaking excessively. This valve is an outboard isolation valve. Because the inboard valve had minimum leakage and the test connection was sealed with a threaded cap primary containment was considered to be intact.

0 9 | SYSTEM CODE | S | D | | ⑪ | CAUSE CODE | E | | ⑫ | CAUSE SUBCODE | X | | ⑬ | COMPONENT CODE | V | A | L | V | E | | X | | ⑭ | COMP SUBCODE | F | | ⑮ | VALVE SUBCODE | D | | ⑯ | EVENT YEAR | 8 | 3 | | ⑰ | SEQUENTIAL REPORT NO. | 0 | 0 | 9 | | ⑱ | OCCURRENCE CODE | 0 | 1 | | ⑲ | REPORT TYPE | T | | ⑳ | REVISION NO. | 0 | | ㉑ | ACTION TAKEN | A | | ㉒ | FUTURE ACTION | Z | | ㉓ | EFFECT ON PLANT | Z | | ㉔ | SHUTDOWN METHOD | Z | | ㉕ | HOURS | 0 | 0 | 0 | | ㉖ | ATTACHMENT SUBMITTED | Y | | ㉗ | NPED-4 FORM SUB. | N | | ㉘ | PRIME COMP. SUPPLIER | A | | ㉙ | COMPONENT MANUFACTURER | R | 3 | 4 | 4 | | ㉚

1 0 | Upon discovery the manual valve in series with the leaking valve was shut. The valve (Rockwell-Edwards MK-130) would not properly close due to a scored seat and the presence of foreign material. The bonnet, stem and plug were replaced, the seat lapped and the valve successfully retested.

5 | FACILITY STATUS | E | | ㉛ | % POWER | 0 | 8 | 0 | | ㉜ | OTHER STATUS | EOL Coastdown | | ㉝ | METHOD OF DISCOVERY | B | | ㉞ | DISCOVERY DESCRIPTION | Local leak rate test | | ㉟ | ACTIVITY CONTENT | Z | | ㊱ | AMOUNT OF ACTIVITY | N/A | | ㊲ | LOCATION OF RELEASE | N/A | | 6 | PERSONNEL EXPOSURES NUMBER | 0 | 0 | 0 | | ㊳ | TYPE | 2 | | ㊴ | DESCRIPTION | N/A | | 7 | PERSONNEL INJURIES NUMBER | 0 | 0 | 0 | | ㊵ | DESCRIPTION | N/A | | 8 | LOSS OF OR DAMAGE TO FACILITY TYPE | Z | | ㊶ | DESCRIPTION | N/A | | 9 | PUBLICITY ISSUED | N | | ㊷ | DESCRIPTION | N/A |

B302220114 830210  
PDR ADOCK 05000278  
S PDR

NRC USE ONLY