



Pennsylvania Power & Light Company

Two North Ninth Street • Allentown, PA 18101 • 215 / 770-5151

February 11, 1983

Mr. R.C. Haynes
Director, Region I
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA 19406

SUSQUEHANNA STEAM ELECTRIC STATION
LICENSEE EVENT REPORT 83-013/03L-0
ER 100450 FILE 841-23
PLA- 1533

Docket No. 50-387
License No. NPF-14

Dear Mr. Haynes:

Attached please find a copy of Licensee Event Report No. 83-13/03L-0. This event was determined to be reportable per Technical Specification 6.9.1.9.c in that the "as found" data for the Reactor Vessel Water Level "A" channel was lost due to incorrect test equipment usage.

This event is being submitted late due to an administrative oversight. Scheduling reportable events on a tracking system should prevent overdue submittals.

H.W. Keiser
Superintendent of Plant-Susquehanna

DGM/cg

Attachment

cc: Director of Nuclear Reactor Regulation
Attention: Mr. A. Schwencer, Chief
Licensing Branch No. 2
Division of Licensing
U.S. Nuclear Regulatory Commission
Washington, DC 20555

G. Rhoads
Resident Inspector
U.S. Nuclear Regulatory Commission
P.O. Box 52
Shickshinny, PA 18655

8302220165 830211
PDR ADOCK 05000387
S FDR

IE22