

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | M | A | P | P | S | I | 2 | 0 | 0 | - | 0 | 0 | 0 | 0 | 0 | - | 0 | 0 | 3 | 4 | 1 | 1 | 1 | 1 | 1 | 4 | 5
7 8 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58

CON'T
01 | L | 6 | 0 | 5 | 0 | - | 0 | 2 | 9 | 3 | 7 | 0 | 1 | 1 | 3 | 8 | 3 | 8 | 0 | 2 | 1 | 1 | 1 | 8 | 3 | 9
7 8 REPORT SOURCE 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 | On 1/13/83, during surveillance test 8.M.2-1.2.1. RWCS High flow isolation DPIS-1243
03 | was found out of calibration in a non-conservative direction. T.S. table 3.2.A.
04 | requires one channel to be operable. The redundant switch (DPIS-1244) was found to
05 | be within T.S. limits. Therefore, primary containment isolation protection was not
06 | affected. This event caused no threat to the public health and safety.
07 |
08 |

09 | C | G | 11 | E | 12 | B | 13 | I | N | S | T | R | U | 14 | S | 15 | Z | 16
7 8 9 SYSTEM CODE 10 CAUSE CODE 11 CAUSE SUBCODE 12 COMPONENT CODE 13 COMP. SUBCODE 14 VALVE SUBCODE 15
17 | 8 | 3 | 21 | 22 | 0 | 0 | 3 | 24 | 26 | / | 0 | 3 | 28 | 29 | L | 30 | - | 31 | 0 | 32
18 | Z | 19 | Z | 20 | Z | 21 | 0 | 0 | 0 | 0 | 22 | N | 23 | N | 24 | A | 25 | I | 2 | 0 | 4 | 26
7 8 9 LER/RO REPORT NUMBER 17 EVENT YEAR 21 SEQUENTIAL REPORT NO. 24 OCCURRENCE CODE 28 REPORT TYPE 30 REVISION NO. 32
ACTION TAKEN 33 FUTURE ACTION 34 EFFECT ON PLANT 35 SHUTDOWN METHOD 36 HOURS 40 ATTACHMENT SUBMITTED 41 NPRO-4 FORM SUB. 42 PRIME COMP. SUPPLIER 43 COMPONENT MANUFACTURER 44

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 | The cause was a loose switch plate locking screw which allowed the setpoint to drift.
11 | The switch was reset within T.S. limits, the screw tightened and the test success-
12 | fully completed. A follow-up calibration check on 2/9/83 was satisfactory. The DPIS
13 | is a ITT-Barton Model 288.
14 |

15 | E | 28 | 1 | 0 | 0 | 29 | NA | 30 | B | 31 | Surveillance | 32
7 8 9 FACILITY STATUS 10 % POWER 12 OTHER STATUS 13 METHOD OF DISCOVERY 14 DISCOVERY DESCRIPTION 15
16 | Z | 33 | Z | 34 | NA | 35 | NA | 36
7 8 9 ACTIVITY RELEASED 10 CONTENT OF RELEASE 11 AMOUNT OF ACTIVITY 12 LOCATION OF RELEASE 13
17 | 0 | 0 | 0 | 37 | Z | 38 | NA | 39
7 8 9 PERSONNEL EXPOSURES NUMBER 10 TYPE 11 DESCRIPTION 12
18 | 0 | 0 | 0 | 40 | NA | 41
7 8 9 PERSONNEL INJURIES NUMBER 10 DESCRIPTION 11
19 | Z | 42 | NA | 43
7 8 9 LOSS OF OR DAMAGE TO FACILITY TYPE 10 DESCRIPTION 11
20 | N | 44 | 8302220351 830211 | 45
7 8 9 ISSUED DESCRIPTION 10 PDR ADOCK 05000293 S PDR
NAME OF PREPARER G.G. Whitney PHONE: (617) 746-7900