



MISSISSIPPI POWER & LIGHT COMPANY
Helping Build Mississippi
 P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

February 14, 1983

JAMES P. McGAUGHY, JR.
 ASSISTANT VICE PRESIDENT

Office of Inspection & Enforcement
 U. S. Nuclear Regulatory Commission
 Region II
 101 Marietta St., N.W., Suite 3100
 Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
 Unit 1
 Docket No. 50-416
 License No. NPF-13
 File: 0260/L-835.0
 Diesel Generator 12 and Division 2 ECCS
 Declared Inoperable
 LER 83-020/03 L-0
 AECM-83/0094

FEB 16 1983
 P12:49

On January 15, 1983, while in shutdown, the lube oil heater on Diesel Generator 12 was found to have failed. Diesel Generator 12 and Division 2 ECCS were declared inoperable. Limiting conditions for operations were entered under Technical Specifications 3.8.1.2 and 3.5.2. The event is reported pursuant to Technical Specification 6.9.1.13.b. Attached is LER 83-020/03 L-0.

Yours truly,

John Hubbard
 FOR J.P. McGaughy, JR

JPM:rg
 Attachment

cc: Mr. N. L. Stampley (w/a)
 Mr. R. B. McGehee (w/o)
 Mr. T. B. Conner (w/o)
 Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)
 Office of Inspection & Enforcement
 U. S. Nuclear Regulatory Commission
 Washington, D. C. 20555

Mr. J. P. O'Reilly, Regional Administrator (w/a)
 Office of Inspection and Enforcement
 U.S. Nuclear Regulatory Commission
 Region II
 101 Marietta St., N.W., Suite 3100
 Atlanta, Georgia 30303

OFFICIAL COPY

IE 22

8302220358 830214
 PDR ADOCK 05000416
 S PDR