



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

February 15, 1983

JAMES P. McGAUGHY, JR.
ASSISTANT VICE PRESIDENT

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 3100
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Fire Doors Blocked Open to
Support Plant Testing
LER 83-013/99 X-0
AECM-83/0106

On January 19, 1983, while in cold shutdown, three doors in the Auxiliary Building were blocked open to support plant testing. Fire watches were established in accordance with Technical Specification 3.7.7. Attached is Special Report LER 83-013/99 X-0.

Yours truly,

J.P. McGaughey
for J.P. McGaughey

JPM:sap
Attachment

- cc: Mr. N. L. Stampley (w/a)
- Mr. R. B. McGehee (w/o)
- Mr. T. B. Conner (w/o)
- Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk (w/a)
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

OFFICIAL COPY

TE 22

8302220369 830215
PDR ADOCK 05000416
S PDR

03 FEB 18 1983 49