

February 16, 1983

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

BEFORE THE ATOMIC SAFETY AND LICENSING APPEAL BOARD

In the Matter of)	
)	
METROPOLITAN EDISON COMPANY)	Docket No. 50-289
)	(Restart)
(Three Mile Island Nuclear)	
Station, Unit No. 1))	

LICENSEE'S TESTIMONY OF

ROBERT C. JONES, JR.

IN RESPONSE TO ALAB-708 ISSUE NOS. 4 THROUGH 7

(ECCS EVALUATIONS AND BOILER-CONDENSER COOLING)

8302220371 830216
PDR ADOCK 05000289
T PDR

SUMMARY

This testimony responds to the Appeal Board's stated concerns with the B&W ECCS evaluations of small-break loss-of-coolant accidents and the efficacy of boiler-condenser cooling to remove decay heat at TMI-1 for those breaks for which it is predicted to occur.

The pre-TMI-2 accident analyses to demonstrate TMI-1 compliance with 10 C.F.R. § 50.46 used the NRC approved Appendix K model and, for certain break sizes, the results of these analyses also exhibited the steam generator heat transfer characteristics associated with boiler-condenser cooling.

The post-TMI-2 accident analyses used the approved CRAFT2 computer code, but modifications were made to the model to provide a more detailed examination of plant response under boiler-condenser conditions.

A revised B&W evaluation model, submitted to the Staff for Appendix K approval, has been used to analyze a 0.01 ft^2 break, during which boiler-condenser cooling is predicted to occur, and an extrapolation of the results demonstrates that adequate core cooling is maintained. While breaks smaller than the original spectrum (i.e., 0.04 ft^2) do not need to be analyzed to demonstrate compliance with section 50.46, the response to NUREG-0737 Items II.K.3.30 and II.K.3.31 will provide further confirmation that the original spectrum analyzed was adequate (i.e., that 0.07 ft^2 is the worst case).

The foregoing analyses demonstrate the adequacy of the boiler-condenser cooling mode to remove decay heat at TMI-1. A heat transfer analysis of the steam generator provides yet a further illustration of that capability. In addition, experimental data is discussed which supports this conclusion from the analyses.

INTRODUCTION

1
2 This testimony, by Robert C. Jones, Jr., Supervisory
3 Engineer, Operational Analysis Unit, Babcock & Wilcox Company,
4 is in response to Issue Nos. 4 through 7 of the Appeal Board's
5 Memorandum and Order of December 29, 1982 (ALAB-708). Collec-
6 tively, those issues address the adequacy of the B&W Emergency
7 Core Cooling System (ECCS) evaluations of small-break
8 loss-of-coolant accidents (small-break LOCAs) and the efficacy
9 of boiler-condenser cooling to remove decay heat at TMI-1 for
10 those breaks for which it is predicted to occur.

11 Licensee evidence in the record which is relevant to these
12 issues, and which may provide valuable background information,
13 includes:

- 14 o Licensee's Testimony of Robert W. Keaten and Robert
15 C. Jones in Response to UCS Contention Nos. 1 and 2
(Natural and Forced Circulation), ff. Tr. 4588;
- 16 o Licensee's Testimony of Robert C. Jones, Jr. and T.
17 Gary Broughton in Response to UCS Contention No. 8
and ECNP Contention No. 1(e) (Additional LOCA
Analysis), ff. Tr. 5038;
- 18 o Licensee's Testimony of Robert C. Jones, Jr. and T.
19 Gary Broughton in Response to the Board Question on
UCS Contention 8, ff. Tr. 5039;
- 20 o Licensee Exhibits 3 through 13 (small-break LOCA and
21 other accident analyses performed before and after
the TMI-2 accident; small break operator guidelines).

1 ISSUE NO. 4: Whether the modified B&W ECCS evaluation model
2 for small breaks that predicts the boiler-
3 condenser process is an NRC approved code under
4 Appendix K to 10 CFR Part 50 (from the staff).

5 RESPONSE

6 BY WITNESS JONES:

7 NRC regulations provide the definition of an ECCS eval-
8 uation model.

9 An evaluation model is the calculational
10 framework for evaluating the behavior of
11 the reactor system during a postulated
12 loss-of-coolant accident (LOCA). It
13 includes one or more computer programs and
14 all other information necessary for
15 application of the calculational framework
16 to a specific LOCA, such as mathematical
17 models used, assumptions included in the
18 programs, procedure for treating the
19 program input and output information,
20 specification of those portions of analysis
21 not included in computer programs, values
22 of parameters, and all other information
23 necessary to specify the calculational
24 procedure.

25 10 C.F.R. § 50.46(c)(2).

26 Analyses performed prior to the TMI-2 accident to demon-
strate the conformance of TMI-1 to 10 C.F.R. § 50.46 used the
NRC-approved B&W ECCS evaluation model and, for certain break
sizes (e.g., the 0.04 ft² break), the results of these
analyses also exhibited the steam generator heat transfer
characteristics associated with boiler-condenser cooling.

The model used for the additional small-break LOCA
analyses performed after the TMI-2 accident that predict the
boiler-condenser process technically was not the B&W ECCS

1 evaluation model approved by the NRC pursuant to Appendix K to
2 10 C.F.R. Part 50. The model used for those analyses was the
3 approved B&W evaluation model modified only by the addition of
4 two control volumes (or nodes) to provide a more detailed
5 examination of plant response under boiler-condenser condi-
6 tions. No changes were made, however, to the CRAFT2 computer
7 code, which is the approved Appendix K code used to predict
8 system response for these breaks.

9 The additional control volumes, one in each Reactor
10 Coolant System loop, were included in order to explicitly
11 represent the upper head, or plenum, region of each steam
12 generator. The analytical impact of the addition of the
13 control volumes was to allow for a more accurate representation
14 of the formation of a steam bubble between the steam generator
15 emergency feedwater injection point and the 180° U-bend in the
16 top of each RCS hot leg. See Licensee Ex. 5, § 6.2.4.2.

17 It should also be noted, as I discuss more fully below in
18 response to Issue No. 7, that the B&W ECCS evaluation model for
19 small-break LOCAs has been further revised, in response to Item
20 II.K.3.30 of NUREG-0737. The changes made to the model include
21 the addition of a steam generator upper head region, as
22 discussed above, and others developed in consonance with the
23 NRC Staff. The revised model has been formally submitted to
24 the NRC (see Licensee Ex.) for review by the Staff for
25 compliance with Appendix K to 10 C.F.R. Part 50.
26

1 ISSUE NO. 5: Whether the staff has reviewed the B&W Appendix
2 K model to determine the ability of the code to
3 calculate the effects of small breaks, including
4 reliance upon boiler-condenser circulation (from
5 the staff).

4 RESPONSE

5 BY WITNESS JONES:

6
7 While I obviously cannot describe the scope of the Staff's
8 review beyond what the Staff itself has reported, as I indi-
9 cated above the results of the analyses performed prior to the
10 TMI-2 accident to demonstrate the conformance of TMI-1 to 10
11 C.F.R. § 50.46, with the approved B&W Appendix K model,
12 exhibited, for certain break sizes, the steam generator heat
13 transfer characteristics associated with boiler-condenser
14 cooling.

15 The documentation of a revised B&W ECCS evaluation model,
16 submitted to the Staff in November, 1982 under NUREG-0737 Item
17 II.K.3.30 for review against Appendix K, includes the results
18 of an analysis of the 0.01 ft² break, during which boiler-
19 condenser cooling is predicted to occur. See Licensee Ex. _____
20 at Appendix E.
21
22
23
24
25
26

1 ISSUE NO. 6: Whether only breaks slightly smaller than 0.07
2 ft² must be analyzed (from the staff).

3 RESPONSE

4 BY WITNESS JONES:

5 The smallest break analyzed in the demonstration, prior to
6 the TMI-2 accident, of TMI-1 conformance to 10 C.F.R. § 50.46
7 was of the size 0.04 ft². See Jones and Broughton, ff. Tr.
8 5038, at 12 (Table 1); Licensee Exs. 3 and 4. Breaks smaller
9 than 0.04 ft² do not need to be analyzed to demonstrate the
10 conformance of TMI-1 to section 50.46.
11

12 Section 50.46 establishes the criteria for an acceptable
13 emergency core cooling system. Appendix K to 10 C.F.R. Part 50
14 sets forth the required and acceptable features of an eval-
15 uation model used to show compliance with 10 C.F.R. § 50.46.
16 ECCS cooling performance is to ". . . be calculated for a number
17 of postulated loss-of-coolant accidents of different sizes,
18 locations, and other properties sufficient to provide assurance
19 that the entire spectrum of postulated loss-of-coolant acci-
20 dents is covered." See 10 C.F.R. § 50.46(a)(1).

21 B&W's selection of the spectrum of small breaks to be
22 evaluated pursuant to 10 C.F.R. § 50.46 was based on the
23 following considerations:

- 24 1. A Core Flood Tank (CFT) line break, by its location,
25 severely limits the Emergency Core Cooling Systems
26

1 available for accident mitigation. Considerations of
2 break location and single active failure dictate that core
3 cooling must be provided by one high pressure injection
4 (HPI) train and one core flood tank, until the active low
5 pressure injection (LPI) train can be switched from its
6 assumed injection into the broken CFT line and balanced
7 between the two CFT lines. This break is analyzed, then,
8 because it would appear to represent a limiting condition.

9 2. A series of break sizes are evaluated wherein the conse-
10 quences of the rupture are mitigated by various combina-
11 tions of the three ECCS systems:

12 A. A break is considered for which mitigation is
13 provided by the LPI, CFT and HPI systems.

14 B. A break is considered for which mitigation is
15 supplied by only the CFT and the HPI systems.

16 C. A break is considered for which mitigation is
17 provided solely by the HPI system.

18 Breaks are uniformly located, with the exception of the
19 Core Flood line break, between the high pressure injection
20 at in the cold leg (reactor coolant pump discharge
21 piping) and the inlet to the reactor vessel. This
22 location minimizes the amount of high pressure injection
23 available for core cooling since a significant portion of
24 the HPI flow can be discharged directly out the break. In
25 addition, breaks at low elevations within the Reactor
26

1 Coolant System drain the Reactor Coolant System of
2 significantly more water than breaks at higher elevations.
3 Thus, for accidents in which the HPI or other ECCS systems
4 cannot instantaneously provide core cooling and cooling
5 must be sustained for some period of time via the initial
6 RCS inventory, that inventory is reduced in the most rapid
7 way possible.

8 3. Additional breaks are considered to confirm that the above
9 spectrum has indeed bounded the worst case. That is, as
10 necessary, break sizes smaller and larger than the
11 calculated worst case are considered in order to confirm
12 that the most adverse core cooling situation has been
13 identified.

14 Very small breaks, i.e., those smaller than the smallest
15 break considered in the spectrum (0.04 ft^2), are not
16 evaluated because they are bounded by larger breaks for the
17 following reasons:

18 1. Because of the internal vent valves, condensation within
19 the steam generator must occur prior to uncovering of the
20 reactor core. At TMI-1, this occurs because the injection
21 location for emergency feedwater is near the top of the
22 steam generator. Ultimately, the steam generator is
23 filled to 95 percent on the operating range, which assures
24 a condensing surface above the top of the core continu-
25 ously.

- 1 2. If steam condensation is occurring in the primary side of
2 the steam generator, then the RCS pressure will be reduced
3 to near the pressure of the secondary side of the steam
4 generators (approximately 1000 psi) or at a higher
5 pressure wherein the HPI flow matches the leak flow.
- 6 3. The breaks evaluated in the spectrum, those with HPI
7 mitigation only, drain the RCS loops faster and establish
8 steam condensation earlier than do smaller breaks. At the
9 start of the steam condensation mode, the decay heat rate
10 for the larger break will be higher than for the smaller
11 break. The larger break will also be losing initial RCS
12 inventory faster than the smaller break. Thus the
13 potential for core uncovering is greater for the larger
14 breaks.
- 15 4. Because it has been shown by evaluation that the HPI
16 provides successful mitigation of a transient at a higher
17 decay heat rate at an earlier time, the HPI will provide
18 successful mitigation of the transient at a lower, later
19 decay heat rate. Therefore, smaller breaks cannot have
20 consequences in the core region more severe than the
21 smallest break considered in the spectrum evaluation.

22 Therefore, while breaks smaller than the spectrum analyzed
23 to demonstrate compliance with 10 C.F.R. § 50.46 may involve
24 different system behavior (i.e., the repressurization cycle
25 which is caused by the interruption of natural circulation),
26

1 core cooling is dependent upon maintaining core coolant
2 inventory. Regardless of the specific sequence of events
3 during a very-small-break LOCA, before core uncovering can occur,
4 reactor coolant pressure will decrease to a point (approx-
5 imately 1000 psig) where high pressure injection has been
6 demonstrated to provide adequate core cooling for the maximum
7 core decay heat level.

8 The additional small-break LOCA analyses performed after
9 the TMI-2 accident provided further confirmation of the
10 validity of the above described methodology. While these
11 evaluations were for the purpose of providing an improved
12 analytical basis for emergency operating procedures, rather
13 than to demonstrate compliance with 10 C.F.R. § 50.46, several
14 breaks smaller than the previously analyzed 0.04 ft² break
15 were addressed. Specifically, breaks of 0.005 ft² and 0.01
16 ft² were evaluated. See Jones and Broughton, ff. Tr. 5038,
17 at 6-7 and 17 (Table 6). In my opinion, the analyses for the
18 0.005 ft² and 0.01 ft² breaks are sufficient to
19 demonstrate conformance to 10 C.F.R. § 50.46 pursuant to
20 Appendix K. The results indeed showed that, compared to the
21 larger break sizes, an increased margin relative to core
22 uncovering existed. The effort now underway, pursuant to
23 NUREG-0737 Items II.K.3.30 and II.K.3.31, to analyze small
24 breaks with an improved Appendix K model, is aimed at providing
25 yet further confirmation that the original spectrum of breaks
26

1 analyzed was adequate to demonstrate conformance to 10 C.F.R.
2 § 50.46.

3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26

1 ISSUE NO. 7: Confirmation (such as by means of detailed
2 computational analysis or experimental testing)
3 that boiler-condenser circulation flow will
4 transport sufficient core decay heat to the
5 steam generators to prevent core damage (from
6 the licensee and the staff).

4 RESPONSE

5
6 BY WITNESS JONES:

7 For certain sized small-break LOCAs, the steam generators
8 are necessary to remove a portion of the decay heat added to
9 the primary system.^{1/} The Appeal Board has questioned the
10 adequacy of energy removal via the steam generators while
11 operating in the boiler-condenser mode of cooling. Additional
12 analyses are presented in this testimony to demonstrate that
13 boiler-condenser heat removal at TMI-1 is sufficient to remove
14 core decay heat following a LOCA. I have also provided a
15 discussion of the experimental data which supports this
16 conclusion from the analyses.

17 Before discussing the boiler-condenser mode of cooling,
18 however, it is necessary to discuss the relationship between
19 energy removal from the fuel rods (core cooling) and energy
20 removal from the reactor coolant system (RCS). To ensure
21 adequate core cooling during a small-break LOCA, it is

22 _____
23 ^{1/} The discussion that follows assumes the availability of
24 emergency feedwater and one HPI train. Steam generator heat
25 removal is not necessary if two HPI pumps are available. See
26 Jones and Broughton, ff. Tr. 5038.

1 necessary to maintain a two-phase level within the reactor
2 vessel which is at or near the top of the core. In this
3 manner, the core decay heat which is being generated can be
4 removed from the fuel rods by pool boiling or, if the core is
5 slightly uncovered, by forced convection to superheated steam.
6 The HPI system has been designed to provide the necessary fluid
7 makeup to the RCS to ensure adequate core heat removal.

8 Decay heat removal from the RCS can be accomplished in
9 several ways, e.g., by break flow, steam generator heat
10 removal, or combinations thereof. During a small-break LOCA,
11 the decay heat removal is important in that it determines the
12 system pressure and, hence, the HPI flow being provided.
13 Therefore, to demonstrate core cooling, it is only necessary to
14 show that sufficient decay heat removal is provided, prior to
15 core uncover, to allow the HPI system to replace the inventory
16 being boiled by core decay heat removal. In this manner, level
17 in the core can be maintained above the top of active fuel
18 rods.

19 For break sizes smaller than 0.02 ft^2 , decay heat
20 removal from the RCS is accomplished by a combination of the
21 break flow and the steam generators. See Keaten and Jones, ff.
22 Tr. 4588, at 7. If the break sizes are smaller than 0.005
23 ft^2 , the HPI system can compensate for the break flow and
24 maintain the primary coolant loops essentially full of liquid
25 such that natural circulation is not interrupted.
26

1 Assuming a break size between 0.005 and 0.02 ft², the
2 HPI flow is unable to compensate for the leak flow and the RCS
3 will saturate. Steam pockets will eventually form and grow to
4 a volume sufficient to fill the 180° inverted U-bends at the
5 top of both hot legs. This will result in an interruption of
6 natural circulation. The loss of natural circulation leads to
7 a loss of heat removal via the steam generators and the system
8 will pressurize. See Jones and Broughton, ff. Tr. 5038, at
9 6-7; Keaten and Jones, ff. Tr. 4588, at 7.

10 As the RCS continues to lose inventory, a condensing
11 surface will be exposed in the steam generators. This will
12 establish the boiler-condenser mode of heat removal. This mode
13 of heat removal will terminate the pressure increase and
14 control RCS pressure at a value sufficient to assure adequate
15 HPI flow for core cooling. See Jones and Broughton, ff. Tr.
16 5038, at 6-7.

17 Small-break LOCA analyses have been performed which
18 demonstrate the adequacy of this cooling mode. These are
19 documented in Licensee's Exhibit 5. Those analyses were
20 performed utilizing the presently approved CRAFT2 code.
21 Comparison of the steam generator heat removal rates calculated
22 in those analyses to that which would be obtained by using the
23 theoretical formulations in the new model show reasonable
24 agreement. That is, an approximate three-foot adjustment in
25 the condensing length would yield the same heat transfer. This
26

1 small loss of inventory, approximately ten percent of the
2 available inventory above the top of the core, would not affect
3 core cooling.

4 Since the analyses in Licensee's Exhibit 5, the B&W ECCS
5 evaluation model and the CRAFT2 code have undergone modifica-
6 tion in response to II.K.3.30 of NUREG-0737. The revised
7 evaluation model and CRAFT2 code have been submitted to the NRC
8 for review.

9 Within the modified CRAFT2 code, an upgraded steam
10 generator model has been incorporated which includes heat
11 transfer correlations specifically oriented to the boiler-
12 condenser mode of cooling. A new 0.01 ft² break analysis
13 has been performed using the revised code and is documented in
14 BAW-10154. See Licensee Ex. _____, Appendix E. Extrapolation
15 of the results demonstrate that adequate core cooling is
16 maintained for breaks of the size for which boiler-condenser
17 cooling is predicted to occur.

18 The capability of the steam generator to remove sufficient
19 core decay heat to assure adequate core cooling via the HPI
20 system during a small break LOCA is further illustrated by the
21 analysis described below. As stated previously, adequate core
22 cooling is assured if the core is continuously covered by a
23 two-phase mixture. Maintenance of this condition is assured if
24 the HPI flow provided to the system is sufficient to match or
25 exceed the inventory boiled off from core decay heat removal.

26

1 Because the HPI flow varies with system pressure, the time
2 at which the injected flow and core boiling match will be a
3 function of the system pressure. The pressure/time relation-
4 ship for this matchup is illustrated on Figure 1. Thus, the
5 significant question is whether the boiler-condenser mode will
6 assure a pressure/time relationship, before the core becomes
7 uncovered, to yield adequate HPI to keep the core covered.

8 A heat transfer analysis of the steam generator, while
9 operating in the boiler-condenser mode, was performed to
10 develop the pressure/time relationship. Prior to any possible
11 uncovering of the core, the full condensing surface of the
12 steam generator will be exposed. Using this surface area, an
13 analysis was performed to determine the RCS temperature, and
14 hence pressure, necessary to condense all the steam being
15 generated as a result of core decay heat removal as a function
16 of time. It should be noted that since none of the generated
17 steam is assumed to be removed via the break, this analysis
18 would overpredict the RCS pressure that could exist just prior
19 to possible core uncovering. Figures 2 and 3 show the results of
20 the steam generator heat removal analysis for cooling on the
21 steam generator level (at 95 percent on the operating range)
22 and the emergency feedwater spray, respectively.

23 Combining the results of the HPI cooling and steam
24 generator heat removal analyses, as illustrated in Figure 4, it
25 is seen that boiler-condenser heat removal will provide
26

1 sufficient pressure control to result in HPI flows necessary to
2 assure adequate core cooling after 1650 seconds. The next
3 subject of the analysis, then, is to determine whether the core
4 is predicted to become uncovered prior to this time.

5 Several small break LOCA analyses have been performed
6 which indicate that the core could not become uncovered prior
7 to 1650 seconds for the break sizes of interest. In Licensee's
8 Exhibits 3 and 4, which are the section 50.46/Appendix K
9 analyses for TMI-1, it can be seen that the 0.04 ft² break
10 reaches its minimum system inventory at 3000 seconds. No
11 uncovering of the core is calculated for this break. Since
12 smaller breaks would lose inventory at a slower rate, the 0.04
13 ft² break would bound the results.

14 In addition, the analyses of the 0.01 ft² break
15 (documented in Licensee's Exhibit ____ (BAW-10154), show that
16 the boiler-condenser mode of cooling is calculated to occur at
17 approximately 1500 seconds. At this time, there is a substan-
18 tial quantity of liquid (105,600 lb or 2440 ft³) remaining
19 above the top of the core. This inventory would have to be
20 lost through the break prior to the core uncovering. Even if
21 an RCS pressure of 2500 psi was assumed, which is well above
22 the 1800 psi pressure calculated for this time, this inventory
23 could not be lost prior to 1650 seconds.

24 Based on this analysis, it is clear that uncovering of the
25 core would not occur prior to 1650 seconds for the break size
26

1 range for which boiler-condenser heat removal is necessary.
2 Since the boiler-condenser cooling mode assures adequate
3 pressure control after this time to enable the HPI to match or
4 exceed the core boil-off, adequate core cooling is assured.

5 Turning to the Appeal Board's interest in experimental
6 testing of the boiler-condenser mode of heat removal, it should
7 be recognized that the actual heat transfer mechanisms are well
8 understood. Within the primary system steam is condensed on
9 the inside wall of the cooled steam generator. The heat then
10 flows through the tubes, via conduction, and is transferred to
11 the secondary side fluid. Two possible mechanisms exist for
12 the secondary side heat transfer. These are by pool boiling on
13 the immersed steam generator tubes and/or cooling by the
14 emergency feedwater which is sprayed directly on the steam
15 generator tubes.

16 There are several data sources available, or planned,
17 which demonstrate the capability of the steam generator to
18 remove heat in a boiler-condenser mode. First, there is the
19 TMI-2 accident itself. After all of the reactor coolant pumps
20 had been tripped at 100 minutes, filling of the steam generator
21 by emergency feedwater commenced. During the fill period, heat
22 removal from the RCS occurred which controlled the primary
23 system pressure within 100 psi of the secondary side pressure.
24 The only explanation for the pressure curves tracking together
25 is the effect of boiler-condenser cooling in removing decay
26

1 heat. See UCS Ex. 1 (minutes 100 to 125). If the HPI system
2 had been actuated and maintained at this time, adequate
3 inventory would have been maintained to prevent core damage.
4 Thus, the TMI-2 accident did not demonstrate an inadequacy of
5 RCS heat removal (i.e., an inadequacy of boiler-condenser
6 cooling), but rather showed the importance of maintaining
7 adequate core inventory via the HPI.

8 Tests have also been run at the Alliance Research Center
9 (ARC) which examined condensation phenomena in a high pressure
10 facility. In these tests, a single steam generator tube was
11 tested by exposing a condensing surface by adjusting water
12 level on the inside surface of the tube. Then, by varying
13 steam flow to the test section, temperature measurements were
14 taken in order to determine the heat transfer coefficient. The
15 calculated coefficients for these tests have confirmed the
16 conservatism of the heat transfer model employed in the
17 upgraded CRAFT2 code.

18 In the future, additional experimental data on the boiler-
19 condenser mode of cooling and small break LOCA response will be
20 developed at ARC. At present, an integrated systems test
21 facility at ARC (GERDA) is being tested. It is a scaled
22 single-loop, full height, full pressure test facility of a B&W
23 NSS and is of similar size to Semiscale. This facility was
24 developed for the BBR company in Germany in order to examine
25 small break LOCA phenomena. The data from this facility is
26 expected to be available in mid-1983.

1 The B&W Owner's Group, in conjunction with the NRC, is
2 presently exploring a two-loop facility to further examine
3 plant response to small break LOCA and other transients. This
4 data will be used to confirm the adequacy of the computer
5 models. Through the computer codes, this data will then
6 enhance the understanding of plant response for improved
7 operator training and procedures. Data from this facility is
8 projected to be available in mid-1985.

9 In summary, the boiler-condenser mode of cooling is relied
10 upon for heat removal during certain sized small break LOCAs.
11 The basic heat removal processes are well understood and have
12 been successfully applied in other engineering applications.
13 The ability of the TMI-1 steam generator to remove core decay
14 heat has been demonstrated as sufficient to provide adequate
15 core cooling. Thus, while there are presently plans to obtain
16 additional experimental data for the purposes of improved
17 understanding of plant response and for code benchmarking,
18 operation of TMI-1 prior to receipt of this data will not
19 endanger the public health and safety.

Figure 1
HPI MATCHUP WITH CORE DECAY HEAT




Figure 2
RC PRESSURE VS TIME FOR BOILER-CONDENSER
HEAT REMOVAL VIA SG LEVEL




Figure 3
RC PRESSURE VS TIME FOR BOILER-CONDENSER
HEAT REMOVAL VIA EFW SPRAY





Figure 4
RELATIONSHIP OF HPI COOLING AND BOILER
CONDENSER HEAT REMOVAL



ROBERT C. JONES, JR.

Business Address: Babcock & Wilcox Company
Nuclear Power Generation Division
Post Office Box 1260
Lynchburg, Virginia 24505

Education: B.S., Nuclear Engineering, Pennsylvania State University, 1971. Post Graduate Courses in Physics, Lynchburg College.

Experience: July 1982 to present: Supervisory Engineer, Operational Analysis Unit, B&W. Responsible for the performance of plant transient analyses and analyses used in the development of operator guidelines. During this period, has continued as Project Engineer for B&W analyses performed in response to NUREG-0737 Item II.K.3.30.

June 1975 to July 1982: Acting Supervisory Engineer and Supervisory Engineer, ECCS Analysis Unit, B&W. Responsible for calculation of large and small break ECCS evaluations, evaluations of mass and energy releases to the containment during a LOCA, and performance of best estimate pretest predictions of LOCA experiments as part of the NRC Standard Problem Program. Involved in the preparation of operator guidelines for small-break LOCA's and inadequate core cooling mitigation.

June 1971 to June 1975: Engineer, ECCS Analysis Unit, B&W. Performed both large and small break ECCS analyses under both the Interim Acceptance Criteria and the present Acceptance Criteria of 10 CFR 50.46 and Appendix K.