

LICENSEE EVENT REPORT

CONTROL BLOCK: (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | A | L | J | M | F | 1 | 2 | 0 | 0 | - | 0 | 0 | 0 | 0 | - | 0 | 0 | 3 | 4 | 1 | 1 | 1 | 1 | 4 | 1 | 5 | 0 | 1 | 0 | 1 | 1 | 4 | 8 | 3 | 8 | 0 | 2 | 1 | 1 | 8 | 3 | 9

CON'T
01 | REPORT SOURCE | L | 6 | 0 | 5 | 0 | 0 | 0 | 3 | 4 | 8 | 7 | 0 | 1 | 1 | 4 | 8 | 3 | 8 | 0 | 2 | 1 | 1 | 8 | 3 | 9

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 | On 1/14/83 and on 1/15/83 during the performance of FNP-1-STP-608.0 (Main Steam Line
03 | Safety Valve Test), main steam safety valves Q1N11V010A, Q1N11V010C, Q1N11V011C and
04 | Q1N11V012B were declared inoperable due to their relief setpoint being out of tolerance
05 | by +2.23%, -7.17%, -1.36%, -2.21% respectively (3 of 4 in the conservative direction).
06 | Tech. Spec. 3.7.1.1, in part, requires all main steam line code safety valves associated
07 | with each steam generator to be within ± 1% of their design lift set point. Tech.
08 | Spec. 3.7.1.1 action statement requirements were met. Health/safety of the public was
9 not affected.

09 | SYSTEM CODE | H | B | 11 | CAUSE CODE | X | 12 | CAUSE SUBCODE | Z | 13 | COMPONENT CODE | V | A | L | V | E | X | 14 | COMP. SUBCODE | F | 15 | VALVE SUBCODE | B | 16
17 | LER/RO REPORT NUMBER | 8 | 3 | 21 | 22 | SEQUENTIAL REPORT NO. | 0 | 0 | 4 | 24 | 26 | OCCURRENCE CODE | 0 | 3 | 28 | 29 | REPORT TYPE | L | 30 | REVISION NO. | 0 | 32
18 | ACTION TAKEN | E | 18 | FUTURE ACTION | Z | 19 | EFFECT ON PLANT | Z | 20 | SHUTDOWN METHOD | Z | 21 | HOURS | 0 | 0 | 0 | 0 | 37 | 40 | ATTACHMENT SUBMITTED | N | 23 | NPRD-4 FORM SUB. | N | 24 | PRIME COMP. SUPPLIER | N | 25 | COMPONENT MANUFACTURER | V | 1 | 3 | 5 | 26

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 | This event was due to setpoint drift. The valves were readjusted and following the
11 | satisfactory completion of FNP-1-STP-608.0, main safety valves Q1N11V010A, Q1N11V010C,
12 | Q1N11V011C and Q1N11V012B were declared operable on 1/14/83 and 1/15/83.
13 |
14 |

15 | FACILITY STATUS | D | 28 | % POWER | 0 | 0 | 0 | 29 | OTHER STATUS | NA | 30 | METHOD OF DISCOVERY | B | 31 | DISCOVERY DESCRIPTION | Surveillance Test | 32

16 | ACTIVITY RELEASED | Z | 33 | CONTENT | Z | 34 | AMOUNT OF ACTIVITY | NA | 35 | LOCATION OF RELEASE | NA | 36

17 | PERSONNEL EXPOSURES NUMBER | 0 | 0 | 0 | 37 | TYPE | Z | 38 | DESCRIPTION | NA | 39

18 | PERSONNEL INJURIES NUMBER | 0 | 0 | 0 | 40 | DESCRIPTION | NA | 41

19 | LOSS OF OR DAMAGE TO FACILITY TYPE | Z | 42 | DESCRIPTION | NA | 43

20 | ISSUED DESCRIPTION | N | 44 | NA | 45

NAME OF PREPARER: W. G. Hairston, III

PHONE: (205) 899-5156