



Pennsylvania Power & Light Company

Two North Ninth Street • Allentown, PA 18101 • 215 / 770-5151

February 10, 1983


Mr. R.C. Haynes  
Director, Region I  
U.S. Nuclear Regulatory Commission  
631 Park Avenue  
King of Prussia, PA 19406

SUSQUEHANNA STEAM ELECTRIC STATION  
LICENSEE EVENT REPORT 83-011/03L-0  
ER 100450 FILE 841-23  
PLA- 1531

Docket No. 50-387  
License No. NPF-14

Dear Mr. Haynes:

Attached please find a copy of Licensee Event Report No. 83-011/03L-0. This event was determined to be reportable per Technical Specification 6.9.1.9.b, in that the "C" Diesel Generator was declared inoperable after determination was made that the air start receiver pressure was below Technical Specification limits.

  
H.W. Keiser  
Superintendent of Plant-Susquehanna

DGM/cg

Attachment

cc: Director of Nuclear Reactor Regulation  
Attention: Mr. A. Schwencer, Chief  
Licensing Branch No. 2  
Division of Licensing  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555

G. Rhoads  
Resident Inspector  
U.S. Nuclear Regulatory Commission  
P.O. Box 52  
Shickshinny, PA 18655

8302220380 830210  
PDR ADOCK 05000387  
S PDR

IEU