



CHARLES CENTER • P. O. BOX 1475 • BALTIMORE, MARYLAND 21203

ARTHUR E. LUNDVALL, JR.  
VICE PRESIDENT  
SUPPLY

September 7, 1982

Office of Nuclear Reactor Regulation  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Attn: Mr. Robert A. Clark, Chief  
Operating Reactors Branch #3  
Division of Licensing

Subject: Calvert Cliffs Nuclear Power Plant  
Units Nos. 1 & 2; Dockets Nos. 50-317 and 50-318  
Appendix R Requirement  
Source Range Flux Monitoring

- References: (a) NRC letter from R. A. Clark to A. E. Lundvall, Jr. dated August 6, 1982  
(b) BG&E letter from A. E. Lundvall, Jr. to R. A. Clark dated May 14, 1982

Gentlemen:

Based upon the NRC Staff's insistence that source range monitoring is a requirement of 10 CFR 50 Appendix R, Section III.L.2 (reference (a)), Baltimore Gas & Electric will provide one channel of source range flux monitoring instrumentation for each unit at Calvert Cliffs Nuclear Power Plant. The indication will be provided on the Alternate Shutdown Panel which is presently being installed under the Auxiliary Feedwater Modification Project. As required by section III.G.3 of the appendix, this indication will be installed so that no single fire can affect source range flux monitoring capability in the main control room and at the auxiliary shutdown panel.

In order to properly coordinate this effort with other projects at Calvert Cliffs, we request an additional 90 days from the date of this letter to provide our schedule for implementation of this requirement.

Very truly yours,

A006

AEL/MDP:gvv

cc: J. A. Biddison, Jr., Esquire  
G. F. Trowbridge, Esquire  
Mr. D. H. Jaffe - NRC  
Mr. R. E. Architzel - NRC

8209140326 820907  
PDR ADOCK 05000317  
F PDR