

ORIGINAL

OFFICIAL TRANSCRIPT PROCEEDINGS BEFORE

NUCLEAR REGULATORY COMMISSION
NRC STAFF WITH PACIFIC GAS & ELECTRIC COMPANY


DKT/CASE NO.

TITLE COMPONENT COOLING WATER SYSTEM
DIABLO CANYON UNIT 1

PLACE Bethesda, Maryland

DATE January 28, 1983

PAGES 1 - 183



8302230006 830203
PDR ADOCK 05000275
PDR

(202) 628-9300
140 FIRST STREET, N.W.
WASHINGTON, D.C. 20541

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION
- - -
MEETING OF NRC STAFF WITH
PACIFIC GAS & ELECTRIC COMPANY
REGARDING
COMPONENT COOLING WATER SYSTEM
DIABLO CANYON UNIT 1
- - -

Bethesda, Maryland
Friday, January 28, 1983

The meeting in the above-entitled matter
convened at 9:10 a.m.

PARTICIPANTS:

FOR THE COMMISSION STAFF:

- | | |
|--------------------|--------------------|
| Harold Denton, NRR | D. Eisenhut, DL |
| R. Mattson, DSI | H. Schierling, DL |
| R. Bosnak, DE | O. Parr, DSI |
| J. Crews, RI | L. Rubenstein, DSI |
| L. Chandler, OELD | J. Goldberg, OELD |
| H. Polk, DE | D. Lasher, DST |
| R. Kirkwood, DE | J. Wermiel, DSI |
| W. LeFave, DSI | R. Buckley, DL |
| J. Knight, DE | |

1 PARTICIPANTS: (Continued)

2 FOR PACIFIC GAS & ELECTRIC COMPANY

3 R. Locke G. Maneatis

4 J. Bergler R. Palm

5 G. Pruett

6 FOR DIABLO CANYON PROJECT:

7 R. Anderson G. Moore

8 J. Tinlin T. Tinlin

9 T. Crawford E. Connell

10 B. Lew C. Ward

11 J. Hoch H. Friend

12 FOR BECHTEL CORPORATION:

13 C. Aronson

14 FOR WESTINGHOUSE:

15 J. Schlonski R. Loose

16 J. Hoebel W. Gangloff

17 D. Popp K. Handerhan

18 FOR TELEDYNE:

19 W. Cooper D. Stratouly

20 FOR SWEC:

21 F. Sestak

22 ON BEHALF OF PACIFIC GAS & ELECTRIC:

23 Bruce Norton, Esq.

24 Norton, Burke, Berry & French

25 ALSO PRESENT:

K. GOLDENBERG

C O N T E N T S

| | | |
|----|---|-------------|
| 1 | | |
| 2 | <u>OPENING REMARKS:</u> | <u>PAGE</u> |
| 3 | By Mr. Maneatis | 8 |
| 4 | | |
| 5 | <u>INTRODUCTION & OUTLINE OF PRESENTATION</u> | |
| 6 | By Mr. Anderson | 8 |
| 7 | <u>AGENDA ITEM 3: DESCRIPTION OF CCW SYSTEM</u> | |
| 8 | By Mr. Connell | 26 |
| 9 | <u>AGENDA ITEM 5: INSTRUMENTATION</u> | |
| 10 | By Mr. Crawford | 107 |
| 11 | | |
| 12 | <u>AGENDA ITEM 6: OPERATION</u> | |
| 13 | By Mr. Tinlin | 132 |
| 14 | <u>AGENDA ITEM VII - RESPONSE TO SPECIFIC</u> | |
| 15 | <u>NRR QUESTIONS</u> | |
| 16 | By Mr. Moore | 150 |
| 17 | <u>AGENDA ITEM VIII - FUTURE PROJECT ACTION</u> | |
| 18 | By Mr. Anderson | 177 |
| 19 | | |
| 20 | | |
| 21 | | |
| 22 | | |
| 23 | | |
| 24 | | |
| 25 | | |

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

PROCEEDINGS

MR. DENTON: Let's begin.

The purpose of this meeting today is to discuss the design and operation of the component cooling water system, including its seismic, nonseismic interfaces, safety and nonsafety interfaces and systems, and the application of single failure criteria design of the system.

It came to our attention a few weeks back that questions such as these had arisen during the course of the internal review of the system. As a result of these questions, I had the Staff go back and review what had been submitted about the system and what we had said about it in our safety evaluation report.

The timing of this plant was such that it was not reviewed against the current version of the standard review plan. It was reviewed against an earlier version.

What we would like to do today is to have you describe the system and its design and its design philosophy and operation and why you think it will perform its intended function. And there is an agenda that has been passed around that looks like an adequate way to begin the meeting, and I would suggest we follow the agenda to the extent we can to allow you an

1 opportunity to cover all the points you want to make.

2 We have a number of people here today that
3 have not been involved in the most recent independent
4 design verification effort, and I think it would be
5 useful to go around the table and perhaps make sure we
6 all know each other.

7 I am Harold Denton of ERR.

8 MR. EISENHUT: I'm Darrell Eisenhut.

9 MR. MATTSON: I'm Roger Mattson, Director of
10 Systems Integration.

11 MR. WATT: I'm Richard Watt, PG&E.

12 MR. HOCH: John Hoch, PG&E Diablo project.

13 MR. FRIEND: Howard Friend, Diablo Canyon
14 project.

15 MR. NORTON: Bruce Norton, representing Diablo
16 Canyon project.

17 MR. MANEATIS: George Maneatis, Pacific Gas &
18 Electric Company.

19 MR. ARONSON: Chuck Aronson, Bechtel
20 Corporation.

21 MR. CONNELL: Ed Connell, Diablo Canyon
22 project.

23 MR. CRAWFORD: Tom Crawford, Diablo Canyon
24 project.

25 MR. TINLIN: Jim Tinlin, Diablo Canyon

1 project.

2 MR. MOORE: Gary Moore, Diablo Canyon

3 project.

4 MR. ANDERSON: Dick Anderson, Diablo Canyon

5 project.

6 MR. RUBENSTEIN: Les Rubenstein, Assistant

7 Director for In-Plant Systems.

8 MR. CREWS: Jess Crews, Region V.

9 MR. BOSNAK: Bob Bosnak, DE.

10 MR. PARR: Olin Parr, DSI.

11 MR. SCHIERLING: Hans Schierling, Division of

12 Licensing.

13 MR. EISENHUT: I think that is probably

14 enough.

15 MR. DENTON: Roger, do you have any opening

16 comments?

17 MR. MATTSON: Well, maybe just to elaborate a
18 little bit on what Harold said. The systems people, the
19 people that look at the functional performance of safety
20 systems, have not really concentrated on this plant in a
21 number of years. The principal review was completed
22 back in the SER stage, maybe 1974.

23 Since that time there have been some advances
24 in the way that we looked at systems reliability, safety
25 systems reliability, safety system function and

1 assurance. The standard review plan is the current
2 manifestation of how we look at the system.

3 So when we began to become involved in the
4 Diablo Canyon project in the last few months, it was an
5 expanse to phase two, and the most recent questions have
6 come up on the missile cooling water system. The
7 easiest charge for us to put our hands on is the
8 standard review plan. That is how our Staff is
9 trained. That is how we think today.

10 Now, the Commission's requirements on the
11 implementation of the standard review plan are somewhat
12 different than just go forth and use it blindly. We
13 can't do that. We don't intend to do that.
14 Nevertheless, the best way for us to get some feeling
15 for how good a safety system is on any plant -- an old
16 plant, a new plant, a future plant -- is to start with
17 the standard review plan.

18 So don't jump to the conclusion, just because
19 we have asked you questions or will ask you questions
20 that flow from today's standard review plan, that you
21 necessarily have to meet it. You may or may not,
22 depending on how good your system is and how it stacks
23 up reliabilitywise, the assurance of its functionwise,
24 as we go along here and dig into it and explore it.

25 But we had a judgment that, given that there

1 were questions raised on component cooling water system,
2 we might as well start from the beginning, looking at it
3 according to the best available light. And that's why
4 you will hear some things that may be different in the
5 criteria against which the component cooling water
6 system was reviewed in 1972, 1973, 1974.

7 MR. EISENHUT: With that, I understand, Mr.
8 Maneatis, you have a number of people to go through a
9 presentation. So at this point why don't you go ahead.

10 OPENING REMARKS

11 MR. MANEATIS: Well, Harold pretty much
12 covered my introductory remarks as to the reason we are
13 here. Since we have a long and hopefully interesting
14 agenda ahead of us, I'm going to turn the meeting over
15 immediately to Dick Anderson, the engineering manager of
16 the Diablo Canyon project, who will provide you with an
17 overview of the presentation and introduce our
18 presenters.

19 INTRODUCTION AND OUTLINE

20 OF PRESENTATION

21 MR. ANDERSON: As you can see from the agenda
22 and outline we passed out, we have a rather broad and
23 comprehensive presentation to make on the component
24 cooling water system, how it is, how it was designed,
25 its requirements, the philosophy, if I could use that

1 term, how it operates. And we plan to go through in
2 some detail and explain that to you today.

3 This is of course in response to Mr.
4 Eisenhut's request at the January 13th meeting to
5 describe the CCW system in all of its different
6 aspects. In introducing this subject, I think it would
7 be worthwhile to go back and briefly, very briefly,
8 review the history of how this issue developed on the
9 project.

10 Certain concerns about the CCW system were
11 raised by one of our own engineers who was reviewing the
12 system in connection with the phase one design
13 verification program. On November 24th, after
14 considerable review and discussion, the engineer's
15 concerns were formally documented in a memo to his
16 supervisor, which in turn triggered a potential
17 nonconformance report being initiated on December 1 in
18 accordance with the project procedure.

19 Again in accordance with the procedures, the
20 project engineer established a technical review group
21 and this technical review group was made up of both
22 on-project and off-project personnel. It was a mixture
23 of on-project and off-project people and also a mixture
24 of Bechtel and PG&E people, to try to get the broadest
25 and most comprehensive review of the issues.

1 The group was chaired by the project engineer,
2 Gary Moore. It had on it Paul Schmitz, who is the chief
3 nuclear engineer from Bechtel's Power Management Group.
4 It had Charles Aronson from the chief nuclear engineer's
5 staff. He is the supervisor of the safety group. It
6 had Ray Ashley, who is the licensing manager for the
7 Diablo Canyon project and former chief nuclear engineer
8 of our Gaithersburg office.

9 It had Dan Brand, who is the assistant project
10 engineer, systems; Dan Hardy, who is the assistant
11 project engineer, quality. It had Ed Connell, the
12 mechanical group supervisor. It had Russ Lesardy, who
13 is the engineer on the project who raised the original
14 concern. It had Jim Tinlin, who is a senior reactor
15 operator and the training coordinator for PG&E's nuclear
16 power operations.

17 It had Mike Jacobson, who is project QA
18 engineer; Jim Hickley, who is PG&E QA engineer; and
19 myself as engineering manager for Diablo Canyon
20 project.

21 Now, when a technical review group is formed,
22 in accordance with the PG&E and project procedures the
23 technical group must vote unanimously before an issue
24 can be resolved. So this group had to have unanimous
25 consensus on any issue that was to be resolved

1 completely.

2 MR. EISENHUT: Dick, can I ask one question of
3 something you said? I think you used the word
4 "nonconformance." You said in December or something you
5 reached an internal determination of a nonconformance.

6 MR. ANDERSON: We opened a potential
7 nonconformance report and then established a technical
8 review group to review the merits of the issue. That
9 was in accordance with the procedures.

10 MR. FRIEND: When was that, Dick?

11 MR. ANDERSON: Well, the nonconformance report
12 was taken up on December 1 and the written notification
13 from the engineer to the supervisor was November 24th.
14 So this has been going on for some time.

15 MR. EISENHUT: My question was, how does that
16 relate to a nonconformance where you notify the NRC of
17 the nonconformance? I mean, you have a potential
18 question, you call it a potential nonconformance or a
19 nonconformance. How does that relate to a
20 nonconformance in the normal jargon that we use?

21 MR. ANDERSON: Maybe Gary can answer that
22 better than I can.

23 MR. MOORE: Well, as a result of the technical
24 review group, it first assesses whether the issue is a
25 nonconformance against a set of criteria, whether that

1 be nonconformance against licensing criteria or other
2 requirements. Once it determines it is a
3 nonconformance, it identifies an active description of
4 the problem, it identifies the cause of the
5 nonconformance, it identifies a resolution to that
6 specific nonconformance. It also identifies any
7 corrective action that might be associated with that
8 nonconformance in regards to other areas outside of the
9 specific issue on the nonconformance.

10 Another action that the TRG performs is it
11 reviews that nonconformance against the various
12 regulations with regard to reportability. On Unit 1,
13 since we have an operating license it was reviewed
14 against 50.59. It was also reviewed against Part
15 21-type reportability. Since Unit 2 is not having an
16 operating license, the Unit 2 organization would review
17 it against the requirements of 50.55(e). And I think
18 Dick's remarks will get into actually how the process
19 has worked with regard to this particular
20 nonconformance, but that is the general procedure.

21 MR. CREWS: Can I follow up just a bit on
22 that?

23 MR. DENTON: Perhaps each speaker, Jesse,
24 should give his name.

25 MR. CREWS: Jess Crews.

1 The question I have is really very much
2 related to Darrell's and it regards reportability. Now,
3 I know that you have established procedures within the
4 company, and I'm sure PG&E has as well, for handling
5 compliance with Part 21 to be sure that matters that may
6 involve defects or other conditions that must be
7 addressed in Part 21, and ultimately that leads to the
8 notification of the corporate officer, who is
9 responsible then to promptly report to the Commission.

10 And I guess my question is, with regard to
11 Part 21 per se, is how you incorporated or adapted those
12 company internal procedures to the internal, to the VPP
13 and to the internal technical group as items are washed
14 up that should be considered.

15 And then I would like to add to that one
16 other, that beyond those mentioned the technical
17 specifications associated with the Unit 1 license have
18 specific requirements for reportability as well, and I
19 know that is a big question. But can you describe
20 generally how that is handled in the framework of
21 procedures you established formally in the past as it
22 relates to this special effort by VPP and the internal
23 Bechtel program?

24 MR. MOORE: Yes, Jess. I think I remembered
25 all the parts of your question.

1 Number one, with regard to how the technical
2 review group addresses Part 21 reportability, it itself
3 does not determine reportability. It only makes a
4 recommendation as to taking the matter to the corporate
5 Part 21 committee. And as a function, I said, with
6 regard to reportability, the technical review group does
7 not determine reportability; it just determines whether
8 it should be recommended on up to the corporate Part 21
9 committee.

10 Secondly, with regard to the internal
11 verification program -- excuse me, the independent
12 verification program, we treat those set of procedures
13 separate from the quality program set of procedures, and
14 in specific with regard to this issue, the project
15 initiated open item 34 in our semi-monthly report, which
16 I believe was the second semi-monthly report in
17 December, with regard to this issue, and that is how we
18 reported it under the internal verification program
19 procedures.

20 Now, with regard to how the tech spec aspect
21 of the nonconformances is reviewed, I may not have
22 correctly cited the regulation, but when I mentioned
23 that we reviewed the nonconformance against 50.59
24 requirements, it is in that review that the tech specs
25 are addressed.

1 MR. ANDERSON: Maybe as we go along you'll see
2 what we did and that is in accordance with the
3 procedures. Remember now that the Letter of concern --

4 MR. CREWS: Dick, before you get to that, the
5 TRG, I guess for my clarification, is the TRG an ongoing
6 function or is it something that is a TRG that is formed
7 to deal with specifics?

8 MR. ANDERSON: This was set up specifically to
9 deal with this issue. The people on the TRG were chosen
10 specifically to be able and capable of dealing with this
11 issue.

12 MR. CREWS: But is there generally a charter
13 for TRG's? And you mentioned the TRG has
14 responsibilities for reporting, that sort of thing. Is
15 that on a case by case basis?

16 MR. MOORE: When a nonconformance is
17 initiated, each time that is done a unique TRG is
18 formed. The chairman is always myself in Unit 1's case
19 and there are a set number of members based upon their
20 organization. We have a member of the PG&E quality
21 assurance department on the committee, we have a member
22 of PG&E's operating department on the committee, we have
23 a member of the project quality assurance department on
24 the committee, and also a member of the quality
25 engineering group within the engineering department on

1 the committee.

2 Then I have the responsible technical area
3 represented on the committee, depending upon what the
4 subject is, and then I have the freedom to add anyone
5 else that I feel is appropriate to the committee, either
6 based upon their experience or their understanding, and
7 it is unique depending upon what the subject is.

8 MR. DENTON: I hoped we could get into the
9 technical side. But having gotten into the procedural
10 side, let me explore this just a bit. Who selects the
11 membership on this committee?

12 MR. MOORE: I do. In the case of Unit 1, the
13 project engineer does.

14 MR. DENTON: Now, I take it some concerns come
15 up the line that you agree with and you never establish
16 such a committee. So what is the basis for establishing
17 that committee when a concern exists?

18 MR. MOORE: At the lowest level, if we can
19 take it that way, a concern is identified to the
20 responsible supervisor. In this case it was the
21 mechanical group supervisor.

22 MR. DENTON: Suppose the supervisor says right
23 on, I agree?

24 MR. MOORE: He has basically three options
25 when the concern is raised to him. Based upon his

1 judgment, he can determine that the issue has no
2 significance and indeed it is not an issue and dispatch
3 it. If he determines it is of a minor nature, a
4 procedural nature, he can open what we call a
5 discrepancy report. And if he determines that it is
6 significant or has potential significance, then he goes
7 and gets the PG&E chief to initiate a nonconformance
8 that addresses the issue and then the TRG is formed.

9 But the initial judgment of whether -- what
10 classification, if you will, the issue should be given
11 is made by that supervisor, and I think it is fair to
12 say that that process is monitored by the quality
13 assurance organization in the project. They look at
14 DR's, they look at nonconformances, to make sure that
15 reasonable judgment is given.

16 MR. DENTON: Does the supervisor's judgment
17 automatically get reviewed by a TRG, then, if it is
18 classified in the most severe significance?

19 MR. MOORE: Yes. With regard to this specific
20 issue, the group supervisor came to me, advised me of
21 the issue, and it was my recommendation, and he
22 concurred, that the issue had enough significance that
23 we shouldn't make the determination ourself and should
24 allow the TRG to make that determination.

25 MR. DENTON: And has the group completed its

1 review?

2 MR. ANDERSON: Maybe I could go on, then, and
3 tell you a little bit about what happened with the TRG.
4 They held meetings on December 10th, December 22nd,
5 January 19th and January 21st to evaluate the issue. In
6 addition, they established a subcommittee to perform
7 specific investigations and report back to the larger
8 TRG group.

9 The project engineer instructed the TRG to do
10 three things. The first was to answer the question,
11 does the CCW system meet the licensing commitments.
12 That was the first question.

13 Secondly, should the issue or any part of the
14 issue be sent to PG&E's 10 CFR Part 21 committee? In
15 other words, does the TRG believe that there is anything
16 reportable under 10 CFR 21, whether or not the system
17 meets the licensing commitments.

18 And then thirdly, should any additional work
19 be done on the system even if it meets the licensing
20 commitments and is not a 10 CFR Part 21 issue.

21 So it was a rather broad-based challenge to
22 the committee to do all of these, to address all of
23 these questions. At this point the TRG has been making
24 good progress in its evaluation of the CCW system, but
25 it has not completed its work. Conclusions and

1 findings, however, have been reached as follows:

2 It was unanimously agreed that the small
3 post-LOCA sample cooler added in response to the TMI
4 backfit requirements does not meet design class 1
5 requirements as required by the FSAR, although it
6 subsequently has been qualified for seismic category 1
7 requirements.

8 It was also unanimously found that the loop C
9 heat exchangers meet the pressure boundary requirements
10 of the FSAR.

11 It was also unanimously agreed, based upon all
12 of the information available to date, that further
13 action under Part 21 would not be recommended. That is,
14 the issues raised were not reportable under Part 21 in
15 the judgment of the technical review group.

16 Unanimous agreement, however, was not achieved
17 on the remaining two issues: the design classification
18 of the surge tank level switch, it voted that it did
19 meet by 11 to 1; and the issue involving heat loads
20 other than design basis accident conditions, voted 10 to
21 2 that the licensing commitments were met.

22 In those two issues, we have referred those to
23 a management level technical review group within the
24 PG&E organization. The technical review group has not
25 yet made its recommendations on further action, the

1 third question that the project engineer wanted
2 answered. However, the project has already initiated
3 some further action to be described under Section 8 of
4 our presentation today.

5 In accordance with the verification
6 procedures, as Gary mentioned, open item number 34 was
7 initiated on December 13th, 1982, and the issue was
8 reported in our semi-monthly report.

9 Now, getting to today's agenda, we have given
10 a great deal of thought as to how to present this broad
11 and comprehensive subject matter. We received on
12 Tuesday a list of your examples of topics and questions
13 to be included on a presentation. We could go directly
14 to those issues and give you a series of kind of
15 one-liner answers, like the CCW system including loop C
16 doesn't meet the seismic category 1 requirements in the
17 piping.

18 However, if we did that I'm afraid we might
19 leave a confused record and might not be responsive to
20 Mr. Eisenhut's rather broad charge given in our January
21 13th meeting.

22 MR. DENTON: I would prefer that we get the
23 complete description and understanding of the system
24 before we go to detailed questions.

25 MR. ANDERSON: Very good. Then if we could go

1 over the agenda, and you all have that in front of you,
2 I would like to kind of point out where we're going, so
3 we get a feel for how this is going to progress.

4 First we want to give a description of the
5 component cooling water system, and Ed Connell is going
6 to go over the system diagram and he's going to give a
7 system description in a somewhat unique way. He's going
8 to use the standard review plan format, even though that
9 was not required for this plant. That certainly is your
10 point of reference and we could use your point of
11 reference to describe the system.

12 Then we're going to show some color slides
13 with emphasis on the C loop piping and components. Now,
14 obviously we run somewhat of a risk in doing that.
15 Color slides do not show up well in the record, and we
16 also in showing color slides, we can have endless
17 questions on the details of the slide. Now, we have all
18 of the slides indexed and we can come back to them later
19 on if you want to discuss a certain picture.

20 But what we want Gary Moore to do is to go
21 through the slides showing the system and point to both
22 the component and the diagram, so that everybody gets a
23 picture in their mind not only of what the diagram looks
24 like but what the plant looks like at the same time. I
25 think that will be interesting for you.

1 Then we have asked Chuck Aronson to give a
2 rundown on the criteria and design philosophy, the
3 general background, the specific component cooling water
4 requirements for licensing basis, the safety-nonsafety
5 related interfaces, the seismic-nonseismic interfaces,
6 the single failure criteria and the heat loads.

7 And then, since instrumentation is woven
8 throughout this, it is hard to put that in at various
9 different points. We have asked Tom Crawford to give a
10 presentation on the instrumentation itself as a separate
11 subject.

12 And then finally we're going to talk about
13 operation, how the system is operated and particularly
14 how contingency modes of operation are handled. And
15 then, since you sent us your questions just recently, we
16 will respond under item 7 of the agenda to those
17 specific questions.

18 At that point I think we can open it up to
19 your questions and discussions, but up to that time we
20 really would prefer to be able to get through the whole
21 presentation. It won't take too long, but it will give
22 a broad base from which further discussion can be then
23 developed.

24 We have handouts that we will be handing out
25 of each presenter's presentation, and I think they are

1 going to follow the written handouts pretty carefully.
2 So if you have questions you can certainly make comments
3 in the margin or something like that and we can come
4 back to the questions.

5 What we want to avoid is getting bogged down
6 in some particular detail without having the broad
7 perspective and understanding of how this particular
8 component cooling water is designed and what the basis
9 for it really is.

10 MR. DENTON: Can you estimate the length of
11 time required for the presentation if it were reasonably
12 uninterrupted?

13 MR. ANDERSON: If it were reasonably
14 uninterrupted, I think maybe an hour and a half to an
15 hour and 45 minutes would be enough to cover the three
16 fundamental presentations and give the whole background,
17 and then we could get into the detailed discussions
18 after that.

19 And then finally we will make a very brief
20 statement about the future project action that we plan.
21 It is listed here as item 8 and you can see by the
22 titles that are given what we plan to do. We do believe
23 that we will demonstrate in this meeting that the system
24 as designed and constructed meets any reasonable
25 interpretation of the design requirement for Diablo

1 Canyon.

2 However, to confirm some of the original
3 judgment regarding seismic capability of loop C
4 components and to evaluate proper operating conditions
5 beyond the FSAR evaluations, we are performing
6 additional evaluations in those specific areas.
7 Obviously, if these further evaluations indicate that
8 changes should be made we will be making changes
9 accordingly.

10 So at this point I would like to turn it over
11 to Ed Connell. He is the mechanical supervisor on the
12 project. He is from Bechtel. He has been involved in
13 the project since March of last year. He has had close
14 to ten years experience in the nuclear industry. And
15 with that I will just turn it over to you, Ed.

16 MR. CHANDLER: Before Ed picks up on it, one
17 question of Gary Moore on the procedures regarding the
18 TRG, if I can. You mentioned earlier that the basic
19 decision as to whether to establish a TRG is, I guess,
20 left to the supervisor based upon a determination of the
21 significance of the concern raised. What is the
22 procedure if there's a dispute between the individual
23 raising a concern and a supervisor as to significance?

24 MR. MOORE: Okay, just one minor correction.
25 He doesn't decide whether a TRG is to be formed or not.

1 He decides whether a potential nonconformance should be
2 filed or not. Then he has, the individual with the
3 concern has, the normal recourses, to go to his
4 supervisor's boss either up through the project
5 organization or in this case he has really two
6 functional organizations he can also go up through,
7 namely to his chief and, if that isn't good enough, on
8 up into the corporate management of the respective
9 organization.

10 And if he's still not satisfied, the ultimate
11 recourse that he has is going to the NRC.

12 MR. ANDERSON: It may seem strange the way we
13 are organized in having always two bosses. The people
14 work for the project group for daily direction and the
15 project team is put together, but they still have their
16 functional chief. In the case of Bechtel people they
17 have the Bechtel chief engineer, who is responsible for
18 that person's career, for their development, and for
19 their salary.

20 So there is a double supervision kind of an
21 organization here and the engineer always has recourse
22 to go to the chief engineer if he feels the project
23 people, the supervisor or the project engineer or
24 whoever else is on the project is not giving a technical
25 issue the proper attention.

1 AGENDA ITEM 3. DESCRIPTION OF CCW SYSTEM

2 MR. CONNELL: Let me describe the component
3 cooling water system in general, and I will discuss its
4 basic arrangement, its components and various operating
5 modes, performance requirements and the interfaces to
6 the other supporting systems. Afterwards I will get
7 into a discussion of principal design considerations of
8 the component cooling water systems.

9 (Slide.)

10 The system is designed to remove waste heat
11 from the primary plant equipment and components during
12 normal operation, plant cooldown and following a loss of
13 coolant accident. The components and equipment served
14 are either engineered safety features or have a
15 potential for leakage of radioactive fluid into the CCW
16 system.

17 The system serves as an intermediate system
18 between normally radioactive systems and the auxiliary
19 salt water system. This double barrier design reduces
20 the possibility of the leakage of radioactive coolant to
21 the ocean.

22 (Slide.)

23 MR. EISENHUT: I think what you're going to
24 have to do is a couple of you are going to have to move
25 back a little bit so we can see where you're pointing on

1 the slide. That's fine, I think.

2 MR. CONNELL: The systems consist of three
3 component cooling water pumps, two heat exchangers, one
4 surge tank which is internally divided so that in effect
5 it acts as two tanks, a split on the three loops called
6 header A, vital, header C, nonvital, header B, vital.
7 Each of them serve a number of users on that loop.
8 There is also two chemical addition tanks, one in each
9 loop.

10 When I mention vital components what I mean by
11 vital is that that component is required to perform a
12 safety function. Notice that except for the components
13 on the C loop, chemical addition tanks and the post-LOCA
14 sample cooler, all of the CCW system including the
15 piping and the valves is a Design Class I system.
16 Design Class I means that the design, fabrication and
17 construction is in accordance with the requirements of
18 10 CFR 50, Appendix B, and it meets the intent of all
19 NRC requirements for safety-related systems.

20 All users, whether vital or nonvital, are
21 capable of being individually isolated by Class 1
22 valves. In general, the components inside containment
23 can be isolated from the control room. The other
24 components are isolated by local manual valves. Each of
25 the three loops can also be isolated using only Design

1 Class I valves.

2 For example, if you wanted to isolate loop C
3 you could do so by closing that valve FCV-355 on the
4 supply side to the C users, and on the discharge or the
5 suction side of the pump you could close this manual
6 locally operated valve. Each of the other loops works
7 in a similar manner.

8 (Slide.)

9 MR. EISENHUT: I'm not sure I heard the last
10 thing you said. They can be closed manually, local or
11 remote?

12 MR. CONNELL: On the suction side, the pump
13 suction side, those are local manual valves. They are
14 located in the pump room.

15 MR. EISENHUT: And on the other side?

16 MR. CONNELL: 355 is remote, manually operable
17 from the control room, as well as, as you can see, it
18 gets a P signal. Those are local manual valves, as Gary
19 just pointed out, on the crosstie header.

20 MR. MATTSON: The center pump there, that is
21 local manual?

22 MR. CONNELL: Yes, all the valves shown are
23 local manual unless they have an operator on them.

24 The three component cooling water pumps are
25 Design Class I horizontal centrifugal, rated at 9200

1 gpm. They are made of carbon steel. They are located
2 in the lower elevation of the auxiliary building. Each
3 of the pumps is fed by a separate vital 4-KV bus.

4 The two heat exchangers are of a shell and
5 straight tube design. The auxiliary salt water goes
6 through the tube side. The manufacturer's rating for
7 the heat exchanger is 258.8 million Btu's per hour.
8 They are located in the turbine building. It is carbon
9 steel in the shell and carbon-nickel in the tubes.

10 The two chemical addition tanks which are used
11 to inject corrosion inhibitor are carbon steel. Note
12 that they are manually, through manual valves. In
13 normal operation the manual valves are closed.

14 MR. DENTON: I'm still unclear. I think one
15 of the points of confusion when we first looked into
16 this was whether or not header C including the heat
17 exchanger and piping valves were or were not considered
18 class 1 by you, and you say that they definitely are.
19 Is that correct?

20 MR. CONNELL: The piping and the valves up to
21 the individual components on the header are Design Class
22 I piping and valves. The individual components, and I
23 think we're going to talk about each one a little bit
24 later, they are not required to be Class I. They do not
25 serve a safety function.

1 Some of the components are built as if they
2 were to perform a safety function. Most of the others
3 have varying degrees of assurance, if you will.

4 MR. DENTON: Well, let me be clear, then.
5 Everything that is in the box header A is seismic
6 category I?

7 MR. CONNELL: That is correct. I have broken
8 out one piece there which is really on the A loop, and
9 that is the post-LOCA sample cooler which I am going to
10 talk about a little in depth in a few minutes.
11 Everything in B is -- everything in A except for the
12 sample cooler is also seismic category I.

13 MR. DENTON: I take it later on you're going
14 to talk about what is inside the box labeled "header
15 C"?

16 MR. CONNELL: That is correct.

17 MR. EISENHUT: Just to make sure I understand,
18 you said the piping up to the component which need not
19 be Class I is Class I, and you said the valves. Now, do
20 each of those non-Class I components, do they have their
21 own isolation devices, valves to take them out?

22 MR. CONNELL: Yes.

23 MR. EISENHUT: And those isolation valves on
24 those components are Class I?

25 MR. CONNELL: That's correct. Gary has some

1 good pictures later on.

2 MR. ANDERSON: We will show this in the
3 pictures and we will show what the breakdown is. The
4 heat exchangers are not designed to Class I, however.
5 Seismic considerations were certainly given to the
6 design of the whole loop. The idea was to have a low
7 stress level at the nozzle and the piping is seismic
8 category I, and we will get into that as we go along.

9 MR. EISENHUT: My question was a little
10 simpler, though, and that is for each component hooked
11 to that loop there is in fact another set of valves that
12 you can see here?

13 MR. CONNELL: That's correct.

14 MR. EISENHUT: That are Class I isolation
15 valves?

16 MR. CONNELL: Yes. We have a slide to show
17 that. It is Class I isolation valves on each side.

18 MR. EISENHUT: Of each non-Class I component?

19 MR. CONNELL: That's correct.

20 MR. BUCKLEY: Are the chemical addition tanks
21 seismic?

22 MR. CONNELL: The chemical addition tanks are
23 not required to be seismic because they are manually
24 valved out of the system. Those valves are Class I
25 according to our classification scheme. They are not

1 seismic.

2 MR. BUCKLEY: The chemical addition tanks
3 themselves, but the valves are?

4 MR. CONNELL: They are not designated design
5 class I. As I said, we have one surge tank. It has a
6 capacity of 10,750 gallons. The minimum level during
7 normal operation is 4,000 gallons. It's also made of
8 carbon steel, and it is located on the roof of the
9 auxiliary building. And as you can see there, it is
10 split so that each side feeds one of the vital loops.

11 The valves I guess I talked about. The piping
12 is carbon steel. It is welded with flange connections.

13 (Slide.)

14 Now I want to talk about what's inside these
15 three boxes here on the vital loops. On loop A, you see
16 we have one RHR heat exchanger as represented as being
17 inside that box, along with an RHR pump, an SI pump.
18 Two containment fan coolers are on loop A. The
19 post-LOCA sample cooler which is shown outside that box
20 is also connected to loop A, and the component cooling
21 water pump is self-cooled. So they are shown there as
22 coming off of that loop also.

23 Loop B has one RHR heat exchanger, the RHR
24 pump, charging pump, injection pump. It has three fan
25 coolers on there, and again the pump is self-cooled.

1 MR. MATTSON: Is the only asymmetry the fan
2 coolers?

3 MR. CONNELL: And the post-LOCA sample
4 cooler.

5 (Slide.)

6 In the nonvital header or the loop C header,
7 none of the components on the header are required to
8 operate for the CCW system to perform its safety
9 function. We have a list there of what is in there: a
10 waste gas compressor, the reactor coolant pumps, and the
11 various coolers off of there, boric acid package, a
12 letdown heat exchanger, a spent fuel heat exchanger.

13 As I say, none of the components on there are
14 required to operate for the CCW to perform its safety
15 function.

16 (Slide.)

17 This is a very simplified elevation drawing to
18 show you the basic arrangements. As you can see, the
19 surge tank is the high point on the loop of the aux
20 building. The heat exchangers are in the turbine
21 building and the pumps are in the aux building at
22 elevation 72. The users and the various loops are both
23 inside the containment, as well as out in the interior
24 building.

25 (Slide.)

1 I want to talk about the basic operating modes
2 right now. In normal operation, one heat exchanger is
3 running --

4 MR. EISENHUT: Excuse me. You went a little
5 fast on that last slide.

6 MR. CONNELL: On the elevation slide?

7 MR. EISENHUT: Well, it is an elevation and it
8 is simplified.

9 (Slide.)

10 And I'm trying to associate that with where
11 the valving is on the system.

12 MR. CONNELL: Which valves?

13 MR. EISENHUT: Well, the isolation valves that
14 would be isolating loop C.

15 MR. CONNELL: The suction valves are in the
16 pump room and the other valves are all in the heat
17 exchanger room.

18 MR. MOORE: In the turbine building for the
19 heat exchanger on basically grade level.

20 MR. ANDERSON: We will see those valves in the
21 pictures, the heat exchangers and how you get to the
22 valves and all of that.

23 MR. EISENHUT: Okay.

24 (Slide.)

25 MR. CONNELL: This is a diagram of a normal

1 operating mode. As you can see, in normal operation one
2 heat exchanger is used, two pumps, all three loops are
3 fed.

4 (Slide.)

5 In the cooldown mode --

6 MR. MATTSON: Excuse me. "Normal operation,"
7 you mean non-accident normal operation?

8 MR. CONNELL: Normal operation, power
9 operation, that's correct. There is about five of these
10 slides coming, and let me see when I get through all
11 five if I get through the one you're interested in.

12 This is in normal cooldown. We bring up the
13 three pumps, the valve in the second heat exchanger, and
14 again you run through all three loops.

15 (Slide.)

16 This is if you have a safety injection
17 signal. You bring up the three pumps on the safety
18 injection signal. You are still feeding the one heat
19 exchanger that you had in service for normal operation.
20 You are feeding all three loops.

21 (Slide.)

22 This is if you have a P signal, P being a high
23 high containment pressure, about 22 pounds. In this
24 case again, you have the three pumps on. They came on
25 at the SI signal. You still have the one heat

1 exchanger. The difference is that this valve FCV-355
2 closes on a P signal, so the C loop is isolated or the
3 flow through the C loop is isolated.

4 (Slide.)

5 Now, this is in the recirculation phase
6 post-LOCA. The system has the capability to valve out
7 loop C or valve it into one of the two separated
8 isolated loops. As I have shown in this particular
9 slide, this shows with the C header isolated as one
10 possible mode. The interesting feature here, of course,
11 is that the A loop and the C loop are not connected.

12 I think that is the last operating mode
13 slide.

14 MR. EISENHUT: If I could ask, could you just
15 back up to the S and P signals and the safety injectio
16 for a moment?

17 MR. MOORE: Do you want to take the S first?

18 MR. EISENHUT: Yes.

19 (Slide.)

20 MR. CONNELL: The difference, if I may say, is
21 this, or the similarity is this: The S signal, which of
22 course is at low pressure, all three pumps are
23 initiated. The heat exchanger that was in normal
24 operation stays there. That valve 355 does not close.
25 No valves close automatically there.

1 (Slide.)

2 When the P signal comes along, if the
3 containment pressure does get up that high where the
4 signal gets that high --

5 MR. MATTSON: What was that pressure again?

6 MR. CONNELL: It's about 22 pounds.

7 MR. MATTSON: Gauge?

8 MR. CONNELL: Gauge.

9 MR. EISENHUT: So I understand, then, that on
10 both of these modes everything is running through the
11 heat exchanger one.

12 MR. CONNELL: It is running through the heat
13 exchanger that happens to be in operation at the time,
14 and of course they are rotated.

15 MR. EISENHUT: I'm sorry. Now, okay, does the
16 seismic -- then the heat exchanger, then, the heat load
17 assumes the A loop, the A loop and the B loop both come
18 on, and is it sized then that all of the equipment on
19 the A and B loops come on, for example all the fan
20 coolers?

21 MR. CONNELL: That's correct. Let me set that
22 out. Let me talk about heat loads a little bit later.
23 We've got about four or five cases.

24 MR. EISENHUT: I just wanted to be sure I
25 understood the operating mode here, though, that hangs

1 upon whatever heat exchanger is in fact in operation at
2 the time.

3 MR. CONNELL: That's correct.

4 MR. MATTSON: Well, let's go back one slide
5 just to make a point.

6 (Slide.)

7 Let's say we got a TMI accident, no high
8 pressure signal in the containment, one heat exchanger,
9 A, B and C all operating off of one heat exchanger. The
10 system is designed to do that?

11 MR. CONNELL: That is the way the system is
12 designed.

13 MR. MATTSON: That would be the most limiting
14 heat load case, right?

15 MR. CONNELL: I don't necessarily know that.
16 What was the heat load in the containment on TMI?

17 MR. MATTSON: Well, let's just say a small
18 break LOCA.

19 MR. CONNELL: What was the energy? I
20 understood your question to be was that the limiting
21 heat load case, and I guess I can't answer because I
22 don't know what the heat load was at TMI.

23 MR. MATTSON: I don't want to go to the TMI
24 event as a design basis. This would be more limiting
25 than the normal cooldown, right?

1 MR. CONNELL: Yes.

2 MR. MATTSON: Isn't this the most limiting
3 heat load case? It's more limiting than a normal
4 cooldown because it is also cooling emergency safety
5 features.

6 MR. ANDERSON: Well, it could be. But there
7 is an alarm on the system and if the temperature goes up
8 over the alarm, and we will talk about that later, then
9 the second heat exchanger would have to be cut in or
10 some of the loads contributing to heat, namely the fan
11 coolers, would have to be cut off.

12 MR. EISENHUT: Let me ask the question a
13 little different. In your design of this plant, which
14 operating mode is the most limiting from a heat load
15 standpoint for design purposes on heat exchanger, either
16 of the heat exchangers?

17 MR. CONNELL: Could I set that aside, because
18 there are some subtleties involved and I will talk about
19 that in just a few minutes. But let me just say here
20 before we leave on this particular drawing, this shows
21 an S signal, which means that you haven't gotten to the
22 22 pounds. So it is not necessarily the limiting case,
23 and let me leave it that way.

24 MR. MATTSON: You're also going to talk about
25 the flow design capability of the heat exchanger later?

1 MR. ANDERSON: Yes.

2 MR. MATTSON: It's clearly three pumps.

3 MR. MOORE: We specifically answered that
4 question in the section 7, where you asked a specific
5 question in that regard.

6 MR. CONNELL: I was going to talk a little bit
7 about supporting systems.

8 (Slide.)

9 There are two principal supporting systems,
10 auxiliary salt water and makeup water system. The
11 auxiliary salt water system takes heat from component
12 cooling water heat exchanger and injects it into the
13 Pacific Ocean.

14 (Slide.)

15 The makeup water to the surge tank or to the
16 component cooling water system is supplied through two
17 redundant makeup valves feeding two redundant component
18 cooling water surge lines. These air-actuated level
19 control valves open automatically in the event of a low
20 level in the surge tank, indicating that system makeup
21 is required. They close automatically when the normal
22 operating level in the surge tank is restored.

23 The makeup to the system is supplied to the
24 above valves by the makeup water system. The makeup
25 water can be provided from the various water sources and

1 through various pumps and flow paths in the makeup water
2 system.

3 Under normal operating conditions, makeup
4 water is provided automatically on demand from the
5 outlet of the makeup water demineralizers, which receive
6 water from the raw water storage reservoir. The
7 elevation of the reservoir provides adequate static head
8 to pressurize the outlet of the demineralizers, so
9 makeup is supplied to the CCW without any pumping. This
10 makeup source is Design Class II up to the check valve.

11 There is a Design Class I source for makeup to
12 the CCW system and that is from the condensate storage
13 tank, which contains 425,000 gallons, with a reserve of
14 170,000 gallons for the auxiliary feedwater, so that
15 255,000 gallons should be available for makeup.

16 The makeup water from the condensate storage
17 tank is pumped by fully redundant Design Class I makeup
18 water transfer pumps. Each pump is energized by a
19 separate vital bus. All piping and valves from the
20 condensate storage tank to the CCW surge lines are
21 Design Class I.

22 There are many other sources of makeup water
23 available for even further backup. Five other sources
24 are described in the FSAR. Some are Design Class I,
25 such as a crossconnect to the Unit 2 condensate storage

1 tank, while others are Design Class II.

2 MR. EISENHUT: You mean on this slide, then,
3 that everything above the Class I symbol and to the left
4 of the Class I symbol there, over in that corner
5 everything is Class I including the instruments?

6 MR. CONNELL: I'm talking about piping,
7 components and valves. The instruments as they form the
8 pressure boundary are Class I.

9 MR. MOORE: These valves are Class I, and with
10 regard to pressure boundaries the instrumentation
11 associated.

12 MR. EISENHUT: So all piping, valving, all
13 pressure boundary in the corner is Class I?

14 MR. MOORE: Tom Crawford will give an
15 explanation of the instrument classification system that
16 goes through what is Class I and what is Class II and
17 some of the permutations of it.

18 MR. MATTSON: It's Class I because you need
19 this makeup following a seismic event, is that right?

20 MR. CONNELL: No, it is Class I because the
21 CCW system is a Design Class I system and this provides
22 the water for any leakages that you might have in the
23 system.

24 MR. MATTSON: But is it Design Class I because
25 you need it following a seismic event?

1 MR. CONNELL: No, that is not what I'm
2 saying.

3 MR. MATTSON: You don't need CCW following a
4 seismic event?

5 MR. CONNELL: No, I wasn't answering that
6 question. The question is why is it category I. It is
7 category I because the component cooling water system
8 provides a safety function and it needs to have a supply
9 of water in the system and this is how it gets there,
10 through the surge tank, through the makeup.

11 MR. MATTSON: Do you need the component
12 cooling water system following an earthquake?

13 MR. CONNELL: This component cooling water
14 system is available after an earthquake, yes.

15 MR. MOORE: I think it would be fair to say
16 that, since this system is normally in service,
17 earthquake or otherwise, that we would expect it to be
18 in service before, during and after an earthquake.

19 MR. EISENHUT: But the real question is, and
20 let me see if I can ask it, the component cooling water
21 system you say is Class I because fulfills a safety
22 function, and our question really is, what safety
23 function is it there needed to provide? And you can
24 make a circular argument that it's needed to provide
25 water to the safety system, and the question is for what

1 kind of an event?

2 Is it for a LOCA, is it for a seismic event,
3 is it for whatever, or what combination?

4 MR. CONNELL: The safety function is a LOCA,
5 to remove heat from containment after a LOCA and you
6 cool various emergency safeguards pumps.

7 MR. EISENHUT: Now, the second part now is, is
8 it also needed for a seismic event with no LOCA?

9 MR. CONNELL: I am a little --

10 MR. MOORE: Only in the sense of safely
11 shutting the plant down and going to cold shutdown, but
12 not in an accident scenario, a shutdown scenario.

13 MR. MATTSON: Does that mean you could stay at
14 hot standby without the component cooling water system?

15 MR. MOORE: John is shaking his head yes. I
16 believe as part of the Hosgri evaluation we also
17 demonstrated that we could go to cold shutdown.

18 MR. MATTSON: Without the CCW pumps?

19 MR. MOORE: With the CCW pumps. The system is
20 being qualified. It seismically has been reviewed for
21 Hosgri requirements.

22 MR. MATTSON: I think the answer that you've
23 given to the question, then, is following earthquake if
24 you stay at hot standby you don't need the system.

25 MR. CONNELL: We are hung up on the need, do

1 you see, because if you're talking a LOCA, for example,
2 I know what you mean when you say need because you have
3 close consequences and the boundary, et cetera. But I'm
4 not sure what you mean by need here.

5 MR. MATTSON: Let me say it a little more
6 specifically. Following an earthquake, discounting all
7 Class II equipment, to stay at hot standby I don't need
8 the system. To go to cold shutdown I do need the
9 system.

10 MR. HOCH: Let me address it very plainly.
11 The original design basis for the plant as stated in the
12 FSAR is that the component cooling water system was only
13 required for a LOCA. As part of the Hosgri evaluation,
14 if you will remember, the Staff required us to come to
15 safe shutdown and interpreted safe shutdown as a cold
16 shutdown.

17 Consequently, as part of the Hosgri evaluation
18 the requirement was made for cold shutdown. That
19 requires the component cooling water system. So now,
20 including the Hosgri evaluation, we have two design
21 bases, if you will, for the system, accident operation
22 in handling the effects of a LOCA and cold shutdown. In
23 either case the component cooling water system is
24 required; to stay at hot standby it is not.

25 MR. MATTSON: So that is a different answer to

1 the question. The licensing basis of the plant today is
2 to reach cold shutdown following a seismic event, and in
3 order to do that you need the component cooling water
4 system. So the functioning of the component cooling
5 water system following a seismic event has to be assured
6 to meet the licensing basis.

7 MR. EISENHUT: With no LOCA. That's two
8 different scenarios.

9 MR. MATTSON: Given the design basis seismic
10 event, the licensing basis for this plant is required to
11 reach cold shutdown. In order to do that you have to
12 have component cooling water system.

13 MR. MOORE: Yes.

14 MR. EISENHUT: There is a nodding of heads
15 around here.

16 (Laughter.)

17 MR. MOORE: Yes. I will point out that there
18 are other things that go into that shutdown scenario,
19 namely the time factor, you can take advantage of
20 operator action, that sort of consideration.

21 MR. MATTSON: Those are details. I understand
22 that.

23 MR. HOCH: That design basis of cold shutdown,
24 the cold shutdown part is very carefully outlined. Both
25 the Hosgri report and the Staff's safety evaluation

1 report on the Hosgri evaluation described that process
2 of getting to cold shutdown.

3 MR. MATTSON: Well, that must involve things
4 like the fact that there are air operators and that
5 there are instruments and a lot of details that you have
6 to look at and show why you can depend upon this whole
7 system, given a seismic event. I don't mean to get into
8 that right now, but we are going to get into that later,
9 is that right?

10 MR. ANDERSON: Yes.

11 MR. MATTSON: Good.

12 MR. NOVAK: What specific components would you
13 call on? I would like to know, is there a point in the
14 cold shutdown procedure from which you would draw
15 component cooling water system in operation? For
16 example, do you need it to operate the auxiliary
17 feedwater system?

18 MR. CONNELL: No. What you need it for is to
19 operate -- I'm not sure you were here when I listed the
20 various users of the system.

21 MR. NOVAK: But I think the answer to the
22 question --

23 MR. CONNELL: You have the RHR heat
24 exchangers.

25 MR. NOVAK: -- sometimes to go to cold

1 shutdown requires you to bring in the component cooling
2 water system, if your end point is a set of temperatures
3 and pressures. But to stay at hot shutdown, that is to
4 utilize an auxiliary feedwater system as a makeup to a
5 steam generator and rely on that for circulation and
6 remove decay heat through the steam generators, that
7 specific mode of decay heat removal does not require the
8 component cooling water system.

9 MR. CONNELL: That's correct.

10 MR. MATTSON: That's what they said.

11 (Slide.)

12 MR. CONNELL: Now I'd like to discuss the
13 major design considerations of the system. In the
14 January 13th meeting in San Francisco, Darrell Eisenhut
15 stated that you will be comparing the design against the
16 standard review plan. I of course heard that again this
17 morning from Harold Denton and Roger Mattson.

18 It should be kept in mind that Revision 0 to
19 the standard review plan came out after Diablo Canyon
20 was built and it was undergoing hot functional testing.
21 Now there is, of course, no requirement for a blanket
22 backfit to the standard review plan.

23 Nonetheless, for your convenience the format
24 of this discussion will follow Revision 1 to the
25 standard review plan, NUREG-0800. Each of the topics

1 that you mentioned, Darrell, in San Francisco, is
2 included in the standard review plan, and of course it
3 will be included in my discussion.

4 MR. EISENHUT: But when you said Rev 1 you
5 really meant the latest version of the standard review
6 plan. Is it Rev 1 or Rev 2?

7 MR. CONNELL: I have Rev 1 to Section 9.2.2,
8 and that is the one I used.

9 The standard review plan lists 15 areas of
10 review directly related to the CCW design. I am going
11 to go through each of those 15 areas, notwithstanding
12 that the system was designed in 1968, 7 years before the
13 first version of the SRP and 13 years before Revision 1
14 to the SRP. Nonetheless, all 15 areas were considered
15 in the design and I think the intent of each area is
16 met, and I will discuss that in the next few minutes.

17 I have broken these 15 areas up into 15 broad
18 groups where I think the SRP -- I'm sorry, the 15 into 3
19 broad groups.

20 MR. FRIEND: Ed, when you're talking to the
21 screen I can barely hear you. You've either got to talk
22 this way or get to the podium.

23 MR. SCHIERLING: And could you also identify
24 the slide by number just for the record?

25 MR. CONNELL: Yes. This is slide B-3.

1 (Slide.)

2 This is the grouping to assure that adequate
3 cooling is supplied, and there are subgroupings in the
4 standard review plan that deal with the functional
5 performance, the multiple functions, the capability of
6 the surge tank, the provisions for providing cooling
7 water and heat loads.

8 Now, slide B-6.

9 (Slide.)

10 The SRP talks about other system aspects. The
11 first one is the interface between seismic and
12 nonseismic portions of the system. We then talk about a
13 leakage requirement for testing and in-service
14 inspection requirements on the reactor coolant pump
15 seals, instrumentation requirements, and they ask for a
16 reliability analysis.

17 (Slide.)

18 The third broad grouping is what I've called
19 interactions, and this includes flood protection,
20 protection against internal and external missiles, and
21 consideration of pipe breaks.

22 Let me go through each of these 15 areas and
23 describe how Diablo Canyon addresses this area.

24 (Slide.)

25 The first is called functional performance,

1 and this talks about the ability to withstand adverse
2 environmental occurrences and reviews operability
3 requirements for normal operation and during and
4 subsequent to an accident. Environmental occurrences:
5 Essential electrical components were environmentally
6 qualified for operation in the required modes, as
7 documented in the FSAR.

8 The qualification program was expanded and
9 updated in response to the CLI-80-21 and NUREG-0588. It
10 was reviewed and approved by the NRC in September of
11 '81.

12 Protection from -- again on more environmental
13 occurrences, protection from high winds and tornado
14 missiles is described in the FSAR. Electrical and
15 mechanical system components which perform a safety
16 function have previously been seismically qualified.
17 However, because of the new seismic input data which is
18 currently being generated, the analyses are being
19 reviewed and updated or replaced as appropriate.

20 MR. RUBENSTEIN: Is the surge tank on the top
21 of the auxiliary building tornado missile-protected?

22 MR. CONNELL: It is discussed in the FSAR that
23 upon the consequence of an event -- a consequence
24 analysis for tornado missiles.

25 MR. RUBENSTEIN: It is not protected? It just

1 assumes it fails?

2 MR. MOORE: I will show you a slide, a
3 35-millimeter slide that shows the tornado shielding
4 that has been provided.

5 MR. RUBENSTEIN: That's a different response.

6 MR. CONNELL: Some of both, I think is the
7 answer.

8 MR. MATTSON: In this business on
9 environmental, how did you identify in the station or
10 are you reviewing for the station how the components are
11 to be qualified for a harsh environment? Have you
12 reviewed how the identification of those components
13 occurred?

14 MR. CRAWFORD: What we did is we took all of
15 the operating procedures involved in accidents that
16 generated harsh environments, we then broke down the
17 instrumentation, our electrical equipment utilized in
18 those procedures under required functions, contingency
19 actions. All of the required functions are
20 environmentally qualified, contingency actions are not.
21 The only kind of confirmation is if it is in Reg Guide
22 1.97 then it is, if it's not in Reg Guide 1.97 then it's
23 not.

24 MR. MATTSON: You don't mean to limit your
25 answer to just electrical equipment?

1 MR. CRAWFORD: We are talking about CLI-80-21
2 was strictly electrical equipment.

3 MR. MATTSON: But in --

4 MR. CONNELL: That includes the electrical
5 stuff.

6 MR. CRAWFORD: It includes motors, pumps.

7 MR. MATTSON: Did you also look at equipment
8 that could fail and then affect safety equipment, not
9 just the safety equipment called upon in the procedures
10 or the nonsafety equipment called upon in the
11 procedures, but something that could fail and move in a
12 particular direction and put a stress on the system that
13 you hain't thought of in the design of the system?

14 MR. CRAWFORD: Not specifically in the
15 response to CLI-80-21, no. What we did do is, we do
16 have sections in CLI-80-21 dealing with devices that are
17 required to fail in a proper position in order for the
18 safety function -- in other words, we have a number of
19 components in the systems, and I'm specifically thinking
20 of valves, that there is a required failure mode and we
21 had to qualify them to be able to fail in the required
22 failure mode.

23 We do not address, for example, in CLI-80-21
24 we did not address th failure of something whose failure
25 mode wasn't required, if you know what I'm saying. We

1 did in our basic system design, not CLI-80-21's response
2 but in the basic system design, obviously failure modes
3 are considered.

4 MR. EISENHUT: Let me see if I understand
5 that. That would say that any component that is not
6 included in the group that had to preferentially fail
7 one way, you really don't care which way it fails?

8 MR. CRAWFORD: We assume it fails, okay, or
9 operates properly, okay. In other words, if you have a
10 non-Class I device it is assumed to either fail or
11 operate properly.

12 Now, the assumption of failure, for example,
13 in our air-operator valve, we assume it to fail in the
14 spring direction. We do not make any assumption about
15 it failing in the wrong direction. In other words, the
16 spring-operated valve, we do not analyze the fact that
17 it failed in the opposite from the spring-pushing
18 direction.

19 But we do consider in our design, not in
20 response to the CLI-80-21 but in our basic design, the
21 fact that any non-Class I component either fails or
22 operates properly.

23 MR. MATTSON: Then you look at the condition
24 that that puts on the safety equipment and design the
25 safety equipment to accommodate it?

1 MR. CRAWFORD: Yes.

2 MR. MATTSON: You say you didn't do that in
3 connection with CLI-80-21 because that isn't what 80-21
4 addressed?

5 MR. CRAWFORD: For example, LCV-69 and 70 are
6 air to open, fail closed valves. It is assumed that
7 they either modulate or they fail closed.

8 MR. CONNELL: The operability in normal
9 operation. There is sufficient redundancy in components
10 so that in normal operation there is always one pump and
11 one heat exchanger in the standby mode. For cooldown
12 all three pumps are used. If one of the pumps or one of
13 the heat exchangers is nonoperative for a cooldown, then
14 an orderly shutdown is not affected, but the time for
15 cooldown is extended.

16 (Slide A-10.)

17 (Slide B-9.)

18 Operation for accidents. Each of the
19 essential pumps in the CCW system and in the support
20 systems, auxiliary salt water and makeup, are assigned
21 to one of three emergency safeguards buses. The CCW
22 pumps and the ASW pumps are automatically started on a
23 safety injection signal, the S signal.

24 The limiting failure would be a failure of one
25 bus to energize. In this case there would still remain

1 one makeup water transfer pump with two CCW pumps and
2 one ASW pump. This meets the requirements for the
3 short-term post-LOCA operation.

4 MR. NOVAK: Question. The emergency power
5 supply system does not require component cooling water?

6 MR. CONNELL: That is correct.

7 MR. NOVAK: So the emergency diesel -- well,
8 they provide power to the component cooling water system
9 instead of providing power to the motors?

10 MR. MOORE: If your question is are they
11 air-cooled or not, they are air-cooled, air-cooled
12 diesels.

13 MR. NOVAK: Good. That is my question.

14 (Laughter.)

15 MR. RUBENSTEIN: How many containment fans or
16 fan coolers are required?

17 MR. CONNELL: There are five containment fan
18 coolers. For the design basis accident three fan
19 coolers are required.

20 MR. RUBENSTEIN: Two on one loop and three on
21 the other?

22 MR. CONNELL: That's correct. Mechanically on
23 the loops, three are piped into loop B, two are piped
24 into loop A.

25 MR. RUBENSTEIN: Later on you will address --

1 MR. CONNELL: On the buses, they are assigned
2 as shown here. There are two on bus -- if I can find
3 it, there are two on bus F, two on bus G, and one on bus
4 H.

5 MR. CREWS: So you're saying a single
6 electrical failure wouldn't get you in trouble. But
7 what about the piping signal failure?

8 MR. CONNELL: Okay. In the short term you
9 need three, the short term, which means that you
10 postulate a single active failure and not a passive
11 failure.

12 MR. RUBENSTEIN: Are we going to address this
13 a little later?

14 MR. ANDERSON: We will get into it.

15 MR. CONNELL: Except I think what you really
16 want to do is look again at that slide that we had
17 earlier. That's maybe A-8.

18 MR. RUBENSTEIN: What you need is containment
19 spray?

20 MR. CONNELL: That's right, and the
21 containment spray is -- I should point that out here,
22 too. As you can see, one is on bus G and one is on bus
23 H, and mechanically there is one in each loop.

24 (Slide.)

25 No, what I wanted was the short-term one.

1 MR. BUCKLEY: If I could pick up on Tom
2 Novak's question, the diesels have their own auxiliary
3 salt water cooling system, right?

4 MR. CONNELL: No, they are air-cooled.

5 MR. BUCKLEY: But I thought I recalled a
6 separate salt water system for diesels.

7 MR. CONNELL: There is an auxiliary salt water
8 system which transfers heat to the ultimate heat sink.

9 MR. BUCKLEY: I know the auxiliary salt water
10 system, but associated with just the diesels you do have
11 some cooling water.

12 MR. TINLIN: The diesel generators have a
13 radiator type cooling system. That is a water jacket on
14 the diesel generators and they are cooled by air forced
15 through a radiator.

16 MR. BUCKLEY: I thought it had a separate salt
17 water cooling system also.

18 MR. CONNELL: What I wanted to point out here
19 in connection with the bus diagram is that in the short
20 term post-LOCA the flow goes through all three vital
21 loops. For example, the way that's shown, the FCV-430,
22 that's a motor-operated valve that stays open, so you
23 are getting flow through both loops and then you cut off
24 loop C.

25 But I was going back to your question. That

1 means that the flow goes through all five fan coolers in
2 the short-term.

3 MR. MATTSON: And that is immune to any single
4 failure?

5 MR. CONNELL: Any postulated single active
6 failure. That's a motor-operated valve.

7 MR. WERMIEL: And that could fail, since
8 that's a single activated component?

9 MR. CONNELL: If it fails in the activated
10 position, the motor-operated valve --

11 MR. WERMIEL: You're saying a bus failure
12 would fail as is?

13 MR. CONNELL: That's correct. If it was
14 normally open it would fail open.

15 MR. WERMIEL: And vice versa for FCV-431?

16 MR. CONNELL: That's correct.

17 MR. BUCKLEY: For all motor-operated valves.

18 MR. CONNELL: That's correct.

19 (Slide.)

20 That was for the short-term post-accident. In
21 the long-term post-accident, the system is manually
22 aligned into two separate loops. The valves used for
23 this alignment are located in the component cooling
24 water heat exchanger rooms and the pump rooms. Both
25 areas are relatively low radiation areas post-LOCA.

1 Only one loop is required to operate, so that
2 the system can accommodate a single active or passive
3 failure in the long-term with both loops going.

4 (Slide B-10.)

5 There is a requirement, I guess of GDC-44 as
6 stated in the SRP, that there be component redundancy so
7 that safety functions can be performed assuming a single
8 active component failure coincident with a loss of
9 offsite power. This system meets that design
10 requirement.

11 (Slide A-11.)

12 (Slide B-11.)

13 I will go to the second area in the SRP,
14 multiple performance functions. GDC-5 speaks to the
15 sharing of systems and components between units. There
16 is no required sharing of the CCW system or its support
17 systems, with the exception of emergency safeguards
18 diesel F. This is a swing diesel that is assigned to
19 the local unit. As discussed earlier just a minute ago,
20 if this bus fails to energize there is sufficient
21 redundancy to safely shut down the plant.

22 Although sharing is not required, it is part
23 of the design philosophy of this plant to provide
24 additional flexibility. With this in mind, the plant
25 has been piped up so that by manually opening the valves

1 it is possible to crossconnect various systems from the
2 two units. For example, as I said earlier, you can
3 manually crossconnect the two condensate storage tanks.

4 MR. MATSON: You listed that as one of the
5 backup seismic Class I water supplies.

6 MR. CONNELL: That is correct.

7 All of the components that require CCW for
8 normal operation only are located on the C headers.
9 None of these are components that are required to shut
10 down the plant. That is on the nonvital.

11 Now, radioactivity control, another multiple
12 performance function of the system. The double barrier
13 design reduces the probability of radioactive water
14 escaping to the environment. Leaks of radioactive water
15 into the component cooling water system are detected by
16 radiation monitors which are located in two CCW pump
17 discharge headers. Once again, any leaking component
18 can be isolated by Design Class I valves.

19 (Slide B-12.)

20 MR. MOORE: Excuse me, Ed. Is there a problem
21 with this slide here?

22 MR. CONNELL: No. It is on the pump
23 discharge.

24 MR. BUCKLEY: The surge tank, is that vented
25 or pressurized?

1 MR. CONNELL: Vented.

2 MR. MATTSON: Let me make sure I understand
3 some of the words you're using. I am following your
4 written presentation and I think you are at about page
5 14. At the top of that page you say, "None of these
6 components is required to shut down the plant."

7 You mean, I think, in that sentence that in
8 order to meet the Commission's regulations you can use
9 equipment other than what is on the C header to shut
10 down the plant. But isn't it true that in some design
11 basis events you would prefer to use equipment that is
12 on the C header?

13 MR. CONNELL: Yes.

14 MR. MATTSON: Like the reactor coolant pump.

15 MR. CONNELL: Yes.

16 MR. MATTSON: Like for a steam generator tube
17 rupture.

18 MR. CONNELL: That's correct.

19 MR. MATTSON: That is perfectly acceptable. I
20 just wanted to make sure what you meant when you said
21 "required to shut down the plant."

22 MR. CONNELL: That is what I meant.

23 MR. MATTSON: You meant required in order to
24 show that you meet the Commission's regulations?

25 MR. CONNELL: That's correct. The reactor

1 coolant pumps I guess are the best example of something
2 that you would like to have them available.

3 MR. MATTSON: You would prefer to go that
4 way?

5 MR. CONNELL: That's correct.

6 MR. MATTSON: And your procedures probably
7 call for you going that way.

8 MR. CONNELL: Yes.

9 MR. TINLIN: I'm sorry, I didn't get that
10 question.

11 MR. MATTSON: Well, the procedures probably
12 call for you to go in the preferred way first, and if
13 that doesn't work, that is if you've lost offsite power
14 for example, reactor coolant pumps aren't available, you
15 go to some other mode of shutdown. The Commission's
16 regulations generally fall back to some small island of
17 equipment that is the bare minimum needed to assure safe
18 operation or safe shutdown of the plant following a
19 design basis event.

20 MR. TINLIN: Right, which I believe Ed said
21 are all of the vital headers.

22 MR. CONNELL: The surge tank, the surge tank
23 is internally divided, thus providing an entirely
24 independent surge volume with supporting
25 instrumentation, feeding one of the redundant vital CCW

1 headers. This meets the standard review plan
2 requirement that in the event of a header rupture the
3 loss of the entire contents of the surge tank will not
4 occur.

5 As I said earlier, there are many makeup
6 sources to the surge tank for the requirement to provide
7 cooling water.

8 (Slide B-13.)

9 As I discussed earlier, because of the use of
10 redundant Design Class I components backed by emergency
11 power supplies and considering the capability for
12 isolation of the system into independent trains, an
13 adequate supply of cooling water is assured for all
14 operating modes.

15 (Slide A-12.)

16 (Slide B-14.)

17 Heat loads. During normal operation, the heat
18 load is approximately 72 million Btu's per hour. This
19 is well within the capability of one CCW heat
20 exchanger.

21 Now I want to talk about three or four cases.
22 Let's consider the case when you have a safety injection
23 signal but you don't have a P signal. The major heat
24 load, assuming there is an accident when you get these
25 signals, is probably fan coolers. All other loads

1 amount to about 40 million Btu's, 39 of which are on the
2 C header.

3 It is difficult to estimate the heat load in
4 containment for this case, that is the case where you
5 are above an S signal but you are below a P, because
6 this does not correspond to any of the supposedly
7 postulated design basis accidents. Let's assume that
8 the heat load inside containment is 50 percent of that
9 that is calculated for the design basis accident and the
10 resulting heat load of the system is about 230 million
11 Btu's per hour.

12 Again, this is -- you can handle this with one
13 heat exchanger. In this case that I just described, I
14 just assumed that all of the five fan coolers are
15 working. You have fewer fan coolers and the rate of
16 heat rejection in the CCW system will be less.

17 MR. NOVAK: Would this result in loss of SPSH
18 or how has this fed back into the CCW performance? In
19 other words, if you get elevated temperatures I would
20 assume you are concerned about 10 NPSH requirements.
21 What margin do you look for?

22 MR. CONNELL: NPSH on the pumps themselves?

23 MR. NOVAK: Well, assuming that the water is
24 continuing. I would assume that might be one concern
25 you would have if you are exceeding the heat load.

1 MR. CONNELL: Well, we are not exceeding the
2 heat load yet.

3 MR. NOVAK: Let me leave the question for
4 now.

5 MR. MATSON: Well, this is not a bad
6 question. If you throttle back in essence on the
7 component cooling water system and temperature and
8 pressure stay up in containment and it's a small LCCA
9 instead of a design LOCA, then you want to know if the
10 recirculation system for a low head, recirculation
11 system for emergency coolant, has an NPSH problem or
12 not.

13 That part of the design has been considered?
14 I think you agree, right?

15 MR. HOCH: Jim Tinlin I'm sure can answer
16 that.

17 MR. TINLIN: I've been confused as to where
18 we're worried about NPSH, because is that in the
19 component cooling water system?

20 MR. NOVAK: Yes.

21 MR. TINLIN: All right. As far as that is
22 concerned, having that surge tank up on the 152-foot
23 level and the pumps down on the 73-foot level, as I'm
24 sure -- and I can be corrected if I am wrong -- there is
25 plenty of static pressure. So that even if you do get

1 up to whatever the design temperature of the CCW system
2 is, you're not even going to be close to losing NPSH on
3 the pumps.

4 MR. MATTSON: I was thinking of a different
5 NPSH problem. In order to protect the component cooling
6 water system, you were talking about not bringing the
7 heat out by the fan coolers as fast. If you don't do
8 that, I mean follow that course, then temperature stays
9 high in the containment longer than if you didn't do
10 that.

11 If the containment temperature stays higher,
12 then that is a design challenge to the emergency core
13 cooling system from an NPSH point of view. Is that
14 within its design basis?

15 MR. HOCH: A chapter 15 analysis is conducted
16 with three fan coolers, Roger. So that solves the
17 problem.

18 MR. MATTSON: You ought to be able to show
19 that if you stay within design pressure of containment
20 in saturation you have an NPSH problem on the ECCS,
21 right?

22 MR. CONNELL: On the ECCS pumps, certainly.

23 MR. MATTSON: And there's no systems
24 interaction with this mode of operation?

25 MR. CONNELL: Not that I see, no.

1 MR. TINLIN: As far as this mode of operation
2 is concerned, the supply of water is not from
3 containment?

4 MR. CONNELL: No, he's talking about the SI
5 pump. You're talking about a header on the SI pumps?

6 MR. MATTSON: You see, you are rather
7 callously deciding what to do with these fan coolers and
8 there are other systems that depend upon those fan
9 coolers operating too, right?

10 MR. HOCH: That is exactly correct. But since
11 the design basis accident is analyzed with three fan
12 coolers, the fact that you're going to cut two of the
13 fan coolers out just puts you in the situation of the
14 analysis.

15 MR. EISENHUT: Then let me make sure I
16 understand. You said a couple of times that there were
17 so many million Btu's it is well within the capability
18 of one heat exchanger. Help me again. What is the
19 capability? What number are you thinking?

20 MR. CONNELL: The manufacturer's rating on the
21 heat exchanger is 258.8 million Btu's per hour.

22 MR. EISENHUT: And this scenario you're going
23 through now, is this what you considered when you're
24 looking at a couple of different cases here? What was
25 really your design assumption?

1 MR. CONNELL: Can I put that aside? I've got
2 a couple of more cases and I'm sure you're going to find
3 them both more interesting than these two.

4 MR. EISENHUT: I just -- I understand. I just
5 want to know the yardstick you're using.

6 MR. CONNELL: What is the design basis? That
7 is the next case.

8 MR. EISENHUT: All right, good.

9 MR. CONNELL: Here comes the design basis.
10 The design basis is a limiting --

11 (Laughter.)

12 MR. CONNELL: This is the design basis
13 accident with the worst single failure. This assumes
14 the complete double-ended rupture of the pipe inside
15 containment, concurrent with a loss of offsite power and
16 the worst single active failure in the plant.

17 MR. MATTSON: Now, worst from what
18 standpoint?

19 MR. CONNELL: The worst single active failure
20 means the active failure that causes the least amount of
21 containment heat removal capability to be available, the
22 least amount of containment heat removal capability.
23 That is the design basis for the plant.

24 This, if you will recall --

25 (Slide.)

1 MR. MATTSON: The assumptions on which is the
2 worst failure can change depending upon what system
3 you're looking at. You just described the worst single
4 failure from the standpoint of protecting the
5 containment integrity, is that correct?

6 MR. CONNELL: That is correct.

7 MR. MATTSON: What is the worst single failure
8 for assuring the continued viability of the component
9 cooling water system, the same failure or another
10 failure?

11 MR. CONNELL: You're always one case ahead of
12 me.

13 (Laughter.)

14 MR. CONNELL: That is the next one or possibly
15 the one after the next one.

16 MR. EISENHUT: Maybe we ought to go for a cup
17 of coffee and let you continue.

18 (Laughter.)

19 MR. CONNELL: For this particular one, the
20 design basis accident with the worst single failure,
21 this is the failure of bus G to energize. And if that
22 happens, you notice that you will lose two fan coolers
23 and you will lose a spray pump.

24 Notice also that if that is the failure, the G
25 bus failing to energize, that means the other two buses

1 do energize, and that means in particular that bus H
2 energizes. That means that FCV-355, which is a supply
3 side valve on the C header, has power and it will close
4 on the P signal. This is a case that was used for the
5 design basis heat removal capability for Diablo Canyon
6 in response to general design criteria 44.

7 Let me talk about another case --

8 (Slide B-16.)

9 -- the case that I think you were alluding to,
10 Roger. This was recognized by PG&E, that under
11 different postulated conditions it would be possible to
12 reject more heat than for this design case to one heat
13 exchanger and thus raise the heat exchanger outlet
14 temperature above the design value.

15 For example, if it is assumed that all
16 equipment functions as designed, that is you have this
17 failure of bus G, both containment spray pumps and all
18 coolers will be operating. And if you further assume
19 the same design basis temperature time history inside
20 containment and you assume all of the other parameters
21 that are normally used in a DBA worst case analysis,
22 then you can calculate the temperature of the discharge
23 of a single component cooling water heat exchanger, and
24 that temperature would go up to about 140 degrees or
25 approach 140.

1 This case, while it is not the design basis
2 case, was calculated by PG&E. The total heat load is
3 approximately 406 million Btu's per hour. For this
4 case, which I think going back to yours exceeds the
5 manufacturer's rating of the heat exchanger, in this
6 case the operator action that is taken is the same as
7 what you would take in the DBA case, which is, as I
8 said, you would cut in a second heat exchanger which is
9 available.

10 MR. RUBENSTEIN: When in the long agonizing
11 design of Diablo Canyon did you calculate this case?

12 MR. CONNELL: I haven't been on Diablo Canyon
13 for long, but this is in the files, was in the files in
14 1974. It is in the '74 time frame.

15 MR. MATTSON: How long does the operator have
16 to valve in that other heat exchanger?

17 MR. CONNELL: Jim Tinlin is going to talk
18 about that. Maybe I didn't understand your question.
19 He's going to talk about --

20 MR. MATTSON: Well, I gather the procedures
21 say if you start to go up to 140 degrees Fahrenheit you
22 better start thinking about putting another heat
23 exchanger in.

24 MR. CONNELL: It is a low number, but that's
25 what the procedure says.

1 MR. MATTSON: If you were in this situation
2 how long would it be, days, hours, minutes?

3 MR. CONNELL: He's going to talk about that.

4 MR. TINLIN: Do you mean the time it takes to
5 get to that temperature or the time it takes the
6 operator to perform a manual action?

7 MR. MATTSON: Both. Minutes or hours?

8 MR. TINLIN: Minutes before the operator
9 action.

10 MR. MATTSON: And you will explain why that is
11 enough time later?

12 MR. TINLIN: Yes.

13 MR. WERMIEL: Can't I compound that scenario
14 even further and make it worse by taking a single
15 failure in one of the containment sprays?

16 MR. CONNELL: You really are going to get to
17 my next question, which is what about if your failure
18 were to that C loop.

19 MR. WERMIEL: No. If one of the spray pumps
20 fails, I'm not putting even more heat load on the
21 containment cooler.

22 MR. CONNELL: That's true.

23 MR. WERMIEL: So that 140 would actually be
24 somewhat more.

25 MR. CONNELL: I don't have a number with me

1 today on that.

2 MR. WERMIEL: Given a different single failure
3 for what Roger was alluding to, it would go even higher
4 than the 140.

5 MR. MATTSON: The same procedures would
6 apply. You just put a greater time demand on the
7 operator.

8 MR. WERMIEL: That is what I was leading to.
9 It seems to me the limiting condition is not quite that
10 even yet. It's even more limited time.

11 MR. MOORE: I would like to reference back to
12 some of Dick Anderson's remarks and what Ed said. There
13 was a very conservative bounding calculation done which
14 indicated this 140 degree situation. We feel, number
15 one, that is not realistic when you look at it in
16 detail, and one of the future actions that is currently
17 going on in the project is to explore these questions in
18 more depth and identify what the temperature is,
19 identify what the rate of temperature is, and judge that
20 against operator actions.

21 MR. CRAWFORD: Could I say something? The
22 reason that's not really true is the assumption used in
23 this calculation was the design basis profile, which
24 assumed you only had three fan coolers and one spray
25 pump. Therefore, the temperature profile he was using

1 to get to 140 degrees really isn't real. It is assuming
2 you have only three fan coolers and one spray pump in
3 terms of heat in the containment.

4 MR. MATTSON: That's a case where the single
5 failure criteria has really turned into a double failure
6 criteria, because you started with the failure of a
7 bus.

8 MR. CRAWFORD: You got it.

9 MR. CONNELL: I had thought of at least one
10 more case.

11 (Laughter.)

12 MR. MATTSON: Quick, think of another one.

13 (Laughter.)

14 MR. CONNELL: This case is very similar to the
15 one we just talked about, where you have the same
16 conditions inside containment as you would under a DBA,
17 but you assume all your five fan coolers are running and
18 your two core spray pumps are running. But now your
19 single failure is valve FCV-355 fails to respond on the
20 P signal.

21 So now you've got the additional heat loads
22 from the C header on there, and if you do that then the
23 total peak heat rejection rate may rise to above 440
24 million Btu's per hour, a little bit more than the case
25 we just talked about before. Of course the actions are

1 the same.

2

3

4

5

6

7

8

9

10

11 ~~-----~~

12

13

14

15

16

17

18

19

20

21

22

23

24

25

1 MR. EISENHUT: On that scenario -- let me make
2 sure I understand. Since you are starting on that
3 scenario from 140 degrees, and you assumed one of the
4 buses failed, and you are postulating FCV 355 fails.
5 That is the scenario you went through.

6 MR. CONNELL: It was kind of a mixed scenario.
7 This last case was this. The temperature-time profile
8 in the containment corresponds to the case where you
9 have failed bus G. In other words, you have got three
10 fan coolers and one core containment spray. Now,
11 otherwise that is just used for the mathematics to
12 calculate temperature-time. You have now assumed you
13 really don't have any failure, all five fan coolers and
14 one containment spray. Then you calculate some number
15 approaching 140.

16 MR. EISENHUT: I understand.

17 MR. LE FAVE: In your FSAR you calculate 215
18 degrees in your air coolers. Would that be based upon
19 140 degrees?

20 MR. CONNELL: No, that is based upon the
21 design basis case which is in that FSAR, which is the
22 the fan coolers and the one containment spray pump.
23 And I think that FSAR is different, the temperature
24 values in different spots on the system.

25 MR. LE FAVE: Well, as I recall, it was 216

1 degrees from the fan coolers.

2 MR. CONNELL: Yes.

3 MR. LE FAVE: And I noticed the design
4 pressure at the suction end of the pump is 161 degrees.
5 I was really kind of curious as to how did you have to
6 meet that 171 degree value at the suction end of the
7 pump.

8 MR. NOVAK: I have one more question before we
9 take a break. What parameter of design are you reaching
10 for or coming up with to go to 140. Is it bearing
11 temperatures? What portion of the CCW, I mean, would
12 first be affected?

13 MR. CONNELL: I don't really know, but for
14 purposes of the design, it looks like it is going to be
15 the bearings on some of the pumps, SI and charger
16 pumps. The safety injection pump.

17 MR. ANDERSON: Let's be sure we don't get
18 locked into 140 degrees because that is a very
19 preliminary analysis that does not include the real
20 situation inside of containment. That also is based
21 upon a 70 degree ocean temperature, and that has some
22 long background and history as to exactly how 70 degrees
23 was arrived at. That is ultraconservative, I think
24 based upon something like six plants at the site with
25 recirculation. Normally the warmest temperature is 50,

1 55 or 56 degrees, so we plan in our further action to
2 take a look at these temperature profiles and develop
3 more information on the temperatures and the operation
4 times involved. That is part of what we are going to do.

5 MR. NOVAK: This is the water temperature
6 leaving the CCW heat exchanger?

7 MR. CONNELL: That's correct.

8 MR. DOPE: I would like to go back to your
9 question, the fan cooler. Water side considerations will
10 be looked at as a part of this further analysis that we
11 spoke of earlier. I don't believe that it was
12 considered in this 1974 calculation. The situation was
13 recognized and resolved as not being the case by putting
14 a second heat exchanger into service.

15 MR. ANDERSON: Okay. Ed, continue.

16 [Slide B-17]

17 [Slide A-13]

18 MR. CONNELL: The next thing I want to look at
19 are the effects of nonseismic Category I equipment on
20 seismic Category I components. The design philosophy
21 employed in Diablo Canyon in meeting the regulatory
22 requirements for this interface and for those
23 requirements given in Reg Guide 1.29 will be discussed
24 later by Chuck Aronson. I want to just talk about two
25 specific equipment interfaces, those for the chemical

1 addition tanks and those for the Sentry post LOCA sample
2 cooler.

3 The chemical addition tank meets all the
4 requirements for separation of seismic and nonseismic
5 components. This is achieved by the piping from the
6 vital headers, up to and including a normally closed
7 manual isolation valve, being seismic Category I.

8 [Slide A-14]

9 Now let me talk about the post-LOCA sample
10 cooler. This was added in 1980 as part of the NUREG
11 0737 changes. It had a similar arrangement and thus
12 could have met the same separation criteria. However,
13 PG&E believed that it would be valuable to have the
14 operators use the same post-LOCA sample station for
15 normal sampling, and this way they would be sure that
16 the operators were familiar with the equipment and were
17 able to safely take hot samples if required post-LOCA.
18 Thus, the manual isolation valves are shown open on the
19 current version of the P&ID.

20 With the valves open the arrangement would
21 still meet requirements if the piping and the small
22 sample cooler were designated as design Class I. The
23 piping is, in fact, as we have said earlier, design
24 Class I. The cooler, while specifically designed and
25 built for the nuclear industry, did not employ a full 10

1 CFR 50 Appendix B quality assurance program. The cooler
2 has recently been fully qualified by analysis for all
3 postulated seismic conditions. Gary Moore is going to
4 show you some pictures of the cooler and you can see how
5 sturdy an installation it is.

6 Thus, it is assured that the cooler will not
7 fail under accident or seismic conditions and will not
8 jeopardize the safety function of the component cooling
9 water system.

10 [Slide A-15]

11 [Slide B-18]

12 MR. MANEATIS: Would this be a good time to
13 take a break?

14 MR. NOVAK: Let's take ten minutes.

15 [Recess]

16 MR. EISENHUT: Let's get moving again.

17 MR. CONNELL: I would like to go to the next
18 area of review of the Standard Review Plans, which
19 concerns leakage. There are numerous provisions for
20 collection, isolation and control of leakage to assure
21 compliance with the requirements. Leakage of
22 radioactive fluid into the system would be detected by
23 the radiation monitors in the CCW pump discharge lines.
24 Also, this could be detected by rising surge tank level
25 and alarm. The tank itself and the components in the

1 system are protected by a relief valve with the
2 discharge routed to the auxiliary building sump. The
3 relief valve is sized for the rupture of the reactor
4 coolant pump thermal barrier. Leakage out of the system
5 is detected by falling surge tank level and alarm.

6 I have described earlier the numerous makeup
7 sources that are available. Mitigation of a leakage
8 from a passive failure, which is defined in Section 3.1
9 of the FSAR, has 50 gpm for 30 minutes, which is well
10 within the makeup capabilities of the system.

11 The NRC in FSAR Question 9.26 asked for some
12 further discussions of system features and to assure
13 continuous supply of CCW to equipment required for the
14 safe shutdown until postulated leaks or ruptures could
15 be isolated. As described earlier, any individual user
16 can be valved out using design Class I valves, or an
17 entire loop of the system can be valved out, again using
18 design Class I valves.

19 In response to the NRC Question 9.26, Table
20 9.2-8 of the FSAR was amended to discuss a postulated
21 leak or rupture of 200 gpm. This leakage value is a
22 limiting case derived from a balancing of a number of
23 different considerations, such as operator reactor
24 times, detection capabilities, isolation capabilities,
25 and the system makeup provisions. It is a reasonable

1 number for design purposes.

2 MR. NOVAK: Do you have any flow limiting
3 devices in the system?

4 MR. CONNELL: Not in general, no.

5 MR. FRIEND: There are control valves.

6 MR. CONNELL: I assume you mean automatic?

7 MR. NOVAK: No, I meant fixed.

8 MR. CONNELL: I'm sorry, that is what I
9 thought you meant, and the answer is no.

10 MR. CRAWFORD: We do have some. In general we
11 don't. We do have on certain heat exchangers.

12 MR. WATTSON: Let's see. There is an 0737
13 requirement, a TMI requirement that says something to
14 the effect of applicants and licensees go forth into the
15 auxiliary building and think about places that
16 radioactivity could arise following a bad accident and
17 places where you might want to send an auxiliary
18 operator to open and close a valve, or you might have a
19 piece of equipment located near one of those hot places
20 and think about what leakage provision you want to
21 improve or what shielding provision you would want to
22 improve.

23 Now you have done that, I assume. That has
24 been reviewed separately, not in connection with this
25 matter. But have you looked at -- there are a lot of

1 places where heat is coming up and the operator can go
2 down and close them out.

3 MR. CONNELL: Yes. Perhaps I didn't state
4 that earlier, but I thought I had. On this basic
5 diagram the valves on the suction side of the pump there
6 are accessible. They are in the component pump rooms,
7 the CCW pump rooms, which is a low radiation area, and
8 the other valves on the discharge side are located in
9 the heat exchanger room, and those valves -- the heat
10 exchanger room is also a low radiation area.

11 MR. MATTSON: There aren't any other lines
12 that go through there that carry hot stuff?

13 MR. CONNELL: That's correct.

14 MR. MATTSON: The makeup system doesn't have a
15 line running through there?

16 MR. CONNELL: What makeup system? There isn't
17 a hot line.

18 MR. MATTSON: Like the one at TMI that was
19 full of crud.

20 MR. TINLIN: Are you talking about the reactor
21 coolant makeup system?

22 MR. MATTSON: Yes.

23 MR. TINLIN: No, it doesn't.

24 MR. CONNELL: That's correct, it doesn't.

25 MR. MATTSON: There is nothing else in there

1 that connects with the primary coolant system?

2 MR. CONNELL: That's correct

3 MR. MATTSON: Fine.

4 [Slide E-19]

5 MR. CONNELL: Testing and ISI requirements.

6 The active components of the CCW system are accessible
7 for visual observation and maintenance, and also they
8 are in continuous or intermittent use during normal
9 plant operation. Thus, no additional special provisions
10 are necessary to meet testing and inspection
11 requirements.

12 [Slide A-16]

13 [Slide B-20]

14 Reactor coolant pump seal coolant, NUREG 0737,
15 Section II.K.3.25, requires that cooling water be
16 available to the reactor coolant pump seals given a loss
17 of off-site power or the loss of instrument error.
18 Diablo Canyon meets this requirement. Note that the
19 valves in question on Diablo Canyon have motor operators
20 which are fed from emergency on-site power and the CCW
21 pumps are also fed from emergency on-site power sources,
22 and therefore the requirement is met.

23 [Slide B-21]

24 On instrumentation. Tom Crawford is going to
25 talk about that later on.

1 [Slide B-22]

2 There is a requirement in the Standard Review
3 Plan to provide a failure modes and effects analysis in
4 the SAR to ensure that essential portions of the system
5 will function following design basis accidents, assuming
6 a concurrent single active component failure.

7 MR. MATTSON: I'm sorry. Go slow. I have to
8 go back one. Reactor coolant pump seals.

9 [Slide]

10 Section II.K.3.25. Diablo Canyon meets this
11 requirement because you say -- didn't we see a slide a
12 couple of hours ago that said makeup for the component
13 cooling water is dependent upon air-operated valves?

14 MR. CRAWFORD: Only the automatic makeup, not
15 the manual.

16 MR. MATTSON: That would be an answer to my
17 question. Is that what I misunderstood?

18 [Slide]

19 MR. MOORE: These particular valves are air
20 operated. They have a manual bypass system around them.

21 MR. MATTSON: That is manual local, and again,
22 it is the kind of thing that you look through to see
23 whether other lines potentially carry --

24 MR. CONNELL: I don't know about those
25 particular valves.

1 MR. TINLIN: Something you maybe ought to
2 point out, that the CCW system is not the only mode of
3 cooling for reactor coolant pump seals. The normal
4 charging system is the other mode.

5 MR. MATTSON: The normal cooling water cooling
6 system depends upon component cooling water.

7 MR. TINLIN: The component cooling water gets
8 the flow from the vital headers.

9 MR. MATTSON: I was going more to the
10 II.K.3.25 requirement. I didn't want to pass over that
11 too quickly. But I understand you say that is an
12 acceptable answer. I'm happy with that.

13 [Slide B-22]

14 MR. CONNELL: Now, on reliability analysis,
15 the FMEA is presented in Section 9.2 of the FSAR.

16 [Slide B-23]

17 The next area is flood protection, and also in
18 the FSAR there is an analysis that was done some years
19 ago to assure that the system will operate under
20 postulated flooding conditions, internal missiles --

21 MR. LE FAVE: Just internal missiles from pipe
22 break, or external flooding?

23 MR. CONNELL: Well, we have done both. The
24 way I read the Standard Review Plan, this was talking
25 about external, but the answer is yes for both.

1 MR. MATTSON: Is this a system that you looked
2 at when you did nonseismic/seismic systems interaction
3 study?

4 MR. CONNELL: Is what? Is the CCW part of, do
5 you mean, what we call the systems interaction program?

6 MR. MATTSON: Yes.

7 MR. CONNELL: Yes, but it is for the effects
8 on that system, yes.

9 MR. MATTSON: The flooding was included in
10 that, wasn't it?

11 MR. CONNELL: Yes.

12 MR. HOCH: Let me correct that. The flooding
13 is included in that only if you are coming out of a
14 seismically-induced interaction, which is something that
15 might lead to flooding.

16 MR. MATTSON: Yes, that is what I meant.

17 MR. RUBENSTEIN: What you call a target system.

18 MR. CONNELL: Yes, correct.

19 Internal missiles. This was presented in
20 Section 3.4 of the FSAR. An analysis was presented
21 which demonstrates acceptable protection of the
22 safety-related systems.

23 [Slide B-24]

24 External missiles. The effects on system
25 operation from external missiles is discussed in the

1 FSAR in Section 3.3. Compliance with the requirements
2 is demonstrated by location within missile-protected
3 structures or by a failure analysis which demonstrates
4 acceptable consequences.

5 [Slide B-25]

6 Now, the last section in the FSAR is pipe
7 breaks. An analysis and a field walkdown was conducted
8 to demonstrate that CCW is adequately protected against
9 the effects, that is, jet impingement and pipe whip, of
10 high energy line breaks. About 1977 a heavy metal
11 doghouse was added around the CCW heat exchangers to
12 provide this protection for the system.

13 MR. BUCKLEY: That is just for outside
14 containment, right? Jet impingement?

15 MR. CONNELL: That is the way I read your
16 standard review plan, yes; but we, of course, have jet
17 impingement inside.

18 MR. BUCKLEY: You are looking at that.

19 MR. CONNELL: That's correct.

20 This concludes my prepared remarks. Although
21 the CCW system was designed and constructed years before
22 Rev. 1 to the Standard Review Plan was issued, I think
23 each of the 15 broad areas of review was properly
24 considered and implemented.

25 MR. ANDERSON: Maybe at this point we could

1 show the slides, and I would like to ask Gary Moore to
2 show that, and that would firm up some of the
3 understanding of the system, particularly how it is
4 operated and where some of this equipment is located.

5 MR. NORTON: Excuse me, Dick, before we go
6 further. One housekeeping detail. One of the reasons I
7 asked this to be prepared in writing, in written detail
8 and presented this way was because of two or three
9 things. One, we knew it was going to be transcribed, and
10 two, because there are allegations that are made and
11 there is some sensitivity about the interpretation,
12 about material representation.

13 What I would like to ask is that this
14 prepared, which was basically followed by the presenter,
15 be incorporated in the transcript. I followed it along
16 most of the time. The words are precisely the same, but
17 once in a while he would turn his head away from what he
18 was reading and the words would vary a little bit, and I
19 think it is proper to put the prepared thing in the
20 transcript.

21 MR. EISENHUT: I don't think we have a problem
22 with that. The slides will also be in there as a whole
23 standard package.

24 I would like to ask you a question about the
25 last sentence of the package that is in the record.

1 [Laughter]

2 You said something to the effect in here that
3 each of the 15 broad areas of review was properly
4 considered and implemented. Would you say, then, that
5 you meet the Standard Review Plan, Rev. 1, Section
6 9.2.2? I am trying to explore, really.

7 MR. CONNELL: To my knowledge I would say we
8 meet the intent of the Standard Review Plan.

9 MR. EISENHUT: And you don't know of any
10 significant deviations?

11 MR. CONNELL: Not that I know of; significant
12 deviation from the way I read the Standard Review Plan,
13 no.

14 MR. ANDERSON: Okay. I will ask Gary Moore,
15 then, to show the slides. Gary is the project engineer
16 from the PG&E organization. He has been with PG&E since
17 1969 and has been associated with Diablo Canyon for the
18 last four years.

19 [Slide]

20 MR. MOORE: I think for these slides we will
21 need the lights dimmed a little bit.

22 [Discussion off the record]

23 I am going to present some pictures taken of
24 the Diablo Canyon plant of the component cooling water
25 system. Specifically these pictures are heat

1 exchangers, valves, pumps and piping and the piping
2 support system, and I will also correlate the pictures
3 with the flow diagram.

4 The first slide is of the component cooling
5 water heat exchanger.

6 MR. EISENHUT: Could I suggest you stand on
7 the other side? That might help you out a little bit.

8 MR. MOORE: Then I interfere with this. All
9 right.

10 This green heat exchanger is the component
11 cooling water heat exchanger, and Chris is pointing that
12 out on the flow diagram.

13 [Slide]

14 This slide is depicting how we have physically
15 separated the two component heat exchangers from each
16 other: namely, this is the 1-1 heat exchanger shown in
17 the last slide, and this is the heat exchanger 1-2.

18 MR. EISENHUT: That is a concrete wall?

19 MR. MOORE: Yes. This is a concrete wall that
20 is separating the two heat exchangers inside of this
21 heavy metal doghouse that Ed just mentioned.

22 [Slide]

23 This picture is showing the discharge piping
24 leaving the component cooling water heat exchanger on
25 the component cooling water side. This header here

1 happens to be the "B" header. This header here is the
2 "C" header. This is the component cooling water heat
3 exchanger. I wanted to just have you note how the pipe
4 is supported. Both of these are seismic pipe restraints.

5 MR. MATTSON: Do you see the remote manual
6 valve in that picture?

7 MR. MOORE: We have a much better picture of
8 it.

9 MR. EISENHUT: Excuse me. As you go through
10 this, if there were any supports, hangers, braces that
11 were modified as a part of the ongoing seismic redesign
12 effort, if you know of any, would you flag those as you
13 go through?

14 MR. MOORE: I am personally unaware of any
15 supports that have been modified on the component
16 cooling water system, but there happens to be one slide
17 where a modification is being performed on the fire
18 water system, which is in the same area.

19 [Slide]

20 Once again, this is a different view of the
21 same piping, once again showing the seismic supports.

22 [Slide]

23 This is where the component cooling water
24 header "C" goes through the wall separating the turbine
25 building from the auxiliary building, and this is a

1 rather massive seismic restraint on that header. And
2 this is the answer to your question one slide later.
3 This is the support modification to the fire system
4 header.

5 [Slide]

6 All right. This picture is showing FCV 355,
7 which is the automatic isolation valve on the C header.
8 It is motor operated, and is provided with means of
9 manually operating it also.

10 [Slide]

11 Another view of the same valve operator
12 showing the platform and the relative position of the
13 platform and the valve operator.

14 [Slide]

15 This is a view of the discharge valving
16 associated with the component cooling water heat
17 exchanger discharge. What you are seeing here is FCV
18 431, which is a motor-operated valve with manual
19 operator. You can see the back side, if you will, of
20 FCV 430. The operator for this valve is on the other
21 side. These two valves -- operator is this here, and
22 you can just see the edge of an operator there -- are
23 the two manual isolation valves in the crosstie to the C
24 header, which is here, and it joins right behind this
25 beam.

1 MR. EISENHUT: Is that a wall that separates
2 those two?

3 MR. MOORE: I believe that is just a column.

4 MR. NOVAK: So there is no actual physical
5 separation between those two operators?

6 MR. MOORE: That is correct.

7 MR. ANDERSON: There is distance. One is on
8 one side of the pipe and one is on the other.

9 MR. MOORE: The first slide, if I can go back
10 to that.

11 [Slide]

12 These are the two manual operators that I just
13 referenced, and you will see that there is no wall.

14 [Slide]

15 This picture is showing some of the seismic
16 restraints which were added to the component cooling
17 water heat exchanger as a result of the Hosgri
18 evaluation.

19 [Slide]

20 This slide is showing a discharge on the
21 component cooling water pump. Here is the centrifugal
22 pump, the discharge piping, and this is showing the
23 split on how it is divided into the two discharge
24 headers leaving the pump. You will also note the two
25 manual isolation valves on the discharge header.

1 [Slide]

2 This slide is showing the suction piping
3 associated with one of the component cooling water
4 pumps, and you will note here is a vital header.

5 George, could you possibly focus that?

6 MR. ANDERSON: I think it is a little bit out
7 of focus in the picture.

8 MR. MOORE: This is the vital header here.
9 This is the C header here. Here are some of the manual
10 isolation valves that are shown in the flow diagram.

11 [Slide]

12 This is a picture of the component cooling
13 water system piping in the auxiliary building, and you
14 will note that this is header C and this is header B,
15 and you will note how the piping is supported
16 seismically on both the two headers.

17 [Slide]

18 This is a slightly different perspective of
19 the same picture. This is Header B and this is Header
20 A. And why you note so many blue pipes is that in this
21 particular area we have both return and supply piping
22 going to the heat exchangers.

23 [Slide]

24 Once again, this picture is showing the pipe
25 supports and how the headers are treated in exactly a

1 similar manner. This is Header C.

2 [Slide]

3 This slide is showing the post-LOCA sample
4 cooler that has been identified as a nonconformance on
5 the job. This the component cooling water supply and
6 return line. These units right here are the heat
7 exchangers themselves. Please note what I would
8 consider a very substantial support connected to a
9 rather massive concrete wall.

10 [Slide]

11 This view is from the opposite side.

12 [Slide]

13 This slide is showing how the component
14 cooling water piping is routed back to the headers.

15 [Slide]

16 This is showing how this piping is supported
17 seismically.

18 [Slide]

19 This is a seismic restraint for the supply and
20 return lines to the sample cooler.

21 [Slide]

22 We are now into a series of slides that will
23 show some of the heat exchangers that are connected to
24 Loop C. This particular heat exchanger is a letdown
25 heat exchanger, and this particular heat exchanger

1 happens to be seismically qualified.

2 [Slide]

3 This is the component cooling water piping
4 going to this heat exchanger. You can see the seismic
5 restraint.

6 [Slide]

7 This is the seal water heat exchanger, which
8 is also seismically qualified.

9 [Slide]

10 This is a view of the same heat exchanger from
11 the opposite direction, once again showing the seismic
12 restraint of the piping.

13 [Slide]

14 This is the spent fuel pit cooling water
15 system heat exchanger.

16 MR. MATTSON: Could we interrupt you a
17 moment? I didn't see any isolation valve in that last
18 one.

19 MR. MOORE: I believe these are on the other
20 side of the wall. I have some pictures. I don't know
21 if I have pictures of the isolation valves with this
22 particular heat exchanger, but you can see how they have
23 been arranged.

24 MR. MATTSON: I understand the point you were
25 trying to make on that last slide. Could you go back?

1 [Slide]

2 Let's say the isolation valve is on the other
3 side of the wall. It is a Seismic Category I isolation
4 valve. Even though this piping and this heat exchanger
5 wouldn't have to be Seismic Category I, you have said
6 that this one happens to be and so is the one that
7 services it. Is that right?

8 MR. MOORE: That's correct.

9 MR. NOVAK: That is a letdown heat exchanger?

10 MR. MOORE: This particular one is. The seal
11 water, I believe. The first two sides of this series
12 where the letdown heat exchanger -- they both happen to
13 be yellow.

14 MR. ANDERSON: The point that we are trying to
15 make is that even though Loop C is not officially a
16 Seismic Category I loop, a great deal of seismic
17 consideration was built into the design.

18 MR. MATTSON: That is all very nice, but the
19 key -- and I don't mean that to be a facetious comment,
20 but the key to the Commissions's regulations would be
21 the isolation valve you can see in this picture and then
22 that other one back there, 355. I am still
23 understanding your story, right?

24 MR. ANDERSON: Right.

25 MR. MOORE: John, do you have a point?

1 MR. HOCH: I just wanted to emphasize the
2 piping. You said this particular piping and this
3 particular heat exchanger happen to be qualified. The
4 piping to every heat exchanger on C loop is completely
5 seismically qualified.

6 MR. MATTSON: Even inside that last isolation?

7 MR. HOCH: Yes.

8 MR. FRIEND: Up to the nozzle.

9 MR. MATTSON: Up to the nozzle.

10 MR. FRIEND: Yes.

11 MR. MATTSON: You hadn't made that point.

12 MR. EISENHUT: That's right, you hadn't. So
13 then let me ask the second piece here. When you
14 relooked at this post-Hosgri, you kept that intact and
15 you kept any modifications you had to make, so now when
16 you are doing the seismic rereview, you are in fact,
17 then, rereviewing and you put Loop C into the program
18 for the seismic review, to the point where if you had to
19 make anything as a result of the present program, you
20 would be making it in Loop C up to the nozzles again.

21 MR. MOORE: Yes. All Category I piping is
22 being reviewed, and this is Category I piping.

23 MR. WERMIEL: I guess the whole crux of the
24 problem, if you could call it that, is whether or not
25 the program is considering or reconsidering the 200 gpm

1 supposed leak rate. Did you in any mechanistic way
2 decide that that number was reasonable based upon the
3 failure of those heat exchanger components that are not
4 seismic Class I like this one is, or is the 200 just a
5 number that you rationalized with engineering judgment?

6 MR. MOORE: Well I think, to answer that
7 question directly, I have a little bit of a problem with
8 your first statement. Part of the program, the design --

9 MR. WERMIEL: Is the 200 gpm being
10 reconsidered, I guess, at all?

11 MR. MOORE: Let's kind of separate the pieces
12 here. As part of the internal verification program, the
13 answer to that is no. As part of the ongoing project
14 work concerning the potential nonconformance of the
15 system, the answer is yes. Okay. To answer the second
16 part of your question, there is evidence that there is
17 some basis, okay, of the 200 gpm leak, but we feel --
18 and that is why I asked for this particular area to be
19 further considered -- I feel that there is not enough
20 objective evidence to satisfy people looking at it
21 today. And I can certainly say that there was
22 engineering judgment used in the development of that 200
23 gpm leak.

24 MR. WERMIEL: And the consideration, the
25 reconsideration that you are undertaking is both a

1 mitigative type thing -- in other words, following the
2 seismic event, I must assure I have the time to isolate
3 whatever is broken with my qualified valves, and in a
4 functional consideration, gee, what does that leak do to
5 my component cooling water system while it is occurring?

6 MR. MOORE: Let me kind of rephrase it. With
7 regard to the 200 gpm and the review of seismic
8 capability of Loop C components in that area, we are
9 presently revisiting that issue to verify the validity
10 and the credibility of the design assumption used,
11 namely, 200 gpm, and in the FSAR we say that that is the
12 maximum credible leak that can occur to the component
13 cooling water system. I guess it is fair to say that
14 that design assumption has been questioned. So to try
15 to put that question to bed, we were reviewing it.

16 [Slide]

17 Okay, this is, as I said, the spent fuel pit
18 cooling system heat exchanger. I know I couldn't say
19 that twice. This particular heat exchanger is not
20 seismically qualified.

21 [Slide]

22 This slide is of this pipe restraint.

23 [Slide]

24 And once again showing the seismic
25 considerations of the piping.

1 [Slide]

2 Another view.

3 [Slide]

4 All right. Getting to the subject of
5 isolation valves, this slide is showing manual isolation
6 valves associated with this type of equipment.

7 [Slide]

8 This is the boric acid evaporator coolers. It
9 happens to be an equipment sked. These heat exchangers
10 are not seismically qualified equipment. This is
11 showing component cooling water going to that piece of
12 equipment.

13 MR. LE FAVE: Where would the seismic boundary
14 be in something like that?

15 MR. MOORE: At the nozzle.

16 MR. WERMIEL: What is the relative distance, I
17 guess, from the spent fuel pool cooler to some of the
18 other nonqualified heat exchangers? They are all in the
19 auxiliary building, I gather, but are we talking --

20 MR. MOORE: I will let my operating friend
21 give you that answer.

22 MR. HOCH: Jim, it is not near any of the
23 other heat exchangers. As a matter of fact, it is in
24 its own compartment with a shield in front of it.

25 MR. WERMIEL: So some of these would require

1 some time for the operators to shake it back and forth.

2 MR. MOORE: Well, in answer, once again, I
3 don't want to beg off on your question, but the question
4 of response time of the operator was one of your
5 specific questions and we plan to give you the answer in
6 Section 7 now or wait till Section 7 of the
7 presentation.

8 Once again, another picture showing manual
9 isolation valves.

10 [Slide]

11 This is a picture of the positive displacement
12 charging pump. The lube oil cooler happens to be cooled
13 off of component cooling water headers C.

14 [Slide]

15 Now this is a picture of the surge tank, which
16 is, as Ed pointed out, located on top of the auxiliary
17 building. This is the tank itself. The question came
18 up this morning about tornado shielding. That is what
19 this is. There is a better view of that, and you will
20 notice seismic restraints on the tank, and I have a
21 better slide but this is the instrumentation we have
22 been discussing.

23 [Slide]

24 This is a closeup of the same view. This
25 happens to be the level switch that has been discussed.

1 [Slide]

2 This is a shot from the other side of the
3 surge tank, once again showing the tornado initial
4 shielding and the seismic restraints.

5 [Slide]

6 This is showing the two surge lines that the
7 makeup system ties to, and this is those lines entering
8 the surge tank through this hole.

9 I believe that concludes the slides.

10 MR. ANDERSON: Mr. Eisenhut, what we would
11 like to suggest, I think, is a little change in the
12 agenda. We have been going through this with a number
13 of questions. The exact same thing happened when we
14 were putting this together. We had a hard time getting
15 through it ourselves without getting into discussion,
16 and many of the questions have been answered as we go
17 along.

18 So I would suggest that over the lunch break
19 we ask people to read Mr. Aronson's remarks. It is all
20 written down. The slides are there and I think maybe
21 after lunch we can discuss any specific questions you
22 have on that, and we will not bother, then, to go
23 through and read that. We would include it with the
24 transcript. You can ask questions on it but we would
25 not have Mr. Aronson read that particular presentation,

1 just to speed things up, and then maybe we could begin
2 after lunch with the questions on the criteria design
3 philosophy and then go on to instrumentation because I
4 think there we get into some specifics that we would
5 like to show you and then finally the operation and try
6 to get through that as quickly as we can so we can open
7 up our discussion.

8 MR. EISENHUT: Let me make a suggestion.
9 First, I agree we need to figure out how to speed it
10 up. I think you will find in the end a lot of our
11 questions have been answered as we go along, asked and
12 answered. Roger Mattson we lose this afternoon. What I
13 would prefer to do is press on for a while and get
14 another section done if we could.

15 MR. ANDERSON: Well, let's go to Crawford,
16 then, on instrumentation.

17 MR. MOORE: Excuse me. I would like to just
18 make one clarification. John Hoch helped me with one of
19 the questions that was asked. The question was asked on
20 the spent fuel pool heat exchanger whether the manual
21 isolation valves were outside the room. I guess I
22 didn't get a very clear answer on that. Yes, and they
23 are accessible. John wrote down accessible without
24 entry, yes, you don't have to go into that room. And
25 Jim Tinlin estimates that it takes something like five

1 minutes to get to those valves.

2 MR. EISENHUT: From the control room?

3 MR. TINLIN: Yes.

4 MR. MOORE: And we will better discuss the
5 basis on how those times are developed.

6 MR. ANDERSON: Okay. We will ask Tom Crawford
7 to go on here. It is a pleasure to introduce Tom to
8 give this presentation. Tom is one of those rare
9 engineers who has been on Diablo Canyon on one project
10 for a period of nearly 12 years. He started in 1971. He
11 was responsible for writing much of the criteria
12 involved in instrumentation. Today he serves on two ISA
13 committees, and one of them involves seismic or involves
14 the classification of in-line instruments, and so he is
15 very well qualified to talk about instruments, and
16 particularly well qualified to talk about the
17 instrumentation on the Diablo Canyon project.

18 AGENDA ITEM 5: INSTRUMENTATION

19 MR. CRAWFORD: I am going to describe the PG&E
20 design philosophy as it applies to Diablo Canyon. I
21 will then describe how we actually classify instruments
22 and how it complies with industry standards, NRC
23 guidance and regulations. Next I will give a short
24 history of our classification system, and finally I will
25 describe how that classification system is implemented

1 in the component cooling water system.

2 [Slide 1]

3 In keeping with Criterion 1 of Appendix A to
4 10 CFR 50, if we were unconstrained by any other
5 standards, we would develop six instrument
6 classifications, from the most important function to the
7 least. They would be: first, those devices which
8 actually perform safety functions themselves; two, those
9 devices which the operator uses to perform manual safety
10 functions; three, those devices that tell the operator
11 the condition of the vital systems; those devices that
12 tell the operator if the safety systems are working;
13 five, those devices which the operator needs to
14 troubleshoot the safety systems; and finally, six, those
15 devices not involved in safety systems.

16 In actuality our classification systems do
17 directly parallel standards and regulations, so it is
18 impractical to have six classifications. But remember
19 this logic because you will see that the first two
20 levels closely match our Class I.A, the second two
21 closely match our I.B, and the third two are not safety
22 related.

23 The design classification of instrumentation
24 at Diablo Canyon specified by Design Criteria Memorandum
25 M3 was titled, appropriately, "Design Class I

1 Instrumentation." The original version was dated March
2 18, 1971 and the current revision was dated March 5,
3 1980. The first classification that it identifies is
4 Instrument Class I.A.

5 [Slide 2]

6 Instrument Class I.A instruments are those
7 which are required to accomplish the functions of the
8 reactor protection or engineered safety feature systems.
9 Simply stated, any instrument which performs a function
10 which is necessary to complete the safeguards function
11 is classified as Instrument Class I.A.

12 This parallels the definition of IEEE Class IE
13 electrical equipment. Class IE is defined as "the safety
14 classification of electrical equipment and systems that
15 are essential to emergency reactor shutdown, containment
16 isolation, reactor core cooling and containment and
17 reactor heat removal or otherwise are essential in
18 preventing significant releases of radioactive material
19 to the environment," and that is from IEEE Standard
20 308-1974.

21 Although not specifically stated in the
22 explanation, the instrumentation which performs the
23 safety function can be operator controlled if manual
24 action is an acceptable way of performing the safety
25 function. Instrument Class I.A complies with 10 CFR 50,

1 paragraph 50.55(a)(h), which requires compliance with
2 IEEE 279. Instrument Class I.A totally envelopes IEEE
3 Class IE as defined in IEEE Standard 308-1974. The
4 electrical portions meet IEEE 279, 323 and 344 as
5 appropriate.

6 There does not appear to be any industry
7 standard with which to compare our requirements from the
8 mechanical and pneumatical portions of I.A. Class I.A
9 instruments are seismically and environmentally
10 qualified to meet single failure criteria and have Class
11 IE power.

12 [Slide 3]

13 Instrument Class I.B instruments are those
14 which provide post-accident monitoring functions. This
15 classification meets the requirements of the U.S. NRC
16 Regulatory Guide 1.97, Rev. 2. It is broken down into
17 five types defined in the Regulatory Guide. They are
18 Type A, those instruments that provide information
19 required to take preplanned manual actions. Type A
20 instruments are seismically and environmentally
21 qualified, meet single failure criteria and have Class
22 IE power.

23 Type B instruments are those instruments that
24 provide information to monitor the process of
25 accomplishing critical safety functions. Type B

1 instruments are seismically qualified, environmentally
2 qualified, meet single failure criteria and have Class
3 IE power.

4 Type C are those instruments that indicate the
5 potential for breaching or actual breach of barriers to
6 fission product release. Type C instruments are
7 seismically and environmentally qualified, meet single
8 failure criteria and have Class IE power.

9 Type D are those instruments that indicate the
10 performance of individual safety systems. Type D
11 instruments are seismically and environmentally
12 qualified and have Class IE power. Type E are those
13 instruments that provide information for use in
14 determining the magnitude of the release of radioactive
15 materials.

16

17

18

19

20

21

22

23

24

25

1 These classifications were written to meet
2 Draft 2 of Reg Guide 1.97, Revision 2. We are in the
3 process of revising our criteria to precisely comply
4 with the issued reg guide. It will be issued before
5 June 1st, 1983 as required by the reg guide. We, like
6 others, are having delivery problems with qualified
7 state-of-the-art devices, and the physical plant does
8 not yet fully comply with the issued reg guide.

9 (Slide 4.)

10 Okay. Instrument Class IC instrumentation is
11 all instrumentation which has no safety function but is
12 attached to a design Class I pressure boundary. It does
13 not parallel any current industry classifications.
14 Class IC instruments are seismically qualified to
15 maintain their pressure boundary.

16 We are addressing this in ISA's SP-67.07
17 committee, but we aren't really there yet. The
18 committee is limiting its work to in-line devices, but
19 the PG&E classification also addresses off-line devices.

20 (Slide 5.)

21 All instrumentation not covered by these
22 classifications is instrument Class II which performs no
23 safety function.

24 Before I go on I would like to make a
25 clarification on a point that may be confusing. All

1 valves with actuating devices on them have two
2 classifications. The instrument classification applies
3 only to the actuator. The piping classification applies
4 only to the valve. It is entirely possible to have an
5 instrument Class II, piping Class I valve and
6 vice-versa.

7 The instrument Class II valves, which you see
8 on the Class I piping in the component cooling water
9 system are indeed piping Class I valves.

10 I would like to capsulize the minimum
11 requirements for our classifications.

12 (Slide 6.)

13 This table is taken directly from our design
14 criteria memo, and not all the information on it is
15 pertinent to the issue at hand. What I want to point
16 out is an instrument Class IA is seismically qualified
17 single failure criteria, environmentally qualified Class
18 IE power. It's actually classified as Class IE.

19 Instrument Class IB, types A, B and C, are all
20 seismically qualified to meet single failure criteria,
21 have environmental qualifications, have IE power. Type
22 D is also seismically qualified. It doesn't have to
23 meet single failure. It does have environmental
24 qualification, and it has emergency power; and emergency
25 power at Diablo Canyon is indeed IEEEE, Class IE. We

1 don't have a separate kind of emergency power.

2 Okay. I would like to address an area which I
3 know has caused considerable debate, and this is the
4 area of contingency actions. Our instrument Class IB,
5 type A is the classification which we allow to
6 instruments which the operator uses to perform manual
7 safety functions. The verbiage in our design criteria
8 memo is "preplanned manual actions."

9 In actual implementation we refer to Reg Guide
10 1.97, Revision 2, which calls type A variables, and I
11 quote, "Those variables to be monitored that provide the
12 primary information required to permit the control room
13 operator to take specific manually controlled actions
14 for which no automatic control is provided, and that are
15 required for safety systems to accomplish their safety
16 functions for design basis accident events. Primary
17 information is information that is essential for the
18 direct accomplishment of the specified safety functions;
19 it does not include those variables that are associated
20 with contingency actions that may also be identified in
21 written procedures."

22 As I said earlier, in our revised criteria
23 memo we used this definition precisely. We defined
24 "contingency actions" as actions for which capability is
25 provided to diagnose and correct system problems which

1 are not part of the direct accomplishment of the safety
2 function. We believe this is consistent with the
3 regulatory guidance, and that is consistent with the
4 design philosophy which I described earlier.

5 I would like to point out that instrument
6 Class II is simply a functional classification. It is
7 not necessarily a measure of the availability of the
8 device. There are many instrument Class II devices in
9 the plant which have been seismically qualified and are
10 wired and powered as IEEE Class IE devices. Some are
11 even redundant. This goes to a very conservative PG&E
12 philosophy that requirements are only minimums. Quality
13 should be commensurate with importance regardless of
14 which box it fits into.

15 This is important enough for me to restate
16 it. These are classifications which fit into little
17 boxes to comply with NRC requirements. PG&E has many
18 devices under our old classifications which were
19 seismically qualified, wired and powered as IEEE Class
20 IE but which have been reclassified as Class II to
21 conform with NRC definitions.

22 The component cooling water surge tank level
23 switch which apparently sparked the controversy at hand
24 is just such an instrument. It performs a contingency
25 function, and it's therefore not instrument Class IA or

1 IB. As you will hear later, it is used in an abnormal
2 condition procedure and not in an emergency procedure.
3 It is, however, provided with Class IE power and inputs
4 into a seismically qualified enunciator.

5 (Slide 1.)

6 I would like to share with you the history of
7 our design classification system. The original design
8 criteria memo was written in March of 1981 to drafts of
9 ANSI N-18.2.

10 MR. NORTON: Excuse me, Tom. You misspoke.
11 That's 1971.

12 MR. CRAWFORD: I'm sorry. 1971.

13 Instrument Class IA was reserved for those
14 instruments defined in Section 5.3 and 5.5 of N-18.2.
15 Instrument Class IB was everything else in the safety
16 functions; that is, the next four items on our
17 philosophy list.

18 Although some specific minimum criteria were
19 given for IB, the unwritten criteria was basically the
20 embodiment of GDC 1, quality commensurate with its
21 function.

22 In December of 1976 the NRC Region V was
23 auditing us and found inconsistencies in the wiring of
24 IB devices and asked what the criteria were. Since we
25 couldn't provide a single set of criteria, we agreed

1 that an overhaul was in order.

2 In 1977 we wrote design criteria memo M-3,
3 Revision 1, putting all devices which perform safety
4 functions into IA and paralleled IA to IEEE Class IE.
5 We relabeled Class IB as devices used for "peripheral
6 control and monitoring of safeguards systems," with
7 requirements consistent with the importance to be
8 determined on a case-by-case basis. None of it was
9 called IE, but we wired it, powered it, and qualified it
10 as if it were IE, if we felt it to be appropriate.

11 After TMI I participated in the staff-industry
12 meetings on Reg Guide 1.97, Revision 2, and when I
13 thought that it was basically firm, the Draft 2 stage, I
14 rewrote our criteria memo M-3 to make IB reflect the
15 draft regulatory guide. The upgrade to the physical
16 plant, which is still in progress, has been minimal.

17 Our Class IB previously included peripheral
18 control and some diagnostic monitoring. When we made it
19 match the regulatory guide there was no place for these
20 functions. From a classification point of view they
21 became Class II, but they will still be available when
22 we think the operator needs them. The surge tank level
23 switch is just such a device.

24 Now I want to discuss the implementation of
25 these classifications in the component cooling water

1 system.

2 (Slide 7.)

3 This slide shows the diagram or this is the
4 system diagram which Mr. Connell showed you earlier, and
5 I'm going to go through each classification, one
6 classification at a time, and show you which instruments
7 in the system fit that classification and why they fit
8 it.

9 (Slide 8.)

10 Okay. This slide shows the instrument Class
11 IA, automatic functions in the component cooling water
12 system. There are no protection systems signal
13 initiating, in other words IA instruments in the
14 system. There are several system automatic functions
15 which are initiated by devices outside of the system. A
16 safety injection signal is initiated by LOCAs and main
17 steam line breaks. Containment high pressure, that
18 causes all three component cooling water pumps to
19 start. It opens FCV-366 and 360 which are on the
20 containment fan coolers. That is all I get the safety
21 injection does.

22 Containment isolation signal, which is
23 initiated from a safety injection signal in phase A,
24 closes some of the containment valves on header C of the
25 component cooling water system. A phase B containment

1 isolation signal which is initiated when the pressure in
2 the containment exceeds 22 psi closes the remaining
3 containment isolation valves on header C, and it
4 isolates the entire header C by closing FCV-355.

5 (Slide 9.)

6 In addition to the automatic safety functions,
7 there is one manual safety function which this slide
8 shows; that is, the system changeover when one goes on
9 to RHR. Most of this is accomplished locally, but the
10 radiation dose level is such that access to the RHR heat
11 exchanger valves is not feasible. I should point out
12 that is the only place we have analyzed where that is
13 the case. Therefore, these valves, FCV-364 and 365, are
14 remote manual valves and are indeed Class IA.

15 (Slide 10.)

16 This slide shows the instrument Class IB
17 devices. Since the only manual safety function is the
18 RHR realignment, the only IB type A instrumentation
19 would be that used for such a realignment. The operator
20 makes this change when he goes into the recirculation
21 mode after a LOCA.

22 The type A instruments for this function are
23 the refueling water storage tank level and the
24 containment recirc sump level, neither of which is in
25 the component cooling water system. There are not type

1 B or C variables by definition, and also if you compare
2 it with the table in the reg guide, there are two type D
3 variables. The reg guide defines the flow and the
4 temperature, two vital systems, as being the instruments
5 needed to monitor whether the component cooling water
6 system is doing its job, and therefore they are the type
7 D variables. So we indeed have discharge variables, and
8 we have flow to the vital headers.

9 In addition, PG&E considered the flow to the
10 nonvital header as a very legitimate way of determining
11 whether the system is performing its function. So we've
12 also classified that indicator as IB, type D.

13 MR. MATTSON: You've got a temperature
14 indicator and a flow indicator, but one of the things
15 you worry about is whether you have got enough water
16 contained in the component cooling water system.

17 MR. CRAWFORD: The safety function of the
18 component cooling water system is to provide flow to its
19 vital functions. We know whether we have enough flow.

20 MR. MATTSON: So if you had a makeup problem,
21 you would see a flow deficiency.

22 MR. CRAWFORD: Yes. The point you are getting
23 at precisely, which I might as well just hit head on, is
24 there is a concern obviously about how does the guy know
25 that he is going to lose his flow. Right now what we're

1 talking about, well, is a device which specifically
2 issues to alert the operator that if he doesn't do
3 something, he might lose his system.

4 But the regulatory guide does not talk about
5 what I will call preventative measures, which is what
6 we're talking about here. The reg guide addresses
7 whether or not the safety system is working. It doesn't
8 say it's going to be working in ten minutes if you don't
9 do something. It says is it working now?

10 As I said earlier, we feel that it is a good
11 idea for the operator to know if he is going to lose it,
12 and therefore, we provided that level switch, and we've
13 made sure that it has got Class IA power, et cetera.
14 But that doesn't fit the box in the reg guide is what
15 I'm telling you.

16 MR. MATTSON: Let's see. If we reached down
17 out of the sky and said make the level indicator IB, you
18 could do that?

19 MR. CRAWFORD: Well, to meet IB you have to
20 meet the reg guide, and the reg guide talks about
21 indication. Okay. It is an irony the reg guide doesn't
22 talk about an alarm, and the alarm does not meet the
23 requirements of a reg guide.

24 MR. MATTSON: Except for an alarm versus an
25 indicator, you would meet it?

1 MR. CRAWFORD: One minor thing is these
2 instruments were installed as seismically qualified. As
3 you are well aware, we are going through phase 1 in all
4 of this. We have not upgraded or maintained those
5 seismic qualifications to the current thinking. They
6 have been tested, and there is a response specter
7 available, and we would have to go through and check.
8 There is a possibility, a very real possibility because
9 of that area that they may need to be reshaped. But it
10 is more of a testing thing. It is not a matter of
11 function.

12 MR. MATTSON: A different kind of question:
13 If there was a makeup deficiency and the surge tank had
14 trouble of some kind and the level didn't serve that
15 function because of a loss of capacity of your seismic
16 event, after a seismic event you would get some
17 indication from the flow meters of the loss of makeup
18 and probably go through some diagnosis to figure out
19 that it wasn't the pump that was causing the trouble,
20 but it was in fact the loss of fluid.

21 How long would you have for what size leak?

22 MR. CRAWFORD: It depends upon the leak.

23 MR. MATTSON: To identify, can you give me
24 some feel?

25 MR. CRAWFORD: It depends specifically on the

1 leak. The operator action would first be to isolate the
2 leak. As I described earlier, we have flow indicators
3 on every heat exchanger or every significant heat
4 exchanger.

5 MR. MATTSON: I was trying to get a feel if it
6 was a 10 gpm leaking at 3 nanoseconds or something.

7 MR. CRAWFORD: Well, the design of the system
8 is assuming 200 gpm leak. He has something like 20
9 minutes.

10 MR. MATTSON: How big a leak?

11 MR. CRAWFORD: Two hundred.

12 MR. MATTSON: For a 200 gpm leak he has 20
13 minutes to find it and fix it or else he's going to lose
14 a pump?

15 MR. CRAWFORD: He has 20 minutes to get to the
16 bottom. He has still got water in the surge tank for 20
17 minutes.

18 MR. CONNELL: That assumes no makeup.

19 MR. CRAWFORD: That assumes the automatic
20 makeup function doesn't work. It assumes that.

21 MR. MATTSON: That is a little bit different
22 question. After the surge tank runs out, now at X gpm
23 how many minutes has he got before he does what, burns
24 up a pump?

25 MR. CRAWFORD: Something I haven't indicated

1 here, he also has low pressure switches on the headers,
2 so that is the first thing he will actually see.

3 MR. MATTSON: Are those Class IB?

4 MR. CRAWFORD: They are IC. Again, they are
5 enunciators.

6 MR. MATTSON: They are seismically qualified
7 but?

8 MR. CRAWFORD: They are IC. They are
9 enunciators and therefore are not within the scope of
10 the reg guide. They will not trip the pump.

11 MR. MATTSON: But he still gets the indication.

12 MR. CRAWFORD: Yes.

13 MR. LE FAVE: The standby pumps do not
14 automatically pick up on low discharge pressure, do they?

15 MR. CRAWFORD: In an accident all the pumps
16 start automatically.

17 MR. LE FAVE: In normal operation you would be
18 talking about a pipe break.

19 MR. CRAWFORD: He would not.

20 MR. LE FAVE: It would pick up or he wouldn't.

21 MR. CRAWFORD: I'm sorry. That low switch
22 also starts all pumps.

23 MR. BUCKLEY: But in response to Roger's
24 question, if you drained the surge tank, you've only got
25 whatever water is in that surge line, so you're talking

1 about minutes.

2 MR. CRAWFORD: You're talking about however
3 long it takes to drain the surge line basically.

4 MR. HATTSON: But the pumps will work without
5 the lines being full for a while, won't they?

6 MR. CRAWFORD: Sure. The first thing he's
7 going to have, he's going to have low pressure alarm,
8 and then he's going to get a low flow.

9 MR. EISENHUT: I'm not sure I understand the
10 answer, though. Suppose one of these heat exchangers
11 out on loop C has a leak and suppose -- let's stipulate
12 for whatever reason for the moment it's more than 20
13 gpm. In the normal operating mode how long does he
14 have? You start draining the system. You get
15 indication. How long is it before an operator must be
16 doing something to isolate that?

17 MR. CRAWFORD: Must be doing something to
18 protect what?

19 MR. EISENHUT: To ensure that he has an
20 adequate flow for the safe emission of the CCW.

21 MR. FRIEND: Nothing. As long as the makeup
22 system is functioning, he could go for a long darn time
23 because it's just running on the floor, and it's making
24 up at 250 gpm.

25 MR. EISENHUT: So it is really, as Roger says,

1 it's a horse race. You've got water going out of the
2 heat exchanger.

3 MR. CRAWFORD: Could I have Ed Connell's slide
4 of the makeup system?

5 MR. EISENHUT: So actually the time is a lot
6 more than any 20 minutes, and you really have to look at
7 this in the overall context of what kind of leaks.
8 You've got the whole system full. You've got a surge
9 tank. You might or might not have makeup on. You've
10 really got to put it in a different perspective.

11 (Slide.)

12 MR. CRAWFORD: I should explain something.
13 When we put these control valves in, we seismically
14 qualified them. The level of controls are seismically
15 qualified to function. I was talking to John Lasher
16 about it. It's interesting. This level controller was
17 the only instrument we've ever had that actually had a
18 problem. It is a pneumatic controller, and it jumped
19 its seismic shock mills in the test, and it drifted by
20 10 percent, but it still works.

21 We have a seismically qualified level control
22 on that tank. Now, it doesn't have backup error. I
23 don't want to mislead you. In other words, if you lose
24 offsite power, you have no error to it. But I'm saying
25 that device is bought as a Class I device. It will work

1 through a seismic event just fine.

2 We have redundant capability automatic
3 makeup. We fully feel that we're going to have makeup.

4 MR. MATTSON: I think your point is even
5 stronger than that. I think your basic point is we meet
6 Reg Guide 1.97.

7 MR. CRAWFORD: That's right.

8 MR. MATTSON: And that is after all the
9 staff's best, most current thinking of what is required
10 to function after design basis events and beyond design
11 basis events for all PWRs no matter their design
12 vintage, and that is a very strong statement.

13 MR. CRAWFORD: ~~That's right.~~ That's right. In fact, we go
14 beyond it.

15 MR. EISENHUT: The point I think you're
16 making, if you go beyond it, if I understand what you're
17 telling us, you go beyond it, and from looking at your
18 Table 1 I don't see really much difference between --
19 ID, type C is really no different than ID, type A or B.
20 They are all really the same bag. The only difference
21 is item 5, the IEEE classification, between a Class IA.

22 MR. CRAWFORD: Only IA meets IEEE
23 classification because most of that has to do with
24 system bi-stables. They don't imply two indicators.

25 MR. EISENHUT: But all of this instrument is

1 Class IB, I guess.

2 MR. CRAWFORD: No. B's instruments are level
3 switches. They are not IB at all. They are instrument
4 Class IC.

5 MR. EISENHUT: I'm sorry. The level switches
6 --

7 MR. CRAWFORD: The level switches are IC.

8 MR. EISENHUT: But you say it is seismically
9 qualified.

10 MR. CRAWFORD: It was seismically qualified
11 when we installed it. Because of the declassification,
12 we have never revisited that qualification.

13 MR. EISENHUT: I understand.

14 MR. DUNNING: Did you say the enunciator
15 system was seismically qualified?

16 MR. CRAWFORD: That is correct, with
17 limitations. The drum isn't. But you will get the
18 alarm on the window.

19 MR. DUNNING: Your only point was that Reg
20 Guide 1.97 didn't address enunciator systems?

21 MR. MATTSON: Before you get too far afield, I
22 think where Tom and Daryl are headed is trying to prove
23 that it's even better. I think there must be
24 instruments in more directly applicable safety systems
25 where we have to make the same statement.

1 Let's take the RHR or the ECCS in the low
2 circulation mode. Let's assume we're asking the same
3 question. It probably has a flow indicator and a
4 temperature indicator to show that it is accomplishing
5 its decay heat removal system and that it has got
6 adequate flow. It probably does not under Reg Guide
7 1.97 have to have an instrument saying that it is losing
8 suction, right?

9 MR. CRAWFORD: You've got it.

10 MR. MATTSON: You would know it by loss of
11 flow eventually, but you don't have to be able to
12 anticipate it under Reg Guide 1.97.

13 MR. CRAWFORD: That's exactly right. You said
14 it. That level switch is an anticipatory device.

15 Okay. So all the remaining instrumentation
16 physically on the system is instrument Class IC. There
17 are many devices, none of which have a safety function,
18 so I will not discuss them here.

19 (Slide 11.)

20 I would like to discuss other devices which
21 are not Class IA or IB which we feel are important.
22 Most were Class IB under our old definition of
23 "peripheral control and monitoring." They don't,
24 however, fit our current definition of Class I devices
25 except IC as appropriate.

1 This slide shows some of those devices. First
2 off, we have the ability to automatically make up the
3 surge tank with redundant instrument Class IC
4 controllers and the instrument Class II control valves.
5 We have the instrument Class IC low alarms on the surge
6 tanks, which I discussed earlier. They are functionally
7 redundant and powered as IEEE, Class IE.

8 We feel the determination of the surge tank
9 level is an important diagnostic tool for leak
10 detection. Although I didn't show them on this slide,
11 we have Class IC flow indicators in every significant
12 heat exchanger on loops -- on headers A and B. We also
13 have a flow indicator on every heat exchanger on the C
14 header which has a line size over two inches, except for
15 one which is isolated by a containment isolation
16 signal. Some of these are local and some are on the
17 main control board basically depending upon how
18 important we felt they are. These allow the operator to
19 quickly locate and isolate leaks.

20 MR. FRIEND: Read that paragraph again, please.

21 MR. CRAWFORD: Although I didn't show them on
22 this diagram, we have Class IC flow indicators on every
23 significant heat exchanger on headers A and B. We also
24 have a flow indicator on every heat exchanger on the C
25 header which has a line size over two inches, except for

1 one which is isolated by a containment isolation
2 signal. Some of these are local, and some are on the
3 main control board. These allow the operator to quickly
4 locate and isolate leaks.

5 MR. MATTSON: Jerry, does that help with your
6 question?

7 MR. WERMIEL: To some extent.

8 MR. CRAWFORD: Although our design basis is
9 the ability to operate given a long-term single failure
10 where the operator goes down and manually isolates the
11 system halves, we felt it would be wise to provide
12 immediate capability to cut in or out heat exchangers.
13 Therefore, we have motor operators on the discharge
14 valves for the heat exchangers, FCV-430 and 431. These
15 are instrument Class II simply by definition, but they
16 are seismically qualified, powered and wired as IE
17 devices. They are also environmental devices.

18 We have Class IC radiation monitors on the
19 system to detect radioactive leaks into the system, and
20 these monitors also isolate the system vent as a
21 precautionary measure.

22 In summary, the instrument classification
23 system for Diablo Canyon meets all applicable standards,
24 regulations and guidance, and the actual implementation
25 is more conservative than classifications themselves.

1 MR. ANDERSON: If we could ask you to maybe
2 take a look at Chuck Aronson's written presentation over
3 lunch, we could talk about some of the specifics in that.

4 MR. FRIEND: Unless you want to keep going.

5 MR. EISENHUT: I will give you a choice.
6 Since we're going to have to come back, I would suggest
7 go ahead and maybe taking a break at this point. I
8 don't think you can make it all the way through the
9 whole thing.

10 MR. MOORE: No, we can't.

11 MR. ANDERSON: But Jim Tinlin on the
12 operation, that might be fairly short if we could get
13 through that.

14 MR. EISENHUT: Okay. Why don't we go ahead
15 and do that and then break for lunch?

16 (Discussion off the record.)

17 MR. ANDERSON: Okay. We have asked Jim Tinlin
18 to give this next part of the presentation.

19 I mentioned some of his background before. He
20 is a senior reactor operator, and he is also the
21 training coordinator for the Diablo Canyon operations
22 and training section, so he has very good qualifications
23 in talking about plant operations.

24 Jim.

25 MR. TINLIN: Basically I'm going to cover the

1 operation of the system. Much of it has been covered
2 already before, but I'm just going to reiterate it from
3 an operations standpoint.

4 (Slide 1.)

5 You can see the normal operation of the CCW
6 system in this slide. We will normally have two pumps
7 in operation, one heat exchanger to remove all of the
8 normal heat loads from the system during operation. All
9 the components are normally connected to the system, not
10 isolated, with the exception of a few specific
11 components which we have capability of supplying it from
12 the other unit, and that's the only reason why I
13 included that. They may not or may be connected to the
14 system, but they have no vital function.

15 The standby heat exchanger will be in service
16 and capable of being used if it is filled, vented, and
17 essentially all the operator has to do is open one valve
18 in the heat exchanger.

19 MR. EISENHUT: Let me ask a simple question,
20 and really I am not sure I understand the question. Why
21 did you -- when you did the design why did you line it
22 up so that under these normal conditions following these
23 events you really only used one heat exchanger rather
24 than just lining it up in parallel from the start?

25 I mean what was just really the philosophy of

1 it?

2 MR. TINLIN: Why one heat exchanger during
3 normal operation rather than two?

4 MR. CRAWFORD: You have one for standby.

5 MR. HOCH: During normal operation you have
6 one auxiliary feedwater pump. You don't use all three
7 component cooling water pumps. There is some
8 consideration for other power users, and we are
9 sensitive to from an economical standpoint there's no
10 reason to operate it.

11 MR. EISENHUT: Then following an event as you
12 go through various phases does the same thing hold? Is
13 that why you hold on one and sort of reserve the second
14 for backup?

15 MR. TINLIN: According to the design of the
16 system, one heat exchanger is sufficient to remove the
17 design heat load during the design basis accident. The
18 other one there has a standby just in case you need it.
19 At least that's my philosophy.

20 MR. EISENHUT: Well, I just wanted to be sure
21 that that is the logic, and then in essence you keep a
22 perfectly good heat exchanger in reserve all the time.

23 MR. TINLIN: In standby.

24 MR. FRIEND: You have a whole loop, Daryl, so
25 you can take an active failure and another one.

1 MR. EISENHUT: Earlier it was mentioned when I
2 referred to normally used heat exchanger, one, do you
3 really do that from an operation standpoint, or do you
4 alternate?

5 MR. TINLIN: That was my next paragraph.
6 Basically, the way we operate the system is like I said,
7 two pumps, one heat exchanger, and normally on a weekly
8 basis we slop off the heat exchanger and pumps to
9 equalize run times.

10 MR. WERMIEL: Can I ask a question on the
11 pumps? What are your tech specs say for availability.
12 Do you enter an LCO with one pump down or two?

13 MR. TINLIN: The technical specification for
14 this system specifically states that two vital headers
15 must be available. We interpret that to say one header
16 flow path and one pump.

17 MR. WERMIEL: And one pump is sufficient to
18 fulfill the design basis?

19 MR. EISENHUT: Let me see this. Now I have a
20 whole slew of questions.

21 Is there -- if you took that interpretation it
22 would say that one of the vital loops could be down
23 essentially indefinitely.

24 MR. TINLIN: No. We have a time period. If
25 you see that LCO, you have 72 hours to repair the

1 header. If you don't, you have to go to hot shutdown in
2 six hours and a cold standby in 30.

3 MR. EISENHUT: Okay.

4 (Slide 2.)

5 MR. TINLIN: During plant cooldown which was
6 previously mentioned, the third CCW pump and second heat
7 exchanger is placed into operation, mostly for
8 convenience because you are using two RHR heat
9 exchangers to cool the reactor coolant system down to
10 cold shutdown conditions. It is not required that both
11 the exchangers be in operation. It is just that having
12 two in it decreases the amount of time it takes to cool
13 down, which is a little bit easier for the operators to
14 do that way.

15 We can cool the plant down with one heat
16 exchanger if necessary. It has the capability.

17 MR. EISENHUT: Excuse me. Then let me clarify
18 your presentation, and your writeup said, and it
19 appeared earlier also that you switched and put on the
20 second heat exchanger 1-2 due to the increased heat load.

21 MR. TINLIN: Right.

22 MR. EISENHUT: What you're really saying, as I
23 understood what you now say, is mostly for convenience,
24 and in fact you could handle it with one.

25 MR. TINLIN: Sure. It would take a lot longer

1 to cool down, though, but you can remove sufficient heat
2 with one heat exchanger.

3 (Slide 3.)

4 And then it is placed back to its normal
5 configuration once the system has been cooled down.

6 Abnormal operation I have broken down
7 basically into two contingency actions. One of them
8 would be the event of a high heat exchanger outlet
9 temperature. This alarms the main control board at
10 approximately 120 degrees to indicate to the operator
11 that either excessive heat loads exist on the system or
12 that a flow reduction has occurred.

13 Per procedure the operator has several
14 immediate actions he can perform. One, he is going to
15 verify the condition exists by looking at the
16 temperature indicator on the main control board. If the
17 heat load is in fact too high, the standby heat
18 exchanger is placed in service using all applicable
19 operating procedures.

20 In addition to that, he will also check flows
21 on the ASW system as well as the CCW system to verify
22 that that is not the cause of the excessive temperature.

23 MR. NOVAK: With regard to the component
24 cooling water pumps, do they have any special
25 characteristics to clear air binding problems?

1 MR. WARD: Do you mean in the sense of being
2 automatically vented?

3 MR. NOVAK: Yes. If you do get air binding,
4 do you have to bleed them?

5 MR. TINLIN: Not on the pumps specifically.
6 There is a system on the heat exchangers to fill in
7 there.

8 MR. MOORE: The answer to your question is --
9 I believe the correct answer to your question is there
10 are no special features or design features for that
11 purpose. Venting and filling of the system I believe is
12 a manual operation.

13 MR. FRIEND: But the surge tank is vented, and
14 it is high up in the system, so once you get the system
15 solid, it is not going to --

16 MR. MOORE: I anticipated his question. I
17 think he was postulating down here.

18 MR. WERMIEL: Let me just ask another question
19 on the same thing Daryl and I were talking about
20 before. The tech spec allows one CCRB pump to be out
21 indefinitely.

22 MR. TINLIN: That's the way we interpret it.

23 MR. WERMIEL: Okay. Now, I have that pump
24 down. I have two pumps available. I now get an event
25 which requires at the P signal to close up CV-366, the

1 C-loop.

2 MR. TINLIN: 355.

3 MR. WERMIEL: 355. Whatever it is. If the
4 C-loop is isolated, do I lose suction to the 1-2 pump?
5 On the suction side I'm talking about. Because the
6 valves are closed there, it appears to me I don't have
7 any suction to that pump -- that is the way it looks --
8 which means that a single failure in the 1-3 pump now
9 leaves me with no CCW. That is the way it looks.

10 MR. LE FAVE: That is the condition we want to
11 discuss, though, not the P signal. It is the pipe break
12 in a single failure that takes you out, not the P signal.

13 MR. WERMIEL: It's anything, I guess, that
14 could cause isolation or failure in the C-loop, which
15 could be a pipe break.

16 MR. TINLIN: That other condition that was
17 shown was isolating the entire C-header loop which is
18 one of the what I guess you could say the biggest
19 contingency action you could do. Normally you would
20 isolate each individual heat exchanger. In that case
21 you would not be isolating the pump. And this big
22 failure on C-loop, according to the FSAR, is not
23 postulated. We're looking at 200 gpm again.

24 MR. WERMIEL: With a 200 gpm leak do you know
25 that you won't get an unacceptable suction condition?

1 MR. TINLIN: Sure, because we can make up for
2 it with the makeup system.

MR. WERMIEL: And you're saying I will have
4 that makeup capability even following some seismic event?

5 MR. TINLIN: Yes.

6 MR. MOORE: That was the Class I makeup system.

7 MR. TINLIN: This can be indicated by several
8 indicators and/or alarms on the control board. One can
9 be a low CCW surge level, as was talked about
10 previously, and/or low header pressure alarms which are
11 on the vital loops. Automatic actions that can occur in
12 this case are the standby CCW pumps start on low
13 pressure, and the automatic makeup system valves will
14 open to raise the surge tank level on low levels.

15 Immediate operator actions that the operator
16 has to perform are: one, to verify that those
17 previously mentioned automatic actions occurred. If
18 they don't occur, he is directed to specifically perform
19 manual backup actions for those automatic actions, which
20 would include starting additional pumps, open bypasses
21 around those makeup valves if necessary, whatever he has
22 to do.

23 If level is lost in both halves of the surge
24 tank, the operator is instructed to trip the reactor and
25 trip the reactor coolant pumps, because the reactor

1 coolant pumps will lose cooling, and rather than trip
2 the coolant pumps and trip the reactor, he puts the
3 plant in a safe condition and removes that heat load.
4 If, in fact, only the level 1 half of the surge tank is
5 lost, he can physically separate the systems, run on one
6 good vital header and then place the plant in a safe
7 condition.

8 (Slide 4.)

9 As indicated --

10 MR. BUCKLEY: Can I ask you a question on
11 that? Your makeup through your solenoid valves in the
12 surge tank comes on before you get a low level alarm.
13 You get an indication to make up before you get a low
14 level, right, I would imagine.

15 MR. CRAWFORD: Yes. It is proportional
16 controllers, not an on/off.

17 MR. BUCKLEY: So you could have the makeup
18 pumps continuing to make up without ever getting a low
19 level alarm in the surge tank, is that correct?

20 MR. TINLIN: That's possible.

21 MR. BUCKLEY: So you could have a leak and not
22 get an indication of a leak.

23 MR. CRAWFORD: Not true.

24 MR. TINLIN: The level control valves are
25 equipped with an alarm on them to indicate the fact that

1 they have opened. That will clue the operator into the
2 fact that makeup should be taking place.

3 MR. BUCKLEY: They would be making up -- I
4 mean they would be alarming every time they make up,
5 right?

6 MR. TINLIN: That's right.

7 MR. BUCKLEY: So the operator would not
8 necessarily know it is a leak or just a normal makeup.

9 MR. TINLIN: Well, that amount of makeup would
10 definitely be an unusual occurrence.

11 MR. BUCKLEY: The valves will be open for an
12 indefinite period of time, and would you have a
13 continued alarm?

14 MR. TINLIN: Yes. The alarm stays in.

15 MR. BUCKLEY: So that would be a kind of
16 indication.

17 MR. CRAWFORD: Not only an alarm but there's a
18 counter on it. In other words, for a whole lot of
19 reasons we want to know when we are making up, so we
20 have a position switch, and we have a little mechanical
21 device on the valve that counts every time the valve is
22 open. We let the operator know that he is making up.

23 MR. MOORE: And we use this counter in time
24 to, if you will, allow the operator to determine the
25 rate at which he is having to make up or the rate of the

1 leak that he has.

2 MR. TINLIN: Or a fairly good estimation of
3 what the leak is. When this procedure is completed,
4 basically the following steps are to determine the
5 source of leakage and some of the indicators, as we
6 pointed out before, flow meters, both local^{ly} and
7 remotely, that he can use and then isolate that source
8 of leakage.

9 This particular slide shows a typical
10 component isolation valve arrangement. Every component
11 on the CCW system has at least one supply and return
12 isolation valve. Some have more than one. Some have
13 automatic valves. So every one of them is capable of
14 being isolated independently or if there needs to be an
15 entire train.

16 (Slide 5.)

17 During emergency operation, which would be a
18 LOCA and post-LOCA condition, a safety injection signal
19 starts all three component cooling water pumps to
20 protect against any single active failure. Also, during
21 a safety injection signal, a phase A containment
22 isolation signal is generated which isolates most of the
23 process lines in and out of the containment, which will
24 significantly reduce the normal heat loads in the system.

25 If a phase B containment isolation signal is

1 generated, which will come about under most LOCA
2 conditions but definitely during a design basis LOCA,
3 the miscellaneous header C supply, reactor coolant pumps
4 and vessel support pad coolers, which are also on header
5 C, automatically isolate. Operators are required by
6 procedures to specifically verify all these actions have
7 occurred. If they don't occur, he manually backs them
8 up. This is in the immediate operator action section of
9 the procedures which they are required to memorize and
10 know word for word to get a license to isolate the plant.

11 Post-LOCA conditions require the safeguard
12 system to be separated into redundant trains to prevent
13 loss of a system in the event of a single passive
14 failure. This procedure specifically states the time
15 frame when this must be done and the valve lineups
16 required.

17 (Slide 6.)

18 Basically, as you can see by this slide, both
19 heat exchangers will be placed in service, one supplying
20 each vital header, and one pump will be aligned to one
21 vital header, and the other pump or pumps will be
22 aligned to the other vital header and/or header C as
23 necessary.

24 (Slide 7.)

25 If a failure happens to occur on header C, the

1 loop can be manually valved out of the system completely
2 to maintain the integrity of the vital loops A and B.
3 All of these manual actions which would have to be
4 performed to valve this out are all located, as was
5 previously mentioned, in low radiation areas, CCW pump
6 rooms and CCW heat exchanger rooms, and can be
7 accomplished in a fairly short period of time.

8 MR. NOVAK: Do you have any estimates as to
9 the times -- let me call them a break period. If you
10 were say in a post-accident LOCA, for some reason all
11 CCW pumps were secured, do you have any analysis or
12 feeling for the amount of time it would take or the
13 amount of time you would have to perform certain safety
14 functions which would be lost or challenged?

15 MR. TINLIN: What you're saying is if I
16 completely use the CCW system during a safety injection,
17 how long do I have before I have to get it back before I
18 start losing safeguards components?

19 MR. NOVAK: Yes.

20 MR. CONNELL: No CCW at all?

21 MR. NOVAK: Yes. For some reason. I would
22 expect that there is some lag time, some grace period
23 for which you could restart, for example, the
24 containment, the failure to turn on coolers.

25 MR. CONNELL: I don't have a quantitative

1 answer to that.

2 MR. ANDERSON: I guess we can't answer that
3 question. We haven't looked at that, and that is not
4 part of the design basis.

5 MR. FRIEND: We approach it the other way,
6 Tom, to do our best to ensure that we don't have a loss
7 of CCW system rather than to try to make an evaluation
8 of how long it can survive without it.

9 MR. NOVAK: There is no specific procedure
10 prepared that would suggest for some reason securing all
11 CCW pumps?

12 MR. TINLIN: No, never. There is no reason to
13 shut that entire system down. I can't think of any,
14 whether it be normal operations or abnormal.

15 MR. MOORE: I think that is what the license
16 allows you to do.

17 MR. NOVAK: I realize that, but I still asked.

18 MR. ANDERSON: Okay. Are we finished with
19 that section then? And maybe we could ask you maybe to
20 look at Mr. Aronson's prepared remarks during lunch, and
21 we can discuss that further.

22 And the questions, of course, the NRC
23 questions we received on Tuesday, and then any
24 discussion, that can take place this afternoon.

25 MR. CREWS: Can I add one more thought? We

1 looked at the procedures within the operating department
2 for assuring the reportability to make sure they are
3 according to the tech specs.

4 Can you just say when we come back, tell us
5 how you adopt this interface, the internal technical
6 program information? It would give me a great deal of
7 comfort if I knew, for example, that those findings got
8 to the operating department.

9 MR. MOORE: I can answer that question right
10 now. As I pointed out, when I formed the technical
11 review group when the interim nonconformance was
12 identified, one member, one standing member of the TRG
13 is a member of the operating department. It happened to
14 be Jim Tinlin, I believe, on the second, third and
15 fourth meetings, and it was another member of the
16 operating department on the initial one. And one of
17 their responsibilities is to monitor those activities
18 and make sure that we are in conformance with their
19 reporting requirements.

20 I don't know. John, would you like me to just
21 briefly discuss how we have been reporting issues like
22 this out of the verification program?

23 MR. HOCH: I would rather do it, if you don't
24 mind.

25 MR. MOORE: That answers I think the only

1 other question.

2 MR. FRIEND: Why don't we break for lunch, and
3 we could get out act together and give you a good
4 discussion after lunch.

5 MR. EISENHUT: I think that is a good idea.
6 Why don't we come back at 2:00?

7 (Whereupon, at 12:50 p.m., the meeting was
8 recessed for lunch, to be reconvened at 2:00 p.m., the
9 same day.)

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

1 AFTERNOON SESSION

2 (2:00 p.m.)

3 MR. ANDERSON: We have been through a number
4 of answers and questions. I guess at this point it is
5 best to just open it up to your questions. We can
6 discuss further questions sent to us this Tuesday, if
7 that would be your wish, or we can deal with any other
8 questions you might have from the morning's presentation
9 or from reading Mr. Aronson's presentation or anything
10 else you want to talk about at this point.

11 MR. EISENHUT: Well, first of all, let's see.
12 I might suggest the following. Does the Staff have any
13 specific items on Aronson, on the Aronson paper? And if
14 not, why don't we go ahead to the specific questions
15 that were identified, sent out and referred to in the
16 agenda. And a number of those, of course, we already
17 addressed; some we did not.

18 Maybe we ought to walk through those that have
19 obviously been addressed, and it would be pretty simple
20 just to move on down the line. Would that be a fair way
21 to proceed?

22 MR. NORTON: I think Jess had a question
23 pending over the lunch hour, and maybe we ought to do
24 that first because that is not in that list.

25 MR. EISENHUT: Sure.

1 MR. HOCH: Jess, could you phrase your
2 question once again?

3 MR. EISENHUT: No. You understand the
4 question, right?

5 (Laughter.)

6 MR. HOCH: Well, I will try to pick it up. I
7 would prefer, Daryl, since lunch has come in between
8 that he ask us again.

9 MR. CREWS: Basically, we have looked in some
10 depth at the procedures you set up internally, focusing
11 primarily on the operating QA program and the
12 operational phase and assuring the recording
13 requirements and the regulations be complied with.

14 We feel comfortable with the system
15 established there, and what I was asking was what sort
16 of evidence do you have to assure that the IDBP's
17 findings and your technical program findings are fed
18 into that system? And I'm talking now in part about the
19 IDBP reporting.

20 MR. HOCH: Okay. First of all, we are
21 accomplishing reporting of items that we identify as
22 part of either the internal technical program and either
23 identified to us by the IDBP by means of the
24 semi-monthly report, and that report, of course, was
25 ordered by the Commission as part of the Commission

1 order. We are identifying items in that report.

2 Unit 1, of course, does have an operating
3 license, and the project works very closely with PG&E's
4 nuclear plant operations department and the people at
5 the site. We have on project an operations coordinator
6 who reports to the project and has his other foot, so to
7 speak, back across the street in nuclear plant
8 operations and reports to Jim Shepard, who is manager of
9 nuclear plant operations.

10 We have a continuing relationship with plant
11 operations that requires us to keep them informed of
12 ~~the~~ items that we identify in the internal program and of
13 items that are identified from the IDPP, and that is
14 done both by means of the semi-monthly report, by
15 periodic meetings with them. The project meets with
16 PG&E management on a bi-weekly basis, every two weeks,
17 and that includes meeting with Jim Scott, our vice
18 president for nuclear power generation, and quite often
19 directly with Jim Shepard, director of nuclear plant
20 operations, to keep them informed about the progress of
21 the project's work.

22 In addition, all of the IDBP reports that are
23 distributed are provided also to Nuclear Plant
24 Operations and directly to the plant staff. They are
25 reviewed by the plant staff. We have a continuing

1 dialogue with them. We respond to their questions, keep
2 them informed about what is going on, not only internal
3 technical program items but what has been identified by
4 the IDBP. That is the mechanism we are using. That is
5 the agreement we have with Nuclear Plant Operations to
6 make sure that they feel that all of the reporting
7 requirements and the technical specifications continue
8 to be satisfied.

9 MR. RUBENSTEIN: Those are excellent words,
10 but do you have a system that carries these forward
11 until they're disposed of?

12 MR. MOORE: Actually, we have two. I kind of
13 appreciate your problem. You haven't had the benefit of
14 all of the various presentations with regard to the
15 verification program. But we have really two systems.
16 If the issue is identified as being under -- an issue
17 under our quality program, then it has a tracking system
18 to close those issues out. But separately from and in
19 addition to that program, all programs identified either
20 by the IDBP or ourselves are put into a computerized
21 tracking system when they are first identified, and that
22 item is not closed until we get either final completion
23 of concurrence from the IDBP or we close the issue on
24 the project ourselves.

25 MR. RUBENSTEIN: To walk the last mile, what

1 is the level for identification? Is that when someone
2 comes to a supervisor or when someone writes a letter to
3 a supervisor, or where does this become officially in
4 the tracking system?

5 MR. MOORE: Once again, we have two different
6 systems. I think I kind of outlined the system that is
7 a part of our quality program, namely the employee comes
8 to a supervisor, and a determination is made at that
9 point. That doesn't necessarily have to be in writing.

10 As far as the verification program is
11 concerned, I think there are two different thresholds,
12 and I can have Dr. Cooper address the thresholds that
13 are used in the IDBP. But basically, if they identify
14 an item that seems open to them, they initiate an open
15 item, and depending upon what they determine when we
16 send them further information or they get more involved,
17 they may categorize that in one of the four different
18 classifications as an error, or a deviation, or it may
19 just close upon further investigation if it is not an
20 open issue any more.

21 With regard to the project, we have a little
22 more specific threshold definition. There is actually
23 three different ways it can be triggered over a
24 threshold: number one, if it has safety significance;
25 if it is generic; or if we can't figure out what it is

1 within 14 days. And I guess in terms of the staff, that
2 is 21 days, but on the project it is 14 days to allow
3 getting it reported.

4 MR. NORTON: In terms of reportability it is
5 21 days.

6 MR. MOORE: Yes. In terms of the staff
7 getting it notified in our semi-monthly report, it is 21
8 days.

9 MR. RUBENSTEIN: I understand.

10 MR. EISENHUT: Okay. Why don't we go on to
11 the questions.

12 MR. MOORE: I will ask Jim Tinlin to address
13 very quickly the answers to question 1, parts A through
14 F. And I think they will be very quick answers, because
15 I believe he's answered all of them already.

16 MR. MANEATIS: I thought we were going to
17 allow the staff to ask any questions that they feel we
18 haven't answered rather than plow the ground all over
19 again.

20 MR. EISENHUT: You can do it either way. I
21 think I agree with you. But I just would like to have
22 you -- if you tell me you've answered which ones of
23 these, and if not, let's just move to those where you
24 have yet to answer some of them, you obviously haven't,
25 and then go on to any other questions.

1 I think I agree with you. I think you can go
2 through them very, very rapidly. I don't expect to
3 complete reverification information.

4 MR. MOORE: Okay. Based upon what I think the
5 instructions are, I feel that we have answered really
6 all the questions except for those questions asked under
7 question 4.

8 MR. EISENHUT: Let me see if the staff -- if
9 you have any more questions, I guess falling under 1, 2
10 or 3, or follow-on questions. Maybe we ought to dispose
11 of those.

12 MR. BOSNAK: Really, it's probably under
13 question 3 and also in the Aronson paper on page 10 of
14 that document. Really, the basic question, that is:
15 Have you varied from what we understood your
16 seismic-nonseismic interface criteria was when we went
17 through accessory 8?

18 At that time we understood that the interface
19 was generally an anchor between seismic and nonseismic
20 portions of piping. And what I'm reading here is what
21 you're saying is most of the nonseismic portions of the
22 branches, the heat exchangers in loop C, if they are not
23 seismically qualified, they are small. That is what I
24 read this paper as saying.

25 Do you have any that are large? And if you

1 didn't have an anchor say at the interface, would that
2 be a problem if the nonseismic portion were postulated
3 to fail?

4 Are you still meeting your basic criteria
5 where you have a line that goes from seismic to
6 nonseismic and you have an anchor, and generally, of
7 course, you have the isolation valves.

8 MR. ARONSON: It's not exactly that situation
9 from the standpoint of the analysis, as I understand
10 it. The nozzle on the heat exchanger is being treated
11 as a point in space which is an anchor; in other words,
12 this is where the piping system terminates.

13 MR. POSNAK: If the whole area were considered
14 to be nonseismic where this is postulated to go, what
15 kinds of loads would you have on the piping that is
16 seismic, and have you looked at that?

17 MR. ANDERSON: I think we have to understand a
18 little bit about the design philosophy as far as the
19 seismic design goes. From my own experience with PG&E
20 back in 1971 when I worked on the Mendocino project, we
21 were really quite surprised at the care that PG&E put
22 into all of their specifications, whether they were
23 safety-related or not, that dealt with earthquake
24 requirements. And this is kind of a unique situation.

25 Most utilities were dragged into the seismic

1 design arena by their nuclear power program, and PG&E
2 being an area that has earthquakes was very much
3 involved in designing for earthquakes totally apart from
4 the safety aspects of nuclear power. They had sent
5 people up to Fort Richardson, Alaska after the 1964
6 earthquake to evaluate the damage up there, and as we
7 talked to the original designers, a great deal of
8 judgment and good judgment was applied to the equipment
9 in loop C.

10 The original designers judged that the
11 equipment in loop C would not fail in a design basis
12 seismic event, even though it was not classified as
13 seismic category 1. And that judgment was based in some
14 cases on some equipment being qualified or being
15 furnished as qualified for seismic 1. In some cases it
16 was based on some simplified analyses they did, and in
17 some cases, particularly in the cases of the smaller
18 heat exchangers, it was based upon just simply judgment
19 that that kind of equipment won't fail, and if it did
20 fail, it was small anyway. So that is the basic
21 judgment that went into the system.

22 The original designers feel that they are not
23 going to have any failure due to an earthquake. Well,
24 now, what we have offered to do here is we will go back
25 and do some analyses and some evaluations to confirm

1 that original judgment. So they did not think that the
2 nonseismic portions would fail, so really the equipment
3 was assumed to be there, and the piping was classified
4 seismic category 1 right down to the nozzle, even though
5 it would not have to be.

6 MR. POSNAK: So even though the item was not
7 seismic, it is supported seismically. Is that what
8 you're saying?

9 MR. ANDERSON: The piping is designed to put a
10 minimal load on the nozzles so that there will be no
11 failure at that point. The equipment itself would be
12 very unlikely to fail just by the nature of the kind of
13 equipment that is in that loop.

14 MR. MOORE: Maybe another way to look at it,
15 although I'm not a piping engineer, to try to answer
16 your original question directly, I feel that the
17 criteria is being met because we're carrying one seismic
18 support beyond the Class I isolation valve. And maybe
19 John can help me or help me find an error. And that, I
20 think, was very adequately pointed out in the slides.
21 Which allows you to quantify, if you will, the loads at
22 the heat exchanger nozzle, but that is not to say that
23 there is a seismic anchor at the heat exchanger-piping
24 interface. Hopefully, I haven't given you that
25 impression.

1 MR. POSNAK: No, you haven't. I was trying to
2 find out exactly what you did.

3 MR. MOORE: But in terms of our category 1
4 piping criteria, I believe, as shown in the picture, it
5 is consistent, I believe, with the criteria that you
6 reviewed, too.

7 MR. HOCH: Let me help a little bit. What
8 generally happens, to draw from what Dick and Gary just
9 said, in order to meet manufacturer's requirements for
10 nozzle loads, what generally happens is that although
11 this last seismic restraint may not indeed be an anchor,
12 may not indeed be a complete anchor, it generally is a
13 bilateral restraint at least. And as Gary showed you in
14 most of those pictures, I think in the general case
15 there is one after the valve and before the heat
16 exchanger. And that is at least some response.

17 MR. MOORE: And I think it's very safe to say
18 that when we do do our review of seismic capability of
19 these particular heat exchangers, small nozzle loads
20 transferred from the piping most certainly will be
21 accounted for.

22 MR. LE FAVE: You will have to do that to
23 defend that 200 gpm, I believe. On the surge tank the
24 minimum for a 1000-gallon level, is that the alarm set
25 point or is that the automatic makeup set point?

1 MR. CRAWFORD: That is the alarm set point.

2 MR. LE FAVE: What is the makeup rate from the
3 automatic system?

4 MR. CRAWFORD: 250 gpm.

5 MR. LE FAVE: Both systems are 250?

6 MR. CRAWFORD: Well, it's a minimum 250.

7 MR. WERMIEL: You've assumed following a
8 seismic event if I had a failure in the air supply and
9 the normal makeup level control valves fail closed, I
10 have 20 minutes to get out there and open up those
11 bypass valves.

12 MR. CRAWFORD: Yes.

13 MR. WERMIEL: Assuming the design basis leak.

14 MR. CONNELL: Which exceeds the passive
15 failure which is 50 gpm.

16 MR. LE FAVE: That is what he used there.

17 MR. FRIEND: Doesn't the 20 minutes start up
18 the low-level alarm?

19 MR. WERMIEL: Yes. At the 4000 gpm level.

20 MR. FRIEND: But if you're just talking about
21 losing the level control, you are some place up
22 mid-range of the normal level, so you have more than
23 that even.

24 MR. WERMIEL: It's possible they could have
25 been operating for a while near the level alarm point.

1 MR. MOORE: We have not taken credit for
2 that. I think Howard is probably referencing the actual
3 situation, but the design basis doesn't take that.

4 MR. LE FAVE: We use the pipe crack criteria
5 size that we have now for ASME SSS 301.

6 MR. CONNELL: We haven't calculated that
7 number.

8 MR. LE FAVE: I think right at the discharge
9 header of the pumps. I think that would be much greater
10 than the 200.

11 MR. MOORE: Daryl, if there is --

12 MR. EISENHUT: I have one sort of in item 3.
13 You mentioned earlier the post-TMI, post-accident
14 sampling heat exchanger was an area that you're going to
15 continue to look at. And I think in your very opening
16 comments that was an area that you decided that does not
17 meet the FSAR.

18 MR. MOORE: Yes, sir.

19 MR. EISENHUT: Can you tell me what the
20 deficiency was?

21 MR. HOCH: Unfortunately, Daryl, you and Roger
22 stepped out during that part of the presentation.

23 MR. CONNELL: The FSAR has a statement that
24 says in there no Class I components attached to the
25 Group A and B except for the leak -- and now you have

1 something that is not designated but is design Class I.

2 We have subsequently gone back and done an
3 analysis of this so as to get an analysis, a computer
4 model of the cooler, and it passes for the seismic
5 loading. The cooler itself, as I think you know, was
6 specifically designed for the nuclear industry in
7 response to 737. However, the industry did not require
8 that that have the full 10 CFR 50 Appendix B quality
9 program, so it doesn't. So that is the slight
10 inconsistency.

11 MR. EISENHUT: In normal operation it would be
12 valved out?

13 MR. CONNELL: No. What PG&E did was when the
14 PEID shows this valved in, and the reason for that, and
15 I think a very good reason, was that because we want the
16 operators to use that during normal operation so that
17 they are familiar with how to operate it should it ever
18 happen in the LILCC situation.

19 MR. EISENHUT: And the valves on that heat
20 exchanger are remote?

21 MR. CONNELL: They are local manual.

22 MR. EISENHUT: Would you have access to them
23 during an event of radiation levels similar to TMI?

24 MR. CONNELL: On the pump suction side, yes.
25 On the other side we are investigating it right now.

1 MR. EISENHUT: Those valves are local, though,
2 to sort of the inlet exhaust, the inlet discharge line?

3 MR. CONNELL: Yes. On one side the answer is
4 yes. On the other side we are looking.

5 MR. BUCKLEY: Is that because they're located
6 so far away on another elevation?

7 MR. CONNELL: What gentleman asked this
8 morning, are there other hot lines in the area, we are
9 looking at that.

10 MR. BUCKLEY: But you had two valves upstream
11 of the sampler, right, coming off into the suction side
12 of the RHR pump, and presumably the sampler is in a
13 location a fair distance from the 12-inch suction line.

14 MR. CONNELL: Yes. The sampler itself is.

15 MR. BUCKLEY: So that would be the reason why
16 it wouldn't be so hot.

17 MR. CONNELL: Yes.

18 MR. EISENHUT: How far away are the valves
19 from the actual sampling heat exchanger?

20 MR. CONNELL: Somewhere 30, 40 feet.

21 MR. EISENHUT: And you have a shielding
22 between the valve and the heat exchanger then?

23 MR. CONNELL: The sample cooler is on one side
24 of the wall, and the shielded sample station is on the
25 other side of the wall.

1 MR. EISENHUT: So you have adequate shielding?

2 MR. CONNELL: To take a sample, yes, but
3 taking a sample that has been checked, of course, and
4 you do have adequate shielding.

5 MR. EISENHUT: One other question, which I
6 apologize again might have been asked this morning.
7 When you put in the post-TMI sampling heat exchanger why
8 did the system break down? I mean was this just an
9 oversight that you put it on inconsistent with the FSAR?

10 MR. CONNELL: I guess I wasn't there, so I
11 don't know firsthand; but as near as I can tell, it was
12 a balancing of whether the system is -- it was a
13 balancing of wanting to make sure that the operators
14 knew how to do it, which I think is another thing that
15 was discussed in relation to 737.

16 MR. ANDERSON: When it was first put on a
17 vital header it was assumed that the valves would be
18 closed during normal operation, and then this decision
19 came about later that said why leave those valves
20 closed; why don't we use that sample cooler during
21 normal operation. So that is how it happened. It was
22 kind of an evolving thing, and if the valves are left
23 closed during normal operation, then it would meet the
24 requirements of the FSAR even though it is not
25 described. With the valves opened and on that loop, we

1 feel technically it doesn't meet the requirements;
2 however, it certainly isn't any kind of significant
3 problem or safety issue.

4 MR. MOORE: To answer your question directly,
5 how I can postulate it happening, when the design
6 request, change request came through for the schematic
7 to be changed to show the valves open, it was not
8 appreciated, the impact of that. If you want to label
9 that, I guess that could be labeled as a minor loss of
10 design control is what I would classify it. And I think
11 it is only a loss of design control at this point in
12 time with the fact that we cannot retrofit, if you will,
13 the quality assurance portion of the sample. I think we
14 have demonstrated, at least seismically, that there is
15 not an issue.

16 MR. EISENHUT: Okay. Don't take our passing
17 on to say we've asked the questions we're going to. I
18 think we will continue to be looking into that area, but
19 why don't we go on to item 4.

20 MR. MOORE: I will take item 4A. Just for
21 those who don't have a copy of the question, I will read
22 the question and then I will give you the response.

23 The question has several parts. I will only
24 address part A, and then other members of this panel
25 will address parts B, C and D.

1 Regarding the interfacing of seismic and
2 nonseismic portions of systems, such as on the component
3 cooling water system, and the operating capability of
4 the seismic portions of systems, what design approach
5 wherein (both piping and both INC) was used throughout
6 the plant, for example, when applied to part A,
7 emergency diesel generator intake/exhaust piping
8 silencers and filters.

9 I will answer your question regarding the
10 design approach used for interfacing seismic and
11 nonseismic portions of the emergency diesel generator
12 system by outlining the approach uses.

13 Originally, the diesel generator exhaust and
14 inlet piping was classified as design Class II.
15 However, the supporting system for this piping was
16 designed to design Class I criteria. The exhaust
17 silencers were treated in a similar manner, and its
18 design included failures which would result in
19 significant flow blockage. The air inlet filter and
20 silencer were procured as design Class I. What I have
21 just read is information that is currently in our FSAR,
22 PG&E's FSAR.

23 The design of the exhaust system was changed
24 in 1974 to accommodate the operating department's
25 request to reroute the piping through the turbine

1 building roof. The original design requirements were
2 maintained for this design change. As part of the phase
3 1 internal technical program the diesel generator system
4 components were checked to ensure the adequacy of the
5 seismic qualification.

6 The documentation was assessed to be
7 inadequate to fully support their seismic
8 qualifications. Therefore, on September 28, 1982 the
9 project initiated analyses to objectively demonstrate
10 the seismic adequacy of the inlet and outlet piping
11 support systems. In addition, on January 1, 1983 the
12 project confirmed reanalysis responsibility of the
13 design Class I components in the system.

14 To date, the piping portions, the piping
15 support portions of the system have been reanalyzed to
16 the latest Hosgri spectra and modification to the
17 support spectrum will be issued to the field shortly.

18 The design Class I portions of the system will
19 be qualified on a schedule consistent with the precept
20 licensing commitments.

21 MR. EISENHUT: Let me understand what that
22 means. For, for example, a Hosgri event, today you
23 would not conclude that the intake exhaust piping -- you
24 wouldn't conclude that you have confidence that it would
25 withstand the event and that you are re-evaluating it to

1 ensure that it either does or make modifications in
2 accordance with the ongoing verification program.

- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17
- 18
- 19
- 20
- 21
- 22
- 23
- 24
- 25

1 MR. MOORE: I think that we believe -- well,
2 let me put it this way. Today we don't know. We feel
3 that the documentation is inadequate and therefore are
4 revisiting the Sequoyah system for that piping to assure
5 that it is seismically adequate.

6 MR. EISENHUT: But have you proceeded far
7 enough to the point where you have determined that
8 modifications will be required?

9 MR. MOORE: Yes, I'm sorry. Those analyses
10 are complete with regard to the piping support systems,
11 and there are modifications required as a result of
12 those analyses and are being presently issued to the
13 field.

14 MR. SCHIERLING: Was that issue raised in any
15 of the semi-monthly reports?

16 MR. MOORE: No, sir. This came out as part of
17 the normal activity of the piping program. And I don't
18 know if it has been identified in the phase one results
19 of not. I would expect to see it identified in the
20 phase one final report.

21 MR. FRIEND: It is a timing problem, Hans. It
22 may not have been yet, but all of the modifications as a
23 result will be in our report.

24 MR. MOORE: Let me clear up maybe a
25 misconception here. We don't know what is causing the

1 changes, because there are current spectra that is
2 different on the job than the original spectra that were
3 used to qualify this. And I do not know whether that is
4 causing the modification or something else is causing
5 the modification.

6 MR. EISENHUT: But in any event, you have
7 determined there will be modifications. And can I get
8 one other feeling, as to when it was decided that those
9 modifications would have to be made? I mean, it wasn't
10 in the last two weeks, right?

11 MR. MOORE: Well, let me put it this way. The
12 reanalysis was requested in the end of September of last
13 year. Now, when the analyses were completed that told
14 you you had to do modifications, I don't know.

15 MR. EISENHUT: That's fine. My real question
16 was the question about the reanalysis.

17 Now, any other questions on that item?

18 (No response.)

19 MR. EISENHUT: Why don't we go to the next
20 item.

21 MR. MOORE: I will have E1 respond to B.
22 Could you read the question?

23 MR. CONNELL: Yes. As I understand the
24 question, it is, what is the seismic-nonseismic
25 interface criteria for the lube oil system or the lube

1 oil filter of the safety injection system.

2 There is no interface.

3 MR. EISENHUT: Let me help you. I wrote the
4 question, that question, so maybe it is my ignorance.

5 The safety injection pumps often come from a
6 manufacturer. Sometimes they may come from Westinghouse
7 or they may come from someone else. They may come with
8 a lube oil filter system physically attached on some
9 arrangement or they may leave the lube oil system to the
10 AE, in this case the utility.

11 My real question is, it is really not the
12 seismic versus nonseismic interface; it is an interface
13 of a seismic design safety injection pump and a seismic
14 design lube oil filter system that come from two
15 different sources.

16 MR. CONNELL: Okay. Let me talk about how the
17 two different sources meshed up on this. On the Pacific
18 Pumps, through Westinghouse you had a lube oil system on
19 them. They did and still do. They were not delivered
20 with a filter in the lube oil system. PG&E subsequently
21 added a filter from Pacific Pumps.

22 The pumps and the lube oil system were
23 seismically qualified by Westinghouse. When PG&E put
24 the filter in the lube oil system, they went back and
25 checked the seismic adequacy of their installation.

1 MR. EISENHUT: Who is "they"?

2 MR. CONNELL: PG&E. The way they did that was
3 a piping engineer did it by inspecting the design. If
4 the filter weighs less than 20 pounds, there was
5 essentially no nozzle loads because it is tubing, and
6 you look at the support details. And that is the way it
7 stood until September of '82, when as part of the phase
8 one program we went back and reanalyzed, or reexamined
9 rather, all of the seismic qualifications, and when we
10 did that we decided to do an analysis to back up the
11 piping engineer's judgment.

12 My understanding today is that the analysis
13 has been complete, but it has not yet received the final
14 checking. As of today that analysis confirms the
15 original piping engineer's judgment of that about
16 seismically qualified.

17 MR. EISENHUT: Let me ask another ignorance
18 question. When it was done sort of by judgment from a
19 piping engineer, was that documented originally in any
20 form?

21 MR. CONNELL: We have a couple of documents on
22 that. The first is it was, the filter was put in by NPO
23 Nuclear Power Operations. They initiated the DCN, the
24 design change notice. It came to San Francisco and they
25 had a note on there that, engineering to confirm the

1 seismic adequacy of the details. And that is when it
2 went to the piping engineer, and it is my understanding
3 that he documented this in two ways: one by signing a
4 DCN or initialing; and two, I believe that he wrote a
5 memo to the file or some such thing saying, this DCN is
6 okay.

7 MR. BOSNAK: Are there any other units where
8 you add tubing?

9 MR. CONNELL: On Westinghouse equipment, that
10 is the only piece that I know of. I mean, that is the
11 only piece of mechanical equipment where we added a
12 component.

13 MR. BOSNAK: Sometimes things are added in the
14 field.

15 MR. CONNELL: Yes. This was added.

16 MR. BOSNAK: And the supports for the tubing
17 are oftentimes overlooked as to the amount of supports
18 they might need for seismic input.

19 MR. CONNELL: My understanding on the supports
20 is this, that NPO did this for Unit 1, Construction did
21 it for Unit 2 or is doing it for Unit 2, and they've
22 gotten together and compared notes on the tubing
23 supports. And I think that eventually the two units are
24 going to look the same on the tube supports.

25 MR. BOSNAK: So all of the tubing that might

1 have been added on at a later time has been taken care
2 of with regard to supports?

3 MR. CONNELL: Well, I know for sure with
4 regard to this pump it has been, yes.

5 MR. EISENHUT: His question was the tubing.

6 MR. CONNELL: I'm talking about the support
7 for the tubing, yes. Each unit started out with a
8 little bit different tubing support design after the
9 modification and they are comparing notes on it. So it
10 has certainly been considered, yes.

11 MR. EISENHUT: Well, I recognize the filters
12 are a small physical component. It happens to be a
13 pretty critical component.

14 MR. CONNELL: It is similar to a filter that
15 was on the charging pump, which came from Westinghouse
16 with a filter on it.

17 MR. EISENHUT: Go ahead.

18 MR. MOORE: Okay. I will ask Tom Crawford to
19 read and answer parts C and D to question 4.

20 MR. CRAWFORD: Part 4 asked: What is the
21 interface between seismic and nonseismic on the reactor
22 protection circuitry? In the seismic qualified class,
23 that means it meets 279. All isolation between Class 1E
24 and non-Class 1E equipment is by IEEE qualified
25 isolators.

1 It's all redundant as necessary, it's all
2 seismically qualified as necessary. Anything that is
3 not electrically isolated by an isolator, it is treated
4 as an associated circuit. The associated circuits are
5 treated as Class 1E circuits.

6 MR. EISENHUT: So all signals to the reactor
7 protection circuit come from Class 1E seismic 1, 1A?

8 MR. CRAWFORD: Not true. That wasn't the
9 question you asked the first time.

10 MR. EISENHUT: I know. I was just trying to
11 make sure I asked the right question.

12 (Laughter.)

13 MR. CRAWFORD: We have specifically -- and the
14 NRC is aware of this, because the NRC asked the question
15 to everyone, the same question, and everyone knows that
16 certain radiation monitors on the inputs to the solid
17 state protection system are not Class 1E. They are
18 wired as 1E and treated as 1E, but the devices
19 themselves are not qualified as Class 1E components.

20 There is a relatively long explanation, but
21 this is well documented in the file.

22 MR. EISENHUT: And my question is really
23 except for that item.

24 MR. CRAWFORD: None others. There are inputs
25 from the turbine, that is all Class 1E equipment. The

1 first stage pressure transmitters are all Class 1E.

2 MR. LeFAVE: The same from the feed pumps to
3 the feed pump input, loss of feedwater?

4 MR. CRAWFORD: I would have to look at that.
5 The only one that we know of that is not a Class 1E
6 component is the radiation monitor. That is Class 1E
7 components, treated as Class 1E components.

8 Now, if the question you're asking is do they
9 -- in other words, a trip signal is not a safety
10 requirement. In other words, it's not part of an
11 accident analysis and it may not have the three out of
12 four logic in it, but it is a Class 1E component.

13 MR. MOORE: Okay. 4D.

14 MR. CRAWFORD: Again, 4D is just the
15 seismic-nonseismic interface for instrument controls
16 needed by the operator to respond to DBE's. Okay,
17 basically what we have at this time, all of the Class 1E
18 equipment is as I described in the answer to the last
19 question.

20 The only place where we have this -- at this
21 very minute aren't totally in compliance with
22 everything, right now the equipment that is type D or
23 the stuff that is under Reg Guide 1.97 doesn't always
24 have the isolators between the indicators on the board
25 and the computer in the plant. Okay, so that they will

1 -- I mean, everything will met Reg Guide 1.97 on the
2 schedule we're committing to and all of that, but right
3 at this very minute I can't honestly say that the
4 indicators are isolated from the computer.

5 But the circuitry, all of the circuitry is
6 Class 1E and is wired as 1E, and actually we have done
7 analyses that show there is no failure in the computer
8 circuit. In other words, it is a floating resistor such
9 that a short circuit on the computer side would have no
10 affect on the function of the indicator.

11 MR. EISENHUT: All right. Let's see, there
12 was an item 5 and I think we probably discussed this
13 before.

14 MR. MOORE: I believe we have.

15 MR. EISENHUT: All right, back to your
16 agenda.

17 MR. ANDERSON: Well, I guess we just have one
18 more item. That is the future action.

19 AGENDA ITEM 8. FUTURE PROJECT ACTION

20 MR. ANDERSON: I hope we have been able to
21 demonstrate by what we have said in this meeting that we
22 do meet the licensing commitments for the Diablo Canyon
23 project as far as the component cooling water system
24 goes. And as I say, we have mentioned several times we
25 will be looking further at certain issues.

1 One issue is this 200 gpm leak design basis
2 that was stated in the FSAR, and we will be confirming
3 the judgment that went into that commitment. And we
4 also will be looking at heat loads beyond the bases
5 given in the FSAR, particularly looking at temperature
6 conditions in the component cooling water system for
7 other conditions of operation, several of which or most
8 of which have been discussed in our meeting today.

9 And beyond that, I think we will just be
10 answering any questions that come up from the NRC. We
11 hope that this has put any of your concerns to rest and
12 we will be expecting to hear any further questions that
13 you might have on this.

14 MR. EISENHUT: Well, let's see. When you
15 originally started today you said the TRG still had a
16 couple of issues before it.

17 MR. ANDERSON: That's correct.

18 MR. EISENHUT: One was the heat load and one
19 was the surge tank, as I recall.

20 MR. ANDERSON: One was the classification of
21 the level switch on the surge tank. Now, that issue
22 will be submitted to the higher level review group
23 within the PG&E organization and the project does not
24 plan any further action on that. We plan to just give
25 them the information and they will make their decision

1 based upon that information or gather any further
2 information that they feel necessary. So that really
3 was not included in the project.

4 MR. EISENHUT: I guess my question then is,
5 what is the vehicle and how will we see that these are
6 resolved? I mean, this issue, you have a couple of
7 issues for the project you mentioned. There's another
8 one.

9 How does this get closed out and how will we
10 see it?

11 MR. MOORE: Well, with regard, obviously, I
12 think the only public way that I would see it being
13 closed is you would see us close our open item 34 with
14 regard to this subject. If we found other concerns you
15 would see that being reflected in possibly another open
16 item being identified.

17 But, in terms of what the NRC would see, I
18 think you would have to come in and visit our offices
19 and audit our quality assurance records to see how the
20 problem is being disposed. I think that is accurate.

21 MR. EISENHUT: And let's see. Well, I guess
22 it is easier to say at some point we would be asking you
23 to think how you could document, as far as we are having
24 this meeting, with a few open issues or a few issues
25 where you've stated that you're going to be following

1 up. I think certainly we will be asking a way to close
2 them out on the project. So that will certainly be one
3 issue we want.

4 Do you have a schedule for when you're going
5 to hope to wrap up either the issues that came out of
6 the TRG which are now going to management review -- is
7 there any kind of indication of when those will be
8 resolved?

9 MR. MOORE: I've committed to management to
10 try to have this issue closed by three weeks to a
11 month. The only thing that makes me kind of want to
12 throw a caveat in, if you will, is that I have not to
13 date sat down with the people doing the thermal analysis
14 and scoped what further situations we're going to look
15 at and how long that will actually take.

16 MR. EISENHUT: So on the order of a month,
17 let's say?

18 MR. MOORE: That is what our goal is.

19 MR. EISENHUT: And the other question is on
20 the reevaluation of the 200 gpm that the project is
21 undertaking; the same kind of time?

22 MR. MOORE: Yes.

23 MR. EISENHUT: Let's see. Jesse, do you have
24 any other questions?

25 MR. CREWS: No.

1 MR. HOCH: Darrell, I do know that as of
2 Wednesday the management level review group that we've
3 been talking about was being formed, was being put
4 together.

5 MR. MOORE: I believe the nonconformances were
6 written, the new nonconformances were written and
7 directed to that group on Monday of this week.

8 MR. EISENHUT: Let's see. Any other comments
9 from the Staff?

10 (No response.)

11 MR. EISENHUT: If not, let's see, Mr. Cooper
12 is over there in the corner. Any comments, Bill?

13 MR. COOPER: No, we don't have any comments.

14 MR. EISENHUT: Mr. Goldenberg is here. Do you
15 have any comments?

16 MR. GOLDENBERG: I don't have any comments
17 myself. If Joel intends to provide comments he will do
18 it in writing.

19 MR. EISENHUT: Certainly if he has any
20 comments feel free to send me any.

21 MR. MANEATIS: I can't say any more than I
22 hope that we have provided you the response that you
23 were looking for, the details on the component cooling
24 water system, and hopefully we have given you another
25 perspective from which to judge some of the concerns

1 raised on this system.

2 MR. EISENHUT: Okay. You certainly have. And
3 the only other comment that I have is, we gave you a
4 charge at our meeting in January a couple of weeks ago.
5 I want to personally commend you. I think you all have
6 really put together an effort to go through the
7 component cooling water system, looking at all of the
8 design aspects.

9 I will tell you, I intended to make the
10 questions as broad as I know how to make the questions.
11 And I will tell you that we tried to make the detailed
12 agenda which we sent out to you earlier this week cover
13 as broad an array of questions to really focus on the
14 issues. And we think you certainly presented some very
15 valuable information.

16 We will be taking a hard look at it and the
17 Staff will be getting together and sort of seeing where
18 we go from here. But at least for my own personal self,
19 I want to tell you, you've made a very fine
20 presentation. I really appreciate your getting
21 everything together in short order and it was very
22 valuable.

23 And we want to thank you all for coming back
24 here, and we will be back in touch very shortly on how
25 we want to proceed, if any, and what form that will take

1 to close out these issues. So again, thank you very
2 much and thanks, everyone.

3 (Whereupon, at 2:55 p.m., the meeting was
4 adjourned.)

5

* * *

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

NUCLEAR REGULATORY COMMISSION

This is to certify that the attached proceedings before the
NRC Staff with Pacific Gas & Electric Company

in the matter of: COMPONENT COLLING WATER SYSTEM DIABLO CANYON UNIT 1

Date of Proceeding: Bethesda, Maryland

Docket Number: _____

Place of Proceeding: January 28, 1983

were held as herein appears, and that this is the original transcript thereof for the file of the Commission.

Ray Heer

Official Reporter (Typed)

Ray Heer

Official Reporter (Signature)

Diablo Canyon Unit 1

Component Cooling Water System

Phillips Building - Room P-118

Bethesda, Maryland

January 28, 1983

DESCRIPTION OF THE
COMPONENT COOLING WATER SYSTEM

Presented By

E.C. Connell

I would like first to present to you a general description of the DCPD Component Cooling Water (CCW) System and discuss its arrangement, basic components, operating modes, performance requirements, and interfaces with supporting systems.

I will then discuss in detail the principal design considerations for the system.

I. GENERAL DESCRIPTION

(Slide A-1)

A. Purpose

The CCW system is designed to remove waste heat from the primary plant equipment and components during normal plant operation, plant cooldown, and following a loss of coolant accident. The components and equipment served are either engineered safety features or have a potential for leakage of radioactive fluid into the CCW System. The CCW System serves as an intermediate system between the normally radioactive systems and the Auxiliary Saltwater System. This double barrier design reduces the possibility of potentially radioactive coolant from leaking to the ocean through the Auxiliary Saltwater System. Component cooling water flows through components in parallel circuits absorbing heat which is rejected to the Auxiliary Saltwater System via the component cooling water heat exchangers. The ASW system rejects heat to the ultimate heat sink, the Pacific Ocean.

(Slide A-2)

B. System General

1. Overall Arrangement

The CCW System consists of three component cooling water pumps, two component cooling water heat exchangers, a component cooling water surge tank which is internally divided so that in effect it is two tanks, two Chemical Addition Tanks (CATs), valves, and piping. The piping system consists of three parallel loops of two separable redundant vital service loops "A" and "B" and a miscellaneous service loop "C" which serves nonvital equipment. By "vital" it is meant "required to perform a safety function." Except for the components on the "C" loop, the chemical addition tanks and the post-LOCA sample cooler, the CCW system, including all piping and valves, is a Design Class I system. Design Class I means the design, fabrication and construction is in accordance with the requirements of 10 CFR 50 Appendix B and meets the intent of the NRC requirements for safety-related systems.

2. Isolation Capabilities

All users whether vital or non-vital are capable of being individually isolated by Design Class I valves. In general, components inside containment can be isolated from the control room. Other components are isolated by local manual valves.

Each of the three loops can also be isolated using only Design Class I valves. For example, if one wanted to isolate loop C, valve FCV-355 would be closed from the control room and local manual valves

on the suction piping to the pumps would be closed. These valves are located in the pump rooms which are accessible at all times.

(Slide B-1)

3. Basic Components

a. CCW Pumps

3, Design Class I, horizontal, centrifugal

Rated capacity 9,200 gpm

Carbon Steel

Located in AB

Each on different 4 KV vital bus

b. CCW HX

2, Design Class I, shell-tube

ASW in tube

258.8×10^6 BTU/hr - Manufacturer's rating

Located in TB

Shell carbon steel, tubes 90-10 CuNi

c. CATs

2, one each loop

Carbon steel

Manually valved out

Corrosion inhibitor

d. CCW Surge Tank

1, split internally so each side feeds one vital loop

Design Class I

Volume 10,750 gal.

4,000 gal. minimum during normal operation

Carbon steel

Relief valve to AB sump

e. Valves and Piping

Design Class I

Valves carbon steel - bronze or SS trim

Piping - carbon steel, welded joints, flanged connections to
equipment

(Slide B-2)

4. Users

a. Vital Headers

RHR HX

RHR PP Seal Water Cooler

SI PP L.O. & Seal Water Coolers

Containment Fan Coolers

Only inside containment components

3 on B, 2 on A

CCW pump coolers

Post-LOCA sample cooler on A

(Slide B-3)

b. Non-Vital Header

None of the components on this header, the C loop, are required to operate for the CCW system to perform its safety function.

(1) Inside Containment

RCP

Thermal Barrier

Bearing Oil Cooler

Reactor Vessel Support Coolers

Excess Letdown HX

(2) Outside Containment

Waste gas compressor seal water cooler

Sample Panel coolers

PD Charging PP Oil Coolers

Gross Failed Fuel HX

Boric Acid evaporator coolers

Waste concentrator package coolers

Seal Water HX

Letdown HX

Spent Fuel Pit HX

SG Blowdown Sample Coolers

(Slide A-3)

5. Layout

Surge tank on AB roof. CCW HX in TB. CCW PP in AB.

(Slide A-4)

6. Operating Modes

a. Normal Operation

2 pumps

1 HX

All loops

(Slide A-5)

b. Plant Cooldown

All loops

3 pumps

2 HXs

RHR HXs are cut in

If 1 pump or 1 HX is not available, orderly shutdown is not affected, just takes longer

(Slide A-6)

c. LOCA

(1) Short Term

3 pumps start on S signal

Any One HX

(Slide A-7)

Loop C isolated on P signal

(Slide A-8)

(2) Long Term

Manual valve system into 2 separate subsystems.

Capability to valve out loop C or valve it into one of the two separated, isolated redundant vital loops.

C. Support Systems

1. ASW

Picks up heat from CCW HX and rejects heat to the Pacific Ocean.

(Slide A-9)

(Slide B-4)

2. MU

Makeup water is supplied to the Component Cooling Water System through two redundant makeup valves feeding into the two redundant component cooling water surge lines. These air-actuated level control valves open automatically in the event of low level in the component cooling water surge tank, indicating that system makeup is required. They close automatically when the normal operating level in the surge tank is restored.

Makeup water for the CCW System is supplied to the above valves by the Makeup Water System. Makeup water can be provided from various water sources and through various pumps and flow paths in the Makeup Water System.

The makeup water under normal operating conditions is provided automatically on demand from the outlet of the makeup water demineralizers, which receive water from the raw water storage reservoir. The elevation of the reservoir provides adequate static head to pressurize the outlet of the demineralizers so makeup is supplied to the Component Cooling Water System without pumping. This makeup source is Design Class II up to the Design Class I check valve.

The Design Class I source for makeup to the CCW System is the Condensate Storage Tank (CST), which contains 425,000 gallons of which a minimum reserve of 170,000 gallons is for auxiliary feed water pump operation, so that 255,000 gallons is available.

The makeup water from the CST is pumped by the fully redundant, Design Class I makeup water transfer pumps. Each pump is energized by a separate vital 480 volt bus. All piping and valves from the CST to the CCW surge lines are Design Class I.

There are many other sources of makeup water available for even further backup. Five of these other sources are described in Section 9.2 of the FSAR. Some are Design Class I, such as a cross connect to the Unit 2 CST, while others are Design Class II.

II PRINCIPAL DESIGN CONSIDERATIONS

I would like to discuss now the major design considerations of the CCW system. In the January 13, 1983 meeting in San Francisco, Darryl Eisenhut stated that you will be comparing the system design against the Standard Review Plan (SRP). It should be kept in mind that Revision 0 to the SRP came out after Diablo Canyon was built and was undergoing hot functional testing. There is of course no requirement in the regulations for a blanket backfit to the SRP. Nonetheless, for your convenience the format of this discussion will follow Revision 1 to NUREG-0800, which is your Standard Review Plan. Each of the topics mentioned by Darryl Eisenhut in the San Francisco meeting is included in the SRP and will be discussed here.

The SRP lists 15 areas of review directly related to CCW design.

Notwithstanding, that the system was designed in 1968, 7 years before the first SRP was issued and 13 years before the current revision to the SRP was issued, all 15 of the areas were considered in the design. Naturally, the design philosophy and acceptance criteria used by the designer and by the NRC in their review of the FSAR in 1974 have in some cases changed over the years. Nonetheless, the intent of each review area is met as discussed below.

The NRC has arranged the 15 areas of review into 3 major groups as follows:

(Slide B-5)

- a. Provide adequate cooling
 - o Functional performance
 - o Multiple performance functions
 - o Surge tank capability
 - o Provide cooling water
 - o Heat loads

(Slide B-6)

- b. Other Systems Aspects
 - o Effects of non-Cat. I Systems on Cat. I systems
 - o Leakage
 - o Testing, ISI
 - o RCP seals
 - o Instrumentation
 - o Reliability analysis

(Slide B-7)

c. Interactions

- o Flood protection
- o Internal missiles
- o External missiles
- o Pipe breaks

I will now discuss each of the areas of review.

(Slide B-8)

A. Functional Performance

This area assesses the ability to withstand adverse environmental occurrences and reviews operability requirements for normal operation and during and subsequent to an accident.

1. Environmental Occurrences

Essential electrical components were environmentally qualified for operation in the required modes as documented in the FSAR. The qualification program was expanded and updated in response to CLI-80-21 and NUREG-0588. It was reviewed and approved by the NRC in September 1981.

Protection of essential system components from high winds and tornado missiles is described in Chapter 3 of the FSAR.

Electrical and mechanical system components which perform a safety function have previously been seismically qualified.

Because of the new seismic input data currently being generated, the analyses are being reviewed and updated or replaced as appropriate. This fulfills the regulatory requirements.

2. Operability in Normal Operation

There is sufficient redundancy in components so that in normal operation there is always one pump and one HX in standby mode. For cooldown all three pumps are used. However, if one of the pumps or one of the HXs is inoperative, orderly shutdown is not affected, but the time for cooldown is extended.

(Slide A-10)

(Slide B-9)

3. Operation for Accidents

Each of the essential pumps in the CCW system and in the support systems, ASW and MU, are assigned to one of three emergency safeguards buses. The CCW and ASW pumps are automatically started on an "S" signal. The limiting failure would be failure of one bus to energize. In this case there would still remain one MU water transfer pump, 2 CCW pumps and one ASW pump. This meets the requirements for short term post-LOCA operation.

In the long term post-LOCA, the system is manually aligned into two separate loops. The valves used for this alignment are located in the CCW HX and pump rooms, both relatively low radiation areas post-LOCA. Only one loop is required to operate. Thus this system can accommodate a single active or passive failure.

(Slide B-10)

- There is a requirement of GDC 44 stated in the SRP that there be "component redundancy so that safety functions can be performed assuming a single active component failure coincident with a loss of off-site power." The system design meets this requirement.

(Slide A-11)

(Slide B-11)

B. Multiple Performance Functions

1. GDC 5

GDC 5 speaks to sharing of system and components between units. There is no required sharing of the CCW system or its support systems except for emergency safeguards diesel F. This is a swing diesel that is assigned to the LOCA unit. As discussed earlier, if this bus fails to energize there is sufficient redundancy to safely shut down the plant.

Although sharing is not required it is part of the design philosophy to provide additional flexibility. With this in mind, the plant has been piped up so that by manually opening valves it is possible to cross connect various systems from the two units. One example is the cross connection for the Condensate Storage Tanks.

2. Normal Operation Users

All of the components that require CCW for normal operation only

are located on the "C" headers. None of these components is required to shut down the plant.

3. Radioactivity Control

The double barrier design of the CCW reduces the probability of radioactive water escaping to the environment.

Leaks of radioactive water into the CCW system are detected by radiation monitors located in the two component cooling water pump discharge headers.

Any leaky component can be isolated by Design Class I valves.

(Slide B-12)

C. Surge Tank Capability

The CCW surge tank is internally divided thus providing an entirely independent surge volume with supporting instrumentation feeding one of the redundant vital CCW headers. This meets the SRP requirement that in the event of a header rupture, the loss of the entire contents of the surge tank will not occur.

The many makeup sources to the surge tank, including the safety related path from the CST, were described earlier.

(Slide B-13)

D. Provide Cooling Water

As I discussed earlier, because of the use of redundant Design Class I components backed by emergency power supplies and considering the

capability of isolating the system into independent trains, an adequate supply of cooling water is assured for all operating conditions.

(Slide A-12)

(Slide B-14)

E. Heat Loads

1. Normal Operation

During normal operation the heat load is approximately 72 million BTU/hr. This is well within the capability of one CCW HX.

2. SI but Less Than P

The major heat load assuming an accident is from the fan coolers. All other loads amount to about 40 million BTUs, 39 million of which are on the "C" header. It is difficult to estimate the heat load in containment for the case where the pressure is higher than the setpoint for an S signal and lower than the setpoint for a P signal since this does not correspond to any of the postulated DBAs. If the heat load is assumed to be 50% of that for the limiting postulated accident, the resulting heat load on the system will be about 240 million BTUs. Again, this can be handled by 1 CCW HX.

This assumes all five fan coolers are working. With fewer fan coolers available, the rate of heat rejection to the CCW System will be less.

3. Limiting DBA With Worst Single Failure

For the postulated case of the limiting complete double ended rupture of a pipe inside containment concurrent with a loss of offsite power and the worst single active failure in the plant, the heat load on the CCW is approximately 244 million BTUs. The "worst single active failure" means the active failure that causes the least amount of containment heat removal capability to be available.

(Slide B-15)

This is the failure of bus "G" to energize. This causes the loss of two fan coolers and one containment spray pump. Since valve FCV-355 is powered from bus "H", it will close and isolate the C header given the design basis accident with the worst single active failure.

This is the case that was used for the design basis heat removal capability in response to the requirements of GDC 44.

(Slide B-16)

4. PG&E's design recognized that under different postulated conditions it would be possible to reject more heat than this to one heat exchanger and thus raise the HX outlet temperature above the design value. For example, if it is assumed that all equipment functions as designed, i.e., both containment spray pumps and all five fan coolers operate, and if the same design basis temperature time history inside containment is assumed and all the other parameters used in a DBA worst case

analysis are used, e.g., 70° F ocean water, the calculated temperature at the discharge of a single CCW HX approaches 140° F.

This case, while not the design basis case, was calculated by PG&E. The total heat load is approximately 406 million BTU. For this case operator procedures require another CCW HX to be cut in.

5. Let us consider one more case. Assume design basis accident conditions inside containment, all fan coolers and containment spray pumps running, design basis accident worst case analysis parameters and the failure of valve FCV-355 to isolate on the P signal. In this case, the total peak heat rejection rate to the CCW system will not exceed 440 million Ptu/hr. The effect of all five fan coolers and both containment spray pumps may result in lower heat rejection to CCW. Thus, failure of the valve to close does not effect significantly the heat input to CCW. The operating procedure for this hypothetical case would be identical to that for the case just described above.

(Slide B-17)

(Slide A-13)

F. Effects of Non-Seismic Category I Components on
Seismic Category I Components

The design philosophy employed by Diablo Canyon in meeting the regulatory requirements for seismic/non-seismic interfaces including

those given in Regulatory Guide 1.29, will be discussed later by Chuck Aronson.

I just want to talk now about two specific equipment interfaces: those for the Chemical Addition Tank and those for the Sentry post-LOCA sample cooler.

The Chemical Addition Tanks meet all requirements for separation of seismic and non-seismic components. The piping from the vital headers up to and including a normally closed manual isolation is seismic category I.

(Slide A-14)

The post-LOCA sample cooler which was added in 1980 as part of the NUREG-737 changes had a similar arrangement and thus could have met the same separation criteria. However, PG&E believed that it would be valuable to have the operators use the same post-LOCA sample station for normal sampling. In this way they would be sure the operators were familiar with the equipment and be able to safely take hot samples if required post-LOCA. Thus the manual isolation valves are shown open on the current P&ID. With the valves open, the arrangement would still meet requirements if the piping and the small sample cooler were designated as Design Class I. The piping is in fact Design Class I. The cooler, while specifically designed and built for the nuclear industry, did not employ a full 10 CFR 50, Appendix B quality program. The cooler has recently been fully qualified by analysis for all postulated seismic conditions. You will see a few pictures later that demonstrate how "sturdy" this installation really

is. Thus it is assured that the cooler will not fail under accident or seismic loading and will not jeopardize the safety function of the CCW system.

(Slide A-15)

(Slide B-18)

G. Leakage

Numerous provisions for detection, collection, isolation, and control of leakage assure compliance with requirements.

Leakage of radioactive fluid into the system would be detected by the radiation monitors in the CCW pump discharge lines. Also, this could be detected by rising surge tank level and an alarm. The tank itself and the components in the system are protected by a relief valve with the discharge routed to the AB sump. The relief valve is sized for the rupture of a reactor coolant pump thermal barrier.

Leakage out of the system is detected by falling surge tank level and alarm. The numerous makeup sources have been described earlier. Mitigation of leakage from a passive failure, which is defined in Section 3.1 of the FSAR as 50 gpm for 30 minutes, is well within the capabilities of the system.

The NRC in FSAR question 9.26 asked for further discussions of the system features which assure a continuous supply of CCW to equipment required for safe shutdown until postulated leaks or ruptures could be isolated. As described earlier, any individual user can be valved out using Design Class I valves or an entire loop of the system can be valved out. In response to the NRC's question, Table 9.2-8 of the FSAR was amended to discuss a postulated leak or rupture of 200 gpm.

This leakage value is a limiting case. It is derived from a balancing of a number of considerations such as, operation action times, detection capabilities, isolation capabilities, and system makeup provisions. It is a reasonable number for design purposes.

(Slide B-19)

H. Testing and ISI

The active components of the CCW system are accessible for visual observation and maintenance as well as in either continuous or intermittent use during normal plant operation. Thus no additional special provisions are necessary to meet testing and inspection requirements.

(Slide A-16)

(Slide B-20)

I. RCP Seals

NUREG-737, Section II.K.3.25 requires that cooling water be available to the RCP seals given a loss of offsite power or the loss of instrument air. Diablo Canyon meets this requirement. Note that the valves in question on Diablo have motor operators fed from emergency onsite power and the CCW pumps are also fed from emergency onsite power sources.

(Slide B-21)

J. Instrumentation

As Tom Crawford will discuss later, the CCW instrumentation meets the applicable regulations.

(Slide B-22)

K. Reliability Analysis

The Commission's Standard Review Plan today requires a "failure-modes and effects analysis (FMEA) in the SAR --- to ensure that essential portions of the system will function following design basis accidents assuming a concurrent single, active, component failure."

The FMEA in Section 9.2 of the FSAR demonstrates this.

(Slide B-23)

L. Flood Protection

A flooding analysis was done some years ago to assure the system will operate under postulated flooding conditions.

M. Internal Missiles

An analysis is presented in Section 3.4 of the FSAR which demonstrates acceptable protection of safety-related systems from the effects of postulated missiles.

(Slide B-24)

N. External Missiles

The effects on system operation from external missiles is discussed in detail in Section 3.3 of the FSAR. Compliance with the regulatory requirements is demonstrated by location within missile protected structures or by a failure analyses which demonstrates acceptable consequences.

0. Pipe Breaks

An analysis and field walkdown was conducted to demonstrate that the CCW is adequately protected against the effects (i.e., jet impingement and whip) of high energy line breaks. A heavy metal dog house was added in 1977 around the CCW HX to provide a high degree of protection.

This concludes my prepared remarks. Although the Component Cooling Water System at Diablo Canyon was designed and constructed years before NUREG-0800 was issued, each of the 15 broad areas of review was properly considered and implemented in the design.

LIST OF SLIDES USED
IN E.C. CONNELL'S PRESENTATION


- Slide A1: Purpose
- Slide A2: CCW System Basic Arrangement
- Slide A3: CCW System Basic Layout (Elevation)
- Slide A4: CCW System Normal Operation
- Slide A5: CCW System Cooldown
- Slide A6: CCW System Safety Injection ("S" Signal)
- Slide A7: CCW System Safety Injection ("P" Signal)
- Slide A8: CCW System Recirculation Post-LOCA (Without "C" Header)
- Slide A9: Major Sources of CCW System Make-Up
- Slide A10: Vital Power Sources for Major CCW System (and Related) Users
- Slide A11: CCW System Basic Arrangement
- Slide A12: CCW System Heat Loads Summary
- Slide A13: CCW System Basic Arrangement
- Slide A14: Post-LOCA Sample Cooler Basic Arrangement
- Slide A15: CCW System Basic Arrangement
- Slide A16: CCW System Reactor Coolant Pump Isolation
- Slide B1: Components All Class I
- Slide B2: CCW System Users: Vital Components
- Slide B3: CCW System Users: Non-Vital Components
- Slide B4: Make-Up Water
- Slide B5: A. Provide Adequate Cooling
- Slide B6: B. Other System Aspects
- Slide B7: C. Interactions
- Slide B8: A. Functional Performance
- Slide B9: A. Functional Performance (cont'd)
- Slide B10: SRP Requirement for GDC 44

- Slide B11: B. Multiple Performance Functions
- Slide B12: C. Surge Tank Capability
- Slide B13: D. Provide Adequate Cooling Water
- Slide B14: E. Heat Loads
- Slide B15: Vital Power Sources for Major CCW System (and Related) Users
- Slide B16: E. Heat Loads (cont'd)
- Slide B17: F. Seismic/Non-Seismic Interface
- Slide B18: G. Leakage
- Slide B19: H. Testing and ISI
- Slide B20: I. RCP Seals
- Slide B21: J. Instrumentation
- Slide B22: K. Reliability Analysis
- Slide B23: L. Flood Protection
M. Internal Missiles
- Slide B24: N. External Missiles
- Slide B25: O. Pipe Break


PURPOSE

- REMOVE WASTE HEAT
- ESF OR RADIOACTIVE COMPONENTS
- DOUBLE BARRIER
- REJECT TO ASW


CCW SYSTEM BASIC ARRANGEMENT




CCW SYSTEM BASIC LAYOUT (ELEVATION)




CCW SYSTEM NORMAL OPERATION




CCW SYSTEM COOLDOWN




CCW SYSTEM SAFETY INJECTION ("S" SIGNAL)




CCW SYSTEM SAFETY INJECTION ("P" SIGNAL)



CCW SYSTEM RECIRCULATION POST-LOCA (WITHOUT "C" HEADER)



MAJOR SOURCES OF CCW SYSTEM MAKE-UP



VITAL POWER SOURCES FOR MAJOR CCW SYSTEM (AND RELATED) USERS

VITAL BUS 1F

CONTAINMENT FAN
COOLERS (2)

CCW PUMP

AUXILIARY SALTWATER PUMP

VITAL BUS 1G

CONTAINMENT FAN
COOLERS (2)

CCW PUMP

AUXILIARY SALTWATER PUMP

MAKE-UP WATER TRANSFER PUMP

CONTAINMENT SPRAY PUMP

VITAL BUS 1H

CONTAINMENT FAN COOLER


CCW PUMP

"C" HEADER ISOLATION
VALVE FCV-355

MAKE-UP WATER TRANSFER
PUMP

CONTAINMENT SPRAY PUMP


CCW SYSTEM BASIC ARRANGEMENT




CCW SYSTEM HEAT LOADS SUMMARY

| OPERATING CONDITION | TOTAL HEAT LOAD (10 ⁶ BTU/HR) |
|---|---|
| NORMAL | 72 |
| SAFETY INJECTION ("S" SIGNAL-5 FAN COOLERS) | 240 |
| SAFETY INJECTION ("P" SIGNAL) | |
| i) DBA LOCA AND WORST SINGLE FAILURE ANALYSIS | 244 |
| ii) NO FAILURES | 406 |
| RECIRCULATION (MAXIMUM ON ONE HEAT EXCHANGER) | 229 |


CCW SYSTEM BASIC ARRANGEMENT




POST-LOCA SAMPLE COOLER BASIC ARRANGEMENT



CCW SYSTEM BASIC ARRANGEMENT



CCW SYSTEM REACTOR COOLANT PUMP ISOLATION



COMPONENTS

ALL DESIGN CLASS I

PUMPS

3, HORIZONTAL, CENTRIFUGAL
9200 gpm
CARBON STEEL
AB
4kV VITAL BUS

CAT

2
CARBON STEEL
VALVED OUT
CORROSION INHIBITOR

VALVES

CARBON STEEL
BRONZE OR SS TRIM

HX

2
ASW TUBE SIDE
258.8 x 10⁶ BTU/HR
TB
CARBON STEEL/CuNi

SURGE TANK

1, INTERNALLY SPLIT
10,750 GAL
4000 GAL MINIMUM
CARBON STEEL
RELIEF TO AB SUMP

PIPING

WELDED
FLANGE CONNECTIONS

CCW SYSTEM USERS: VITAL COMPONENTS

"A" LOOP

RHR HEAT EXCHANGER

RHR PUMP

CENTRIFUGAL CHARGING PUMP

SAFETY INJECTION PUMP

CONTAINMENT FAN COOLERS (2)

POST-LOCA SAMPLE COOLERS

CCW PUMP(S)

"B" LOOP

RHR HEAT EXCHANGER

RHR PUMP

CENTRIFUGAL CHARGING PUMP

SAFETY INJECTION PUMP

CONTAINMENT FAN COOLERS (3)

CCW PUMP(S)

CCW SYSTEM USERS: NON-VITAL COMPONENTS

"C" LOOP

WASTE GAS COMPRESSORS (2)
CENTRAL SAMPLE PANEL COOLERS
RECIPROCATING CHARGING PUMP
REACTOR COOLANT PUMPS (4)
GROSS FAILED FUEL DETECTOR HX
REACTOR VESSEL SUPPORT COOLERS (4)
BORIC ACID EVAPORATOR PACKAGE
AUXILIARY STEAM DRAIN RECEIVER VENT CONDENSER
WASTE CONCENTRATOR PACKAGE
NSSS SAMPLE HEAT EXCHANGER
SEAL WATER HEAT EXCHANGER
LETDOWN HEAT EXCHANGER
STEAM GENERATOR BLOWDOWN SAMPLE COOLERS
BLOWDOWN TANK VENT CONDENSER
SPENT FUEL PIT HEAT EXCHANGER
EXCESS LETDOWN HEAT EXCHANGER

MAKE-UP WATER

- AIR-ACTUATED LEVEL CONTROL VALVES
 - REDUNDANT
 - SURGE TANK LEVEL
 - LOW NORMAL OPERATING

- MAKE-UP PATHS
 - MU WATER DEMINERALIZERS
 - CLASS II FROM CHECK VALVE
 - CST
 - CLASS I — PIPE, VALVES, PUMPS
 - MU WATER X-FER PP, REDUNDANT
 - VITAL BUS
 - 425,000 GAL, 255,000 GAL
 - MANY OTHER PATHS
 - DESIGN CLASS I AND II
 - UNIT 2 CST

A. PROVIDE ADEQUATE COOLING

- FUNCTIONAL PERFORMANCE
- MULTIPLE PERFORMANCE FUNCTIONS
- SURGE TANK CAPABILITY
- PROVIDE COOLING WATER
- HEAT LOADS

B. OTHER SYSTEMS' ASPECTS

- EFFECTS OF NON-CATEGORY I
- LEAKAGE
- TESTING, ISI
- RCP SEALS
- INSTRUMENTATION
- RELIABILITY ANALYSIS

C. INTERACTIONS

- FLOOD PROTECTION
- INTERNAL MISSILES
- EXTERNAL MISSILES
- PIPE BREAKS

A. FUNCTIONAL PERFORMANCE

- ENVIRONMENTAL OCCURRENCES

CLI-80-21, NUREG 0588
NRC REVIEW 9/81
SEISMIC ANALYSES

- NORMAL OPERATION

1 PP, 1 HX IN STANDBY NORMALLY
COOLDOWN WITHOUT 1 HX OR 1 PP

A. FUNCTIONAL PERFORMANCE (Cont'd)

- OPERATION AFTER ACCIDENT

ESSENTIAL SAFEGUARDS BUS — CCW,
ASW, MU

S SIGNAL CCW, ASW

LIMITING FAILURE LEAVES

1 MU, 2 CCW, 1 ASW

REDUNDANT USERS

STILL FEEDS BOTH PAIRS

LONG TERM

MANUALLY ALIGNED

ONE LOOP REQUIRED

ACTIVE OR PASSIVE FAILURE

SRP REQUIREMENT FOR GDC 44

REQUIRES "COMPONENT REDUNDANCY SO THAT SAFETY FUNCTIONS CAN BE PERFORMED ASSUMING A SINGLE ACTIVE COMPONENT FAILURE COINCIDENT WITH A LOSS OF OFFSITE POWER."

B. MULTIPLE PERFORMANCE FUNCTIONS

- GDC 5

SHARING BETWEEN UNITS
SWING DIESEL
ADDITIONAL REDUNDANCY
CST CROSSTIE

- NORMAL USERS

C HEADER HAS NORMAL USERS ONLY
ISOLATION NOT AFFECT SAFETY

- RADIOACTIVITY CONTROL

DOUBLE BARRIER DESIGN
RADIATION MONITORS
DESIGN CLASS I ISOLATION VALVES

C. SURGE TANK CAPABILITY

- ① INTERNALLY DIVIDED
- ① FEEDS REDUNDANT SURGE LINES
- ① SRP REQUIRES POSTULATED RUPTURE OF VITAL HEADER NOT DRAIN TANK
- ① MANY MAKE-UP PATHS

D. PROVIDE ADEQUATE COOLING WATER

- ④ REDUNDANT
- ④ DESIGN CLASS I
- ④ EMERGENCY POWER
- ④ ISOLATION INTO TRAINS

E. HEAT LOADS

- NORMAL OPERATION

72M BTU

HX — 258M BTU

- SI BUT NO P

MAJOR LOAD F.C.

ALL OTHERS 40M

C HEADER 39M

SAY 50% HEAT LOAD

- DBA, WORST FAILURE

DOUBLE-ENDED RUPTURE, LOOP, WORST
FAILURE

BUS G

WORST — LEAST CONT. COOLING

LOSS — 1 CS, 2 F.C., C HEADER

244M BTU

DESIGN CASE FOR GDC 44 AND FSAR

VITAL POWER SOURCES FOR MAJOR CCW SYSTEM (AND RELATED) USERS

VITAL BUS 1F

CONTAINMENT FAN
COOLERS (2)

CCW PUMP

AUXILIARY SALTWATER PUMP

VITAL BUS 1G

CONTAINMENT FAN
COOLERS (2)

CCW PUMP

AUXILIARY SALTWATER PUMP

MAKE-UP WATER TRANSFER PUMP
CONTAINMENT SPRAY PUMP

VITAL BUS 1H

CONTAINMENT FAN COOLER

CCW PUMP

"C" HEADER ISOLATION
VALVE FCV-355

MAKE-UP WATER TRANSFER
PUMP

CONTAINMENT SPRAY PUMP

E. HEAT LOADS (Cont'd)

- LESS THAN WORST FAILURE
CONSIDERED IN EARLY DESIGN
POSSIBLE INCREASED TEMPERATURE
E.G. - 5 F.C., 2 CS, DBA ASSUMPTION'S
YIELDS 140°F, 406M BTU
OPERATOR ACTION
SECOND HX

F. SEISMIC/NON-SEISMIC INTERFACE

- REG GUIDE 1.29
- CAT
MANUAL CLOSED VALVES
- SENTRY COOLER
1980, NUREG 588
OPERATOR FAMILIARITY
VALVES OPEN
PIPING DESIGN CLASS I
SEISMICALLY ANALYZED
SPECIFICALLY DESIGNED FOR NUREG 588
NO APPROVED NUCLEAR QA PROGRAM

G. LEAKAGE

- INTO SYSTEM
REs
TANK LI AND LA
RELIEF VALVE
- OUT OF SYSTEM
TANK LI AND LA
NUMEROUS MAKE-UP PATHS
DESIGN CLASS I VALVES

H. TESTING AND ISI

- ACCESSIBLE
- VISUAL OBSERVATION
- CONTINUOUS, INTERMITTENT OPERATION

I. RCP SEALS

- II.K.3.25
- LCOP
- LOSS OF AIR
- MOTOR OPERATORS FROM EMERGENCY BUS
- PUMPS ON EMERGENCY BUS

J. INSTRUMENTATION

K. RELIABILITY ANALYSIS

- ① SRP — "FMEA IN THE FSAR -- TO ENSURE THAT ESSENTIAL PORTIONS OF THE SYSTEM WILL FUNCTION FOLLOWING DESIGN BASIS ACCIDENTS ASSUMING A CONCURRENT SINGLE, ACTIVE COMPONENT FAILURE."

L. FLOOD PROTECTION

M. INTERNAL MISSILES

N. EXTERNAL MISSILES

- INSIDE BUILDINGS
- FAILURE ANALYSIS FOR SURGE TANK

O. PIPE BREAK

● JET IMPINGEMENT

● PIPE WHIP

● DOG HOUSE

Diablo Canyon Unit 1

Component Cooling Water System

Phillips Building - Room P-118

Bethesda, Maryland

January 28, 1983

CRITERIA AND DESIGN BASES

Presented By

C. Aronson

INTRODUCTION

I would like to begin with a brief overview of my presentation.

First, I will establish a point of reference for the Diablo Canyon design and licensing process, in relation to the contemporaneous development of AEC and NRC basic licensing requirements, as well as to other specific nuclear plants of interest.

Second, I will discuss PGandE's basic safety design criteria for Diablo Canyon, and how those criteria developed.

Third, I plan to outline the specific history of Diablo Canyon licensing as related to major NRC requirements bearing on the issues raised.

Fourth, I will discuss the specific licensing commitments for the Diablo Canyon Plant Component Cooling Water System.

Finally, I will address in detail certain of the specific areas of interest identified by the NRC as they relate to the CCW System. These areas include safety and seismic classification interfaces, application of the single failure criterion and considerations related to CCW system heat loads. Mr. Crawford will then follow with a presentation on the other basic issue of interest, the Instrumentation design philosophy.

EARLY DIABLO CANYON LICENSING AND DESIGN ACTIVITIES

In order to place the Diablo Canyon original design and licensing schedule in perspective, I have prepared a simple slide noting the relationship between the early Diablo Canyon licensing history and the development of the AEC General Design Criteria. I won't read this information but you will note the close parallel between these activities, indicating that a significant portion of Diablo Canyon design effort took place prior to the formal issuance of the GDC.

I would also like to point out that the Diablo Canyon early design effort took place during the transition from "turnkey" plants, in which the reactor supplier was prime contractor, to the current arrangement of Nuclear Steam Supply System vendor/utility coordination of the project. During this transition period, Westinghouse, as the NSSS vendor for Diablo Canyon maintained a close liaison with the designers of interfacing systems, such as CCW. Other plants which were designed in the general time frame of Diablo Canyon include Indian Point Unit 2, Ginna and San Onofre Unit 1.

BASIC DESIGN CRITERIA

Next I will discuss the subject of basic design criteria for Diablo Canyon.

During Mr. Eisenhut's remarks at the status meeting of January 13th, he stressed the Staff's need for a clear statement of PGandE's design criteria in a number of areas. PGandE's basic design approach is to meet the NRC's stated requirements, as discussed to in the licensing documents for the Diablo Canyon Plant. In addition, it is PGandE's design approach to employ sound engineering practices, consistent with the licensing basis for the plant, in interpreting NRC requirements which are not explicitly stated.

Basic safety design criteria for nuclear power plants, are, of course, found in NRC regulations and various guidance documents. The main source for NRC requirements concerning design is in the General Design Criteria, Appendix A to 10 CFR Part 50. Some of these criteria are reasonably specific in nature, requiring a minimum of interpretation. There are certain design areas, however, in which NRC criteria are less clear, even after considering the related NRC guidance material. In these cases some measure of engineering judgment must necessarily be applied. This is often difficult in these areas in that the designer must convert partially non-mechanistic event scenarios into mechanistic events and event combinations. It appears that virtually all of the areas of interest raised by Mr. Eisenhut are in areas where such judgment must be applied. For example, General Design Criterion 2

requires consideration of appropriate combinations of natural phenomena and in plant events in the design process. However, the scope of application of seismic design requirements enumerated in Appendix A to 10 CFR Part 100 simply provide a listing of basic safety functions for the purpose of determining which plant features must be designed to Seismic Category I requirements. It is left to the designer to decide exactly which aspects of the plant must be designed for simultaneous occurrence of a Loss of Coolant Accident and a large earthquake and what assumptions he must make concerning failure of items not fully designed to these seismic requirements.

With these thoughts in mind, I would emphasize our position that the design of the Diablo Canyon Plant Component Cooling Water System is consistent with NRC requirements.

DIABLO CANYON LICENSING HISTORY

I have noted that the early Diablo Canyon design and licensing process closely paralleled the development of the AEC's General Design Criteria (GDC). PGandE adhered to the 1967 draft GDC and, as indicated in the FSAR, reviewed its compliance with the formally issued GDC of 1971. One of the most significant GDC related to the issues of interest is GDC number 2. This criterion concerns design bases for protection against natural phenomena. While this criterion changed significantly between 1967 and 1971, PGandE committed to meet the intent of the 1971 version. I have a slide of GDC 2 for reference. The Diablo Canyon FSAR specifically states that the plant conforms with the important requirement that it be designed for the most severe natural phenomena, with appropriate combinations of postulated accidents and those natural phenomena.

Another GDC of significance is that for design of cooling water systems, GDC 44, for which I also have a slide. This particular GDC had no counterpart in the 1967 draft but the Diablo Canyon FSAR states that the CCW System design conforms to the intent of GDC 44. Note the use of the application of the single failure criterion in this GDC, clearly relates to the safety function of the system being maintained.

Another important portion of 10 CFR 50 Appendix A is the single failure definition included in this slide. The Diablo Canyon FSAR adopts a similar definition of single failure and commits to its application for all safety-related systems including the CCW system. The Diablo Canyon

FSAR amplifies this definition by applying the active failure to the "short term" or an active or passive failure to the "long term". The "short term" is defined as 24 hours. The passive failure is defined as 50 gpm.

I would also note, at this point, that the dominant event upon which the General Design Criteria are structured is the large LOCA, together with worst case single failures in required response systems. Similar emphasis is clearly shown in a review of the licensing documents for Diablo Canyon. Thus the Diablo Canyon licensing approach is consistent with the NRC's oft-stated philosophy of establishing non-mechanistic worst case accident scenarios in order to provide bounding values of parameters for design of plant features. It should be noted that there are no additional specific NRC requirements to evaluate all intermediate combinations of events on a worst-case parameters basis. The Diablo Canyon FSAR includes only the worst case scenario for the CCW System.

In addition to the GDC, another AEC guidance document of particular significance during that time frame is Safety Guide 29 which covers Seismic Design Classification. The Diablo Canyon FSAR states that the design complies with the intent of this Guide. This slide shows one item included in the listing of items which must be designed seismically and which involves interfaces. This is one of the few areas in which regulatory guidance specifically addresses interfaces. However, there is little further guidance in this particular area.

LICENSING BASIS OF THE DIABLO CANYON

CCW SYSTEM

The FSAR describes the CCW System as "Design Class 1" with specific exceptions as noted. A Design Class 1 system is defined in the FSAR as one which is "vital to safe shutdown and isolation of the reactor, or whose failure might cause or increase the severity of a loss of coolant accident, or result in an uncontrolled release of excessive amounts of radioactivity". The CCW safety function under this definition as described in the FSAR consists of cooling of the safety-related equipment following LOCA, as described in an earlier presentation. This slide shows the exceptions to Design Class 1 for the CCW system mentioned earlier. Please note that these exceptions are prominently mentioned at the beginning of the section.

SAFETY/NON-SAFETY-RELATED INTERFACES

I will now discuss the first specific issue, that of interfaces between safety and non-safety related portions of the CCW System. As indicated in the (same) slide, and indicated in the previous presentation, the major safety/non-safety interface concerns CCW Loop "C". No exact point of demarcation is identified between these portions of the system, as the distinction is in reference to portions of the system required, or not required, post LOCA, and does not indicate that items served by loop "C" have no importance. For example the reactor coolant pumps, as discussed in the previous presentation, are served by Loop "C". The significance of this is that, although in the context of Diablo Canyon licensing only loops A and B of the CCW are safety-related, we believe it important that loop C not be subjected to unnecessary inadvertent isolation. The important requirement for the interface is that its design be such as to prevent unacceptable effects of the non-safety related portions on the safety-related portions of the system. Individual interface subjects discussed previously, and to be discussed later, cover individual issues related to potentially unacceptable effects. However, we have determined that the interfaces between safety and non-safety related portions of the CCW system have been adequately designed.

SEISMIC/NON-SEISMIC INTERFACES

As noted at several points earlier in these presentations not all components in the CCW system are Design Class 1. The non-Design Class 1 components attached to loops A and B were discussed in Mr. Connell's presentation. This discussion is confined to loop C components, and, more specifically, to their seismic capability relative to that required for Design Class 1 components. First, let me reiterate that all loop C piping and valves meet Design Class 1 seismic requirements. Therefore, the seismic interfaces are located at certain loop C heat exchanger nozzles connecting to CCW piping. The loop C heat exchangers vary over a rather wide range with regard to meeting Design Class 1 seismic requirements. In several cases they fully meet these requirements. In other cases they were purchased with various seismic design requirements specified, but there is inadequate documentation to assure that these requirements have been met. Still others were purchased with no seismic design requirements specified. The latter are tabulated on this slide which indicates that they are all small components, for which the leakage potential is very limited.

In our investigations relative to this aspect of the potential non-conformance we have found the following:

1. There is a general trend of increasingly conservative requirements for seismic design with increasing size among these heat exchangers.

2. The heat exchangers were purchased to the same ANSI code requirements as the safety-related equipment in loops A and B.
3. Only ductile materials were allowed to be used in the pressure boundaries of the heat exchangers.
4. The design of the C loop piping supports was intended to limit nozzle reactions on the equipment, as indicated in the slides of the actual system that you have just seen.

The importance of maintaining pressure integrity in loop C was recognized by the designers. Also, as discussed in an earlier presentation, in the event of leakage, each heat exchanger may be isolated with manual valves which are in accessible locations.

Although we are continuing to examine certain of the C loop heat exchangers to provide additional confirmation of their seismic capability we believe that adequate provisions have been made to assure meeting NRC guidance in this area. Specifically, no degradation of safety-related equipment to an "unacceptable safety level," as specified in Safety Guide 2, for such interfaces, will occur.

SINGLE CRITERIA FAILURE

The issue of adequate design for required single failure assumptions apparently originates from the fact that only one automatic isolation valve exists on CCW loop "C" serving non-vital equipment in the system. This issue arises from an incorrect assumption that each individual active component in a system is required to have a redundant counterpart. Single failure analyses can only be made in the context of performance of system safety functions as they contribute to plant safety. Furthermore single failure analyses must be considered in the context of support functions required at all levels to perform the safety function. Note that the slide for GDC 44 does not state that the single failure applies only to the CCW system, that is, any single failure must be considered. As mentioned earlier the worst case single failure assumed in the FSAR for the CCW System is one which has the maximum impact on the most important safety function for the CCW System, removal of heat from the containment fan coolers post-LOCA.

The FSAR clearly states that this case is one involving the loss of two containment coolers, leaving only 3 of 5 available. The only single failures that could cause this condition would be loss of one of the two diesel generators which supply power to two containment coolers. However, the power to the loop "C" isolation valve is not supplied by either of these two diesel generators, so no failure of the isolation valve need be assumed. Therefore the single active failure of this valve is not relevant to the case tabulated in the licensing basis, that is Chapter 9 of the FSAR. There are additional single failures that

require examination but they are more closely related to the next issue on heat loads, which I will discuss shortly.

Once again, after thorough review and analysis we have concluded that there is no error in the single failure analysis stated in the FSAR.

HEAT LOADS

The issue involved here concerns possible failure to account properly for heat loads which might result from consideration of single failures other than those covered in the FSAR, or in the absence of single failures. As I indicated earlier, consistent with NRC licensing requirements the FSAR single failure analysis is limited to a single worst case scenario. It does not appear necessary to analyze all other permutations and combinations of failures or non failures in the exact same manner and to the exact same acceptance criteria. There are cases of single failure other than diesel generator failures, as well as non-failures, in combination with non-loss of offsite power, which would result in fairly rapid increase in the CCW system temperature. If 5 containment coolers were operating post LOCA and if an unrealistic Pacific Ocean temperature of 70°F is assumed, the limiting CCW heat exchanger outlet temperature could be reached in a short period of time. This situation has been recognized for Diablo Canyon for many years, and the plant operating procedures specifically include provision for coping with such a situation. In those cases where the number of operating containment coolers require reduction and/or where an additional CCW heat exchanger must be placed in service, such actions can be accomplished from the main control room.

However, you should be aware that this issue is currently being evaluated to assure that adequate provisions and procedures exist to accommodate all credible situations which could occur.

This issue is one which is not specifically covered in the licensing basis, which requires evaluation of operator action times only for those cases where credit for operator action is taken in the FSAR Chapter 15 analysis. This does not apply in the cases under evaluation.

LIST OF SLIDES USED
IN C. ARONSON'S PRESENTATION

- Slide 1: Diablo Canyon Schedule Relative to NRC
Requirements
- Slide 2: 10CFR50 Appendix A (GDC) - Criterion 2
- Slide 3: 10CFR50 Appendix A (GDC) - Criterion 44
- Slide 4: 10CFR50 Appendix A (GDC) - Single Failure
Definition
- Slide 5: Safety Guide 29
- Slide 6: DCP FSAR Chapter 9
- Slide 7: CCW Loop C Components

DIABLO CANYON PLANT SCHEDULE RELATIVE TO NRC REQUIREMENTS

| <u>AEC/NRC REQUIREMENTS</u> | <u>YEAR</u> | <u>DIABLO CANYON SCHEDULE</u> |
|---|-------------|-----------------------------------|
| | EARLY 1967 | PSAR SUBMITTAL |
| AEC DRAFT GENERAL DESIGN CRITERIA ISSUED | 1967 | |
| | 1969 | CONSTRUCTION PERMIT |
| GENERAL DESIGN CRITERIA FORMALLY ISSUED | 1971 | |

TAKEN FROM 10CFR50, APPENDIX A
(GDC)

CRITERION 2—DESIGN BASES FOR PROTECTION
AGAINST NATURAL PHENOMENA.

STRUCTURES, SYSTEMS, AND COMPONENTS
IMPORTANT TO SAFETY SHALL BE DESIGNED
TO WITHSTAND THE EFFECTS OF NATURAL
PHENOMENA SUCH AS EARTHQUAKES,...
WITHOUT LOSS OF CAPABILITY TO PERFORM
THEIR SAFETY FUNCTIONS. THE DESIGN
BASES...SHALL REFLECT:

- (1) APPROPRIATE CONSIDERATION OF THE
MOST SEVERE OF THE NATURAL
PHENOMENA THAT HAVE BEEN
HISTORICALLY REPORTED FOR THE SITE
AND SURROUNDING AREA,...
- (2) APPROPRIATE COMBINATIONS OF THE
EFFECTS OF NORMAL AND ACCIDENT
CONDITIONS WITH THE EFFECTS OF THE
NATURAL PHENOMENA...

TAKEN FROM 10CFR50, APPENDIX A
(GDC)

CRITERION 44

SUITABLE REDUNDANCY IN COMPONENTS AND FEATURES, AND SUITABLE INTERCONNECTIONS, LEAK DETECTION, AND ISOLATION CAPABILITIES SHALL BE PROVIDED TO ASSURE THAT FOR ONSITE ELECTRIC POWER SYSTEM OPERATION (ASSUMING OFFSITE POWER IS NOT AVAILABLE) AND FOR OFFSITE ELECTRIC POWER SYSTEM OPERATION (ASSUMING ONSITE POWER IS NOT AVAILABLE) THE SYSTEM SAFETY FUNCTION CAN BE ACCOMPLISHED, ASSUMING A SINGLE FAILURE.

TAKEN FROM PREAMBLE OF 10CFR50,
APPENDIX A

SINGLE FAILURE. A SINGLE FAILURE MEANS AN OCCURRENCE WHICH RESULTS IN THE LOSS OF CAPABILITY OF A COMPONENT TO PERFORM ITS INTENDED SAFETY FUNCTIONS... FLUID AND ELECTRIC SYSTEMS ARE CONSIDERED TO BE DESIGNED AGAINST AN ASSUMED SINGLE FAILURE IF NEITHER A SINGLE FAILURE OF ANY ACTIVE COMPONENT... RESULTS IN A LOSS OF THE CAPABILITY OF THE SYSTEM TO PERFORM ITS SAFETY FUNCTIONS.

THE CONDITIONS UNDER WHICH A SINGLE FAILURE OF A PASSIVE COMPONENT SHOULD BE CONSIDERED...ARE UNDER DEVELOPMENT.

TAKEN FROM SAFETY GUIDE 29

r. STRUCTURES, SYSTEMS, OR COMPONENTS WHOSE FAILURE COULD REDUCE THE FUNCTIONING OF ANY PLANT FEATURE INCLUDED IN ITEMS 1.a. THROUGH 1.q. ABOVE TO AN UNACCEPTABLE SAFETY LEVEL.

TAKEN FROM D.C.P. FSAR, CH. 9

EXCEPT FOR NON-VITAL COMPONENTS IN LOOP "C" AND THE CHEMICAL ADDITION TANKS, THE COMPONENT COOLING WATER SYSTEM IS A DESIGN CLASS I SYSTEM AND IS SHOWN IN FIGURE 9.2-4. THE SYSTEM IS DESIGNED TO REMOVE WASTE HEAT FROM THE NUCLEAR (PRIMARY) PLANT EQUIPMENT AND COMPONENTS DURING NORMAL PLANT OPERATION, PLANT COOLDOWN, AND FOLLOWING A LOSS OF COOLANT ACCIDENT.

PRELIMINARY

CCW LOOP "C" COMPONENTS FOR WHICH
NO SEISMIC REQUIREMENTS WERE SPECIFIED

| <u>HEAT EXCHANGER</u> | <u>INLET NOZZLE SIZE</u> |
|--|------------------------------|
| CENTRAL SAMPLE PANEL COOLERS PACKAGE | 2" |
| BORIC ACID EVAPORATOR PACKAGE SAMPLE COOLER | 1" |
| WASTE CONCENTRATOR PACKAGE SAMPLE COOLER | 1" |
| STEAM GENERATOR BLOWDOWN SAMPLE COOLER | 3/4" |
| STEAM GENERATOR BLOWDOWN VENT CONDENSER (NORMALLY ISOLATED) | 3/4" |

Diablo Canyon Unit 1

Component Cooling Water System

Phillips Building Room P-118

Bethesda, Maryland

January 28, 1983

INSTRUMENT CLASSIFICATIONS
AT DIABLO CANYON POWER PLANT
AND
THEIR APPLICATION TO THE
COMPONENT COOLING WATER SYSTEM

Presented By

T.N. Crawford

0035L/0068P-1

INTRODUCTION

I am going to describe the PGandE Design Philosophy for Instrumentation as it applies to Diablo Canyon. I will then describe how we actually classify instrumentation, and how it complies with industry standards and NRC regulations and guidance. Next, I will give a short history of our Classification System. Finally, I will describe how that Classification System is implemented in the Component Cooling Water System.

DESIGN PHILOSOPHY

(Slide 1)

In keeping with Criterion 1 of Appendix A to 10CFR50, if we were unconstrained by any other standards, we would develop six instrument classifications from the most important function to the least. They would be:

- (1) Those devices which actually perform safety functions themselves;
- (2) Those devices which the operator uses to perform manual safety functions;
- (3) Those devices that tell the operator the condition of the vital systems;
- (4) Those devices that tell the operator if the safety systems are working;
- (5) Those devices which the operator needs to troubleshoot the safety systems;

and finally

- (6) Those devices not involved in safety systems.

In actuality, our classification systems do directly parallel standards and regulations, so it is impractical to have 6 classifications. But remember this logic, because you will see that the first two levels closely match our Class 1A; the second two closely match our Class 1B; and the third two are not safety related.

Classification

The design classification of instrumentation at Diablo Canyon is specified by Design Criteria Memorandum M-3 titled "Design Class I Instrumentation". The original version was dated March 18, 1971, and the current revision was dated March 5, 1980. The first classification that it identifies is Instrument Class IA.

Instrument Class 1A

(Slide 2)

Instrument Class IA instruments are those which are required to accomplish the functions of the Reactor Protection or Engineered Safety Features Systems.

Simply stated, any instrument which performs a function which is necessary to complete a safeguards action is classified as Instrument Class IA.

This parallels the definition of IEEE Class IE electrical equipment. Class IE is defined as "The safety classification of electric equipment and systems that are essential to emergency reactor shutdown, containment isolation, reactor core cooling, and containment and reactor heat removal, or otherwise are essential in preventing significant release of radioactive material to the environment." (IEEE Standard 308-1974).

Although not specifically stated in the explanation, the instrumentation which performs a safety function can be an operator controlled device if manual action is an acceptable way of performing the safety function.

Instrument Class IA complies with 10CFR50 Paragraph 50.55 a (h), which requires compliance with IEEE 279.

Instrument Class IA totally envelopes IEEE Class IE as defined in IEEE Standard 308-1974. The electrical portions meet IEEE 279, 323, and 344 as appropriate. There does not appear to be any industry standard with which to compare our requirements for the mechanical and pneumatic portions of IA.

Class IA instruments are seismically and environmentally qualified, meet single failure criteria, and have Class IE power.

Instrument Class 1B

(Slide 3)

Instrument Class IB instruments are those which provide Post Accident Monitoring functions. This classification meets the requirements of USNRC Regulatory Guide 1.97, Revision 2. It is broken down into the types defined in the Regulatory Guide. They are:

Type A - Those instruments that provide information required to take preplanned manual actions. Type A instruments are seismically and environmentally qualified, meet single failure criteria and have Class IE power.

Type B - Those instruments that provide information to monitor the process of accomplishing critical safety functions. Type B instruments are seismically and environmentally qualified, meet single failure criteria, and have Class IE power.

Type C - Those instruments that indicate the potential for breaching or actual breach of barriers to fission product release. Type C instruments are seismically and environmentally qualified, meet single failure criteria, and have Class IE power.

Type D - Those instruments that indicate the performance of individual safety systems. Type D instruments are seismically and environmentally qualified, and have Class IE power.

Type E - Those instruments that provide information for use in determining the magnitude of the release of radioactive materials.

These classifications were written to meet Draft 2 of Reg. Guide 1.97, Rev. 2. We are in the process of revising our criteria to precisely comply with the issued Reg. Guide. It will be issued before June 1, 1983, as required by the Reg. Guide. We, like others, are having delivery problems with qualified state-of-the art devices, and the physical plant does not yet fully comply with the issued Reg. Guide.

Instrument Class IC

(Slide 4)

Instrument Class IC instrumentation is all instrumentation which has no safety function, but is attached to a Design Class I pressure boundary. It does not parallel any current industry classifications. Class IC instruments are seismically qualified to maintain their pressure boundary.

We are addressing this in the ISA SP67.07 committee, which I am a member of, but we aren't really there yet. The committee is limiting its work to in-line devices, but PGandE also addresses offline devices.

(Slide 5)

All instrumentation not covered by these classifications is Instrument Class II, which perform no safety function.

Before I go on, I would like to make a clarification on a point that may be confusing. All valves with actuating devices on them have two

classifications. The instrument classification applies only to the actuator. The piping classification applies only to the valve. It is entirely possible to have an Instrument Class II, Piping Class I valve, and vice-versa. The Instrument Class II valves which you see on the Class I piping in the Component Cooling Water System are indeed Piping Class I valves.

I would like to capulize the minimum requirements for our classifications.

(Slide 6)

(This slide is a copy of the matrix from our design criteria memo and not all the information here is germane to the discussion at hand.)

Instrument Class IA and IB, Type A, B, C, and D instruments are seismically and environmentally qualified, and have Class IE power. This diagram shows the criteria for Type D to be emergency power. Our emergency power is Class IE. Class IA and IB Types A, B, and C meet single failure criteria.

I would like to address an area which I know has caused considerable debate. That is the area of contingency actions.

Our Instrument Class IB Type A is the classification which we allot to instruments which the operator uses to perform manual safety functions. The verbiage in our Design Criteria Memorandum is "preplanned manual

actions". In actual implementation, we refer to Regulatory Guide 1.97 Revision 2, which calls Type A variables:

"those variables to be monitored that provide the primary information required to permit the control room operator to take specific manually controlled actions for which no automatic control is provided and that are required for safety systems to accomplish their safety functions for design basis accident events. Primary information is information that is essential for the direct accomplishment of the specified safety functions; it does not include those variables that are associated with contingency actions that may also be identified in written procedures."

As I said earlier, our revised criteria memo will use this definition precisely.

We define contingency actions as actions for which capability is provided to diagnose and correct system problems, but which are not part of the direct accomplishment of the safety function. We believe this is consistent with the regulatory guidance, and it is consistent with the design philosophy I described earlier.

I would like to point out that Instrument Class II is simply a functional classification. It is not necessarily a measure of the availability of the device. There are many Instrument Class II devices in the plant which have been seismically qualified, and are wired and powered as IEEE Class IE devices. Some are even redundant. This goes

to a very conservative PGandE philosophy that requirements are only minimums; quality should be commensurate with importance regardless of which box it fits into. This is important enough for me to restate it. These are classifications which fit into little boxes to comply with NRC requirements. PGandE has many devices which under our old classification were seismically qualified, wired and powered as IEEE Class IE, but which have been reclassified as Class II to conform with NRC definitions. The Component Cooling Water Surge Tank Level Switch, which apparently sparked the controversy at hand, is just such an instrument. It performs a contingency function and is therefore not Instrument Class IA or IB. As you will hear later, it is used in an abnormal condition procedure, and not in an emergency procedure. It is, however, provided with IEEE Class IE power, and inputs into a seismically qualified annunciator.

HISTORY

(Slide 1 Repeat)

I would like to share with you the history of our design classification system.

The original design criteria memo was written in March of 1971 to drafts of ANSI N18.2. Instrument Class IA was reserved for those instruments defined in Sections 5.3 and 5.5 of N18.2.

Instrument Class IB was everything else involved in safety functions; that is, the next 4 items on our philosophy list. Although some specific minimum criteria were given, the unwritten criteria was the embodiment of GDC 1: "Quality commensurate with its function."

In December of 1976, the NRC, Region V, was auditing us and found inconsistencies in the wiring of IB instruments, and asked what the criteria were. Since we couldn't provide a single set of criteria, we agreed that an overhaul was in order.

In 1977, we wrote Design Criteria Memo M-3, Revision 1, putting all devices which performed safety functions into IA, and paralleled Class IA to IEEE Class IE. We relabeled Class IB as devices used for "Peripheral Control and Monitoring of Safeguards Systems" with requirements consistent with the importance, to be determined on a case by case basis. None of it was called IE, but we wired it, powered it and qualified it as if IE if we felt it to be appropriate.

After TMI, I participated in the Staff-Industry Meetings on Reg. Guide 1.97, Revision 2, and when I thought that it was basically firm (Draft 2), I rewrote our Criteria Memo M-3 to make IB reflect the Draft Regulatory Guide. The upgrade to the physical plant (which is still in progress) has been minimal.

Our Class IB previously included peripheral control and some diagnostic monitoring. When we made it match the Reg. Guide, there was no place for these functions. From a classification point of view, they became

Class II. But they will still be available when we think the operator needs them. The surge tank level switch is just such a device.

IMPLEMENTATION IN THE CCW SYSTEM

I would now like to describe how we implement these classifications in the Component Cooling Water System.

(Slide 7)

This slide shows the system diagram which Mr. Connell showed you previously. I will go through each classification, and show you which instruments in the system fit that classification and why.

(Slide 8)

This slide shows the Instrument Class IA automatic functions in the Component Cooling Water System.

There are no Protection System signal initiating (IA) instruments in the system. There are several system automatic functions which are initiated by devices outside of the system.

A Safety Injection Signal is initiated by LOCAs and Main Steam Line Breaks or High Containment Pressure (3 PSIG). It starts all of the component cooling water pumps and opens the containment fan cooler valves, FCV 360 and FCV 366.

The Phase A containment isolation signal is initiated by the Safety Injection Signal, and it isolates various containment isolation valves on the C header.

The Phase B containment isolation signal is initiated when Containment Pressure exceeds 22 PSIG. It closes the remaining containment isolation valves, and isolates Header C itself by closing FCV 355.

(Slide 9)

In addition to the automatic safety functions, there is one manual safety function which this slide shows. That is the system changeover when one goes onto RHR. Most of this is accomplished locally, but the radiation dose level is such that access to the RHR heat exchanger valves is not feasible. Therefore, those valves, FCV 364 and 365, are remote manual valves, and are Class IA.

(Slide 10)

This slide shows the Instrument Class IB devices.

Since the only manual safety function is the RHR realignment, the only IB Type A instrumentation would be that used for such a realignment. The operator makes this change when he goes into the recirculation mode after a LOCA. The IB Type A instruments for this function are Refueling Water Storage Tank Level and Containment Recirc. Sump Level, neither of which is in the CCW System.

There are no Type B or C variables, by definition, and by comparison with Table 2 of Reg. Guide 1.97, Rev. 2.

There are two Type D variables. Reg. Guide 1.97, Table 2, lists temperature and flow to vital components. These are used to determine if there is adequate flow to vital components, and to insure that the heat exchangers are doing their job properly. Diablo Canyon has added the C header flow just to be on the safe side. All of these devices are seismically and environmentally qualified, and have Class IE power.

There are no Type E variables on the system.

All of the remaining instrumentation physically on the system is Class IC. There are many devices, none of which have a safety function, so I'll not discuss them here.

(Slide 11)

I would like to discuss other devices which are not Class IA or IB which we feel are important. Most were Class IB under our old definition of "Peripheral Control and Monitoring." They don't, however, fit our current definitions of Class I devices (except IC as appropriate). This slide shows some of those devices.

We have the ability to automatically makeup the surge tank with redundant Instrument Class IC controllers and the Instrument Class II control valves.

We have the Class IC low alarms on the surge tank which I discussed earlier. They are functionally redundant, and are powered as Class IE. We feel that the determination of the surge tank level is an important diagnostic tool for leak detection.

Although I didn't show them on this diagram, we have Class IC flow indicators on every significant heat exchanger on headers A and B. We also have a flow indicator on every heat exchanger on the C header which has a line size over 2", except for one which is isolated by a containment isolation signal. Some of these are local, and some are on the Main Control Board. These allow the operator to quickly locate and isolate leaks.

Although our design basis is the ability to operate given a long term single failure where the operator goes down and manually isolates the system halves, we felt that it would be wise to provide immediate capability to cut in or out heat exchangers. Therefore, we have motor operators on the discharge valves for the heat exchangers (FCV 430 and 431). They are Instrument Class II, but are seismically qualified, and powered and wired as Class IE devices.

We have Class IC radiation monitors on the system to detect radioactive leaks into the system. These monitors also isolate the system vent as a precaution.

In summary, the Instrument Classification System for Diablo Canyon meets all applicable standards, regulations, and guidance, and the actual implementation is more conservative than the classifications themselves.

LIST OF SLIDES USED IN T.N. CRAWFORD'S PRESENTATION

- Slide 1: Diablo Canyon Instrumentation Philosophy
- Slide 2: Instrument Class IA
- Slide 3: Instrument Class IB
- Slide 4: Instrument Class IC
- Slide 5: Diablo Canyon Instrument Classifications
- Slide 6: "Table 1"
- Repeat of Slide 1: Diablo Canyon Instrumentation Philosophy
- Slide 7: CCW System Basic Arrangement
- Slide 8: Class IA Automatic Functions
- Slide 9: Class IA Manual Functions
- Slide 10: Class IB Functions (All Type D)
- Slide 11: Contingency or Convenience Devices

LIST OF SLIDES USED
IN T.N. CRAWFORD'S PRESENTATION

Slide 1: Diablo Canyon Instrumentation Philosophy

Slide 2: Instrument Class IA

Slide 3: Instrument Class IB

Slide 4: Instrument Class IC

Slide 5: Diablo Canyon Instrument Classifications

Slide 6: "Table 1"

Repeat of Slide 1 Diablo Canyon Instrumentation Philosophy

Slide 7: CCM System Basic Arrangement

Slide 8: Class IA Automatic Functions

Slide 9: Class IA Manual Functions

Slide 10: Class IB Functions (All Type D)

Slide 11: Contingency or Convenience Devices

DIABLO CANYON INSTRUMENTATION PHILOSOPHY

MOST IMPORTANT

- DEVICES WHICH PERFORM SAFETY FUNCTIONS THEMSELVES
- DEVICES WHICH THE OPERATOR USES TO PERFORM MANUAL SAFETY FUNCTIONS
- DEVICES TO MONITOR CRITICAL CONDITIONS
- DEVICES TO DETERMINE IF THE SAFETY SYSTEMS ARE WORKING
- DEVICES TO TROUBLESHOOT SAFETY SYSTEMS

-
- DEVICES NOT INVOLVED IN SAFETY SYSTEMS

LEAST IMPORTANT

INSTRUMENT CLASS IA

- DEVICES WHICH ACTUALLY PERFORM SAFETY FUNCTIONS

- 1) INPUTS
- 2) OUTPUTS
- 3) MANUAL

- NRC

- MEETS 10CFR50, PARA. 50.55 a(h)
- MEETS SRP CHAPTER 7.1, 7.2, 7.3, AND 7.4

- INDUSTRY

- MEETS IEEE 308 - 1974 |
- MEETS IEEE 279, 323, AND 344
- NO STANDARDS FOR MECHANICAL/PNEUMATIC PORTIONS

INSTRUMENT CLASS IB

- INSTRUMENTS TO ASSESS PLANT CONDITIONS

TYPE A PREPLANNED MANUAL ACTIONS

TYPE B SAFETY FUNCTION ACCOMPLISHMENT

TYPE C BREACH OR POTENTIAL BREACH

TYPE D SAFETY SYSTEM PERFORMANCE

TYPE E RADIOACTIVE RELEASES

- NRC

- MEETS REGULATORY GUIDE 1.97, REV. 2, DRAFT 2

- WILL MEET R.G.1.97, REV. 2, FINAL VERSION, BY JUNE 1, 1983

- INDUSTRY

- ENVELOPES ANSI/ANS 4.5 - 1980 AS MODIFIED BY R.G.1.97, REV. 2

INSTRUMENT CLASS IC

- ① INSTRUMENTS WHICH MUST MAINTAIN A SYSTEM PRESSURE BOUNDARY
- ① NOT SPECIFICALLY ADDRESSED BY NRC OR INDUSTRY STANDARDS OTHER THAN REFERENCES IN THE APPLICABLE PIPING CODES
- ① ISA's SP67.07 WILL ADDRESS INLINE DEVICES

DIABLO CANYON INSTRUMENT CLASSIFICATIONS

IA ○ DEVICES WHICH ACTUALLY PERFORM SAFETY FUNCTIONS

- 1) INPUTS
- 2) OUTPUTS
- 3) MANUAL

IB ○ INSTRUMENTS TO ASSESS PLANT CONDITIONS

- | | |
|--------|--------------------------------|
| TYPE A | PREPLANNED MANUAL ACTIONS |
| TYPE B | SAFETY FUNCTION ACCOMPLISHMENT |
| TYPE C | BREACH OR POTENTIAL BREACH |
| TYPE D | SAFETY SYSTEM PERFORMANCE |
| TYPE E | RADIOACTIVE RELEASES |

IC ○ INSTRUMENT WHICH MUST MAINTAIN A SYSTEM PRESSURE BOUNDARY

II ○ NOT REQUIRED TO PERFORM A SAFETY FUNCTION


TABLE 1

| Criteria | IA | Classification | | | | | IC |
|--------------------------------|-----|------------------|------------------|------------------|------------------|--------------------|----|
| | | IB | | | | | |
| | | Type | | | | | |
| | A | B | C | D | E | | |
| 1. Seismic ¹ | Yes | Yes ² | Yes ² | Yes ² | Yes ² | No | No |
| 2. Single Failure Criteria | Yes | Yes | Yes | Yes | No | No | No |
| 3. Environmental Qualification | Yes | Yes | Yes | Yes | Yes | No | No |
| 4. Power Source | IE | IE | IE | IE | EMR ³ | EMR ³ | - |
| 5. IEEE Classification | IE | - | - | - | - | - | - |
| 6. Display Type | - | Con ⁴ | Con ⁴ | Con ⁴ | OD ⁵ | OD ⁵ | - |
| 7. Display Method | - | Rec ⁶ | Rec ⁶ | Rec ⁶ | Ind ⁷ | Ind ^{7,8} | - |
| 8. Unique Identification | - | Yes | Yes | Yes | No | No | No |
| 9. Periodic Testing | Yes | Yes | Yes | Yes | Yes | No ⁹ | No |


Notes:

- 1) Applies to function. All devices must have qualified pressure boundaries if applicable to Class I Piping.
- 2) Seismic qualification for after seismic event.
- 3) EMR - Emergency Power, need not be battery backed.
- 4) Con - Continuous Display. Intermittent displays such as data loggers and scanning recorders may be used for multi-point parameters if no significant transient response can occur inside the recording interval.
- 5) OD - On Demand.
- 6) Rec - Recording for those parameters where trend or historical information is required to monitor the function.
- 7) Ind - Dial or digital indication.
- 8) Effluent release monitors require recording. including effluent radioactivity monitors, environs exposure rate monitors, and meteorology monitors.
- 9) Radiation monitors shall be periodically tested.


CCW SYSTEM BASIC ARRANGEMENT




CLASS IA AUTOMATIC FUNCTIONS




CLASS IA MANUVAL FUNCTIONS



CLASS IB FUNC: JNS (ALL TYPE D)



CONTINGENCY OR CONVENIENCE DEVICES



Diablo Canyon unit 1

Component Cooling Water System
Phillips Building - Room P-118
Bethesda, Maryland
January 28, 1983

BASIC OPERATION
OF THE
COMPONENT COOLING WATER SYSTEM
INCLUDING CONTINGENCY MODES OF OPERATION

Presented By
Jim Tinlin

Introduction

Jim Tinlin holds a current Senior Operator License on DCPP Unit 1, and has had previous experience as a simulator instructor at Westinghouse Nuclear Training Center, Zion plant.

He is currently acting in the Capacity of Training Coordinator in the Operations Training Section.

This presentation will cover basic operation of the system, including contingency actions during abnormal operation, and emergency operations.

I. PRESENTATION

A. Normal Operation of the CCW system is broken into two basic categories: At power and plant cooldown.

1. At power operation (Slide 1): During normal operation, the system heat load is removed by operating two CCW pumps and one CCW heat exchanger. All heat loads may be supplied by cooling water, although not all will be. Components which are not used during normal operation are those such as RHR heat exchangers, safety injection pump seal water coolers, etc.

The standby heat exchanger will be available for immediate use by being filled/vented and pressurized up to the outlet valve. All pump suction valves, crosstie valves (both suction and discharge, and heat exchanger crosstie valves) will be open.

Normally, to equalize run times, the pumps and/or heat exchangers are changed over weekly. This ensures operability of the system and enhances overall reliability and equipment availability.

2. During plant cooldown (Slide 2) the idle heat exchanger and standby CCW pump is placed in service due to the increased heat load on the system by the RHR heat exchangers.

Once the Reactor Coolant has been cooled down to less than 140°F the CCW system can be returned to its original configuration.

B. Abnormal Operation of the system is broken down into two basic contingency actions:

1. (Slide 3) High heat exchanger outlet temperature will alarm at the control board (120°F) to clue the operator into the fact that either excessive heat load has been placed on the system or a flow reduction has occurred.

The operator has several immediate actions he will perform:

- a. Check the temperature indication on the control board to verify the condition.
 - b. If the heat load is too high, the standby heat exchanger will be placed in service.
 - c. ASW flows will be checked to ensure sufficient flows.
2. CCW leakage out of the system will be indicated by either low CCW surge tank level alarms or CCW low header pressure alarms.

Automatic actions that will occur on the above are: Standby CCW pump starts and/or makeup valves open to raise CCW surge tank level.

Immediate operator actions include:

- a. Verify automatic actions take place, if they don't the operator will manually perform them.
- b. Start an additional makeup water transfer pump if required (one normally running).
- c. If level is lost in both halves of the surge tank, trip the reactor and reactor coolant pumps.

Subsequent actions include:

- a. If level is lost in only half of the surge tank, separate the system and run the system on one "train".
 - b. (Slide 4) determine the source of leakage and isolate.
- C. Emergency Operation is considered to be during a LOCA and Post LOCA conditions.
- I. During a LOCA (Slide 5) a safety injection signal starts all three CCW pumps to protect against a single active failure. Also, during a safety injection signal a Phase A containment isolation signal is generated which isolates most process lines in and out of containment which will significantly reduce the normal heat loads.

If a Phase B containment isolation signal is generated (as during most large LOCA's and certainly during the design basis LOCA) the miscellaneous header 'C' supply, Reactor Coolant Pumps, and vessel support pad coolers are isolated.

Operators are required, during a LOCA condition (EP OP-0), to verify the above conditions occur and manually back them up if necessary.

2. Post LOCA conditions (Slide 6) require the safeguards systems to be separated into redundant trains to prevent loss of the entire system in the event of a single passive failure. This procedure specifically states when this must be done and the valve lineups required.

Basically, both heat exchangers are in service (one supplying each vital header), one pump is aligned to one vital header and the other pump(s) are aligned to the other vital header (and/or header C as necessary).

If a failure has occurred on header C (Slide 7) the loop will be manually valved out of the system to maintain the integrity of the vital loops A and B.


REFERENCE

1. Plant Manual, Volume 2 (Operating Procedures), OP-F2 CCW System.
2. Plant Manual, Volume 3 (Emergency Operating Procedures) EP-OP-11 Loss of Component Cooling Water.
3. Plant Manual, Volume 3 (Emergency Operating Procedures) EP-OP-0 and EP-OP-1 Safety Injection and LOCA.
4. Plant Manual, Volume 11 (Annunciator Response Manual), Annunciator windows PK 01-06, -07, -08, -09 (Various alarms associated with CCW system).
5. Diablo Canyon Power Plant Piping and Instrumentation Drawings 102014: CCW System.


LIST OF SLIDES USED
IN JIM TINLIN'S PRESENTATION

- Slide 1: CCW System Normal Operation
- Slide 2: CCW System Normal Operation During Cooldown
- Slide 3: CCW System Abnormal Operation
- Slide 4: Typical Component Isolation Arrangement
- Slide 5: CCW System Safety Injection ("S" Signal)
- Slide 6: CCW System Recirculation Post-LOCA (with "C" Header)
- Slide 7: CCW System Recirculation Post-LOCA (without "C" Header)


CCW SYSTEM NORMAL OPERATION



CCW SYSTEM NORMAL OPERATION DURING COOLDOWN




CCW SYSTEM ABNORMAL OPERATION




NOTE: 1. 1-1, 1-2, 1-3

TYPICAL COMPONENT ISOLATION ARRANGEMENT




ALL PIPING AND ISOLATION VALVES ARE CLASS I

CCW SYSTEM SAFETY INJECTION ("S" SIGNAL)



CCW SYSTEM RECIRCULATION POST-LOCA (WITH "C" HEADER)



CCW SYSTEM RECIRCULATION POST-LOCA (WITHOUT "C" HEADER)

