



Pennsylvania Power & Light Company

Two North Ninth Street • Allentown, PA 18101 • 215 / 770-5151

February 2, 1983

Mr. R.C. Haynes  
Director, Region I  
U.S. Nuclear Regulatory Commission  
631 Park Avenue  
King of Prussia, PA 19406

SUSQUEHANNA STEAM ELECTRIC STATION  
LICENSEE EVENT REPORT 83-002/01T-0  
ER 100450 FILE 841-23  
PLA- 1511

Docket No. 50-387  
License No. NPF-14

Dear Mr. Haynes:

Attached please find a copy of Licensee Event Report No. 83-002/01T-0. This event was determined to be reportable per Technical Specification 6.9.1.8.f, in that the monthly channel function test of the Main Steam Isolation Valve closure position switches was not performed.

H.W. Keiser  
Superintendent of Plant-Susquehanna

DGM/cg

cc: Director of Nuclear Reactor Regulation  
Attention: Mr. A. Schwencer, Chief  
Licensing Branch No. 2  
Division of Licensing  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555

G. Rhoads  
Resident Inspector  
U.S. Nuclear Regulatory Commission  
P.O. Box 52  
Shickshinny, PA 18655

8302230289 830202  
PDR ADOCK 05000387  
S PDR

IE22