

Docket No. 50-245

FEB 10 1983

Northeast Nuclear Energy Company
ATTN: Mr. W. G. Council
Senior Vice President - Nuclear
Engineering and Operations Group
P. O. Box 270
Hartford, Connecticut 06101

Gentlemen:

Subject: Inspection No. 50-245/81-13

This refers to your letter dated January 12, 1983, in response to our letter dated October 1, 1981.

Thank you for informing us of the corrective and preventive actions documented in your letter. These actions will be examined during a future inspection of your licensed program.

Your letter indicates that calculation and documentation of the average control rod insertion times are an optional practice for information. As we indicated in our original correspondence, these activities are required to demonstrate compliance with Technical Specification 3.3.C.

Your cooperation with us is appreciated.

Sincerely,

ORIGINAL SIGNED BY *Lee Bettenhausen*

for Thomas T. Martin, Director
Division of Engineering and
Technical Programs

cc:
J. F. Opeka, Vice President, Nuclear Operations
E. J. Mroczka, Station Superintendent
D. G. Diedrick, Manager of Quality Assurance
R. T. Laudenat, Manager, Generation Facilities Licensing
Public Document Room (PDR)
Local Public Document Room (LPDR)
Nuclear Safety Information Center (NSIC)
NRC Resident Inspector
State of Connecticut

bcc:
Region I Docket Room (with concurrences)
DPRP Section Chief

8302230522 830210
PDR ADOCK 05000245
Q PDR

1E01

OFFICE	DET P	DET P	DPRP <i>et</i>	DET P <i>et</i>			
SURNAME	Chung	Norrholm	Greenman	Bettenhausen			
DATE	<i>we 2/1/83</i>	<i>2/8/83</i>	<i>2/3/83</i>	<i>2/1/83</i>			