

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | N Y R E G I | 2 | 0 0 - 0 0 0 0 0 - 0 0 | 3 | 4 1 1 1 1 | 4 | _____ | 5 |
7 8 9 14 15 25 26 30 57 CAT 58

CON'T
01 | L | 6 | 0 5 0 0 0 2 4 4 | 7 | 0 1 1 4 8 3 | 8 | 0 2 1 1 8 3 | 9 |
7 8 60 61 68 69 74 75 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 | During the performance of PT-3, Containment Spray System, check valve 862B failed |
03 | to close promptly. As per the revised test criteria, a leakage test was performed |
04 | per PT-23.23 and the valve failed this test. The valve was declared inoperable |
05 | which is a limiting condition for operation based on Tech. Spec. 3.6.3.1. |
06 | _____ |
07 | _____ |
08 | _____ |

09 | S A | 11 | E | 12 | C | 13 | V A L V E X | 14 | C | 15 | A | 16 |
9 10 11 12 13 18 19 20

17 | LER/RO REPORT NUMBER | 8 3 | 0 0 4 | 0 3 | L | 0 |
21 22 23 24 26 27 28 29 30 31 32

ACTION TAKEN | FUTURE ACTION | EFFECT ON PLANT | SHUTDOWN METHOD | HOURS | ATTACHMENT SUBMITTED | NPRD-4 FORM SUB. | PRIME COMP. SUPPLIER | COMPONENT MANUFACTURER
B | 18 | Z | 19 | Z | 20 | Z | 21 | 0 0 0 0 | 22 | N | 23 | N | 24 | N | 25 | A Z O O | 26
33 34 35 36 37 40 41 42 43 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 | Maintenance performed on check valve 862B and the valve was retested satisfactory. |
11 | As a result of this test, a revised test method was developed which will demonstrate |
12 | valve operability more effectively. |
13 | _____ |
14 | _____ |

15 | E | 28 | 1 0 0 | 29 | NA | 30 | B | 31 | Periodic Test | 32 |
7 8 9 10 12 13 44 45 46 80

16 | Z | 33 | Z | 34 | NA | 35 | NA | 36 |
7 8 9 10 11 44 45 80

17 | 0 0 0 | 37 | Z | 38 | NA | 39 |
7 8 9 11 12 13 80

18 | 0 0 0 | 40 | NA | 41 |
7 8 9 11 12 80

19 | Z | 42 | NA | 43 |
7 8 9 10 80

20 | N | 44 | NA | 45 |
7 8 9 10 80

8302230674 830211
PDR ADCK 05000244
S PDR

NRC USE ONLY

NAME OF PREPARER J. C. Bodine

PHONE: (315) 524-4446