

March 24, 1994

Docket No. 50-245

Mr. John F. Opeka  
Executive Vice President, Nuclear  
Connecticut Yankee Atomic Power Company  
Northeast Nuclear Energy Company  
Post Office Box 270  
Hartford, Connecticut 06141-0270

Dear Mr. Opeka:

SUBJECT: ISSUANCE OF AMENDMENT (TAC NO. M88547)

The Commission has issued the enclosed Amendment No. 72 to Facility Operating License No. DPR-21 for Millstone Nuclear Power Station, Unit 1, in response to your application dated January 14, 1994.

The amendment corrects an editorial error. Specifically, the amendment changes the reference in Limiting Condition for Operation (LCO) 3.4.D from "3.3.A through C" to "3.4.A, 3.4.B, and 3.4.C." The amendment also changes the associated bases to clarify the LCO minimum solution concentration requirement of 11 weight percent and updates the excerpt from 10 CFR 50.62 to reflect the current text of the regulation. The staff has reviewed the changes to the bases and has no objections to the wording.

A copy of the related Safety Evaluation is also enclosed. The notice of issuance will be included in the Commission's biweekly Federal Register notice.

Sincerely,

Original signed by Dave H. Jaffe

for: James W. Andersen, Acting Project Manager  
Project Directorate I-4  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

9404050020 940324  
PDR ADOCK 05000245  
P PDR

Enclosures:

- 1. Amendment No. 72 to DPR-21
- 2. Safety Evaluation

cc w/enclosures:

See next page  
DISTRIBUTION:

Docket File SNorris ACRS (10)  
NRC & Local PDRs JAndersen OPA  
PDI-4 Plant OGC OC/LFDCB  
SVarga DHagan LDoerflein, RGI  
JCalvo GHill (2)

300089

DF01  
111

OFFICE	LA:PDI-4	PM:PDI-4	D:PDI-4	OGC	
NAME	SNorris	JAndersen	JSteitz	H. Jorgensen	
DATE	3/17/94	3/17/94	3/18/94	3/15/94	1/1

OFFICIAL RECORD COPY

Document Name: G:\ANDERSEN\88547

NRC FILE CENTER COPY

March 24, 1994

Docket No. 50-245

Mr. John F. Opeka  
Executive Vice President, Nuclear  
Connecticut Yankee Atomic Power Company  
Northeast Nuclear Energy Company  
Post Office Box 270  
Hartford, Connecticut 06141-0270

Dear Mr. Opeka:

SUBJECT: ISSUANCE OF AMENDMENT (TAC NO. M88547)

The Commission has issued the enclosed Amendment No. 72 to Facility Operating License No. DPR-21 for Millstone Nuclear Power Station, Unit 1, in response to your application dated January 14, 1994.

The amendment corrects an editorial error. Specifically, the amendment changes the reference in Limiting Condition for Operation (LCO) 3.4.D from "3.3.A through C" to "3.4.A, 3.4.B, and 3.4.C." The amendment also changes the associated bases to clarify the LCO minimum solution concentration requirement of 11 weight percent and updates the excerpt from 10 CFR 50.62 to reflect the current text of the regulation. The staff has reviewed the changes to the bases and has no objections to the wording.

A copy of the related Safety Evaluation is also enclosed. The notice of issuance will be included in the Commission's biweekly Federal Register notice.

Sincerely,

Original signed by Dave H. Jaffe

for: James W. Andersen, Acting Project Manager  
Project Directorate I-4  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Enclosures:

1. Amendment No. 72 to DPR-21
2. Safety Evaluation

cc w/enclosures:

See next page

DISTRIBUTION:

Docket File	SNorris	ACRS (10)
NRC & Local PDRs	JAndersen	OPA
PDI-4 Plant	OGC	OC/LFDCB
SVarga	DHagan	LDoerflein, RGI
JCalvo	GHill (2)	

OFFICE	LA:PDI-4	PM:PDI-4	D:PDI-4	OGC	
NAME	SNorris	JAndersen	JSto	H. Jensen	
DATE	3/17/94	3/17/94	3/18/94	3/15/94	1/1

OFFICIAL RECORD COPY

Document Name: G:\ANDERSEN\88547



UNITED STATES  
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

March 24, 1994

Docket No. 50-245

Mr. John F. Opeka  
Executive Vice President, Nuclear  
Connecticut Yankee Atomic Power Company  
Northeast Nuclear Energy Company  
Post Office Box 270  
Hartford, Connecticut 06141-0270

Dear Mr. Opeka:

SUBJECT: ISSUANCE OF AMENDMENT (TAC NO. M88547)

The Commission has issued the enclosed Amendment No. 72 to Facility Operating License No. DPR-21 for Millstone Nuclear Power Station, Unit 1, in response to your application dated January 14, 1994.

The amendment corrects an editorial error. Specifically, the amendment changes the reference in Limiting Condition for Operation (LCO) 3.4.D from "3.3.A through C" to "3.4.A, 3.4.B, and 3.4.C." The amendment also changes the associated bases to clarify the LCO minimum solution concentration requirement of 11 weight percent and updates the excerpt from 10 CFR 50.62 to reflect the current text of the regulation. The staff has reviewed the changes to the bases and has no objections to the wording.

A copy of the related Safety Evaluation is also enclosed. The notice of issuance will be included in the Commission's biweekly Federal Register notice.

Sincerely,

A handwritten signature in black ink, appearing to read "James W. Anderson".

James W. Anderson, Acting Project Manager  
Project Directorate I-4  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Enclosures:

1. Amendment No. 72 to DPR-21
2. Safety Evaluation

cc w/enclosures:  
See next page

Mr. John F. Opeka  
Northeast Nuclear Energy Company

Millstone Nuclear Power Station  
Unit 1

cc:

Gerald Garfield, Esquire  
Day, Berry and Howard  
Counselors at Law  
City Place  
Hartford, Connecticut 06103-3499

R. M. Kacich, Director  
Nuclear Planning, Licensing & Budgeting  
Northeast Utilities Service Company  
Post Office Box 270  
Hartford, Connecticut 06141-0270

J. P. Stetz, Vice President  
Haddam Neck Plant  
Connecticut Yankee Atomic Power Company  
362 Injun Hollow Road  
East Hampton, Connecticut 06424-3099

J. M. Solymossy, Director  
Nuclear Quality and Assessment Services  
Northeast Utilities Service Company  
Post Office Box 270  
Hartford, Connecticut 06141-0270

Kevin T. A. McCarthy, Director  
Monitoring and Radiation Division  
Department of Environmental Protection  
79 Elm Street  
Hartford, Connecticut 06106-5127

Regional Administrator  
Region I  
U.S. Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, Pennsylvania 19406

Allan Johanson, Assistant Director  
Office of Policy and Management  
Policy Development and Planning Division  
80 Washington Street  
Hartford, Connecticut 06106

First Selectmen  
Town of Waterford  
Hall of Records  
200 Boston Post Road  
Waterford, Connecticut 06385

S. E. Scace, Vice President  
Nuclear Operations Services  
Northeast Utilities Service Company  
Post Office Box 270  
Hartford, Connecticut 06141-0270

P. D. Swetland, Resident Inspector  
Millstone Nuclear Power Station  
c/o U.S. Nuclear Regulatory Commission  
Post Office Box 513  
Niantic, Connecticut 06357

H. F. Haynes, Nuclear Unit Director  
Millstone Unit No. 1  
Northeast Nuclear Energy Company  
Post Office Box 128  
Waterford, Connecticut 06385

Donald B. Miller, Jr.  
Senior Vice President  
Millstone Station  
Northeast Nuclear Energy Company  
Post Office Box 128  
Waterford, Connecticut 06385

Nicholas S. Reynolds  
Winston & Strawn  
1400 L Street, NW  
Washington, DC 20005-3502