



7000 Second Avenue
Detroit, Michigan 48226
(313) 237-8000

July 12, 1982
EF2-57,501

Mr. James Konklin,
Section Chief - Reactor Projects
U. S. Nuclear Regulatory Commission
Region III
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Reference: Enrico Fermi Power Plant - Unit No. 2

Subject: NRC Construction Assessment, June 21 -
July 2, 1982.

Dear Mr. Konklin:

This letter confirms information provided to Mr. K. R. Naidu and you during a meeting at the Fermi 2 Site on July 1, 1982.

In response to concerns expressed by Mr. Naidu regarding the inspection of electrical cable tray and tray support installations, the following actions have been, or are in process of being implemented:

1. A stop work order was initiated for all new installation of safety related cable trays and tray supports.
2. The acceptance criteria used and the results of cable tray and tray support inspection through August, 1978 will be reviewed by Detroit Edison Project Engineering and Project Quality Assurance organizations.
3. Safety Related cable tray hold-down welds installed after August, 1978 will be inspected for compliance with acceptance criteria established by Detroit Edison Engineering.
4. The Electrical Contractor's inspection program for cable tray and tray supports will undergo an in-depth evaluation by Edison Project Quality Assurance. Improvements including those suggested by Mr. Naidu, will be incorporated as appropriate.

8209230183 820916
PDR ADOCK 05000341
Q PDR

JUL 15 1982


James E. Konklin
July 12, 1982
EF2-57,501
Page Two

5. Suggestions made by Mr. Naidu which are inappropriate for incorporation into the Electrical Contractor's inspection program will be addressed by other organizations (e.g., Project Quality Assurance, Project Engineering, etc.).

The stop work order was issued on July 2, 1982 and will remain in effect until items 2, 3, and 4 are accomplished. Items 2, 3, 4, and 5 are currently in process. The total effort includes inspection program modification and redefinition, personnel training and qualification, and closer scrutiny by Project Quality Assurance during implementation.

If additional information regarding this matter is needed, contact our Messrs. T. A. Alessi at (313) 586-5513 or G. M. Trahey at (313) 586-5039.

Sincerely,



W. J. Fahrner, Manager
Enrico Fermi Unit 2 Project

WJF/GMT/gam

cc: Mr. Bruce H. Little, Sr. Resident Inspector
U. S. Nuclear Regulatory Commission
6450 North Dixie Highway
Newport, Michigan 48166