

THE CINCINNATI GAS & ELECTRIC COMPANY



CINCINNATI, OHIO 45201

September 14, 1982

QA-1975

E. A. BORGMANN  
SENIOR VICE PRESIDENT

U. S. Nuclear Regulatory Commission  
Region III  
799 Roosevelt Road  
Glen Ellyn, Illinois 60137

Attention: Mr. J. G. Keppler  
Regional Administrator

RE: WM. H. ZIMMER NUCLEAR POWER STATION UNIT 1  
10CFR50.55(e) - ITEM S-2, LAMINATIONS IN  
STRUCTURAL STEEL - DOCKET NO. 50-358  
CONSTRUCTION PERMIT NO. CPPR-88, W.O. #57300  
JOB E-5590, FILE NO. NRC-9, S-2

Gentlemen:

This letter constitutes a supplementary report to QA-1904 submitted July 28, 1982. On August 10, 1982, CG&E notified the Commission of a lamination identified in a portion of a heat of structural plate. Considering this material was supplied by the same vendor as that which supplied the previously reported 3" x 3" x 1/2" angle, it was determined that the additional discovery required a supplement to our original report.

Three hundred (300) linear feet of A-36, 1/2" x 9" plate, purchased from E. K. Morris Company, manufactured by Bethlehem Steel Corporation, heat #802P54610 was identified on H. J. Kaiser Company Nonconformance Report (NR) #E-8369 as containing an edge lamination. This condition was detected when the plate was being cut in the hanger fabrication shop to be used in safety related supports.

H. J. Kaiser Company will ultrasonically test all material in the warehouse and fabrication shop to determine the extent of this problem and the acceptability of any installed material. This is expected to be completed by October 31, 1982, at which time a final report will be submitted.

*Handwritten signature/initials*

*TE27*

8209230238 820914  
PDR ADOCK 05000353  
S PDR

SEP 17 1982

Mr. J. G. Keppler  
U. S. Nuclear Regulatory Commission  
Region III  
September 14, 1982 - QA-1975  
Page 2

With regard to our responding within thirty (30) days of the August 10, 1982 supplementary notification date, a request to extend the response date to September 15, 1982 was granted in a September 9, 1982 telephone conversation between Mr. E. R. Schweibinz of the NRC and Mr. F. K. Pfeifer of CG&E.

We trust the above will be found acceptable as a supplementary report under 10CFR50.55(e).

Very truly yours,

THE CINCINNATI GAS & ELECTRIC COMPANY

By



E. A. BORGMANN  
SENIOR VICE PRESIDENT

FKP:plc

cc: NRC Office of Inspection & Enforcement  
Washington, D.C. 20555  
NRC Senior Resident Inspector  
Attn: W. F. Christianson  
Zimmer Project Inspector  
Region III