



ENTERGY

Entergy Operations, Inc.
P.O. Box 756
Port Gibson, MS 39150
Tel 601 437 2800

March 31, 1994

C. R. Hutchinson
Vice President
Operations
Grand Gulf Nuclear Station

U.S. Nuclear Regulatory Commission
Mail Station P1-137
Washington, D.C. 20555

Attention: Document Control Desk

Subject: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
1993 Grand Gulf Nuclear Station (GGNS)
Annual Radioactive Effluent Release
Report (ARERR)

GNRO-94/00051

Gentlemen:

Attached is the Grand Gulf Nuclear Station (GGNS) Annual Radioactive Effluent Release Report (ARERR). This report covers the period from July 1, 1993 through December 31, 1993. Amendment No. 111 to the GGNS Operating License modified the reporting frequency for this report from semiannual to annually (Reference: GNRI-94/00004, dated January 10, 1994). Data for the first six-months of 1993 were previously submitted via our letter dated August 26, 1993 (GNRO-94/00105).

This report is submitted in accordance with the requirements of 10 CFR50.36.(a)(2) and the GGNS Technical Specifications 6.9.1.8, 6.9.1.9, and 6.14. This report also complies with the GGNS Offsite Dose Calculation Manual (ODCM).

9404050158 931231
PDR ADOCK 05000416
R PDR

050000


G9403301

IFAS
111

March 31, 1994
GNRO-94/00051
Page 2 of 3

If you have any questions or require additional information concerning this report, please contact Jewel Summers at (601) 437-2149, or this office.

Yours truly,



CRH/JS/amb

attachment: 1993 Annual Radioactive Effluent
Release Report

cc: Mr. R. H. Bernhard (w/a)
Mr. H. w. Keiser (w/a)
Mr. R. B. McGehee (w/a)
Mr. N. S. Reynolds (w/a)
Mr. H. L. Thomas (w/o)

Mr. Stewart D. Ebnetter (w/a)
Regional Administrator
U.S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 2900
Atlanta, Georgia 30323

Mr. P. W. O'Connor, Project Manager (w/2)
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Mail Stop 13H3
Washington, D.C. 20555

Grand Gulf Nuclear Station
ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT
January 1 - December 31, 1993

Prepared By: JM. Lassetter 13-15-94
Reviewed By: DH Croney 13-16-94
Approved By: DE Jackson 13-17-94

TABLE OF CONTENTS

<u>SUBJECT</u>	<u>PAGE</u>
I. INTRODUCTION.....	1
II. DETAILED INFORMATION.....	2
A. Regulatory Limits.....	2
1. 10CFR20 Limits	
a. Fission and Activation Gases.....	2
b. Radioiodines and Particulates.....	2
c. Liquid Effluents.....	2
2. 10CFR50, Appendix I Limits	
a. Fission and Activation Gases.....	2
b. Radioiodines and Particulates.....	3
c. Liquid Effluents.....	3
3. 40CFR190 Limits.....	3
B. Maximum Permissible Concentrations.....	3
1. Airborne.....	3
2. Liquid.....	3
C. Average Energy.....	4
D. Measurements and Approximations of Total Activity.....	4
1. For Fission and Activation Gases.....	4
2. For Particulates and Radioiodines.....	5
3. For Continuous Releases.....	5
4. For Batch Releases: Gases.....	5
5. For Batch Releases: Liquid Effluents.....	5
E. Batch Releases.....	6
1. Liquid.....	6
2. Gaseous.....	6
F. Unplanned Releases.....	6
1. Liquid.....	6
2. Gaseous.....	6
G. Estimate of Total Error.....	6
1. Liquid.....	6
2. Gaseous.....	7
3. Solid Radioactive Waste.....	7
H. Solid Radioactive Waste Shipments.....	7
I. Meteorological Data.....	7
J. Radioactive Effluent Monitoring Instrumentation Operability.....	7
K. Annual Sewage Disposal Summary.....	7

TABLE OF CONTENTS (Continued)

III. RADIATION DOSE SUMMARY	8
A. Water-Related Exposure Pathways	8
B. Airborne-Related Exposure Pathways	8
IV. OFFSITE DOSE CALCULATION MANUAL/RADIOACTIVE WASTE TREATMENT SYSTEM CHANGES.....	9
A. Offsite Dose Calculation Manual (ODCM).....	9
B. Radioactive Waste Treatment Systems.....	9

LIST OF TABLES

<u>TABLE</u>	<u>PAGE</u>
1A Gaseous Effluents - Summation of All Releases.....	10
1B Gaseous Effluents - Elevated Releases.....	11
1C Gaseous Effluents - Ground-Level Releases.....	12
1D Radioactive Gaseous Waste Sampling and Analysis Program....	13
2A Liquid Effluents - Summation of All Releases.....	15
2B Liquid Effluents - Continuous and Batch Modes.....	16
2C Radioactive Liquid Waste Sampling and Analysis Program.....	17
3 Solid Radioactive Waste and Irradiated Fuel Shipments.....	18
4A Meteorological Data - July - September, 1993	20-36
4B Meteorological Data - October - December, 1993 ...	37-53
4C Meteorological Data Summary (January-December).....	54-70
4D Classification of Atmospheric Stability.....	71

LIST OF ATTACHMENTS

None

I. INTRODUCTION

This Radioactive Effluent Release Report for the period of July 1 through December 31, 1993 is submitted in accordance with Section 6.9.1.8 of Appendix A to Grand Gulf Nuclear Station (GGNS) License No. NPF-29. Data for the previous six month period (January - June, 1993) was submitted as the first semiannual report of 1993. Future submittals will be on an annual basis. The monitoring of radioactive effluents is referenced in Appendix A, Sections 3/4.11 and 3/4.12 and the Offsite Dose Calculation Manual (ODCM).

Airborne discharges at GGNS are considered ground-level releases. All liquid and airborne discharges to the environment were analyzed in accordance with ODCM requirements. All effluent releases were within the concentration and total release limits specified by the ODCM.

Projected offsite doses were within the dose limits specified by the ODCM.

The summation of all gaseous releases during the reporting period is given in Table 1A, while elevated releases and ground-level releases are given in Tables 1B and 1C, respectively. Table 1D describes the radioactive gaseous sampling and analysis program implemented at GGNS.

The summation of all liquid releases during the reporting period is given in Table 2A, while continuous and batch mode releases are given in Table 2B. Table 2C describes the radioactive liquid waste sampling and analysis program implemented at GGNS.

Solid radioactive waste and irradiated fuel shipments during the reporting period are summarized in Table 3. Meteorological data is included in Tables 4A - 4C. Table 4D presents atmospheric stability classifications.

II. DETAILED INFORMATION

A. Regulatory Limits

1. 10CFR20 Limits

- a. Fission and Activation Gases - The release rate limit at any time for noble gases to areas at or beyond the site boundary shall be such that:

$$D_{tb} = \text{average total body dose rate in the current year (mrem/yr)} \\ = \overline{X/Q} \sum K_i Q'_i \leq 500 \text{ mrem/yr}$$

$$D_s = \text{average skin dose rate in the current year (mrem/yr)} \\ = \overline{X/Q} \sum (L_i + 1.1 M_i) Q'_i \leq 3000 \text{ mrem/yr}$$

where the terms are defined in the GGNS ODCM.

- b. Radioiodines and Particulates - The release rate limit for the sampling period for all radioiodines, tritium and radioactive materials in particulate form with half-lives greater than 8 days shall be such that:

$$D_o = \text{average organ dose rate in current year (mrem/yr)} \\ = \sum_i W P_i \overline{Q'_i} \leq 1500 \text{ mrem/yr}$$

where the terms are defined in the GGNS ODCM.

- c. Liquid Effluents - The concentration of radioactive materials released in liquid effluents to unrestricted areas from the reactors at the site shall not exceed at any time the values specified in 10CFR20, Appendix B, Table II, Column 2. The concentration of dissolved or entrained noble gases, released in liquid effluents to unrestricted areas from all reactors at the site, shall be limited to 2×10^{-4} microcuries/ml total activity.

Note: Revised 10 CFR, Part 20 was implemented in January, 1994.

2. 10CFR50, Appendix I Limits

- a. Fission and Activation Gases - The dose from noble gases in gaseous effluents to areas at or beyond the site boundary shall be such that:

$$D_\gamma = \text{air dose due to gamma emissions from noble gases} \\ = 3.17 \times 10^{-8} \sum_i M_i \overline{X/Q'} Q_i \leq 5 \text{ mrad/qtr} \\ \leq 10 \text{ mrad/yr}$$

$$D_\beta = \text{air dose due to beta emissions from noble gas} \\ = 3.17 \times 10^{-8} \sum_i N_i \overline{X/Q'} Q_i \leq 10 \text{ mrad/qtr} \\ \leq 20 \text{ mrad/yr}$$

where the terms are defined in the GGNS ODCM.

- b. Radioiodines and Particulates - The dose to an individual from tritium, I-131, I-133 and radioactive material in particulate form with half-lives greater than 8 days in gaseous effluents shall be such that:

D = dose to an individual from tritium, I-131, I-133 and radionuclides in particulate form with half-lives greater than 8 days (mrem)

$$= 3.17 \times 10^{-8} \sum_i R_i W_i Q_i \leq 7.5 \text{ mrem/qr Any Organ}$$

$$\leq 15 \text{ mrem/yr Any Organ}$$

where the terms are defined in the GGNS ODCM.

- c. Liquid Effluents - The dose from radioactive materials in liquid effluents shall be such that:

$$D_{\text{Tau}} = \sum_i [A_{i\text{Tau}} \sum_{l=1}^m \Delta t_l C_{il} F_l] \leq 1.5 \text{ mrem/qr Total Body}$$

$$\leq 5 \text{ mrem/qr Any Organ}$$

$$\leq 3 \text{ mrem/yr Total Body}$$

$$\leq 10 \text{ mrem/yr Any Organ}$$

where the terms are defined in the GGNS ODCM.

3. 40CFR190 Limits

Doses are calculated for Fission and Activation Gases; Radioiodines and Particulates; and Liquid Effluents according to equations contained in Sections 2.(a), (b), and (c) respectively, with the exception that the limits applied are:

≤25 mrem/yr, Total Body or any Organ except Thyroid

≤75 mrem/yr, Thyroid

≤10 mrad γ/qr or ≤20 mrad γ/yr, Fission and Activation Gases

≤20 mrad β/qr or ≤40 mrad β/yr, Fission and Activation Gases

≤15 mrem/qr or ≤30 mrem/yr, any Organ, Iodine and Particulates

≤3 mrem/qr or ≤6 mrem/yr, Total Body, Liquid Effluents

≤10 mrem/qr or ≤20 mrem/yr, any Organ, Liquid Effluents

B. Maximum Permissible Concentrations

1. Airborne

The Maximum Permissible Concentration (MPC) of radioactive materials in gaseous effluents is limited by the dose rate restrictions of 10CFR20. In this case, the MPCs are actually determined by the dose factors in Table 2.1-1 of the GGNS ODCM.

2. Liquid

The MPC of radioactive materials in liquid effluents is limited by 10CFR20, Appendix B, Table II, Column 2. The MPC chosen is the most conservative value of either the soluble or insoluble MPC for each radioisotope.

C. Average Energy

Not applicable for GGNS ODCM Appendix A.

D. Measurements and Approximations of Total Activity

The following discussion details the methods used to measure and approximate total activity for the following:

1. Fission and Activation Gases
2. Radioiodines
3. Particulates
4. Liquid Effluents

Tables 1D and 2C give sampling frequencies and minimum detectable sensitivity requirements for the analysis of gaseous and liquid effluent streams, respectively.

Values in the attached tables given as zero do not necessarily imply that the radionuclides were not present. A zero indicates that the radionuclide was not present at levels greater than the sensitivity requirements shown in Tables 1D and 2C. For some radionuclides, lower detection limits than required may be readily achievable; when a radionuclide is measured below its stated detection limits, it is reported.

1. For Fission and Activation Gases

The following noble gases are considered in evaluating gaseous airborne discharges:

Ar-41	Xe-131m
Kr-85m	Xe-133
Kr-85	Xe-133m
Kr-87	Xe-135m
Kr-88	Xe-135
Kr-89	Xe-138

Periodic grab samples from Station effluent streams are analyzed by a computerized pulse height analyzer system utilizing high-resolution germanium detectors. (See Table 1D for sampling and analytical requirements.) Isotopic values thus obtained are used for dose release rate calculations due to effluent releases as given in Section II.A.1. of this report. Only those radionuclides that are detected are used in this computation. During the period between grab samples, the amount of radioactivity released is based on the effluent monitor readings. Monitors are assigned a calibration factor based upon the last isotopic analysis, using the following relationship:

$$C_i = U_i + m$$

where

C_i = isotopic calibration factor for isotope i

U_i = concentration of isotope i in the grab sample in $\mu\text{Ci/ml}$.

m = net monitor reading associated with the effluent stream (determined at the time of grab sampling).

These calibration factors, along with the hourly effluent monitor values and flow rates, are entered into the laboratory computer where the release rates for individual radionuclides are calculated and stored. If no activity is detected in the grab sample, the calibration factor defaults to a historical mixture of Kr-88, Xe-133, Xe-135m, Xe-135, and Xe-138.

2. For Particulates and Radioiodines

The radioiodines and radioactive materials in particulate form to be considered are:

Zn-65	I-133
Cr-51	Cs-134
Mn-54	Cs-136
Fe-59	Cs-137
Co-58	Ba-140
Co-60	Ce-141
Sr-89	Ce-144
Sr-90	Other radionuclides
Zr-95	with half-lives
Sb-124	greater than
I-131	8 days.

3. For Continuous Releases

Continuous sampling is performed on the continuous release points (i.e., Radwaste Vent, Containment Purge, Fuel Handling Area Vent, Turbine Building Vent). Particulate material is collected by filtration. Radioiodines are collected by adsorption onto a charcoal filter. Periodically these filters are removed and analyzed on the pulse height analyzer to identify and quantify radioactive materials collected on the filters. Particulate filters are then analyzed for gross alpha and Strontium-89 and -90 as required. Gross alpha determinations are made using a 2-pi gas flow proportional counter. Strontium-89 and -90 values are obtained by chemical separation and subsequent analysis using 2-pi gas flow proportional counters. Tritium concentrations are determined using liquid scintillation techniques. During major operational occurrences, the frequency of sampling is increased to satisfy the requirements of footnote "c" of Table 1D, "Radioactive Gaseous Waste Sampling and Analysis," (GGNS ODCM Appendix A, Table 4.11.2.1.2-1).

4. For Batch Releases: Gases

The processing of batch type releases (from Containment Purge) is analogous to that for continuous releases.

5. For Batch Releases: Liquid Effluents

The radionuclides listed below are considered when evaluating liquid effluents:

H-3	Mo-99
Co-58	Tc-99m
Co-60	I-131
Fe-55	I-132
Fe-59	I-133
Zn-65	I-135
Mn-54	Cs-134
Cr-51	Cs-137
Sr-89	Ba-140
Sr-90	La-140
Nb-95	Ce-141
Zr-95	Ce-144

Representative pre-release grab samples are obtained and analyzed as required by Table 2C. Isotopic analyses are performed using the computerized pulse height analysis system previously described. Aliquots of each pre-released sample, proportional to the waste volume released, are composited in accordance with the requirements of Table 2C. Strontium determinations are made by performing a chemical separation and counting the separated strontium using a 2-pi gas flow proportional counter. Gross alpha determinations are made using 2-pi gas flow proportional counters. Tritium and Iron-55 concentrations are determined by using liquid scintillation techniques. Dissolved gases are determined employing grab sampling techniques and then counting on the pulse height analyzer system.

E. Batch Releases

1. Liquid Batch Releases

	1st <u>Qtr</u>	2nd <u>Qtr</u>	3rd <u>Qtr</u>	4th <u>Qtr</u>	1993 <u>Total</u>
a. Number of releases	29	66	86	82	263
<u>Time Period</u> (in minutes)					
b. Total for all batches	8548	20372	26029	23427	78376
c. Max time for a batch	430	424	415	440	440
d. Avg time for a batch	295	309	303	286	298
e. Min time for a batch	190	255	151	2	2

2. Gaseous

No batch releases were made during report period.

F. Unplanned Releases

1. Liquid

No unplanned liquid release occurred during report period.

2. Gaseous

Releases via the Turbine Building Roof hatches occurred in May, June, July and December 1993. These releases were evaluated and resulting dose and radioactivity contribution have been included in the site totals as part of the Turbine Building release.

G. Estimate of Total Error

1. Liquid

The maximum errors are collectively estimated to be

	Fission & Activation <u>Products</u>	<u>Tritium</u>	Dissolved & Entrained <u>Gases</u>	Gross <u>Alpha</u>
Sampling	26%	26%	26%	26%
Measurement	68%	65%	61%	92%
Total	73%	70%	66%	95%

Sampling errors include uncertainty associated with mixing, representative sampling and discharge volume. Measurement errors include uncertainty associated with instrument calibration and the preparation and counting of low-activity samples. Counting errors are based on measurements of blank samples and, for germanium detectors, the least-readily-detectable radioisotope. Calibration errors are calculated by summing the errors associated with the calibration of a particular instrument with a radioactive source.

Total error is calculated by taking the square root of the sum of the squares of the individual errors.

2. Gaseous

The maximum errors (not including sample line loss) are collectively estimated to be

	Fission & Activation Gases	Iodine	Particulate	Alpha	Gross Tritium
Sampling	32%	23%	22%	22%	23%
Measurement	61%	67%	65%	101%	62%
Total	69%	71%	69%	103%	66%

Sampling errors include uncertainty associated with sample flow, vent flow and monitor calibration.

Measurement errors include uncertainty associated with instrument calibration and preparation and counting of low-activity samples. Measurement and total errors are calculated by the same methods used for liquid effluents.

3. Solid Radioactive Waste

See Table 3 for error terms.

H. Solid Radioactive Waste Shipments

See Table 3 for shipment information.

I. Meteorological Data

1. Meteorological Data Recovery Rate (1993)

Parameter	% Data Recovery				
	1st Qtr	2nd Qtr	3rd Qtr	4th Qtr	Average
50m Wind Direction	98.56	88.97	96.87	94.57	94.74
50m Wind Speed	98.56	88.97	96.87	94.57	94.74
10m Wind Direction	98.56	88.97	96.87	94.57	94.74
10m Wind Speed	98.56	88.97	96.87	94.57	94.74
Temperature	98.56	88.97	96.87	94.57	94.74
Dew Point	98.52	88.97	96.87	94.57	94.73
Delta T	98.56	88.97	96.87	94.52	94.73
Precipitation	98.56	95.92	96.92	94.57	96.48

2. Meteorological data for the period of the report is included in Tables 4A through 4C.

J. Radioactive Effluent Monitoring Instrumentation Operability

No reportable instances of inoperability occurred during the report period.

K. Annual Sewage Disposal Summary

There was no sewage disposal in 1993.

III. RADIATION DOSE SUMMARY

Indicated below is the annual summary of offsite doses attributable to GGNS during 1993. Inspection of the values indicate that GGNS releases were within the 10CFR50, Appendix I design objectives.

Since there are no other fuel cycle facilities within 8 km of GGNS, 40CFR190 limits have also been met during this period.

All parameters listed were calculated in accordance with the GGNS ODCM.

A. Water-Related Exposure Pathways

The values calculated in this section utilize the information provided in Tables 2A and 2B of this report and the calculational methodology of the ODCM.

Liquid Effluents

Total body dose and critical organ doses are computed for the maximum exposed individual. The maximum dose contribution from liquid effluents is considered to occur in the adult age group via consumption of fish.

1993 Liquid Effluent Dose (mrem)

	<u>1st Qtr</u>	<u>2nd Qtr</u>	<u>3rd Qtr</u>	<u>4th Qtr</u>	<u>Total</u>
Whole Body	1.24E-03	1.23E-02	6.97E-02	7.27E-02	1.56E-01
Bone	2.95E-03	1.26E-02	5.62E-02	1.04E-01	1.76E-01
Liver	3.24E-03	1.96E-02	1.02E-01	1.01E-01	2.26E-01
Thyroid	3.71E-04	1.37E-03	1.83E-03	1.37E-03	4.94E-03
Kidney	5.54E-04	5.95E-03	3.42E-02	3.03E-02	7.10E-02
Lung	1.53E-03	4.90E-03	1.24E-02	1.15E-02	3.04E-02
GI-LLI	6.31E-03	1.49E-02	3.76E-02	1.62E-01	2.21E-01

B. Airborne-Related Exposure Pathways

The values presented in this section utilize information provided in Tables 1A and 1C of this report and the calculational methodology of the ODCM. Doses and dose rates are computed for locations at the site boundary or at unrestricted areas within the site boundary. The use of unrestricted areas within the site boundary as controlling receptor locations provides assurance that offsite doses will not be substantially underestimated, as well as determining the radiation dose from gaseous effluents to members of the public due to their activities inside the site boundary.

Particulate, Radioiodine and Tritium

Organ doses from exposure to radioiodines, tritium and particulates are computed for an individual located in the south sector at a distance of 0.5 miles. This location corresponds to one of the two onsite GGNS gardens. Pathways considered in the dose calculations are inhalation, ground plane, grass/cow/milk, grass/cow/meat and vegetation. For a particular radionuclide, the maximum dose factor obtainable from a combination of age groups and organs is used in the calculation of organ dose.

Noble Gases

Gamma and beta air dose and individual total body and skin dose rates from exposure to a semi-infinite cloud of noble gas are computed for a location in the west-northwest sector at a distance of 0.75 miles. This controlling location corresponds to the highest annual average atmospheric dispersion for an unrestricted area inside the site boundary (Hamilton Lake). The total body and skin doses reported below are derived from the quarterly average of the maximum instantaneous dose rates determined daily during the reporting period and would represent the maximum possible dose received by members of the public onsite.

Direct Radiation

Direct radiation dose is calculated by subtracting average doses measured by thermoluminescent dosimeter (TLD) badges located at control locations from average doses measured by TLD badges located near the site boundary.

1993 Airborne Effluent Dose (mrem)

	<u>1st Qtr</u>	<u>2nd Qtr</u>	<u>3rd Qtr</u>	<u>4th Qtr</u>	<u>TOTAL</u>
Iodine, Tritium & Particulates	8.09E-3	8.07E-3	2.22E-1	4.08E-3	2.4E-1
Fission and Activation Gases (Total Body dose)	4.93E-3	6.02E-3	1.82E-1	5.46E-2	2.5E-1
(Skin dose)	9.25E-3	1.15E-2	3.23E-1	1.04E-1	4.5E-1
Gamma Air dose*	8.71E-4	1.46E-3	1.38E-2	5.04E-3	2.1E-2
Beta Air dose*	8.80E-4	1.58E-3	1.53E-2	5.44E-3	2.3E-2
Direct Radiation	0	0	0	0	0

*Measurement units are mrad

IV. OFFSITE DOSE CALCULATION MANUAL/RADIOACTIVE WASTE TREATMENT SYSTEM CHANGES

A. Offsite Dose Calculation Manual (ODCM)

No changes were made to ODCM during the report period.

B. Radioactive Waste Treatment Systems

No major changes were made during the report period.

TABLE 1A

EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT 1993

GASEOUS EFFLUENTS-SUMMATION OF ALL RELEASES

JULY - DECEMBER 1993

	Unit	Quarter 3	Quarter 4	Est Total
Grand Gulf Nuclear Station UNIT 1				Error %
A. Fission & Activation Gases				
1. Total release	Ci	6.29E+01	2.17E+01	6.90E+01
2. Average release rate for period	uCi/sec	7.99E+00	2.76E+00	
3. % of Technical specification limit	%	2.76E-01	1.01E-01	
B. Iodines				
1. Total iodine-131	Ci	4.62E-04	3.36E-06	7.10E+01
2. Average release rate for period	uCi/sec	5.87E-05	4.27E-07	
3. % of Technical specification limit	%	2.31E-02	1.68E-04	
C. Particulates				
1. Particulates with half-lives > 8 days	Ci	3.90E-05	2.73E-05	6.90E+01
2. Average release rate for period	uCi/sec	4.96E-06	3.47E-06	
3. % of Technical specification limit	%	1.21E-02	3.88E-03	
4. Gross alpha radioactivity	Ci	0.00E+00	2.38E-08	
D. Tritium				
1. Total release	Ci	6.63E+00	2.48E+00	6.60E+01
2. Average release rate for period	uCi/sec	8.43E-01	3.15E-01	
3. % of Technical specification limit	%	7.87E-02	2.95E-02	
E. Tritium, radioiodines and particulates				
1. % of Technical specification limit	%	9.08E-02	3.33E-02	

TBL1A

TABLE 1B

GRAND GULF NUCLEAR STATION

GASEOUS EFFLUENTS - ELEVATED RELEASES

(Not Applicable - GGNS releases are considered ground level)

TBL1B

TABLE 1C

Grand Gulf Nuclear Station UNIT 1

JULY - DECEMBER 1993

EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT 1993

GASEOUS EFFLUENTS-GROUND-LEVEL RELEASE

Nuclides Released	Unit	CONTINUOUS MODE		BATCH MODE	
		Quarter 3	Quarter 4	Quarter 3	Quarter 4
1. Fission gases					
XE-133	Ci	3.14E+01	1.01E+01	0.00E+00	0.00E+00
KR-88	Ci	2.01E+00	4.33E-01	0.00E+00	0.00E+00
XE-135	Ci	2.16E+01	9.70E+00	0.00E+00	0.00E+00
XE-138	Ci	2.73E-02	2.60E-01	0.00E+00	0.00E+00
XE-135M	Ci	1.20E-01	1.14E+00	0.00E+00	0.00E+00
KR-85M	Ci	4.82E+00	0.00E+00	0.00E+00	0.00E+00
XE-131M	Ci	2.25E+00	0.00E+00	0.00E+00	0.00E+00
AR-41	Ci	6.06E-01	0.00E+00	0.00E+00	0.00E+00
Total for period	Ci	6.29E+01	2.17E+01	0.00E+00	0.00E+00
2. Iodines					
I-131	Ci	4.60E-04	3.36E-06	0.00E+00	0.00E+00
I-132	Ci	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-133	Ci	1.48E-04	7.79E-07	0.00E+00	0.00E+00
I-134	Ci	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-135	Ci	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Total for period	Ci	6.09E-04	4.14E-06	0.00E+00	0.00E+00
3. Particulates					
H-3	Ci	6.63E+00	2.48E+00	0.00E+00	0.00E+00
Sr-89	Ci	1.32E-06	1.08E-06	0.00E+00	0.00E+00
Sr-90	Ci	5.80E-08	0.00E+00	0.00E+00	0.00E+00
CO-60	Ci	1.37E-05	1.80E-05	0.00E+00	0.00E+00
MN-54	Ci	1.39E-05	8.03E-06	0.00E+00	0.00E+00
I-133	Ci	2.71E-06	0.00E+00	0.00E+00	0.00E+00
Ba-140	Ci	4.53E-08	0.00E+00	0.00E+00	0.00E+00
I-131	Ci	1.31E-06	0.00E+00	0.00E+00	0.00E+00
CO-58	Ci	1.40E-06	2.37E-07	0.00E+00	0.00E+00
CR-51	Ci	4.53E-06	0.00E+00	0.00E+00	0.00E+00
Total for period	Ci	6.63E+00	2.48E+00	0.00E+00	0.00E+00

TBL1C

TABLE 1D

Grand Gulf Nuclear Station

RADIOACTIVE GASEOUS WASTE SAMPLING AND ANALYSIS PROGRAM

	Gaseous Release Type	Sampling Frequency	Minimum Analysis Frequency	Type of Activity Analysis	Lower Limit of Detection Required ^a (LLD) ($\mu\text{Ci/ml}$)	
A.	(1) Radwaste Building Ventilation Exhaust	M Grab Sample	M	Principal Gamma Emitters ^{b,e}	1E-04	
				H-3	1E-06	
	(2) Fuel Handling Area Ventilation Exhaust	Continuous ^d	W ^c Charcoal Sample	I-131	1E-12	
				I-133	1E-10	
(3)	Containment Ventilation Exhaust	Continuous ^d	W ^c Particulate Sample	Principal Gamma Emitters ^e (I-131, Others)	1E-11	
(4)	Turbine Building Ventilation Exhaust	Continuous ^d	M Composite Particulate Sample	Gross Alpha	1E-11	
				Q Composite Particulate Sample	Sr-89, Sr-90	1E-11
					Noble Gas Monitor	Noble Gases Gross Beta or Gamma

Note: Footnotes indicated are listed in GGNS ODCM APPENDIX A, Table 4.11.2.1.2-1.

TBL1D

TABLE 1D (Continued)

Grand Gulf Nuclear Station

RADIOACTIVE GASEOUS WASTE SAMPLING AND ANALYSIS PROGRAM

		Gaseous Release Type	Sampling Frequency	Minimum Analysis Frequency	Type of Activity Analysis	Lower Limit of Detection Required ^a (LLD) (μ Ci/ml)
B.	(1)	Offgas Post Treatment Exhaust, whenever there is flow	M Grab Sample	M	Principal Gamma Emitters ^e	1E-04
	(2)	Standby Gas Treatment A Exhaust, whenever there is flow				
	(3)	Standby Gas Treatment B Exhaust, whenever there is flow				

Note: Footnotes indicated are listed in GGNS ODCM Appendix A, Table 4.11.2.1.2-1.

TBL1D

TABLE 2A

Grand Gulf Nuclear Station

JULY - DECEMBER 1993

LIQUID EFFLUENTS-SUMMATION OF ALL RELEASES

	Unit	Quarter 3	Quarter 4	Est Total Error %
A. Fission & activation products				
1. Total release (not including H3, gases, alpha)	Ci	2.98E-02	7.21E-02	7.30E+01
2. Average diluted concentration during period	uCi/ml	4.08E-08	1.18E-07	
3. Percent of applicable limit	%	4.51E-02	3.47E-01	
B. Tritium				
1. Total release	Ci	2.35E+01	1.65E+01	7.00E+01
2. Average diluted concentration during period	uCi/ml	3.23E-05	2.69E-05	
3. Percent of applicable limit	%	1.08E+00	8.98E-01	
C. Dissolved and entrained gases				
1. Total release	Ci	2.15E-04	2.49E-04	6.60E+01
2. Average diluted concentration during period	uCi/ml	2.95E-10	4.08E-10	
3. Percent of applicable limit	%	4.42E-03	6.12E-03	
D. Gross alpha radioactivity				
1. Total release	Ci	0.00E+00	0.00E+00	9.50E+01
E. Volume of waste (prior to dilution)	liters	8.96E+06	7.97E+06	5.00E+00
F. Volume of dilution water used	liters	7.21E+08	6.04E+08	5.00E+00

TBL2A

TABLE 2B

Grand Gulf Nuclear Station

JULY - DECEMBER 1993

LIQUID EFFLUENTS - CONTINUOUS AND BATCH MODES

Nuclides Released	Unit	CONTINUOUS MODE		BATCH MODE	
		Quarter 3	Quarter 4	Quarter 3	Quarter 4
strontium-89	Ci	0.00E+00	0.00E+00	0.00E+00	3.23E-04
strontium-90	Ci	0.00E+00	0.00E+00	0.00E+00	2.93E-04
cesium-134	Ci	0.00E+00	0.00E+00	1.85E-04	1.36E-04
cesium-137	Ci	0.00E+00	0.00E+00	3.52E-04	2.12E-04
iodine-131	Ci	0.00E+00	0.00E+00	0.00E+00	2.96E-06
cobalt-58	Ci	0.00E+00	0.00E+00	5.14E-04	1.48E-03
cobalt-60	Ci	0.00E+00	0.00E+00	4.58E-03	2.00E-02
iron-59	Ci	0.00E+00	0.00E+00	3.49E-04	5.63E-03
zinc-65	Ci	0.00E+00	0.00E+00	0.00E+00	3.55E-05
manganese-54	Ci	0.00E+00	0.00E+00	5.13E-03	1.78E-02
chromium-51	Ci	0.00E+00	0.00E+00	8.18E-03	3.83E-03
zirconium-niobium-95	Ci	0.00E+00	0.00E+00	0.00E+00	3.26E-05
molybdenum-99	Ci	0.00E+00	0.00E+00	0.00E+00	0.00E+00
technetium-99m	Ci	0.00E+00	0.00E+00	4.07E-06	1.40E-05
barium-lanthanum-140	Ci	0.00E+00	0.00E+00	0.00E+00	0.00E+00
cerium-141	Ci	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Ce-144	Ci	0.00E+00	0.00E+00	0.00E+00	1.79E-05
Sb-125	Ci	0.00E+00	0.00E+00	0.00E+00	1.79E-05
W-187	Ci	0.00E+00	0.00E+00	4.34E-06	0.00E+00
Cu-64	Ci	0.00E+00	0.00E+00	3.17E-04	1.90E-04
I-133	Ci	0.00E+00	0.00E+00	8.42E-06	0.00E+00
As-76	Ci	0.00E+00	0.00E+00	3.76E-05	0.00E+00
Na-24	Ci	0.00E+00	0.00E+00	1.64E-03	0.00E+00
Sb-124	Ci	0.00E+00	0.00E+00	2.19E-06	9.74E-05
Fe-55	Ci	0.00E+00	0.00E+00	8.48E-03	2.19E-02
Total for period (above)	Ci	0.00E+00	0.00E+00	2.98E-02	7.21E-02
xenon-133	Ci	0.00E+00	0.00E+00	4.56E-05	2.49E-04
xenon-135	Ci	0.00E+00	0.00E+00	1.69E-04	0.00E+00
Xe-133m	Ci	0.00E+00	0.00E+00	0.00E+00	0.00E+00

TBL2B

TABLE 2C

Grand Gulf Nuclear Station

RADIOACTIVE LIQUID WASTE SAMPLING AND ANALYSIS PROGRAM

Liquid Release Type	Sampling Frequency	Minimum Analysis Frequency	Type of Activity Analysis	Lower Limit of Detection Required ^a (LLD) ($\mu\text{Ci/ml}$)
A. Batch Waste Release Tanks	P Each Batch	P Each Batch	Principal Gamma Emitters ^d	5E-07
			I-131	1E-06
	P One Batch/M	M	Dissolved and Entrained Gases (gamma emitters)	1E-05
			P Each Batch	M Composite ^b
	Gross Alpha	1E-07		
	P Each Batch	Q Composite ^b	Sr-89, Sr-90	5E-08
Fe-55			1E-06	
B. SSW Basin (prior to blowdown)	Each Blowdown	Each Batch	Principal Gamma Emitters ^d	5E-07
			I-131	1E-06

Note: Footnotes indicated are listed in GGNS ODCM Appendix A, Table 4.11.1.1.1-1.

TBL2C

TABLE 3

Grand Gulf Nuclear Station

JULY - DECEMBER 1993

SOLID RADIOACTIVE WASTE AND IRRADIATED FUEL SHIPMENTS

A. Solid Waste Shipped Offsite for Burial or Disposal

1.	Type of Waste	Unit	6-Month Period	Estimate Total Error, %
a.	Spent resins, filter sludges, oil, evaporator bottoms, etc.	m ³ *Ci	8.87E+01 1.67E+02	7.2E+01
b.	Dry compressible waste, contaminated equipment, etc.	m ³ *Ci	1.94E+01 2.11E+00	6.9E+01
c.	Irradiated components, control rods, etc.	m ³ *Ci	None	N/A
d.	Other	m ³ *Ci	None	N/A

*Total curie quantity determined by measurement. Total volume used is burial container volume.

2. Estimate of major radionuclide composition (by type of waste as identified above).

a.	Fe-55	75.1%
	Co-60	9.1%
	Mn-54	7.8%
	Cr-51	1.2%
	Fe-59	1.2%
	Ni-63	1.4%
	Zn-65	1.5%
	All Others	2.7%
b.	Fe-55	65.1%
	Mn-54	12.3%
	Co-60	18.5%
	Fe-59	2.9%
	C-14	1.2%
c.	N/A	N/A
d.	N/A	N/A

TBL3

TABLE 3 (Continued)

Grand Gulf Nuclear Station

JULY - DECEMBER 1993

3. Solid Waste Disposition

- a. Resins were dewatered in steel liners or High Integrity Containers according to the requirements of the GGNS PCP and shipped to Barnwell, SC for burial. Some resin was shipped to Scientific Ecology Group (SEG) of Oak Ridge, TN for volume reduction. SEG shipped reduced waste to Barnwell, SC. Reduced volume was used in providing information given in A.1.a.
- b. DAW was packaged in 20' sealand containers and shipped to Scientific Ecology Group (SEG) of Oak Ridge, TN for volume reduction. SEG shipped reduced waste to Barnwell, SC. Reduced volume was used in providing information given in A.1.b.
- c. No irradiated components were shipped.
- d. No waste in this category.

<u>Number of Shipments</u>	<u>Mode of Transportation</u>	<u>Destination</u>
48	Truck	Barnwell, SC

B. Irradiated Fuel Shipments (Disposition)

<u>Number of Shipments</u>	<u>Mode of Transportation</u>	<u>Destination</u>
None	N/A	N/A

C. Annual Sewage Sludge Summary

<u>Number of Shipments</u>	<u>Total Gallons</u>	<u>Average Co-60 Activity (pCi/l)</u>	<u>Average Mn-54 Activity (pCi/l)</u>
No sewage was disposed of during 1993.			

TBL3

TABLE 4A

METEOROLOGICAL DATA - JULY - SEPTEMBER

EXTREMELY UNSTABLE STABILITY CLASS A
 PERIOD OF RECORD: 7/ 1/93, 000-- 10/ 1/93, 000

WIND SPEED (M/S) AT 50-M LEVEL

	0-2	3-5	6-8	9-11	12-14	15-17	18 AND UP	TOTAL	AVG SPEED
N	8.2	1.5	.0	.0	.0	.0	.0	9.7	.2
NNE	6.4	.7	.0	.0	.0	.0	.0	7.1	.1
NE	3.7	.0	.0	.0	.0	.0	.0	4.2	.1
ENE	4.6	.2	.0	.0	.0	.0	.0	4.9	.1
E	1.7	.4	.0	.0	.0	.0	.0	4.0	.1
ESE	1.3	.5	.0	.0	.0	.0	.0	3.8	.1
SE	.5	1.1	.0	.0	.0	.0	.0	1.6	.1
SESE	1.5	1.1	.7	.0	.0	.0	.0	3.3	.1
CS	1.6	.5	.0	.0	.0	.0	.0	2.2	.0
TSW	4.6	3.1	.0	.0	.0	.0	.0	8.1	.2
TSW	1.7	1.1	.0	.0	.0	.0	.0	4.8	.1
WSW	6.4	.4	.0	.0	.0	.2	.0	7.0	.2
W	7.1	.0	.0	.3	.0	.0	.0	7.1	.1
WNW	9.0	.6	.2	.0	.0	.0	.0	9.5	.2
W	6.0	4.2	.0	.0	.0	.0	.0	12.8	.3
NNW	5.5	4.0	.0	.0	.0	.0	.0	9.5	.3
CALM	.0							.0	

TOTAL	76.7	20.2	.9	.0	.0	.2	.0	100.0	.2

0. HOURS OF BAD OR MISSING DATA OR .0 PERCENT FOR 545 HOURS

TABLE 4A (Continued)

METEOROLOGICAL DATA - JULY - SEPTEMBER

MODERATELY UNSTABLE STABILITY CLASS B
 PERIOD OF RECORD: 7/ 1/93, 000-- 10/ 1/93, 000

WIND SPEED (M/S) AT 50-M LEVEL

	0-2	3-5	6-8	9-11	12-14	15-17	18 AND UP	TOTAL	AVG SPEED
N	8.8	10.3	.0	.0	.0	.0	.0	19.1	.6
NNE	7.3	1.5	.0	.0	.0	.0	.0	8.8	.2
NE	7.3	.0	.0	.0	.0	.0	.0	7.3	.1
ENE	1.5	.0	.0	.0	.0	.0	.0	1.5	.0
E	2.9	2.9	.0	.0	.0	.0	.0	5.9	.2
ESE	.0	1.5	.0	.0	.0	.0	.0	1.5	.0
SE	2.9	.0	.0	.0	.0	.0	.0	2.9	.0
E SSW	2.9	.0	.0	.0	.0	.0	.0	2.9	.0
SSW	2.9	.0	.0	.0	.0	.0	.0	2.9	.0
WSW	10.3	.0	.0	.0	.0	.0	.0	10.3	.1
W	5.9	.0	.0	.0	.0	.0	.0	5.9	.1
WSW	1.5	1.5	.0	.0	.0	.0	.0	2.9	.1
W	.0	.0	.0	.0	.0	.0	.0	.0	.0
WNW	1.5	.0	.0	.0	.0	.0	.0	1.5	.0
NW	10.3	.0	.0	.0	.0	.0	.0	10.3	.2
NNW	14.7	.0	.0	.0	.0	.0	.0	14.7	.3
CALM	1.5							1.5	
TOTAL	83.3	17.6	.0	.0	.0	.0	.0	100.0	.1

0. HOURS OF BAD OR MISSING DATA OR .0 PERCENT FOR 66 HOURS

TABLE 4A (Continued)
METEOROLOGICAL DATA - JULY - SEPTEMBER

SLIGHTLY UNSTABLE STABILITY CLASS C
 PERIOD OF RECORD: 7/ 1/93, 000-- 10/ 1/93, 000

WIND SPEED (M/S) AT 50-M LEVEL

	0-2	3-5	6-8	9-11	12-14	15-17	18 AND UP	TOTAL	AVG SPEED
N	13.3	.0	.0	.0	.0	.0	.0	13.3	.3
NNE	6.7	3.3	.0	.0	.0	.0	.0	10.0	.3
NE	.0	1.7	.3	.0	.0	.0	.0	1.7	.0
ENE	6.7	.0	.0	.0	.0	.0	.0	6.7	.1
E	3.3	.0	.0	.0	.0	.0	.0	3.3	.0
ESE	1.7	.0	.0	.0	.0	.0	.0	1.7	.0
SE	1.7	1.7	.0	.0	.0	.0	.0	3.3	.1
E SSE	1.7	1.7	.0	.0	.0	.0	.0	3.3	.1
SSE	6.7	.0	.0	.0	.0	.0	.0	6.7	.1
S	3.3	.0	.0	.0	.0	.0	.0	3.3	.0
SSW	3.3	.0	.0	.0	.0	.0	.0	3.3	.1
WSW	6.7	.0	1.7	.0	1.7	.0	.0	10.0	.5
WS	1.7	1.7	.0	.0	.0	.0	.0	3.3	.1
WNW	3.3	.0	.3	.0	.0	.0	.0	3.3	.0
WN	6.7	1.7	.0	.0	.0	.0	.0	10.0	.2
NNW	10.0	.0	.0	.0	.0	.0	.0	10.0	.2
CALM	.0							.0	

TOTAL	69.0	11.7	1.7	.0	1.7	.0	.0	100.0	.1

0. HOURS OF BAD OR MISSING DATA OR .0 PERCENT FOR 60 HOURS

TABLE 4A (Continued)

METEOROLOGICAL DATA - JULY - SEPTEMBER

NEUTRAL STABILITY CLASS D
 PERIOD OF RECORD: 7/ 1/93, 000-- 10/ 1/93, 000

WIND SPEED (M/S) AT 50-M LEVEL

	0-2	3-5	6-8	9-11	12-14	15-17	18 AND UP	TOTAL	AVG SPEED
N	8.8	2.1	.0	.0	.0	.0	.0	10.9	.2
NNE	5.0	.0	.0	.0	.0	.0	.0	5.0	.1
NE	4.2	.0	.0	.0	.0	.0	.0	4.2	.1
ENE	5.4	.0	.0	.0	.0	.0	.0	5.4	.1
E	3.8	1.7	.0	.0	.0	.0	.0	5.4	.1
ESE	2.9	.0	.0	.0	.0	.0	.0	3.8	.1
SE	1.7	1.3	.0	.0	.0	.0	.0	2.9	.1
SSE	5.4	2.9	.0	.0	.0	.0	.0	8.4	.2
S	4.6	1.7	.0	.0	.0	.0	.0	6.3	.1
SSW	5.8	.8	.0	.0	.0	.0	.0	6.7	.1
SW	6.3	2.1	.0	.0	.0	.0	.0	8.4	.2
WSW	5.4	1.7	.0	.0	.0	.0	.0	7.5	.2
W	3.8	.0	.0	.0	.0	.0	.0	4.2	.1
WNW	2.9	2.5	.0	.0	.0	.0	.0	5.4	.1
NW	4.6	.0	.0	.0	.0	.0	.0	4.6	.1
NNW	7.5	1.3	.0	.0	.0	.0	.0	8.8	.2
CALM	2.1							2.1	
TOTAL	80.7	19.2	.0	.0	.0	.0	.0	100.0	.1

0. HOURS OF BAD OR MISSING DATA OR .0 PERCENT FOR 239 HOURS

TABLE 4A (Continued)

METEOROLOGICAL DATA - JULY - SEPTEMBER

SLIGHTLY STABLE STABILITY CLASS B
 PERIOD OF RECORD: 7/ 1/93, 000-- 10/ 1/93, 000

WIND SPEED (M/S) AT 50-M LEVEL

	0-2	3-5	6-8	9-11	12-14	15-17	18 AND UP	TOTAL	AVG SPEED
R	4.2	.6	.0	.0	.0	.0	.0	4.8	.1
NNE	2.5	1.0	.0	.0	.0	.0	.0	4.0	.1
NE	1.6	1.5	.1	.0	.0	.0	.0	3.3	.1
ESE	1.2	1.9	.0	.0	.0	.0	.0	3.1	.1
E	2.5	2.1	.0	.0	.0	.0	.0	4.6	.1
ESE	3.5	1.0	.0	.0	.0	.0	.0	7.2	.2
SE	4.7	3.0	.0	.0	.0	.0	.0	7.2	.2
ESE	6.6	3.6	.0	.0	.0	.0	.0	10.0	.3
E	5.4	1.9	.0	.0	.0	.0	.0	7.3	.2
ESE	6.0	3.0	.0	.0	.0	.0	.0	9.0	.3
ESE	5.4	3.0	.0	.0	.0	.0	.0	8.4	.3
ESE	5.1	.4	.0	.0	.0	.0	.0	5.5	.1
E	5.1	.7	.0	.0	.0	.0	.0	3.9	.1
ESE	7.3	1.6	.0	.0	.0	.0	.0	9.0	.3
ESE	3.5	1.7	.0	.0	.0	.0	.0	6.9	.2
ESE	3.7	1.7	.0	.0	.0	.0	.0	5.1	.1
CALM	.7							.7	
TOTAL	70.7	29.1	.1	.0	.0	.0	.0	100.0	.2

0. HOURS OF BAD OR MISSING DATA OR .0 PERCENT FOR 669 HOURS

TABLE 4A (Continued)

METEOROLOGICAL DATA - JULY - SEPTEMBER

MODERATELY STABLE STABILITY CLASS F
 PERIOD OF RECORD: 7/ 1/93, 000-- 10/ 1/93, 000

WIND SPEED (M/S) AT 50-M LEVEL

	0-2	3-5	6-9	9-11	12-14	15-17	18 AND UP	TOTAL	AVG SPEED
N	5.3	3.5	.0	.0	.0	.0	.0	8.8	.2
NNE	2.1	3.2	.0	.0	.0	.0	.0	5.3	.2
NE	4.7	1.3	.0	.0	.0	.0	.0	6.1	.1
ENE	2.5	2.6	.0	.0	.0	.0	.0	5.3	.1
E	4.4	5.6	.0	.0	.0	.0	.0	10.0	.3
ESE	4.4	3.2	.0	.0	.0	.0	.0	7.6	.2
SE	7.0	2.1	.0	.0	.0	.0	.0	9.1	.2
SSE	4.7	2.9	.0	.0	.0	.0	.0	7.6	.2
S	6.1	.9	.0	.0	.0	.0	.0	7.0	.1
SSW	3.5	.9	.0	.0	.0	.0	.0	4.4	.1
WSW	3.2	.9	.0	.0	.0	.0	.0	4.1	.1
WS	5.6	.9	.0	.0	.0	.0	.0	6.4	.1
W	3.5	.6	.0	.0	.0	.0	.0	4.1	.1
WSW	3.5	.0	.0	.0	.0	.0	.0	3.5	.1
NW	2.7	1.3	.0	.0	.0	.0	.0	4.4	.1
NNW	2.9	2.3	.0	.0	.0	.0	.0	5.3	.1
CALM	.9							.9	

TOTAL	47.4	32.5	.0	.0	.0	.0	.0	100.0	.2

D. HOURS OF BAD OR MISSING DATA OR .0 PERCENT FOR 341 HOURS

TABLE 4A (Continued)

METEOROLOGICAL DATA - JULY - SEPTEMBER

EXTREMELY STABLE STABILITY CLASS G
 PERIOD OF RECORD: 7/ 1/93, 000-- 10/ 1/93, 000

WIND SPEED (M/S) AT 50-M LEVEL

	0-2	3-5	6-8	9-11	12-14	15-17	18 AND UP	TOTAL	AVG SPEED
N	2.3	.0	.0	.0	.0	.0	.0	2.3	.0
NE E	3.2	3.2	.0	.0	.0	.0	.0	6.4	.2
NE E	6.0	4.6	.0	.0	.0	.0	.0	10.6	.3
ENE	6.4	6.0	.0	.0	.0	.0	.0	12.4	.3
E	5.9	3.2	.0	.0	.0	.0	.0	8.8	.2
ESE	1.2	1.2	.0	.0	.0	.0	.0	5.1	.1
ESE	3.3	1.4	.0	.0	.0	.0	.0	9.7	.2
ESE	3.7	1.4	.0	.0	.0	.0	.0	5.1	.1
ES	8.5	.5	.0	.0	.0	.0	.0	9.2	.2
ESSW	3.7	.0	.0	.0	.0	.0	.0	3.7	.1
ESW	4.1	.0	.0	.0	.0	.0	.0	4.1	.1
ESW	3.7	.0	.0	.0	.0	.0	.0	3.7	.1
W	4.1	.0	.0	.0	.0	.0	.0	4.1	.1
WNW	7.4	.0	.0	.0	.0	.0	.0	7.4	.1
WNW	1.8	.0	.0	.0	.0	.0	.0	1.8	.0
NNW	1.8	.5	.0	.0	.0	.0	.0	2.3	.0
CALM	3.2							3.2	

TOTAL	77.4	32.9	.0	.0	.0	.0	.0	100.0	.1

0. HOURS OF BAD OR MISSING DATA OR .0 PERCENT FOR 217 HOURS

TABLE 4A (Continued)

METEOROLOGICAL DATA - JULY - SEPTEMBER

EXTREMELY UNSTABLE STABILITY CLASS A
 PERIOD OF RECORD: 7/ 1/93, 000-- 10/ 1/93, 000

WIND SPEED (M/S) AT 10-M LEVEL

	0-2	3-5	6-8	9-11	12-14	15-17	18 AND UP	TOTAL	AVG SPEED
N	6.2	.5	.0	.0	.0	.0	.0	6.8	.1
NNE	3.3	.0	.0	.0	.0	.0	.0	3.5	.1
NE	1.1	.0	.0	.0	.0	.0	.0	1.1	.0
NNE	.9	.0	.0	.0	.0	.0	.0	.9	.0
N E	1.6	.0	.0	.0	.0	.0	.0	1.6	.0
E SSE	.5	.0	.0	.0	.0	.0	.0	.5	.0
E SE	1.3	.0	.0	.0	.0	.0	.0	1.3	.0
E SSE	1.5	.5	.0	.0	.0	.0	.0	2.0	.0
E S E	2.4	1.5	.0	.0	.0	.0	.0	3.8	.1
E SSW	7.9	.4	.0	.0	.0	.0	.0	8.4	.2
E SW	12.7	.9	.0	.0	.0	.0	.2	13.8	.3
E WSW	11.2	.0	.0	.0	.0	.0	.0	11.2	.1
E W	8.6	.0	.0	.0	.0	.0	.0	8.6	.1
W SW	11.7	.0	.0	.0	.0	.0	.0	11.7	.2
W W	13.4	.0	.0	.0	.0	.0	.0	13.4	.2
W W	11.2	.0	.0	.0	.0	.0	.0	11.2	.2
CALC	.0							.0	
TOTAL	93.8	3.8	.0	.2	.0	.0	.2	100.0	.1

0. HOURS OF BAD OR MISSING DATA OR .0 PERCENT FOR 545 HOURS

TABLE 4A (Continued)

METEOROLOGICAL DATA - JULY - SEPTEMBER

MODERATELY UNSTABLE STABILITY CLASS B
 PERIOD OF RECORD: 7/ 1/93, 000-- 10/ 1/93, 000

WIND SPEED (M/S) AT 10-M LEVEL

	0-2	3-5	6-8	9-11	12-14	15-17	18 AND UP	TOTAL	AVG SPEED
N	7.3	.0	.0	.0	.0	.0	.0	7.3	.1
NNE	17.6	.0	.0	.0	.0	.0	.0	17.6	.3
NE	4.4	.0	.0	.0	.0	.0	.0	4.4	.0
ENE	.0	.0	.0	.0	.0	.0	.0	.0	.0
E	2.9	.0	.0	.0	.0	.0	.0	2.9	.0
ESE	2.9	.0	.0	.0	.0	.0	.0	2.9	.0
SSE	2.9	.0	.0	.0	.0	.0	.0	2.9	.0
S	1.5	1.5	.0	.0	.0	.0	.0	2.9	.1
SSE	13.2	.0	.0	.0	.0	.0	.0	13.2	.2
SE	20.6	.0	.0	.0	.0	.0	.0	20.6	.3
ESE	5.9	.0	.0	.0	.0	.0	.0	5.9	.1
E	4.4	.0	.0	.0	.0	.0	.0	4.4	.0
ESE	2.9	.0	.0	.0	.0	.0	.0	2.9	.0
SE	5.9	.0	.0	.0	.0	.0	.0	5.9	.1
SESE	1.5	.0	.0	.0	.0	.0	.0	1.5	.0
SE	1.5	.0	.0	.0	.0	.0	.0	1.5	.0
TOTAL	58.5	1.5	.0	.0	.0	.0	.0	100.0	.1

0. HOURS OF BAD OR MISSING DATA OR .0 PERCENT FOR 68 HOURS

TABLE 4A (Continued)

METEOROLOGICAL DATA - JULY - SEPTEMBER

SLIGHTLY UNSTABLE STABILITY CLASS C
 PERIOD OF RECORD: 7/ 1/93, 000-- 10/ 1/93, 000

WIND SPEED (M/S) AT 10-M LEVEL

	0-2	3-5	6-8	9-11	12-14	15-17	18 AND UP	TOTAL	AVG SPEED
R	8.3	.0	.0	.0	.0	.0	.0	8.3	.1
RR	8.3	.0	.0	.0	.0	.0	.0	8.3	.1
NR	1.7	.0	.0	.0	.0	.0	.0	1.7	.0
RNC	1.7	.0	.0	.0	.0	.0	.0	1.7	.0
D	5.0	.0	.0	.0	.0	.0	.0	5.0	.1
DR	3.3	.0	.0	.0	.0	.0	.0	3.3	.0
RRR	.0	.0	.0	.0	.0	.0	.0	.0	.0
RRR	1.7	3.3	.0	.0	.0	.0	.0	5.0	.1
RRR	5.0	1.7	.0	.0	.0	.0	.0	6.7	.1
NR	16.7	.0	.0	.0	.0	.0	.0	16.7	.2
NR	10.0	.0	.0	.0	.0	.0	.0	10.0	.1
NR	8.3	.0	.0	.0	.0	.0	.0	8.3	.1
NR	3.3	1.7	.0	.0	.0	.0	.0	10.0	.2
NR	1.7	.0	.0	.0	.0	.0	.0	1.7	.0
NR	5.0	.0	.0	.0	.0	.0	.0	5.0	.0
NR	5.0	.0	.0	.0	.0	.0	.0	5.0	.1
CALM	3.3							3.3	
TOTAL	53.3	6.7	.0	.0	.0	.0	.0	100.0	.1

0. HOURS OF BAD OR MISSING DATA OR .0 PERCENT FOR 60 HOURS

TABLE 4A (Continued)

METEOROLOGICAL DATA - JULY - SEPTEMBER

NEUTRAL STABILITY CLASS D
 PERIOD OF RECORD: 7/ 1/93, 000-- 10/ 1/93, 000

WIND SPEED (M/S) AT 10-M LEVEL

	0-2	3-5	6-8	9-11	12-14	15-17	18 AND UP	TOTAL	AVG SPEED
N	9.6	.0	.0	.0	.0	.0	.0	9.6	.1
NNE	7.1	.0	.0	.0	.0	.0	.0	7.1	.1
N E	3.3	.0	.0	.0	.0	.0	.0	3.3	.0
E NE	2.9	.0	.0	.0	.0	.0	.0	2.9	.0
E	4.2	.0	.0	.0	.0	.0	.0	4.2	.0
ESE	2.1	.0	.0	.0	.0	.0	.0	2.1	.0
SE	2.9	.0	.0	.0	.0	.0	.0	2.9	.0
W	11.3	.0	.0	.0	.0	.0	.0	11.3	.2
WSW	11.3	.4	.0	.0	.0	.0	.0	11.7	.2
W	10.9	.0	.0	.0	.0	.0	.0	10.9	.1
WSW	8.4	.0	.0	.0	.0	.0	.0	8.4	.1
W	4.6	.0	.0	.0	.0	.0	.0	4.6	.0
WNW	3.8	.0	.0	.0	.0	.0	.0	3.8	.0
WNW	2.5	.0	.0	.0	.0	.0	.0	2.5	.0
NW	3.0	.0	.0	.0	.0	.0	.0	3.0	.1
WNW	2.9	.0	.0	.0	.0	.0	.0	2.9	.0
CALM	6.7							6.7	
TOTAL	99.6	.4	.0	.0	.0	.0	.0	100.0	.1

0. HOURS OF LAD OF MISSING DATA OR .0 PERCENT FOR 239 HOURS

TABLE 4A (Continued)

METEOROLOGICAL DATA - JULY - SEPTEMBER

SLIGHTLY STABLE STABILITY CLASS E
 PERIOD OF RECORD: 7/ 1/93, 000-- 10/ 1/93, 000

WIND SPEED (M/S) AT 10-M LEVEL

	0-2	3-5	6-8	9-11	12-14	15-17	18 AND UP	TOTAL	AVG SPEED
N	4.6	.1	.0	.0	.0	.0	.0	4.9	.1
NNE	0.6	.0	.0	.0	.0	.0	.0	0.6	.1
NE	0.9	.0	.0	.0	.0	.0	.0	0.9	.1
NNE	5.1	.0	.0	.0	.0	.0	.0	5.1	.0
D R	4.0	.0	.0	.0	.0	.0	.0	4.0	.0
E ESE	5.4	.0	.0	.0	.0	.0	.0	5.4	.0
R SE	5.1	.0	.0	.0	.0	.0	.0	5.1	.1
W E WSE	13.1	.1	.0	.0	.0	.0	.0	13.4	.2
I C S	11.4	.1	.0	.0	.0	.0	.0	11.5	.1
W T SSW	6.6	.0	.0	.0	.0	.0	.0	6.6	.1
D T SW	2.2	.0	.0	.0	.0	.0	.0	2.2	.0
O WSW	.7	.0	.0	.0	.0	.0	.0	.7	.0
N W	1.3	.0	.0	.0	.0	.0	.0	1.3	.0
WNW	.4	.0	.0	.0	.0	.0	.0	.4	.0
NW	.6	.0	.0	.0	.0	.0	.0	.6	.0
NNW	1.6	.0	.0	.0	.0	.0	.0	1.6	.0
CALM	22.4							22.4	
TOTAL	99.5	.4	.0	.0	.0	.0	.0	100.0	.1

0.4 HOURS OF BAD OR MISSING DATA OR .0 PERCENT FOR 569 HOURS

TABLE 4A (Continued)

METEOROLOGICAL DATA - JULY - SEPTEMBER

MODERATELY STABLE STABILITY CLASS F
 PERIOD OF RECORD: 7/ 1/93, 000-- 10/ 1/93, 000

WIND SPEED (M/S) AT 10-M LEVEL

	0-2	3-5	6-8	9-11	12-14	15-17	18 AND UP	TOTAL	AVG SPEED
N	2.6	.0	.0	.0	.0	.0	.0	2.6	.0
NNE	8.2	.0	.0	.0	.0	.0	.0	8.2	.1
NE	10.5	.0	.0	.0	.0	.0	.0	10.5	.1
ENE	10.0	.0	.0	.0	.0	.0	.0	10.0	.1
E	6.4	.0	.0	.0	.0	.0	.0	6.4	.0
ESE	6.7	.0	.0	.0	.0	.0	.0	6.7	.1
SE	3.5	.0	.0	.0	.0	.0	.0	3.5	.0
E SSE	2.3	.0	.0	.0	.0	.0	.0	2.3	.0
S	2.1	.0	.0	.0	.0	.0	.0	2.1	.0
SSE	.3	.0	.0	.0	.0	.0	.0	.3	.0
SSW	.3	.0	.0	.0	.0	.0	.0	.3	.0
WSW	.0	.0	.0	.0	.0	.0	.0	.0	.0
W	.3	.0	.0	.0	.0	.0	.0	.3	.0
WSW	.0	.0	.0	.0	.0	.0	.0	.0	.0
W	.6	.0	.0	.0	.0	.0	.0	.6	.0
WNW	1.7	.0	.0	.0	.0	.0	.0	1.7	.0
W	44.3	.0	.0	.0	.0	.0	.0	44.3	.0
CALM									
TOTAL	100.0	.0	.0	.0	.0	.0	.0	100.0	.1

0. HOURS OF BAD OR MISSING DATA OR .0 PERCENT FOR 341 HOURS

TABLE 4A (Continued)

METEOROLOGICAL DATA - JULY - SEPTEMBER

TOTAL FREQUENCY DISTRIBUTION

PERIOD OF RECORD: 7/ 1/93, 000 --10/ 1/93, 000

WIND SPEED (M/S) AT 50-M LEVEL

	0-2	3-5	6-8	9-11	12-14	15-17	18 AND UP	TOTAL	AVG SPEED
N	6.1	1.7	.0	.0	.0	.0	.0	7.8	.2
NNE	4.1	1.6	.0	.0	.0	.0	.0	5.7	.1
NE	1.5	1.4	.0	.0	.0	.0	.0	4.9	.1
NNE	3.5	1.7	.0	.0	.0	.0	.0	5.2	.1
D E	3.6	2.2	.0	.0	.0	.0	.0	5.8	.1
I ESE	4.0	1.5	.0	.0	.0	.0	.0	5.5	.1
R ESE	1.7	1.5	.0	.0	.0	.0	.0	5.6	.1
W E SSE	4.3	2.3	.2	.0	.0	.0	.0	6.8	.2
I C S	4.8	1.1	.0	.0	.0	.0	.0	5.9	.1
N T SW	5.2	2.1	.0	.0	.0	.0	.0	7.2	.2
D I SW	4.5	1.8	.0	.0	.0	.0	.0	6.1	.1
C WSW	3.4	.6	.0	.0	.0	.0	.0	6.1	.1
N W	4.2	.4	.3	.0	.0	.0	.0	4.7	.1
WNW	6.3	.9	.0	.0	.0	.0	.0	7.3	.2
NW	5.6	1.5	.0	.0	.0	.0	.0	7.4	.2
NNW	4.3	2.0	.0	.0	.0	.0	.0	6.8	.2
CALM	4.8							1.0	
TOTAL	74.8	24.3	.3	.0	.0	.0	.0	100.0	.2

69. HOURS OF BAD OR MISSING DATA OR 3.1 PERCENT FOR 2208 HOURS

TABLE 4A (Continued)

METEOROLOGICAL DATA - JULY - SEPTEMBER

TOTAL FREQUENCY DISTRIBUTION

PERIOD OF RECORD: 7/ 1/93, 000 --10/ 1/93, 000

WIND SPEED (M/S) AT 10-M LEVEL

	0-2	3-5	6-8	9-11	12-14	15-17	18 AND UP	TOTAL	AVG SPEED
N	5.0	.2	.0	.0	.0	.0	.0	5.2	.1
NNE	5.7	.0	.0	.0	.0	.0	.0	5.9	.1
NE	5.6	.0	.0	.0	.0	.0	.0	5.5	.1
ENE	6.6	.0	.0	.0	.0	.0	.0	6.6	.1
E	4.1	.0	.0	.0	.0	.0	.0	4.1	.0
ESE	3.7	.0	.0	.0	.0	.0	.0	3.7	.0
SSE	3.2	.0	.0	.0	.0	.0	.0	3.2	.0
SE	6.3	.3	.0	.0	.0	.0	.0	6.6	.1
SSE	5.9	.6	.0	.0	.0	.0	.0	6.5	.1
S	6.2	.1	.0	.0	.0	.0	.0	6.3	.1
SSE	5.3	.2	.0	.0	.0	.0	.0	6.1	.1
SSW	4.0	.0	.0	.0	.0	.0	.0	4.0	.0
SW	3.4	.0	.0	.0	.0	.0	.0	3.5	.0
WSW	3.5	.0	.0	.0	.0	.0	.0	3.5	.0
W	4.6	.0	.0	.0	.0	.0	.0	4.6	.1
WSW	4.2	.0	.0	.0	.0	.0	.0	4.2	.1
W	4.1							20.1	
CALM									
TOTAL	98.5	1.4	.0	.0	.0	.0	.0	100.0	.1

69. HOURS OF BAD OR MISSING DATA OR 1.1 PERCENT FOR 2208 HOURS

TABLE 4A (Continued)

METEOROLOGICAL DATA - JULY - SEPTEMBER

PERCENT EAD DATA REPORT REPORT COVERS 2200HOURS		
	HOURS	PERCENT
50M DIRECTION	69.	3.13
50M WIND SPEED	69.	3.13
10M DIRECTION	69.	3.13
10M WIND SPEED	69.	3.13
TEMPERATURE	69.	3.13
DEW POINT	69.	3.13
DELTA T	69.	3.13
PRECIPITATION	68.	3.08

TABLE 4B

METEOROLOGICAL DATA - OCTOBER - DECEMBER

EXTREMELY UNSTABLE STABILITY CLASS A
 PERIOD OF RECORD: 10/ 1/93, 000-- 1/ 1/94, 000

WIND SPEED (M/S) AT 10-M LEVEL

DIRECTION	18							TOTAL	AVG SPEED
	0-2	3-5	6-8	9-11	12-14	15-17	AND UP		
N	5.2	.0	.0	.0	.0	.0	.0	5.2	.1
NNE	4.8	.0	.0	.0	.0	.0	.0	4.8	.1
NNE	4.8	.0	.0	.0	.0	.0	.0	4.8	.1
NNE	5.2	.0	.0	.0	.0	.0	.0	5.2	.1
NNE	1.4	.0	.0	.0	.0	.0	.0	1.4	.0
NNE	3.8	.0	.0	.0	.0	.0	.0	3.8	.1
NNE	1.4	.0	.0	.0	.0	.0	.0	1.4	.0
NNE	3.8	.0	.0	.0	.0	.0	.0	3.8	.1
NNE	3.3	.0	.0	.0	.0	.0	.0	3.3	.1
NNE	6.7	2.4	.0	.0	.0	.0	.0	6.7	.2
NNE	5.2	1.9	.0	.0	.0	.0	.0	5.2	.1
NNE	4.8	.0	.0	.0	.0	.0	.0	4.8	.1
NNE	2.4	.0	.0	.0	.0	.0	.0	2.4	.0
NNE	6.7	.0	.0	.0	.0	.0	.0	6.7	.1
NNE	15.2	.0	.0	.0	.0	.0	.0	15.2	.3
NNE	21.9	4.8	.0	.0	.0	.0	.0	21.9	.5
CALM	.0							.0	
TOTAL	88.0	11.4	.0	.0	.0	.0	.0	100.0	.1

0. HOURS OF BAD OR MISSING DATA OR .0 PERCENT FOR 210 HOURS

TABLE 4B (Continued)

METEOROLOGICAL DATA - OCTOBER - DECEMBER

MODERATELY UNSTABLE STABILITY CLASS B
 PERIOD OF RECORD: 10/ 1/93, 000-- 1/ 1/94, 000

WIND SPEED (M/S) AT 10-M LEVEL

	0-2	3-5	6-8	9-11	12-14	15-17	18 AND UP	TOTAL	AVG SPEED
N	5.9	.0	.0	.0	.0	.0	.0	5.9	.1
NNE	5.9	2.4	.0	.0	.0	.0	.0	8.3	.2
NE	.0	.0	.0	.0	.0	.0	.0	.0	.0
NNE	3.6	.0	.0	.0	.0	.0	.0	3.6	.0
E	1.2	1.2	.0	.0	.0	.0	.0	2.4	.1
ESE	1.2	.0	.0	.0	.0	.0	.0	1.2	.0
ESE	1.2	.0	.0	.0	.0	.0	.0	1.2	.0
SE	3.6	1.2	.0	.0	.0	.0	.0	4.8	.1
SSE	14.7	2.4	.0	.0	.0	.0	.0	16.7	.4
S	3.6	1.2	.0	.0	.0	.0	.0	7.1	.2
SSW	7.1	.0	.0	.0	.0	.0	.0	7.1	.2
WSW	3.6	1.2	.0	.0	.0	.0	.0	4.8	.1
W	1.2	.0	.0	.0	.0	.0	.0	1.2	.0
WSW	4.8	.0	.0	.0	.0	.0	.0	4.8	.1
SW	11.9	.0	.0	.0	.0	.0	.0	11.9	.2
SSW	17.9	1.2	.0	.0	.0	.0	.0	19.0	.4
CALM	.0							.0	

TOTAL	29.3	10.7	.0	.0	.0	.0	.0	100.0	.1

0. HOURS OF BAD OR MISSING DATA OR .0 PERCENT FOR 24 HOURS

TABLE 4B (Continued)

METEOROLOGICAL DATA - OCTOBER - DECEMBER

SLIGHTLY UNSTABLE STABILITY CLASS C
 PERIOD OF RECORD: 10/ 1/93, 000-- 1/ 1/94, 000

WIND SPEED (MPS) AT 10-M LEVEL

	C-2	3-5	6-8	9-11	12-14	15-17	18 AND UP	TOTAL	AVG SPEED
N	11.3	.0	.0	.0	.0	.0	.0	11.3	.2
NNE	2.1	.0	.0	.0	.0	.0	.0	2.1	.0
NE	3.1	.0	.0	.0	.0	.0	.0	3.1	.0
ENE	3.1	.0	.0	.0	.0	.0	.0	3.1	.0
E	1.0	.0	.0	.0	.0	.0	.0	1.0	.0
ESE	2.1	.0	.0	.0	.0	.0	.0	2.1	.0
SE	4.1	.0	.0	.0	.0	.0	.0	4.1	.1
EWSW	3.1	3.1	.0	.0	.0	.0	.0	6.2	.1
CS	3.1	3.1	.0	.0	.0	.0	.0	6.2	.3
TSW	7.2	1.0	.0	.0	.0	.0	.0	8.2	.2
WSW	3.1	.0	.0	.0	.0	.0	.0	3.1	.1
WSW	3.2	.0	.0	.0	.0	.0	.0	3.2	.1
W	3.1	.0	.0	.0	.0	.0	.0	3.1	.1
WNW	3.2	.0	.0	.0	.0	.0	.0	3.2	.1
NW	11.3	.0	.0	.0	.0	.0	.0	11.3	.2
NNW	13.4	.0	.0	.0	.0	.0	.0	13.4	.3
CALM	1.0							1.0	
TOTAL	92.6	7.2	.0	.0	.0	.0	.0	100.0	.1

0. HOURS OF END OF MISSING DATA OR .0 PERCENT FOR 97 HOURS

TABLE 4B (Continued)

METEOROLOGICAL DATA - OCTOBER - DECEMBER

NEUTRAL STABILITY CLASS D
 PERIOD OF RECORD: 10/ 1/83, 000-- 1/ 1/94, 000

WIND SPEED (M/S) AT 10-M LEVEL

	1-2	3-5	6-8	9-11	12-14	15-17	18 AND UP	TOTAL	AVG SPEED
N	11.2	2.9	.0	.0	.0	.0	.0	14.0	.3
NNE	4.9	.2	.0	.0	.0	.0	.0	5.1	.1
NE	4.3	.2	.0	.0	.0	.0	.0	4.9	.1
ENE	2.6	.0	.0	.0	.0	.0	.0	2.8	.0
E	2.3	.0	.0	.0	.0	.0	.0	2.3	.0
ESE	2.3	.0	.0	.0	.0	.0	.0	2.3	.0
SE	2.0	.2	.0	.0	.0	.0	.0	2.1	.0
SSE	7.7	2.6	.0	.0	.0	.0	.0	10.5	.3
S	6.1	3.6	.0	.0	.0	.0	.0	11.7	.3
SSW	3.3	.5	.0	.0	.0	.0	.0	3.8	.1
SW	2.3	.6	.0	.0	.0	.0	.0	3.0	.1
WSW	3.4	.5	.0	.0	.0	.0	.0	3.9	.1
W	4.1	.2	.0	.0	.0	.0	.0	4.3	.1
WNW	4.8	.2	.0	.0	.0	.0	.0	4.9	.1
WW	6.6	.0	.0	.0	.0	.0	.0	6.6	.1
WNW	11.7	0.0	.0	.0	.0	.0	.0	14.7	.3
CALM	3.0							3.0	

TOTAL	29.5	16.3	.0	.0	.0	.0	.0	100.0	.1

0. HOURS OF RAO OR MISSING DATA OR .0 PERCENT FOR 607 HOURS

TABLE 4B (Continued)

METEOROLOGICAL DATA - OCTOBER - DECEMBER

SLIGHTLY STABLE STABILITY CLASS E
 PERIOD OF RECORD: 10/ 1/93, 000-- 1/ 1/94, 000

WIND SPEED (M/S) AT 10-M LEVEL

	0-2	3-5	6-8	9-11	12-14	15-17	18 AND UP	TOTAL	AVG SPEED
N	0.1	.3	.0	.0	.0	.0	.0	8.4	.1
NNE	4.5	.0	.0	.0	.0	.0	.0	9.5	.1
NE	6.8	.0	.0	.0	.0	.0	.0	6.8	.1
NNE	3.3	.0	.0	.0	.0	.0	.0	5.5	.1
E	3.2	.0	.0	.0	.0	.0	.0	3.2	.0
ESE	3.6	.0	.0	.0	.0	.0	.0	3.8	.0
SE	5.5	.0	.0	.0	.0	.0	.0	5.5	.1
ESE	6.8	.2	.0	.0	.0	.0	.0	7.0	.1
SSE	7.4	1.4	.0	.0	.0	.0	.0	9.8	.2
S	3.0	.5	.0	.0	.0	.0	.0	4.3	.1
SSE	3.0	.1	.0	.0	.0	.0	.0	3.6	.1
SSW	3.2	.5	.0	.0	.0	.0	.0	3.8	.1
SW	2.9	.0	.0	.0	.0	.0	.0	2.9	.0
WSW	2.9	.0	.0	.0	.0	.0	.0	2.9	.0
W	2.3	.0	.0	.0	.0	.0	.0	2.3	.0
WSW	2.9	.3	.0	.0	.0	.0	.0	3.3	.1
CALM	12.5							12.5	
TOTAL	55.4	1.0	.0	.0	.0	.0	.0	100.0	.1

0. HOURS OF BAD OR MISSING DATA OR .0 PERCENT FOR 558 HOURS

TABLE 4B (Continued)

METEOROLOGICAL DATA - OCTOBER - DECEMBER

MODERATELY STABLE STABILITY CLASS F
 PERIOD OF RECORD: 10/ 1/73, 000-- 1/ 1/94, 000

WIND SPEED (M/S) AT 10-M LEVEL

	0-2	3-5	6-8	9-11	12-14	15-17	18 AND UP	TOTAL	AVG SPEED
N	1.6	.0	.0	.0	.0	.0	.0	1.6	.0
NNE	10.1	.0	.0	.0	.0	.0	.0	10.1	.1
NE	14.9	.0	.0	.0	.0	.0	.0	14.9	.1
NNE	11.7	.0	.0	.0	.0	.0	.0	11.7	.1
E	4.8	.0	.0	.0	.0	.0	.0	4.8	.0
ESE	6.9	.0	.0	.0	.0	.0	.0	6.9	.1
SE	3.2	.0	.0	.1	.0	.0	.0	3.2	.0
ESE	5.8	.0	.0	.1	.0	.0	.0	5.8	.1
S	3.2	.0	.0	.0	.0	.0	.0	3.2	.0
SSW	1.6	.0	.0	.0	.0	.0	.0	1.6	.0
SW	.5	.0	.0	.0	.0	.0	.0	.5	.0
WSW	1.1	.0	.0	.0	.0	.0	.0	1.1	.0
W	.5	.0	.0	.0	.0	.0	.0	.5	.0
WNW	.0	.0	.0	.0	.0	.0	.0	.0	.0
W	.0	.0	.0	.0	.0	.0	.0	.0	.0
NRW	1.1	.0	.0	.0	.0	.0	.0	1.1	.0
CLM	33.0							33.0	
TOTAL	100.0	.0	.0	.0	.0	.0	.0	100.0	.1

0. HOURS OF BAD OR MISSING DATA OR .0 PERCENT FOR 188 HOURS

TABLE 4B (Continued)

METEOROLOGICAL DATA - OCTOBER - DECEMBER

EXTREMELY STABLE STABILITY CLASS 5
 PERIOD OF RECORD: 10/ 1/91, 000-- 1/ 1/94, 000

WIND SPEED (#75) AT 10-M LEVEL

	C-2	3-5	6-8	9-11	12-14	15-17	18 AND UP	TOTAL	AVG SPEED
N	.3	.0	.0	.0	.0	.0	.0	.3	.0
NNE	.5	.0	.0	.0	.0	.0	.0	.6	.0
NE	1.3	.0	.0	.0	.0	.0	.0	5.5	.0
ENE	17.8	.0	.0	.0	.0	.0	.0	17.2	.1
E	10.7	.0	.0	.1	.0	.0	.0	18.9	.2
ESE	5.2	.0	.0	.0	.0	.0	.0	5.5	.1
SE	2.6	.0	.0	.0	.0	.0	.0	2.6	.0
SSE	1.4	.0	.0	.0	.0	.0	.0	1.4	.0
S	.0	.0	.0	.0	.0	.0	.0	.0	.0
SSE	.0	.0	.0	.0	.0	.0	.0	.0	.0
SW	.0	.0	.0	.0	.0	.0	.0	.0	.0
WSW	.0	.0	.0	.0	.0	.0	.0	.0	.0
W	.0	.0	.0	.0	.0	.0	.0	.0	.0
WNW	.0	.0	.0	.0	.0	.0	.0	.0	.0
WW	.1	.0	.0	.0	.0	.0	.0	.1	.0
WNW	.0	.0	.0	.0	.0	.0	.0	.0	.0
CALM	47.2							47.2	

TOTAL 100%	.0	.0	.0	.0	.0	.0	.0	100.0	.1

0. HOURS OF GAD OR MISSING DATA OR .0 PERCENT FOR 343 HOURS

TABLE 4B (Continued)

METEOROLOGICAL DATA - OCTOBER - DECEMBER

TOTAL FREQUENCY DISTRIBUTION

PERIOD OF RECORD: 10/ 1/93, 000 -- 1/ 1/94, 000

WIND SPEED (M/S) AT 10-M LEVEL

	0-2	3-5	6-8	9-11	12-14	15-17	18 AND UP	TOTAL	AVG SPEED
N	6.9	.7	.0	.0	.0	.0	.0	7.8	.1
NNE	5.7	.7	.0	.0	.0	.0	.0	6.0	.1
NE	6.1	.0	.0	.0	.0	.0	.0	6.1	.1
ENE	6.9	.0	.0	.0	.0	.0	.0	7.0	.1
E	5.3	.0	.0	.0	.0	.0	.0	5.4	.0
ESE	3.8	.0	.0	.0	.0	.0	.0	3.8	.0
ESE	3.4	.0	.0	.0	.0	.0	.0	3.4	.0
SE	5.3	1.1	.0	.0	.0	.0	.0	6.6	.1
SSE	8.9	1.2	.0	.0	.0	.0	.0	7.7	.2
S	5.1	.0	.0	.0	.0	.0	.0	5.7	.1
SSW	3.0	.4	.0	.0	.0	.0	.0	3.4	.1
SSW	1.0	.3	.0	.0	.0	.0	.0	3.3	.1
SW	2.0	.0	.0	.0	.0	.0	.0	2.6	.0
WSW	3.2	.1	.0	.0	.0	.0	.0	3.3	.0
WSW	5.1	.0	.0	.0	.0	.0	.0	5.1	.1
WSW	5.2	1.4	.0	.0	.0	.0	.0	6.6	.2
W	3.2							15.0	

TOTAL	52.1	7.7	.0	.0	.0	.0	.0	100.0	.1

121. HOURS OF GAD OR MISSING DATA OR - 5.5 PERCENT FOR 2208 HOURS

TABLE 4B (Continued)

METEOROLOGICAL DATA - OCTOBER - DECEMBER

TOTAL FREQUENCY DISTRIBUTION
 PERIOD OF RECORD: 10/ 1/93, 000 -- 1/ 1/94, 000

WIND SPEED (+%) AT 30-M LEVEL

	1-2	3-5	6-8	9-11	12-14	15-17	18 AND UP	TOTAL	AVG SPEED
N	3.5	1.1	.0	.0	.0	.0	.0	4.7	.3
NNE	3.7	.4	.0	.0	.0	.0	.0	4.1	.1
NE	3.4	1.3	.0	.0	.0	.0	.0	4.7	.1
ENE	3.4	3.5	.0	.0	.0	.0	.0	6.9	.2
E	3.4	7.6	.3	.0	.0	.0	.0	11.3	.4
ESE	2.1	7.4	.4	.0	.0	.0	.0	10.0	.4
ESE	2.2	5.0	.9	.0	.0	.0	.0	8.1	.3
SE	1.9	2.4	.1	.0	.0	.0	.0	5.4	.2
SE	1.7	1.3	.2	.0	.0	.0	.0	3.2	.1
SE	2.0	1.4	.1	.0	.0	.0	.0	3.6	.1
SE	1.9	1.1	.2	.0	.0	.0	.0	3.1	.1
SE	1.4	1.4	.0	.0	.0	.0	.0	3.1	.1
SE	3.0	1.5	.0	.0	.0	.0	.0	4.7	.1
SE	4.3	4.4	.4	.0	.0	.0	.0	9.0	.3
SE	3.3	4.8	.5	.0	.0	.0	.0	8.9	.3
SE	4.3	3.9	.0	.0	.0	.0	.0	8.4	.2
CALM	4.5							.5	

TOTAL	46.5	10.0	3.3	.1	.0	.0	.0	100.0	.?

121. HOURS OF BAD OR MISSING DATA OR 5.5 PERCENT FOR 2200 HOURS

TABLE 4B (Continued)

METEOROLOGICAL DATA - OCTOBER - DECEMBER

EXTREMELY UNSTABLE STABILITY CLASS A
 PERIOD OF RECORD: 10/ 1/93, 000-- 1/ 1/94, 000

WIND SPEED (M/S) AT 50-M LEVEL

	0-2	3-5	6-8	9-11	12-14	15-17	18 AND UP	TOTAL	AVG SPEED
N	2.8	.5	.0	.0	.0	.0	.0	3.3	.1
NNE	3.8	.0	.0	.0	.0	.0	.0	3.8	.1
NE	5.2	.0	.0	.0	.0	.0	.0	5.2	.1
ENE	4.3	.5	.0	.0	.0	.0	.0	4.8	.1
E	4.3	2.4	.0	.0	.0	.0	.0	7.1	.2
ESE	2.8	2.8	.5	.0	.0	.0	.0	6.2	.2
SE	2.4	2.4	.0	.0	.0	.0	.0	4.8	.1
E SSE	1.4	3.3	.5	.0	.0	.0	.0	5.2	.2
S	.9	1.9	.9	.0	.0	.0	.0	3.8	.2
SSE	1.9	1.9	.5	.0	.0	.0	.0	4.3	.1
SSW	.0	.9	.0	.0	.0	.0	.0	.9	.0
WSW	2.4	.9	.0	.0	.0	.0	.0	3.3	.1
W	5.2	5.0	.0	.0	.0	.0	.0	10.5	.4
WNW	10.9	10.9	.0	.0	.0	.0	.0	21.9	.7
W	5.7	5.7	.0	.0	.0	.0	.0	11.4	.4
WNW	2.4	.9	.0	.0	.0	.0	.0	3.3	.1
CALM	.0							.0	
TOTAL	37.1	40.5	2.4	.0	.0	.0	.0	100.0	.2

0. HOURS OF 0.00 OR MISSING DATA OF .0 PERCENT FOR 210 HOURS

TABLE 4B (Continued)

METEOROLOGICAL DATA - OCTOBER - DECEMBER

MODERATELY UNSTABLE STABILITY CLASS B
 PERIOD OF RECORD: 10/ 1/93, 000-- 1/ 1/94, 000

WIND SPEED (M/S) AT 50-M LEVEL

	0-2	3-5	6-8	9-11	12-14	15-17	18 AND UP	TOTAL	AVG SPEED
N	3.6	.0	.0	.0	.0	.0	.0	3.6	.1
NNE	.0	.0	.0	.0	.0	.0	.0	.0	.0
NE	2.4	.0	.0	.0	.0	.0	.0	2.4	.1
ENE	2.4	2.4	.0	.0	.0	.0	.0	4.8	.1
D E	7.1	1.2	1.2	.0	.0	.0	.0	9.5	.3
I ESE	3.6	3.6	.0	.0	.0	.0	.0	7.1	.2
R SE	2.4	2.4	2.4	.0	.0	.0	.0	7.1	.3
W E SSE	1.2	1.6	.0	.0	.0	.0	.0	4.8	.2
I C S	3.6	1.2	.0	.1	.0	.0	.0	4.9	.1
N T SSW	4.8	2.4	.0	.0	.0	.0	.0	7.1	.2
D I SW	2.4	.0	1.2	.0	.0	.0	.0	3.6	.1
O WSW	.0	1.2	.0	.0	.0	.0	.0	1.2	.1
N W	5.9	1.2	.0	.0	.0	.0	.0	7.1	.2
WNW	13.1	5.9	.0	.0	.0	.0	.0	19.0	.5
NW	2.4	7.1	.0	.0	.0	.0	.0	9.5	.3
NNW	.0	8.3	.0	.0	.0	.0	.0	8.3	.3
CALM	.0							.0	
TOTAL	34.8	40.9	4.8	.0	.0	.0	.0	100.0	.2

0. HOURS OF BAD OR MISSING DATA OR .0 PERCENT FOR 24 HOURS

TABLE 4B (Continued)

METEOROLOGICAL DATA - OCTOBER - DECEMBER

SLIGHTLY UNSTABLE STABILITY CLASS C
 PERIOD OF RECORD: 10/ 1/93, 000-- 1/ 1/94, 000

WIND SPEED (M/S) AT 50-M LEVEL

	C-2	3-5	6-8	9-11	12-14	15-17	18 AND UP	TOTAL	AVG SPEED
N	2.1	.0	.0	.0	.0	.0	.0	2.1	.0
NNE	.0	.0	.0	.0	.0	.0	.0	.0	.0
NE	2.1	.0	.0	.0	.0	.0	.0	2.1	.0
ENE	1.0	4.1	.0	.0	.0	.0	.0	5.1	.2
E	1.0	5.1	.0	.0	.0	.0	.0	6.2	.3
ESE	1.0	4.1	.0	.0	.0	.0	.0	5.1	.2
SE	4.1	5.1	3.1	.0	.0	.0	.0	12.4	.5
E SSE	1.0	4.1	.0	.0	.0	.0	.0	5.1	.2
SE E	2.1	.0	.0	.0	.0	.0	.0	2.1	.0
SEW	2.1	1.0	.0	.0	.0	.0	.0	3.1	.1
SW	7.2	2.1	.0	.0	.0	.0	.0	9.3	.2
WSW	5.1	2.1	.0	.0	.0	.0	.0	5.1	.2
W	8.2	1.0	.0	.0	.0	.0	.0	9.3	.2
WNW	8.2	5.1	.0	.0	.0	.0	.0	14.4	.4
W	8.2	5.1	.0	.0	.0	.0	.0	13.4	.4
WNW	2.1	5.1	.0	.0	.0	.0	.0	5.1	.2
CALM	.0							.0	

TOTAL	54.8	42.1	3.1	.0	.0	.0	.0	100.0	.2

0. HOURS OF BAD OR MISSING DATA OR .0 PERCENT FOR 97 HOURS

TABLE 4B (Continued)

METEOROLOGICAL DATA - OCTOBER - DECEMBER

NEUTRAL STABILITY CLASS D
 PERIOD OF RECORD: 10/ 1/93, 000-- 1/ 1/94, 000

WIND SPEED (M/S) AT 50-M LEVEL

	C-2	3-5	6-8	9-11	12-14	15-17	18 AND UP	TOTAL	AVG SPEED
N	2.6	.8	.0	.0	.0	.0	.0	3.6	.1
NNE	5.1	.0	.0	.0	.0	.0	.0	3.6	.1
NE	1.6	.0	.0	.0	.0	.0	.0	2.5	.1
ENE	1.3	1.5	.0	.0	.0	.0	.0	3.3	.1
E	2.0	4.3	.7	.2	.0	.0	.0	7.2	.3
ESE	1.0	7.7	1.1	.2	.0	.0	.0	10.0	.5
SSE	2.1	5.6	0.0	.0	.0	.0	.0	9.7	.4
SE	2.1	0.0	.2	.0	.0	.0	.0	5.6	.2
SE	1.1	.6	.5	.0	.0	.0	.0	2.1	.1
SSW	2.1	1.1	.0	.0	.0	.0	.0	3.3	.1
SWS	2.3	.8	.5	.0	.0	.0	.0	3.6	.2
WSW	2.3	1.1	.5	.0	.0	.0	.0	4.3	.1
W	3.9	3.3	.0	.0	.0	.0	.0	7.2	.2
WNW	3.9	5.9	1.7	.0	.0	.0	.0	11.2	.4
WW	2.3	10.2	1.3	.2	.0	.0	.0	14.2	.6
WNW	2.3	5.4	.2	.0	.0	.0	.0	8.1	.3
CALM	.0							.3	
TOTAL	37.6	55.7	8.2	.5	.0	.0	.0	100.0	.2

0. HOURS OF BAD OR MISSING DATA OR .0 PERCENT FOR 507 HOURS

TABLE 4B (Continued)

METEOROLOGICAL DATA - OCTOBER - DECEMBER

SLIGHTLY STABLE STABILITY CLASS E
 PERIOD OF RECORD: 10/ 1/93, 000-- 11/ 1/94, 000

WIND SPEED (KTS) AT 50-M LEVEL

	0-2	3-5	6-8	9-11	12-14	15-17	18 AND UP	TOTAL	AVG SPEED
R	0.0	.7	.0	.0	.0	.0	.0	3.6	.1
NNE	2.9	.7	.0	.0	.0	.0	.0	3.6	.1
NE	2.3	1.4	.0	.0	.0	.0	.0	3.9	.1
ESE	2.8	3.1	.0	.0	.0	.0	.0	8.8	.3
E	3.4	11.1	.5	.0	.0	.0	.0	15.4	.6
ESE	1.3	7.3	.0	.0	.0	.0	.0	8.5	.3
SE	1.4	6.4	.2	.0	.0	.0	.0	8.1	.3
E SSE	6.0	4.1	.0	.0	.0	.0	.0	6.1	.2
SSE	.9	3.1	.0	.0	.0	.0	.0	3.0	.1
S	2.1	2.7	.3	.0	.0	.0	.0	5.2	.2
SSW	2.1	1.8	.0	.0	.0	.0	.0	3.9	.1
WSW	1.3	3.2	.0	.0	.0	.0	.0	4.5	.2
W	.9	.7	.0	.0	.0	.0	.0	1.6	.0
WNW	2.3	3.2	.2	.0	.0	.0	.0	6.4	.2
NW	5.2	4.5	.2	.0	.0	.0	.0	6.3	.2
NWN	6.3	4.3	.0	.0	.0	.0	.0	10.6	.4
CALM	.3							.3	
TOTAL	40.0	59.5	1.6	.0	.0	.0	.0	100.0	.2

0. HOURS OF BAD OR MISSING DATA OR .0 PERCENT FOR 558 HOURS

TABLE 4B (Continued)

METEOROLOGICAL DATA - OCTOBER - DECEMBER

MODERATELY STABLE STABILITY CLASS F
 PERIOD OF RECORD: 10/ 1/93, 000-- 1/ 1/94, 000

WIND SPEED (K/S) AT 50-M LEVEL

	0-2	3-5	6-8	9-11	12-14	15-17	18 AND UP	TOTAL	AVG SPEED
N	4.2	4.3	.0	.0	.0	.0	.0	9.0	.3
NNE	3.2	.5	.0	.0	.0	.0	.0	3.7	.1
NE	3.7	1.1	.0	.0	.0	.0	.0	4.8	.1
NNE	3.7	4.6	.0	.0	.0	.0	.0	8.3	.3
D E	3.7	10.6	.0	.0	.0	.0	.0	14.4	.5
1 ESE	2.1	11.2	.0	.0	.0	.0	.0	13.3	.5
R SE	3.0	3.7	.0	.0	.0	.0	.0	6.9	.2
W E SSE	1.5	2.1	.0	.0	.0	.0	.0	3.7	.1
1 C S	3.1	5.2	.0	.0	.0	.0	.0	8.3	.3
N T SSW	2.1	.0	.0	.0	.0	.0	.0	2.6	.1
D 1 SW	.5	1.5	.0	.0	.0	.0	.0	2.1	.1
3 WSW	.5	.0	.0	.0	.0	.0	.0	.5	.0
N W	2.6	.7	.0	.0	.0	.0	.0	2.6	.0
WWS	2.1	.5	.0	.0	.0	.0	.0	2.6	.0
NW	4.3	.0	.0	.0	.0	.0	.0	4.3	.1
NNW	8.3	3.8	.0	.0	.0	.0	.0	14.4	.4
CALM	.5							.5	

TOTAL	49.5	50.5	.0	.0	.0	.0	.0	100.0	.2

0. HOURS OF BAD OR MISSING DATA OR .0 PERCENT FOR 188 HOURS

TABLE 4B (Continued)

METEOROLOGICAL DATA - OCTOBER - DECEMBER

EXTREMELY STABLE STABILITY CLASS 6
 PERIOD OF RECORD: 10/ 1/93, 000-- 1/ 1/94, 000

WIND SPEED (MPS) AT 50-M LEVEL

	0-2	3-5	6-8	9-11	12-14	15-17	18 AND UP	TOTAL	AVG SPEED
N	0.1	1.7	.0	.0	.0	.0	.0	7.9	.2
NNE	0.2	.0	.0	.0	.0	.0	.0	8.2	.2
NE	7.3	3.7	.0	.0	.0	.0	.0	11.1	.3
ENE	0.4	3.3	.0	.0	.0	.0	.0	11.9	.4
E	4.1	10.5	.0	.0	.0	.0	.0	14.6	.5
ESE	3.2	9.6	.0	.0	.0	.0	.0	14.9	.5
SE	2.6	4.7	.0	.0	.0	.0	.0	7.3	.2
SSE	2.3	2.9	.0	.0	.0	.0	.0	5.2	.1
S	3.3	.3	.0	.0	.0	.0	.0	3.3	.1
SSW	.9	.0	.0	.0	.0	.0	.0	.9	.0
SW	.9	.0	.0	.0	.0	.0	.0	.9	.0
WSW	.0	.0	.0	.0	.0	.0	.0	.0	.0
W	1.2	.0	.0	.0	.0	.0	.0	1.2	.0
WNW	1.2	.0	.0	.0	.0	.0	.0	1.2	.0
W	2.9	.0	.0	.0	.0	.0	.0	2.9	.0
WNW	6.1	.3	.0	.0	.0	.0	.0	6.4	.1
CALM	1.7							1.7	
TOTAL	60.8	39.4	.0	.0	.0	.0	.0	100.0	.2

0. HOURS OF PAD OR MISSING DATA OR .0 PERCENT FOR 343 HOURS

TABLE 4B (Continued)

METEOROLOGICAL DATA - OCTOBER - DECEMBER

PERCENT SMO DATA REPORT REPORT COVERS 2205HOURS		
	HOURS	PERCENT
SOM DIRECTION	120.	5.43
SOM WIND SPEED	120.	5.43
10M DIRECTION	120.	5.43
10M WIND SPEED	120.	5.43
TEMPERATURE	120.	5.43
DEW POINT	120.	5.43
DELTA T	121.	5.43
PRECIPITATION	120.	5.43

TABLE 4C

METEOROLOGICAL DATA SUMMARY JANUARY - DECEMBER

EXTREMELY UNSTABLE STABILITY CLASS A
 PERIOD OF RECORD: 1/ 1/93, 000-- 1/ 1/94, 000

WIND SPEED (M/S) AT 10-M LEVEL

	0-3	3-5	5-8	8-11	11-14	15-17	18	UP	TOTAL	AVG SPEED
N	4.2	.3	.3	.0	.0	.0	.0	.0	4.5	.1
NNE	2.9	.3	.0	.0	.0	.1	.0	.0	3.3	.1
NE	1.9	.0	.3	.0	.0	.0	.0	.0	1.9	.0
NNE	1.9	.0	.0	.0	.0	.0	.0	.0	1.9	.0
E	1.2	.0	.0	.0	.0	.0	.0	.0	1.2	.0
ESE	1.3	.1	.0	.0	.0	.0	.0	.0	1.4	.0
ESE	1.3	.0	.1	.0	.0	.0	.0	.0	1.9	.0
ESSW	4.4	1.5	.1	.0	.0	.0	.0	.0	4.5	.1
CS	2.9	1.4	.0	.0	.0	.0	.0	.0	4.3	.1
SSW	7.8	1.2	.1	.1	.0	.0	.0	.0	9.2	.2
SSW	11.0	2.2	.1	.0	.0	.0	.1	.0	13.3	.3
SSW	9.8	.1	.0	.0	.0	.0	.0	.0	9.9	.2
W	7.4	.4	.0	.0	.0	.0	.0	.0	7.7	.1
WNW	9.5	.5	.0	.0	.0	.0	.0	.0	10.4	.2
NW	12.3	2.0	.0	.0	.0	.0	.0	.0	14.3	.3
NNW	8.4	1.7	.0	.0	.0	.0	.0	.0	10.2	.2
CALM	.0								.0	

TOTAL	25.7	12.8	.5	.1	.0	.1	.1	.1	100.0	.1

0. HOURS OF BAD OR MISSING DATA OR .0 PERCENT FOR 1328 HOURS

TABLE 4C

METEOROLOGICAL DATA SUMMARY JANUARY - DECEMBER

MODERATELY UNSTABLE STABILITY CLASS B
 PERIOD OF RECORD: 1/ 1/43, 000-- 1/ 1/94, 000

WIND SPEED (M/S) AT 10-M LEVEL

	0-2	3-5	6-8	9-11	12-14	15-17	18 AND UP	TOTAL	AVG SPEED
N	3.2	.6	.0	.0	.0	.0	.0	3.8	.1
NNE	7.5	1.2	.0	.0	.1	.0	.0	8.8	.2
NE	1.0	.5	.0	.0	.0	.0	.0	2.1	.0
NNE	1.0	.0	.0	.0	.0	.0	.0	1.0	.0
E	1.0	.1	.0	.0	.0	.0	.0	1.8	.0
ESE	3.0	.0	.0	.0	.0	.0	.0	3.6	.1
SE	2.7	1.2	.3	.0	.0	.0	.0	4.3	.1
SE	3.3	2.4	.0	.0	.0	.0	.0	5.8	.2
SSE	7.0	3.0	.0	.0	.0	.0	.0	10.1	.2
S	9.4	.0	.0	.0	.0	.0	.0	10.1	.0
SSE	10.4	.3	.0	.0	.0	.0	.0	10.7	.2
SSW	7.1	.3	.0	.0	.0	.0	.0	7.6	.1
SW	4.3	.0	.0	.0	.0	.0	.0	4.3	.1
WSW	4.3	.6	.0	.0	.0	.0	.0	4.9	.1
W	7.9	2.4	.0	.0	.0	.0	.0	10.4	.2
WSW	0.4	1.2	.0	.0	.0	.0	.0	2.6	.2
CALM	.3							.3	

TOTAL	83.8	15.5	.3	.0	.3	.0	.0	100.0	.1

0. HOURS OF BAD OR MISSING DATA OR .0 PERCENT FOR 328 HOURS

TABLE 4C (Continued)

METEOROLOGICAL DATA SUMMARY JANUARY - DECEMBER

SLIGHTLY UNSTABLE STABILITY CLASS C
 PERIOD OF RECORD: 1/ 1/93, 000-- 1/ 1/94, 000

WIND SPEED (M/S) AT 10-M LEVEL

		0-2	3-5	6-8	9-11	12-14	15-17	18 AND UP	TOTAL	AVG SPEED
	N	0.0	.0	.0	.0	.0	.0	.0	8.9	.2
	NNE	1.0	.0	.0	.0	.0	.0	.0	4.0	.1
	NE	2.7	.3	.0	.0	.0	.0	.0	3.0	.1
	NNE	0.0	.3	.0	.0	.0	.0	.0	3.4	.1
	E	1.7	.5	.0	.0	.0	.0	.0	3.4	.1
	ESE	1.0	.0	.0	.0	.0	.0	.0	1.8	.0
	SE	2.4	.9	.0	.0	.0	.0	.0	3.4	.1
	SSE	4.9	3.7	.6	.0	.0	.0	.0	9.2	.3
	S	6.6	2.4	.0	.0	.0	.0	.0	8.9	.2
	SSW	9.2	.0	.0	.0	.0	.0	.0	9.3	.2
	SW	6.6	1.2	.0	.0	.0	.0	.0	7.6	.2
	WSW	3.8	.0	.0	.0	.0	.0	.0	5.8	.1
	W	3.3	.3	.0	.0	.0	.0	.0	5.6	.1
	WRW	3.3	.0	.0	.0	.0	.0	.0	5.3	.1
	NW	7.9	1.2	.0	.0	.0	.0	.0	9.2	.2
	NNW	6.5	1.2	.0	.0	.0	.0	.0	9.8	.2
	CALM	.9							.9	

	TOTAL	86.5	18.0	.9	.0	.0	.0	.0	100.0	.1

0. HOURS OF BAD OR MISSING DATA OR .0 PERCENT FOR 327 HOURS

TABLE 4C (Continued)

METEOROLOGICAL DATA SUMMARY JANUARY - DECEMBER

NEUTRAL STABILITY CLASS D
 PERIOD OF RECORD: 1/ 1/93, 000-- 1/ 1/94, 000

WIND SPEED (M/S) AT 10-M LEVEL

	0-2	3-5	6-8	9-11	12-14	15-17	18 AND UP	TOTAL	AVG SPEED
N	11.2	1.3	.0	.0	.0	.0	.0	12.6	.3
NNE	6.4	.3	.0	.0	.0	.0	.0	6.7	.1
NE	5.2	.0	.0	.0	.0	.0	.0	5.3	.1
NNE	3.5	.1	.0	.0	.0	.0	.0	3.6	.1
E	2.6	.1	.0	.0	.0	.0	.0	2.7	.0
ESE	2.4	.3	.0	.0	.0	.0	.0	2.7	.0
SE	3.1	.3	.0	.0	.0	.0	.0	3.7	.1
E SSE	6.0	3.1	.1	.0	.0	.0	.0	9.2	.3
CS	3.6	2.3	.0	.0	.0	.0	.0	6.1	.2
SSW	3.0	.3	.0	.0	.0	.0	.0	3.3	.1
WSW	4.4	.8	.0	.0	.0	.0	.0	5.2	.1
WSW	3.3	.2	.0	.0	.0	.0	.0	3.4	.0
W	3.4	.0	.0	.0	.0	.0	.0	3.4	.0
WNW	3.3	.1	.0	.0	.0	.0	.0	3.4	.0
NW	6.0	.7	.0	.0	.0	.0	.0	7.3	.1
NNW	11.2	2.0	.0	.0	.0	.0	.0	13.2	.3
CALM	3.4							3.4	

TOTAL	80.9	12.9	.2	.0	.0	.0	.0	100.0	.1

0. HOURS OF BAD OR MISSING DATA OR .0 PERCENT FOR 1809 HOURS

TABLE 4C (Continued)

METEOROLOGICAL DATA SUMMARY JANUARY - DECEMBER

SLIGHTLY STABLE STABILITY CLASS E
 PERIOD OF RECORD: 1/ 1/93, 000-- 1/ 1/94, 000

WIND SPEED (M/S) AT 10-M LEVEL

	0-2	3-5	6-8	9-11	12-14	15-17	18	TOTAL	AVG SPEED
N	7.3	.4	.0	.0	.0	.0	.0	7.6	.1
NNE	7.0	.0	.0	.0	.0	.0	.0	7.0	.1
NE	7.3	.0	.0	.0	.0	.0	.0	7.5	.1
NNE	5.3	.0	.0	.0	.0	.0	.0	5.3	.1
D E	3.6	.0	.0	.0	.0	.0	.0	3.6	.0
1 ESE	4.7	.0	.0	.0	.0	.0	.0	4.7	.0
R SE	6.3	.0	.0	.0	.0	.0	.0	6.3	.1
w E SSB	10.3	1.4	.0	.0	.0	.0	.0	11.6	.2
1 C E	7.0	.0	.0	.0	.0	.0	.0	8.5	.1
N I SW	4.1	.0	.0	.0	.0	.0	.0	4.6	.1
D I SW	3.8	.1	.0	.0	.0	.0	.0	4.0	.0
C WSW	2.1	.1	.0	.0	.0	.0	.0	2.3	.0
W	2.2	.0	.0	.0	.0	.0	.0	2.2	.0
WNW	1.7	.0	.0	.0	.0	.0	.0	1.7	.0
NW	3.1	.0	.0	.0	.0	.0	.0	3.2	.0
NNW	3.6	.4	.0	.0	.0	.0	.0	6.3	.1
CALM	13.3							13.3	

TOTAL	95.9	4.0	.0	.0	.0	.0	.0	100.3	.1

0. HOURS OF PAD OR MISSING DATA OR .0 PERCENT FOR 2500 HOURS

TABLE 4C (Continued)

METEOROLOGICAL DATA SUMMARY JANUARY - DECEMBER

MODERATELY STABLE STABILITY CLASS F
 PERIOD OF RECORD: 1/ 1/93, 000-- 1/ 1/94, 000

WIND SPEED (M/S) AT 10-M LEVEL

	0-2	3-5	6-8	9-11	12-14	15-17	18 AND UP	TOTAL	AVG SPEED
N	3.4	.1	.0	.0	.0	.0	.0	3.5	.0
NNE	7.7	.2	.0	.0	.0	.0	.0	7.9	.1
NE	11.0	.0	.0	.0	.0	.0	.0	11.2	.1
ENE	9.4	.1	.0	.0	.0	.0	.0	9.5	.1
D E	6.8	.2	.0	.0	.0	.0	.0	7.1	.1
I ESE	1.0	.2	.0	.0	.0	.0	.0	6.0	.1
R SE	4.6	.0	.0	.0	.0	.0	.0	4.6	.0
W E SSE	3.5	.2	.0	.0	.0	.0	.0	3.7	.0
I C S	2.1	.0	.0	.0	.0	.0	.0	2.1	.0
N I SSW	.9	.0	.0	.0	.0	.0	.0	.9	.0
D I SW	1.0	.0	.0	.0	.0	.0	.0	1.3	.0
O WSW	.6	.1	.0	.0	.0	.0	.0	.8	.0
N W	1.0	.1	.0	.0	.0	.0	.0	1.1	.0
WNW	.2	.0	.0	.0	.0	.0	.0	.2	.0
NW	2.0	.3	.0	.0	.0	.0	.0	2.3	.0
NW	2.7	.1	.0	.0	.0	.0	.0	2.8	.0
CALM	54.7							34.7	

TOTAL	98.4	1.0	.0	.0	.0	.0	.0	100.0	.1

0. HOURS OF BAD OR MISSING DATA OF .0 PERCENT FOR 1048 HOURS

TABLE 4C (Continued)

METEOROLOGICAL DATA SUMMARY JANUARY - DECEMBER

EXTREMELY STABLE STABILITY CLASS 6
 PERIOD OF RECORD: 1/ 1/93, 000-- 1/ 1/94, 000

WIND SPEED (M/S) AT 10-M LEVEL

	0-2	3-5	6-8	9-11	12-14	15-17	18 AND UP	TOTAL	AVG SPEED
N	1.1	.0	.0	.0	.0	.0	3.1	4.3	31.3
NNE	1.6	.0	.0	.0	.0	.0	.0	1.6	.0
NE	11.7	.0	.0	.0	.0	.0	.0	11.7	.1
ENE	20.2	.0	.0	.0	.0	.0	.0	20.2	.2
E S	11.3	.0	.0	.0	.0	.0	.0	11.3	.1
E SE	4.2	.0	.0	.0	.0	.0	.0	4.2	.0
ENE	1.6	.0	.0	.0	.0	.0	.0	1.6	.0
E SSE	.8	.0	.0	.0	.0	.0	.0	.8	.0
E S	.3	.0	.0	.0	.0	.0	.0	.3	.0
E SW	.0	.0	.0	.0	.0	.0	.0	.0	.0
E SW	.4	.0	.0	.0	.0	.0	.0	.4	.0
E WSW	.1	.0	.0	.0	.0	.0	.0	.1	.0
E W	.0	.0	.0	.0	.0	.0	.0	.0	.0
E WNW	.2	.0	.0	.0	.0	.0	.0	.2	.0
E W	.4	.1	.0	.0	.0	.0	.0	.5	.0
E NNW	.1	.0	.0	.0	.0	.0	.0	.1	.0
*CALM	40.7							42.7	

TOTAL	56.2	.1	.0	.0	.0	.0	3.1	100.0	4.0

0. HOURS OF BAD OR MISSING DATA OR .0 PERCENT FOR 955 HOURS

TABLE 4C (Continued)

METEOROLOGICAL DATA SUMMARY JANUARY - DECEMBER

TOTAL FREQUENCY DISTRIBUTION

PERIOD OF RECORD: 1/ 1/93, GDD -- 1/ 1/94, 000

WIND SPEED (M/S) AT 10-M LEVEL

	1-2	3-5	6-8	9-11	12-14	15-17	18 AND UP	TOTAL	AVG SPEED
N	6.4	.0	.0	.0	.0	.0	.4	7.3	3.7
NNE	5.5	.0	.0	.0	.0	.0	.0	5.5	.1
NE	6.6	.1	.0	.0	.0	.0	.0	6.7	.1
NNE	6.4	.0	.0	.0	.0	.0	.0	6.4	.1
D E	4.2	.1	.0	.0	.0	.0	.0	4.3	.0
E	3.8	.1	.0	.0	.0	.0	.0	3.9	.0
ESE	3.8	.2	.0	.0	.0	.0	.0	4.1	.1
SE	3.7	1.7	.1	.0	.0	.0	.0	7.4	.2
ESE	4.8	1.3	.0	.0	.0	.0	.0	6.1	.1
SSE	4.5	.1	.0	.0	.0	.0	.0	5.0	.1
S	4.7	.6	.0	.0	.0	.0	.0	5.4	.1
SSE	3.5	.1	.0	.0	.0	.0	.0	3.7	.1
SSW	3.1	.1	.0	.0	.0	.0	.0	3.2	.0
SW	3.2	.2	.0	.0	.0	.0	.0	3.4	.0
SSW	5.3	.7	.0	.0	.0	.0	.0	6.0	.1
SW	6.9	.9	.0	.0	.0	.0	.0	7.4	.1
SSW	6.9							14.1	
CALM	6.9								
TOTAL	52.0	7.4	.1	.0	.0	.0	.4	100.0	.3

462. HOURS OF PAD OR MISSING DATA OR 5.3 PERCENT FOR 8760 HOURS

TABLE 4C (Continued)

METEOROLOGICAL DATA SUMMARY JANUARY - DECEMBER

EXTREMELY UNSTABLE STABILITY CLASS A
 PERIOD OF RECORD: 1/ 1/93, 000-- 1/ 1/94, 000

WIND SPEED (M/S) AT 50-M LEVEL

	0-2	3-5	6-8	9-11	12-14	15-17	18 AND UP	TOTAL	AVG SPEED
N	4.6	.7	.1	.0	.0	.0	.0	5.3	.1
NNE	3.6	.6	.0	.0	.0	.0	.0	4.2	.1
NE	2.6	.5	.0	.0	.0	.0	.0	3.2	.1
ENE	2.9	.4	.0	.1	.0	.0	.0	3.4	.1
E	2.7	1.3	.0	.1	.0	.0	.0	4.0	.1
ESE	2.3	1.8	.1	.1	.0	.0	.0	4.7	.1
ESE	1.0	1.7	.1	.1	.0	.0	.0	2.6	.1
E SSW	1.8	2.0	.3	.2	.0	.0	.0	4.6	.2
E S	1.6	1.6	.2	.1	.0	.0	.0	3.5	.1
E SSW	3.6	2.9	.1	.1	.0	.0	.0	6.8	.2
E SW	4.3	3.7	.3	.0	.0	.0	.0	6.3	.3
E WSW	5.9	2.2	.8	.0	.0	.1	.0	8.9	.3
E W	6.3	2.0	.4	.0	.0	.0	.0	9.3	.3
E WNW	7.0	2.2	.3	.1	.0	.0	.0	9.8	.3
E W	6.5	2.0	.0	.1	.0	.0	.0	14.4	.5
E NNW	3.2	3.5	.0	.0	.0	.0	.0	6.7	.2
CALM	.1							.1	
TOTAL	61.1	35.2	3.4	.3	.0	.1	.0	100.0	.2

0. HOURS OF GAD OR MISSING DATA OR .0 PERCENT FOR 1328 HOURS

TABLE 4C (Continued)

METEOROLOGICAL DATA SUMMARY JANUARY - DECEMBER

MODERATELY UNSTABLE STABILITY CLASS B
 PERIOD OF RECORD: 1/ 1/93, 000-- 1/ 1/94, 000

WIND SPEED (M/S) AT 50-M LEVEL

	0-2	3-5	6-8	9-11	12-14	15-17	18 AND UP	TOTAL	AVG SPEED
N	3.3	2.7	.3	.0	.0	.0	.0	6.4	.2
NNE	0.0	1.5	.0	.0	.0	.0	.0	4.9	.1
NE	2.7	.6	.0	.0	.0	.0	.0	3.3	.1
NNE	1.5	1.0	.0	.0	.0	.0	.0	2.7	.1
D E	3.3	2.1	.3	.0	.0	.0	.0	5.8	.2
E	2.4	2.7	.6	.0	.0	.0	.0	5.8	.2
R SE	2.1	2.4	2.4	.2	.0	.0	.0	7.3	.3
W E SSE	1.5	2.4	.3	.0	.0	.0	.0	4.3	.1
I C S	2.7	2.4	.3	.0	.0	.0	.0	5.5	.2
N T SW	3.2	3.3	.0	.0	.0	.0	.0	6.5	.2
D I SW	3.2	1.8	.6	.0	.0	.0	.0	7.6	.2
O WSW	2.7	2.4	.3	.0	.0	.0	.0	5.5	.2
W W	3.6	1.2	.6	.0	.0	.0	.0	5.5	.2
WNW	3.5	1.5	.3	.0	.0	.0	.0	7.3	.2
NW	4.6	4.9	.0	.3	.0	.0	.0	9.7	.3
NNW	4.6	4.0	.0	.0	.0	.0	.0	8.8	.3
CALM9	.

TOTAL	55.2	37.8	6.1	.6	.0	.0	.0	100.0	.2

0. HOURS OF BAD OR MISSING DATA OR .0 PERCENT FOR 328 HOURS

TABLE 4C (Continued)

METEOROLOGICAL DATA SUMMARY JANUARY - DECEMBER

SLIGHTLY UNSTABLE STABILITY CLASS C
 PERIOD OF RECORD: 1/ 1/93, 000-- 1/ 1/94, 000

WIND SPEED (M/S) AT 50-M LEVEL

	0-2	3-5	6-8	9-11	12-14	15-17	18 AND UP	TOTAL	AVG SPEED
N	4.9	1.5	.0	.0	.0	.0	.0	6.4	.1
NNE	2.4	1.2	.0	.0	.0	.0	.0	3.7	.1
NE	2.1	.3	.0	.0	.0	.0	.0	2.4	.0
NNE	2.4	2.4	.0	.0	.0	.0	.0	4.9	.1
E	2.1	4.0	.0	.0	.0	.0	.0	6.1	.2
ESE	1.2	2.1	.3	.0	.0	.0	.0	3.7	.1
ESE	3.4	3.7	1.8	.0	.0	.0	.0	8.9	.4
SE	2.1	3.7	.9	.3	.0	.0	.0	7.0	.3
SE	3.7	1.8	.3	.0	.0	.0	.0	5.8	.2
SSW	4.0	.9	.0	.0	.0	.0	.0	4.9	.1
SSW	4.0	2.1	.9	.0	.0	.0	.0	7.0	.2
WSW	3.0	2.4	.0	.0	.3	.0	.0	6.1	.2
WSW	4.0	1.1	.0	.1	.0	.0	.0	5.2	.1
WNW	3.8	1.5	.0	.0	.0	.0	.0	7.3	.2
NW	6.4	4.0	.0	.0	.0	.0	.0	10.4	.3
NW	4.3	4.6	.0	.0	.0	.0	.0	8.9	.3
CALM	.6							.6	
TOTAL	37.2	37.9	4.6	.3	.3	.0	.0	100.0	.2

0, HOURS OF BAD OR MISSING DATA OR .0 PERCENT FOR 327 HOURS

TABLE 4C (Continued)

METEOROLOGICAL DATA SUMMARY JANUARY - DECEMBER

NEUTRAL STABILITY CLASS D
 PERIOD OF RECORD: 1/ 1/93, 000-- 1/ 1/94, 000

WIND SPEED (M/S) AT 50-M LEVEL

	0-2	3-5	6-8	9-11	12-14	15-17	18 AND UP	TOTAL	AVG SPEED
N	3.6	3.0	.2	.0	.0	.0	.0	9.6	.3
NNE	4.4	1.6	.0	.0	.0	.0	.0	6.1	.1
NE	2.7	1.1	.0	.0	.0	.0	.0	4.2	.1
ENE	3.4	1.5	.0	.0	.0	.0	.0	4.9	.1
E	2.5	4.3	.2	.0	.0	.0	.0	7.0	.3
ESE	2.7	4.4	1.4	.0	.0	.0	.0	8.5	.3
SE	1.9	3.0	.9	.0	.0	.0	.0	5.7	.2
ESE	2.5	3.5	.7	.1	.0	.0	.0	7.0	.3
SE	1.9	1.2	.5	.0	.0	.0	.0	3.4	.1
SSE	2.5	1.5	.3	.0	.0	.0	.0	4.4	.1
S	2.9	1.2	.4	.0	.0	.0	.0	4.6	.1
SSW	2.3	1.4	.4	.0	.0	.0	.0	4.3	.1
WSW	2.4	2.2	.1	.0	.0	.0	.0	4.7	.1
WSW	2.5	2.5	.5	.0	.0	.0	.0	5.8	.2
WS	2.8	4.0	.9	.2	.0	.0	.0	8.9	.3
WSW	3.9	3.4	.9	.0	.0	.0	.0	9.7	.3
CALM	1.1							1.1	
TOTAL	48.7	44.0	6.7	.5	.0	.0	.0	100.0	.2

0. HOURS OF BAD OR MISSING DATA OR .0 PERCENT FOR 1809 HOURS

TABLE 4C (Continued)

METEOROLOGICAL DATA SUMMARY JANUARY - DECEMBER

MODERATELY STABLE STABILITY CLASS F
 PERIOD OF RECORD: 1/ 1/93, 000-- 1/ 1/94, 000

WIND SPEED (M/S) AT 50-M LEVEL

	1-2	3-5	6-8	9-11	12-14	15-17	18 AND UP	TOTAL	AVG SPEED
N	4.4	3.4	.0	.0	.0	.0	.0	7.8	.2
NNE	2.3	2.2	.0	.0	.0	.0	.0	4.7	.1
NE	4.7	.0	.0	.0	.0	.0	.0	5.4	.1
NNE	3.0	2.3	.1	.0	.0	.0	.0	5.4	.1
D E	8.1	8.5	.3	.0	.0	.0	.0	12.9	.4
I SSE	5.1	6.2	1.1	.2	.0	.0	.0	13.6	.5
E SE	5.8	2.7	.2	.0	.0	.0	.0	8.7	.2
W S SSE	3.2	2.3	.0	.0	.0	.0	.0	5.6	.1
I C S	4.0	2.1	.0	.0	.0	.0	.0	6.1	.1
N T SSW	3.0	1.0	.0	.0	.0	.0	.0	4.1	.1
O I SW	2.7	2.0	.0	.0	.0	.0	.0	4.7	.1
O SSW	3.3	1.1	.0	.0	.0	.0	.0	4.5	.1
N W	2.1	.4	.0	.0	.0	.0	.0	2.5	.0
WNW	2.4	1.1	.0	.0	.0	.0	.0	2.5	.0
NS	2.9	1.5	.0	.0	.0	.0	.0	4.4	.1
NNW	3.3	2.5	.0	.0	.0	.0	.0	5.9	.2
CALM	1.7							1.1	
TOTAL	40.7	17.4	1.7	.2	.0	.0	.0	100.0	.2

5. HOURS OF BAD OR MISSING DATA OF .0 PERCENT FOR 1048 HOURS

TABLE 4C (Continued)

METEOROLOGICAL DATA SUMMARY JANUARY - DECEMBER

EXTREMELY STABLE STABILITY CLASS 3
 PERIOD OF RECORD: 1/ 1/93, 000-- 1/ 1/94, 000

WIND SPEED (M/S) AT 50-M LEVEL

	0-2	3-5	6-8	9-11	12-14	15-17	18 AND UP	TOTAL	AVG SPEED
W	5.6	.7	.0	.0	.0	.0	3.1	7.6	51.4
WNE	4.3	1.0	.3	.0	.0	.0	.0	5.6	.1
NE	5.3	2.8	.0	.0	.0	.0	.0	8.1	.2
ENE	5.6	4.3	.0	.0	.0	.0	.0	9.9	.3
E	5.7	6.7	.0	.0	.0	.0	.0	12.6	.4
ESE	6.1	5.6	.4	.0	.0	.0	.0	12.2	.4
SSE	6.4	2.9	.0	.0	.0	.0	.0	9.3	.2
S	5.1	1.4	.0	.0	.0	.0	.0	7.0	.2
SSE	6.1	.8	.0	.0	.0	.0	.0	7.0	.1
WSW	2.8	.1	.0	.0	.0	.0	.0	2.7	.0
WSW	1.8	.4	.0	.0	.0	.0	.0	2.2	.0
WSW	1.4	.1	.0	.0	.0	.0	.0	1.5	.0
W	1.6	.1	.0	.0	.0	.0	.0	1.7	.0
WNW	2.0	.2	.1	.0	.0	.0	.0	2.9	.1
NW	2.5	.1	.0	.0	.0	.0	.0	2.6	.0
NNW	3.1	.2	.0	.0	.0	.0	.0	3.3	.1
CALM	3.6							3.6	
TOTAL	45.5	27.9	.5	.0	.0	.0	3.1	100.0	2.1

0. HOURS OF BAD OR MISSING DATA OR .0 PERCENT FOR 955 HOURS

TABLE 4C (Continued)

METEOROLOGICAL DATA SUMMARY JANUARY - DECEMBER

TOTAL FREQUENCY DISTRIBUTION

PERIOD OF RECORD: 1/ 1/93, 000 -- 1/ 1/94, 000

WIND SPEED (M/S) AT 50-M LEVEL

	0-2	3-5	6-8	9-11	12-14	15-17	18 AND UP	TOTAL	AVG SPEED
N	4.0	2.1	.1	.0	.0	.0	.4	7.2	3.8
NNE	3.4	1.5	.0	.0	.0	.0	.0	4.9	.1
NE	3.3	1.2	.0	.0	.0	.0	.0	4.5	.1
NNE	3.4	2.2	.0	.0	.0	.0	.0	5.7	.2
E	3.7	4.5	.1	.0	.0	.0	.0	8.7	.3
ESE	3.8	4.4	.5	.0	.0	.0	.0	8.9	.3
ESE	3.2	2.9	.4	.0	.0	.0	.0	6.5	.2
ESE	3.1	3.4	.5	.0	.0	.0	.0	7.2	.3
ESE	3.2	3.1	.1	.0	.0	.0	.0	5.4	.1
ESE	3.1	1.8	.1	.0	.0	.0	.0	5.1	.1
ESE	3.1	1.8	.2	.0	.0	.0	.0	5.2	.1
ESE	3.1	1.5	.3	.0	.0	.0	.0	5.0	.1
ESE	2.9	1.4	.1	.0	.0	.0	.0	4.4	.1
ESE	3.6	1.5	.2	.0	.0	.0	.0	5.5	.1
ESE	3.8	3.4	.2	.1	.0	.0	.0	7.4	.2
ESE	1.9	3.3	.1	.0	.0	.0	.0	7.2	.2
ESE	5.9							1.1	

TOTAL	36.4	39.7	3.3	.2	.0	.0	.4	100.0	.4

463. HOURS OF BAD OR MISSING DATA OR 5.1 PERCENT FOR 8760 HOURS

TABLE 4C (Continued)

METEOROLOGICAL DATA SUMMARY JANUARY - DECEMBER

PERCENT BAD DATA REPORT
 REPORT COVERS 3760HOURS

	HOURS	PERCENT
5CM DIRECTION	461.	5.25
5CM WIND SPEED	461.	5.25
1CM DIRECTION	461.	5.25
1CM WIND SPEED	461.	5.25
TEMPERATURE	461.	5.25
DEW POINT	461.	5.25
DELTA T	461.	5.25
PRECIPITATION	461.	5.25

TABLE 4D

CLASSIFICATION OF ATMOSPHERIC STABILITY

STABILITY CLASSIFICATION	PASQUILL CATEGORIES	σ_{θ} ^a (degrees)	Temperature Change with height (°C/100m)
Extremely unstable	A	25.0	<-1.9
Moderately unstable	B	20.0	-1.9 to -1.7
Slightly unstable	C	15.0	-1.7 to -1.5
Neutral	D	10.0	-1.5 to -0.5
Slightly stable	E	5.0	-0.5 to 1.5
Moderately stable	F	2.5	1.5 to 4.0
Extremely stable	G	1.7	>4.0

^aStandard deviation of horizontal wind direction fluctuation over a period of 15 minutes to one hour. The values shown are average for each stability classification.