

MAR 31 1994

Docket No. 50-333

Mr. Harry P. Salmon, Jr.  
Resident Manager  
New York Power Authority  
James A. FitzPatrick Nuclear Power Plant  
Post Office Box 41  
Lycoming, New York 13093

SUBJECT: NRC REGION I INSPECTION REPORT NO. 50-333/94-02

This letter refers to the announced inspection conducted by Mr. Thomas J. Kenny on February 7-11, 1994, at the Fitzpatrick Nuclear Power Plant, to assess the adequacy of the activities related to your motor-operated valve (MOV) program. The results of this inspection were discussed with Mr. Harry Salmon on February 11, 1994.

The inspectors reviewed procedures, representative records, interviewed personnel, and overall observed areas important to public health and safety. The inspection focused on the MOV program and the implementation of program enhancements developed in response to a previous NRC team inspection in this area. This inspection was used to determine your progress toward the scheduled program completion date and to assure satisfactory implementation of your commitments to regulatory requirements.

Based on the results of the inspection, our inspector informed your staff of the possibility that your MOV program may not be completed as directed by Generic Letter 89-10. We request that you inform us of your intentions as soon as you have determined the course for the completion of your program. Your cooperation in this matter is appreciated.

Sincerely,

Original Signed By:  
Marvin W. Hodges

Dr. Plackeel K. Eapen, Chief  
Systems Section  
Engineering Branch  
Division of Reactor Safety

Enclosure: NRC Region I Inspection Report No. 50-333/94-02

050120  
9404050218 940331  
PDR ADDCK 05000333  
Q PDR

JED

MAR 31 1994

New York Power Authority

2

cc w/encl:

R. Schoenberger, Acting President  
W. Josiger, Acting Executive Vice President - Nuclear  
G. Goldstein, Assistant General Counsel  
J. Gray, Jr., Director, Nuclear Licensing - BWR  
Supervisor, Town of Scriba  
C. Donaldson, Esquire, Assistant Attorney General, New York Department of Law  
Director, Energy & Water Division, Department of Public Service, State of New York  
K. Abraham, PAO (2)  
Public Document Room (PDR)  
Local Public Document Room (LPDR)  
Nuclear Safety Information Center (NSIC)  
NRC Resident Inspector  
State of New York, SLO Designee

bcc w/encl:

Region I Docket Room (with concurrences)  
C. Cowgill, DRP  
P. Eselgroth, DRP  
R. Urban, DRP  
B. Welling, DRP  
B. Cook - FitzPatrick

bcc w/encl: (VIA E-MAIL)

M. Shannon, NRR  
V. McCree, OEDO  
R. Capra, NRR  
J. Menning, NRR

RI:DRS  
Kenny *JS*

3/19/94

RI:DRS  
Eapen  
*Munt*  
3/17/94 *for*

OFFICIAL RECORD COPY  
A:FITZ9402.INS