LICENSEE EVENT REPORT

| | CONTROL BLOCK: |
|--------|--|
| 0 1 | M 1 D C C 2 2 0 0 - 0 0 0 0 - 0 0 3 4 1 1 1 1 1 1 4 5 6 6 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 |
| CON'T | REPORT LL 6 0 5 0 0 0 3 1 6 7 0 8 2 0 8 2 8 0 9 1 6 8 2 9 |
| 0 2 | DURING NORMAL OPERATION, THE PAPER DRIVE MECHANISM FOR THE CONTAINMENT AIR |
| 0 3 | PARTICULATE SYSTEM (R-11) FAILED. R-11 AND R-12 (CONTAINMENT GASEOUS DETECTOR) |
| 0 4 | WERE DECLARED INOPERABLE AT 1030 HOURS ON AUGUST 20, 1982. THIS EVENT IS NON- |
| 0 5 | CONSERVATIVE WITH RESPECT TO TECHNICAL SPECIFICATIONS 3.3.3.1, 3.3.2.1 TABLE |
| 0 6 | 3.3-3 AND 3.4.6.1. THE PUBLIC HEALTH AND SAFETY WERE NOT AFFECTED. |
| 0 7 | |
| 0 8 | |
| 09 | SYSTEM CAUSE CAUSE COMPONENT CODE SUBCODE SUBC |
| 110 | SEQUENTIAL REPORT NO. 1.ER/RO EVENT YEAR REPORT TYPE 1.ER/RO EVENT YEAR REPORT NO. 1.ER/RO EVENT YEAR REPORT TYPE 1.ER/RO EVENT YEAR REPORT NO. 1.ER/RO EVENT YEAR |
| | PAPER TAKE-UP REEL WERE REALIGNED, VERIFIED TO BE OPERATING CORRECTLY AND RETURNED |
| | TO SERVICE AT 1400 HOURS ON AUGUST 21, 1982. THESE RADIATION MONITORING SYSTEMS , |
| 13 | ARE SCHEDULED TO BE REPLACED DURING THE UPCOMING REFUELING OUTAGE. |
| 1.4 | |
| 8 | STATUS SPOWER OTHER STATUS 30 METHOD OF DISCOVERY DESCRIPTION 32 AUDIBLE ALARM |
| 1 6 RE | CTIVITY CONTENT SLEASED OF RELEASE AMOUNT OF ACTIVITY 35 NA LOCATION OF RELEASE 36 NA |
| 1 7 | PERSONNEL EXPOSURES NUMBER 10 10 10 37 Z 38 DESCRIPTION 39 NA |
| 1 | PERSONNEL INJURIES NUMBER DESCRIPTION 41) NA |
| 8 | SOURCE DESCRIPTION 43 |
| | Z 42 NA PUBLICITY (2) |
| 2 0 | NA NAC USE ONLY NA NAC USE |
| 8 | 09240271 820916 |